BS ISO/IEC 14543-3-10:2020

BSI Standards Publication

Information technology — Home electronic system (HES) architecture

Part 3-10: Amplitude modulated wireless short-packet (AMWSP) protocol optimized for energy harvesting — Architecture and lower layer protocols

Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

National foreword

This British Standard is the UK implementation of ISO/IEC 14543-3-10:2020. It supersedes BS ISO/IEC 14543-3-10:2012, which is withdrawn.

The UK participation in its preparation was entrusted to Technical Committee IST/6/-/12, Home Electronic Systems.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2020
Published by BSI Standards Limited 2020

ISBN 978 0 580 79914 3

ICS 35.200; 35.240.67

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 30 April 2020.

Amendments/corrigenda issued since publication

Date	Text affected

Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

ISO/IEC 14543-3-10

Edition 2.0 2020-03

INTERNATIONAL STANDARD

colour inside

Information technology – Home electronic system (HES) architecture – Part 3-10: Amplitude modulated wireless short-packet (AMWSP) protocol optimized for energy harvesting – Architecture and lower layer protocols

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 35.200

ISBN 978-2-8322-7979-3

Warning! Make sure that you obtained this publication from an authorized distributor.

AVA Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 8
2 Normative references 8
3 Terms, definitions and abbreviated terms 8
3.1 Terms and definitions 8
3.2 Abbreviated terms 13
4 Conformance 13
5 Architecture 13
5.1 Generic protocol description 13
5.1.1 Overview 13
5.1.2 Physical layer 14
5.1.3 Data link layer 14
5.1.4 Network layer 14
5.1.5 Transport layer 15
5.1.6 Session layer 15
5.1.7 Presentation layer 15
5.1.8 Application layer 15
5.2 Data unit description 15
6 Layer 1 – Physical layer 16
6.1 Overview 16
6.2 General description 16
6.3 Requirements for the 315 MHz AMWSP protocol 18
6.4 Requirements for the 868,3 MHz AMWSP protocol 21
6.5 Frame structure 23
7 Layer 2 – Data link layer 25
7.1 Overview 25
7.2 Subtelegram timing 25
7.3 Data integrity 26
7.3.1 General 26
7.3.2 4 bit summation hash function algorithm 27
7.3.3 8 bit summation hash function algorithm 27
7.3.4 8 bit cyclic redundancy check (CRC) hash function algorithm 27
7.4 Listen before talk 28
8 Layer 3 – Network layer 28
8.1 Overview 28
8.2 Switch telegram 28
8.3 Repeater 29
8.3.1 General 29
8.3.2 Time response for collision avoidance 29
8.3.3 Bits of a repeater level in the STATUS byte 30
8.4 Addressing 30
8.4.1 General 30
8.4.2 Encapsulation 31
Annex A (informative) Examples of how to evaluate the hash values 32
Bibliography 34

AVA Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

Figure 1 – Structure of a subtelegram 15
Figure 2 – Illustration of an ASK envelope and various physical parameters 17
Figure 3 – Complete frame structure for the 868,3 MHz AMWSP protocol 23
Figure 4 – Encoded subframe 24
Figure 5 – TX maturity time divided into four 10 ms time ranges 25
Figure 6 – Conversion of a switch telegram to a normal telegram 29
Figure 7 – Example of an encapsulation 31
Figure A.1 – Example of a C code program of the 4 bit long summation hash value 32
Figure A.2 – Example of a C code program of the 8 bit long summation hash value 32
Figure A.3 – Efficient C code program for the evaluation of an 8 bit long CRC type hash value 33

Table 1 – AMWSP protocol stack structure (OSI) 14
Table 2 – Transmitter requirements for the 315 MHz AMWSP protocol 19
Table 3 – Receiver requirements for the 315 MHz AMWSP protocol 20
Table 4 – Minimum required link budget for the 315 MHz AMWSP protocol 20
Table 5 – Maximum RX power for the 315 MHz AMWSP protocol 21
Table 6 – Transmitter requirements for the 868,3 MHz AMWSP protocol 21
Table 7 – Receiver requirements for the 868,3 MHz AMWSP protocol 22
Table 8 – Minimum required link budget for the 868,3 MHz AMWSP protocol 22
Table 9 – Maximum RX power for the 868,3 MHz AMWSP protocol 23
Table 10 – Frame definition for the 315 MHz AMWSP protocol 24
Table 11 – Frame definition for the 868,3 MHz AMWSP protocol 24
Table 12 – Maturity time parameters 25
Table 13 – Allocation of time slots to the different subtelegrams 26
Table 14 – Identification of the hash function used in the telegram 27
Table 15 – Conversion of the telegram type and STATUS fields from a switch telegram to a telegram 29
Table 16 – STATUS byte with repeater level bits 30
Table 17 – Repeating bits in STATUS byte 30

Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

INFORMATION TECHNOLOGY – HOME ELECTRONIC SYSTEM (HES) ARCHITECTURE –

Part 3-10: Amplitude modulated wireless short-packet (AMWSP) protocol optimized for energy harvesting – Architecture and lower layer protocols

FOREWORD

1) ISO (International Organization for Standardization) and IEC (International Electrotechnical Commission) form the specialized system for worldwide standardization. National bodies that are members of ISO or IEC participate in the development of International Standards. Their preparation is entrusted to technical committees; any ISO and IEC member body interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with ISO and IEC also participate in this preparation.
2) In the field of information technology, ISO and IEC have established a joint technical committee, ISO/IEC JTC 1. Draft International Standards adopted by the joint technical committee are circulated to national bodies for voting. Publication as an International Standard requires approval by at least 75 % of the national bodies casting a vote.
3) The formal decisions or agreements of IEC and ISO on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC and ISO member bodies.
4) IEC, ISO and ISO/IEC publications have the form of recommendations for international use and are accepted by IEC and ISO member bodies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC, ISO and ISO/IEC publications is accurate, IEC or ISO cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
5) In order to promote international uniformity, IEC and ISO member bodies undertake to apply IEC, ISO and ISO/IEC publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any ISO/IEC publication and the corresponding national or regional publication should be clearly indicated in the latter.
6) ISO and IEC provide no marking procedure to indicate their approval and cannot be rendered responsible for any equipment declared to be in conformity with an ISO/IEC publication.
7) All users should ensure that they have the latest edition of this publication.
8) No liability shall attach to IEC or ISO or its directors, employees, servants or agents including individual experts and members of their technical committees and IEC or ISO member bodies for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication of, use of, or reliance upon, this ISO/IEC publication or any other IEC, ISO or ISO/IEC publications.
9) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
10) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. ISO and IEC shall not be held responsible for identifying any or all such patent rights.

International Standard ISO/IEC 14543-3-10 was prepared by subcommittee 25: Interconnection of information technology equipment, of ISO/IEC joint technical committee 1: Information technology.

The list of all currently available parts of the ISO/IEC 14543 series, under the general title *Information technology – Home electronic system (HES) architecture*, can be found on the IEC and ISO websites.

This second edition cancels and replaces the first edition published in 2012. This edition constitutes a technical revision.

The text of this standard is based on the following documents:

CDV	Report on voting
JTC1-SC25/2842/CDV	JTC1-SC25/2864/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

INTRODUCTION

Various electrically controlled sensors and switches are used in homes and similar environments for many different applications. Examples of such applications are lighting, heating, energy management, blinds control, different forms of security control and entertainment (audio and video).

In most cases the device, e.g. a switch initiating an action, and the device, e.g. a lamp, are installed at different places. The distance can be bridged by wires, infrared or radio transmission. Presently equipment at both ends of a wireless transmission link needs to be powered by line or battery.

While wireless transmissions are especially attractive to retrofit homes, power maintenance of battery-driven devices is a burden. In addition, these batteries require scarce materials. Since the command and control messages sent by control and sensor devices in homes are very short, they can be powered using new techniques for energy harvesting, provided they use a wireless protocol that operates on relatively low power. Energy available in the environment of a device is captured and stored (harvested) to power operation of the device. Examples of energy sources are mechanical actuation, solar radiation, temperature differences, etc. If this is executed, at least one device in the link neither needs a battery nor a wire. Energy harvesting devices need very limited power and use an energy efficient radio protocol to send data to other conventionally powered devices in the home. In order to ensure interoperability of such devices from different sources within a home, an International Standard for a protocol is required that uses the little power that energy harvesting devices can provide and at the same time spans distances to be bridged within a home environment.

Several such devices used within a home often come from different sources. They are required to interwork with each other using a common internal network (in this document called a home network) and supporting a home automation system. When a home automation system meets ISO/IEC HES Standards, it is called a home electronic system (HES).

Alternative transmission technologies are specified by ISO/IEC 14543 (all parts). ISO/IEC 14543-3-10 and ISO/IEC 14543-3-11 are optimized for energy harvesting based on similar techniques, but with different modulation schemes. ISO/IEC 14543-3-10 and ISO/IEC 14543-3-11 specify two lower layer wireless short-packet protocols: ISO/IEC 14543-3-10 uses an amplitude modulated (AM) signal and ISO/IEC 14543-3-11 a frequency modulated (FM) signal.

Amplitude modulated wireless communications are more energy efficient but less adapted to mobile devices. This is because the impedance of a mobile antenna is affected by the environment of the mobile device, for example, when the device is held in the hand or moved to metal surface. Changes in impedance affect the amplitude linearity of the radio frequency output amplifier, but have no impact on the frequency itself. Thus an AM wireless system is more sensitive to changes in environment than an FM wireless system. Also frequencies above 800 MHz are better suited for mobile devices, since they require smaller antennas. Thus the frequency 315 MHz is not used in the FM specification, which makes the FM wireless system more efficient for mobile devices.

Compared to the AM wireless system, the FM wireless system provides more flexibility in the size of various pieces of information that can be transmitted. This includes the possibility to have larger payloads, different lengths of the identifiers of originators and destinations, and greater variability of structures and lengths of the telegram types. The number of steps a telegram can be repeated is two for the AM wireless system and 15 for the FM wireless system.

Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

They are both efficient enough to

- support energy harvesting products for sensors and switches that require neither cabling nor batteries, and
- extend the life of battery-operated devices.

Both an AM and an FM system can be active at the same time, since each system is so constructed that only permitted messages are accepted. Collisions can be avoided by listen-before-talk (LBT) technology or overcome by redundant transmissions.

Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

INFORMATION TECHNOLOGY – HOME ELECTRONIC SYSTEM (HES) ARCHITECTURE –

Part 3-10: Amplitude modulated wireless short-packet (AMWSP) protocol optimized for energy harvesting – Architecture and lower layer protocols

1 Scope

This part of ISO/IEC 14543 specifies a wireless protocol for low-powered devices such as energy harvesting devices in a home environment. This wireless protocol is specifically designed to keep the energy consumption of such sensors and switches extremely low.

The design is characterized by

- keeping the communications very short, infrequent and mostly unidirectional, and
- using communication frequencies that provide a good range even at low transmit power and avoid collisions from disturbers.

This allows the use of small and low-cost energy harvesting devices that can compete with similar battery-powered devices. The messages sent by energy harvesting devices are received and processed mainly by line-powered devices such as relay switch actuators, repeaters or gateways. Together these form part of a home automation system, which, when conforming to ISO/IEC 14543 (all parts), is defined as a home electronic system.

This document specifies OSI Layers 1 to 3 of the amplitude modulated wireless short-packet (AMWSP) protocols.

The AMWSP protocol system consists of two and optionally three types of components that are specified in this document. These are the transmitter, the receiver and optionally the repeater. Repeaters are needed when the transmitter and the receiver are located in such a way that no good direct communication between them can be established.

Protection against malicious attacks is handled in the upper layers and thus not treated in this document.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ETSI EN 300 220-1 V3.1.1, *Short Range Devices (SRD) operating in the frequency range 25 MHz to 1 000 MHz; Part 1: Technical characteristics and methods of measurement*

3 Terms, definitions and abbreviated terms

3.1 Terms and definitions

For the purposes of this document the following terms and definitions apply.

AVA Documents Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- IEC Electropedia: available at http://www.electropedia.org/
- ISO Online browsing platform: available at http://www.iso.org/obp

3.1.1
amplitude shift keying envelope
ASK envelope
envelope of the modulated signal

3.1.2
bit duration
time between transitions of the mesial amplitude of an ASK envelope in an alternating sequence

Note 1 to entry Figure 2 shows this in detail.

3.1.3
bit duration error
deviation of bit duration from specified bit duration

3.1.4
byte
ordered set of eight binary digits, operated on as an entity

Note 1 to entry: The non-qualified term "byte" designates an 8-bit byte.

[SOURCE: IEC 60050-702:2016, 702-05-09]

3.1.5
collision
state which exists when two wireless transmitters use the same wireless channel and transmit data at the same time

3.1.6
cyclic redundancy check
CRC
integrity hash algorithm based on a polynomial division

3.1.7
DATA
application payload data transmitted in the telegram

3.1.8
energy harvesting device
device able to capture and store (harvest) energy from the environment to power its operations

Note 1 to entry Examples of energy sources are mechanical actuation, solar radiation, temperature differences, etc.

3.1.9
frame
set of data to be transmitted as a complete unit on the physical layer

Note 1 to entry A frame contains the necessary protocol control and synchronization data for transmission between network nodes.

Documents
Document Sharing Hub
Full document details: BS ISO/IEC 14543-3-10:2020

3.1.10
HASH
field in which the hash value for the data integrity control of each transmitted telegram and subtelegram is specified

3.1.11
high nibble
upper four bits of the byte

Note 1 to entry The N value from the byte 0xNM.

3.1.12
high state amplitude
amplitude corresponding to the physical high state level

3.1.13
high state level
level of the ASK envelope that represents the high state amplitude

Note 1 to entry The definition aligns with IEEE 194-1977, 5.2.2.5, static levels. Figure 2 gives an illustration.

3.1.14
identity of the destination device
DESTID
unique identity of the destination device of an AMWSP telegram consisting of four bytes

3.1.15
identity of the transmitting device
TXID
unique identity of the AMWSP protocol transmitting device consisting of four bytes

3.1.16
inverse bits
INV
bits added by the encoding procedure into a subframe behind the third and the sixth bit to reduce the DC content of the data

3.1.17
listen before talk
LBT
technique of checking the occupancy of the wireless channel before transmitting any frames

3.1.18
low nibble
lower four bits of the byte

Note 1 to entry The M value from the byte 0xNM.

3.1.19
low state amplitude
amplitude corresponding to the physical low state level

3.1.20
low state level
level of the ASK envelope that represents the low state amplitude

Note 1 to entry The definition aligns with IEEE 194-1977, 5.2.2.5, static levels. Figure 2 gives an illustration.

AVA Documents
Document Sharing Hub

Full document details: BS ISO/IEC 14543-3-10:2020