

Förderverein für Elektrotechnische Normung (FEN) e. V.
Cenelec Electronic Components Committee

CECC



Système Harmonisé d'Assurance de la Qualité
des Composants Electroniques

SPECIFICATION PARTICULIERE:

**CONNECTEURS COAXIAUX
POUR FREQUENCE
RADIOELECTRIQUE
Série SMA**

Harmonized System of Quality Assessment for
Electronic Components

DETAIL SPECIFICATION:

**RADIO FREQUENCY
COAXIAL CONNECTORS
Series SMA**

Harmonisiertes Gütebestätigungssystem für
Bauelemente der Elektronik

BAUARTSPEZIFIKATION:

**HOCHFREQUENZ-
KOAXIAL-STECKVERBINDER
Serie SMA**

1

Edition
Issue
Ausgabe

CECC 22111-806

1984



Documents

Document Sharing Hub

Cette page bleue doit être insérée après la page de garde de la CECC 22 111-806 Edition 1 (1984)

MODIFICATION 1 DE LA CECC 22 111-806 (Edition 1):

SPECIFICATION PARTICULIERE:

CONNECTEURS COAXIAUX POUR FREQUENCE RADIO-ELECTRIQUE Série SMA

La modification suivante doit être effectuée à la main:

Page 4: [10] Information supplémentaire
sous
information pour commande i):

Supprimer le numéro CECC 22 111-006-xx
et insérer CECC 22 111-806-xx.

This blue page should be inserted after the title page of CECC 22 111-806 Issue 1 (1984)

AMENDMENT 1 TO CECC 22 111-806 (Issue 1):

DETAIL SPECIFICATION:

RADIO FREQUENCY COAXIAL CONNECTORS Series SMA

The following amendment shall be made in manuscript:

Page 4: [10] Supplementary Information
under
i) of ordering information:

Amend CECC 22 111-006-xx to read
CECC 22 111-806-xx.

Dieses blaue Blatt ist nach dem Titelblatt CECC 22 111-806 Ausgabe 1 (1984) einzusetzen

ÄNDERUNG 1 ZU CECC 22 111-806 (Ausgabe 1):

BAUARTSPEZIFIKATION:

HOCHFREQUENZ-KOAXIAL-STECKERBINDER Serie SMA

Die folgende Änderung ist handschriftlich vorzunehmen:

Seite 4: [10] Zusatzaufgaben
unter
i) der Bestellangaben:

CECC 22 111-006-xx ist durch
CECC 22 111-806-xx zu ersetzen.

CECC 22 111-806 Edition 1 Modification 1 1985

CECC 22 111-806 Issue 1 Amendment 1 1985

CECC 22 111-806 Ausgabe 1 Änderung 1 1985

ERRATUM

Cette page bleue doit être insérée après la page de garde de la CECC 22 111-806 Edition 1 (1984)

This blue sheet shall be inserted after the title page of CECC 22 111-806 Issue 1 (1984)

Dieses blaue Blatt ist nach dem Titelblatt der CECC 22 111-806 Ausgabe 1 (1984) einzufügen

La modification suivante doit être effectuée à la main à l'Edition 1 (1984) de la CECC 22 111-806:

Page 2 [9] ELECTRIQUES, colonne 2

- Tension de tenue à 20 km d'altitude:
Modifier 4.4.5 pour lire 4.6.5

The following amendment to Issue 1 (1984) of CECC 22 111-806 should be made in manuscript:

Page 2 [9] ELECTRICAL, column 2

- Proof voltage at 20 km altitude:
Amend 4.4.5 to read 4.6.5

In Ausgabe 1 (1984) der CECC 22 111-806 ist folgende Änderung handschriftlich vorzunehmen:

Seite 2 [9] ELEKTRISCH, Spalte 2

- Spannungsfestigkeit in 20 km Höhe:
4.4.5 ist durch 4.6.5 zu ersetzen

CECC 22 111-806 Edition 1
Issue 1 ERRATUM
Ausgabe 1



Copyright – all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Droits de reproduction réservés

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

Alle Rechte vorbehalten

Insbesondere darf kein Teil dieser Veröffentlichung in irgendeiner Form oder nach irgendeinem Verfahren, elektronisch oder mechanisch, einschließlich Fotokopieren und Mikrofilm, ohne schriftliche Einwilligung des Herausgebers vervielfältigt oder verwertet werden.

PREFACE

This detail specification (DS) was prepared by CECC Working Group 22: 'RF Connectors'.

It relates to Series SMA connectors covered by sectional specification CECC 22 110 and by blank detail specification CECC 22 111. These in turn are related to the generic specification CECC 22 000.

The text of this DS was circulated to the CECC for voting in the documents detailed below and was ratified by the President of the CECC for printing as a CECC specification.

<u>Document</u>	<u>Voting date</u>	<u>Report on the voting</u>
CECC(Secretariat)1294	May 1983	CECC(Secretariat)1421

CECC 22 111-806 Issue 1

[1]	Page 1 of 6	[2] CECC 22 111 - 806	
ELECTRONIC COMPONENT OF ASSESSED QUALITY IN ACCORDANCE WITH GENERIC SPECIFICATION 22 000 SECTIONAL SPECIFICATION 22 110	[3]	[4]	

[5] DETAIL SPECIFICATION for
RADIO FREQUENCY COAXIAL CONNECTOR OF ASSESSED QUALITY :

SERIES

SMA

Style: .. Fixed, straight, socket for semi-rigid cable..

Special Features + Markings:

Method of cable/wire attachment:

narrow flange.....

centre conductor - solder/crimp

.....

outer conductor - solder/clamp/crimp



.....

Mass: 3.8..... (Max.)

[6] Assessment level .. H .. Characteristic impedance 50 Ω Climatic category: 55 / 115 / 21

[7] Outline and maximum dimensions

Panel piercing and mounting details



For mating interface and position of reference plane see CECC 22 110

Maximum panel thickness: for front mounting without limit mm
for rear mounting mm

The outline dimensions meet the requirements of

[8] Variants

Variant No.	Description of Variant	IEC 96-2	Relevant Cables RG	National Cables
.....-01..	Connector, Gold.....		RG 402/U.....	(F).....KS 2.....
(3).....-02..	Connector, Passivated.....		RG 402/U.....	KS 2.....
.....-03..	Stainless Steel.....		RG 405/U.....	KS 1.....
(3).....-04..	Connector, Gold.....		RG 405/U.....	KS 1.....
.....	Connector, Passivated.....			
.....	Stainless Steel.....			
.....				
.....				

Note: (3) The surface to be soldered shall be prepared in a suitable manner so as to accept the solder correctly.

Information about manufacturers who have components qualified to this detail specification is available in the current CECC 00 200: Qualified Products List.

[9] PERFORMANCE - (including limiting conditions of use)

RATINGS + CHARACTERISTICS		CECC 22 110 Clause	VALUE	REMARKS
ELECTRICAL				
	Variant No./ Designation			Measurement freq. range
*Reflection factor	-01	4.4.1		
	-02	)		
	-03	)	$\leq 0,034 \pm 0,004$ f.	2-18 GHz
	-04	)		VSWR $\leq 1,07 \pm 0,009$ f.
				
				
Centre contact resistance		4.4.2	$\leq 3,0$ m Ω	Initial
Outer conductor continuity		4.4.3	$\leq 4,5$ m Ω	After conditioning
Insulation resistance		4.4.4	≤ 5 G Ω	Initial
			≤ 200 M Ω	After conditioning
+Proof voltage at sea level	-01	4.4.5	1 kV	860 to 1060 mbar
	-02		1	(86 to 106 kPa)
	-03		0,750	
	-04		0,750	
				
				
				
+Proof voltage at 20 km altitude	-01	4.6.5	200 V	44 mbar
	-02		200	(4,4 kPa)
	-03		150	
	-04		150	
				
				
				
+Working voltage at sea level	-01		335 V	860 to 1060 mbar
	-02		335	(86 to 106 kPa)
	-03		250	
	-04		250	
				
				
				
+Working voltage at 20 km altitude	-01		85 V	44 mbar
	-02		85	(4,4 kPa)
	-03		65	
	-04		65	
				
				
				
Screening effec- tiveness	-01	4.4.8	$Z_t \leq 1,6 \times 10^{-3} \Omega$	Equivalent to .90. dB
	-02	)		
	-03	)		
	-04	)		
				
				
				
ADDITIONAL ELECTRICAL CHARACTERISTICS				

* f = Frequency in GHz

+ Voltage values are r.m.s values of a.c. at 50-60 Hz unless otherwise stated.

RATINGS + CHARACTERISTICS		CECC 22 110 Clause	VALUE	REMARKS
MECHANICAL				
Contact captivation - axial force - torque		4.5.2	na.....N na.....Nm	CECC 22 000 method (or as specified)
Engagement + separation - torque		4.5.4	na.....Nm max.	
	Variant No./ Designation			
Effectiveness of clamping device	-01	4.5.5	500.....N	(to overcome friction of coupling nut)
against cable pulling	-02	(1)	500.....	
	-03		200.....	
	-04		200.....	
				
				
				
				
				
				
Effectiveness of clamping device	-01	4.5.5	na.....Nm	
against cable torsion	-02	(2)	na.....	
	-03		na.....	
	-04		na.....	
				
				
				
				
				
				
Tensile strength of coupling mechanism		4.5.6	na.....N	
Coupling torque - normal - proof			na.....Nm na.....Nm	
Bending moment		4.5.9	0.45.....Nm	Relative to reference plane
ADDITIONAL MECHANICAL CHARACTERISTICS				
ENVIRONMENTAL				
Bump		4.6.2	390....m/s ² 4000....bumps	(.40.g acceleration)
Vibration		4.6.3	98....m/s ² 10 to 2000 Hz	(.10.g acceleration)
Shock		4.6.4	490....m/s ² 1/2 sine 11 ms	(.50.g acceleration)
Climatic category		4.6.5	.55/.115/.21.	
Sealing (panel + barrier sealed connectors)		4.6.8	na.....	100 to 110 kPa pressure differential (1000 to 1100 mbar)
Sealing (hermetically sealed connectors)		4.6.9	na.....	100 to 110 kPa pressure differential (1000 to 1100 mbar)
ADDITIONAL ENVIRONMENTAL CHARACTERISTICS				
ENDURANCE				
Mechanical		4.7.1	..500...operat.	
High temperature		4.7.2	..1000...h at ..115....°C	
ADDITIONAL ENDURANCE CHARACTERISTICS				

[10] Supplementary Information

- marking of the component : in accordance with 2.4 of CECC 22 000, in the following order or precedence :

i) Component identification	Variant No./ Designation	Identification
	-01	22-111-806-01..
	-02	-02..
	-03	-03..
	-04	-04..
		
		
		
ii) Identity of manufacturer		
iii) Manufacturing date code, year/week		

- marking and contents of package : in accordance with 2.5 and 2.5.1 of CECC 22 000 as follows :

- i) Information prescribed in 2.4 of CECC 22 000 detailed above
- ii) Nominal characteristic impedance 50 Ω
- iii) Assessment level code letter B.....
- iv) Any additional marking required

- ordering information : in accordance with 2.6 of CECC 22 000 as follows :



- i) Number of the detail specification CECC 22 111-806 -xx (No. of Variant)
- ii) Assessment level code letter B.....
- iii) Body finish (if more than one listed) see variant numbers in [8]
- iv) Any additional information or special requirements

- related documents :

CECC 22 000	Generic specification for radio frequency connectors of assessed quality (and related documents, see 2.1 of CECC 22 000)
CECC 22 110	Sectional specification for r.f. connectors Series SMA

- certified test records (RCE) : In accordance with 3.7 of CECC 22 000 (when applicable) (requirements to be included later)

- structural similarity : In accordance with 3.2 and 3.4 of CECC 22 000.

(11) TEST SCHEDULE AND INSPECTION REQUIREMENTS - SERIES SMA

Details of tests and quality assessment inspection requirements for Levels H and U are given in 5.1 of CECC 22 110.

ACCEPTANCE TESTS

GROUP A1

Visual examination

GROUP B1

Outline dimensions
Compatibility mechanical
Engagement + Separation
Gauge retention force
(resilient contacts)
Sealing (panel + barrier seal)
Sealing (hermetic)
Voltage proof

CECC 22 110 Clause	LEVEL H			
	Test Requir.	I.L.	AQL	Period
4.2	a	S 3	1,5 %	Lot by Lot
4.3.1	a	S 3	4 %	
4.5.7	a	S 3	1,5 %	
4.5.4	na			
4.5.1	a	S 3	1,5 %	
4.6.8	na			
4.6.9	na			
4.4.5	a	S 3	4 %	

PERIODIC TESTS

GROUP C1 (d)

Soldering
Insulation resistance

CECC 22 110 Clause	Test	I.L.	AQL	Period
4.6.1	a			
4.4.4	a	S 3	4 %	1 yearly

GROUP D1 (d)

Mechanical tests on cable
clamping device
Bending moment
Tensile strength of
coupling mechanism

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.5.5	a	3 mated pairs or sets min.	1	3 yearly
4.5.9	a			
4.5.6	na			

GROUP D2 (d)

Contact resistance
Outer conductor continuity
Bump
Vibration
Shock
Damp heat, steady state
Salt mist

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.4.2	a			
4.4.3	a			
4.6.2	a	3 mated pairs or sets min.	1	3 yearly
4.6.3	a			
4.6.4	a			
4.6.6	a			
4.6.10	a			

GROUP D3

Dimensions and materials
(piece parts)
Mass

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.3.2	a	1 set of piece parts each style	1	3 yearly
4.3.1	a			

GROUP D4 (d)

Mechanical endurance
High temperature endurance

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.7.1	a	3 mated pairs or sets min.	1	3 yearly
4.7.2	a			

GROUP D5 (d)

Reflection factor
Screening effectiveness

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.4.1	a	3 mated pairs or sets min.	1	3 yearly
4.4.8	a			

GROUP D6 (d)

Contact captivation
Rapid change of temperature
Climatic sequence

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.5.2	na	3 mated pairs or sets min.	1	3 yearly
4.6.7	a			
4.6.5	a			