

Förderverein für Elektrotechnische Normung (FEN) e. V.
Cenelec Electronic Components Committee

CECC



Système Harmonisé d'Assurance de la Qualité
des Composants Electroniques

● SPECIFICATION PARTICULIERE:

**CONNECTEURS COAXIAUX
POUR FREQUENCE
RADIOELECTRIQUE
Série SMA**

Harmonized System of Quality Assessment for
Electronic Components

● DETAIL SPECIFICATION:

**RADIO FREQUENCY
COAXIAL CONNECTORS
Series SMA**

Harmonisiertes Gütebestätigungssystem für
Bauelemente der Elektronik

BAUARTSPEZIFIKATION:

**HOCHFREQUENZ-
KOAXIAL-STECKVERBINDER
Serie SMA**

1

Edition
Issue
Ausgabe

CECC 22 111-816

1987



Documents

Document Sharing Hub

**Copyright – all rights reserved**

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Droits de reproduction réservés

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

Alle Rechte vorbehalten

Insbesondere darf kein Teil dieser Veröffentlichung in irgendeiner Form oder nach irgendeinem Verfahren, elektronisch oder mechanisch, einschließlich Fotokopieren und Mikrofilm, ohne schriftliche Einwilligung des Herausgebers vervielfältigt oder verwertet werden.

PREFACE

This detail specification (DS) was prepared by CECC Working Group 22: 'RF Connectors'.

It relates to Series SMA connectors covered by sectional specification CECC 22 110 and by blank detail specification CECC 22 111. These in turn are related to the generic specification CECC 22 000.

It is based, wherever possible, on the Publications of the International Electrotechnical Commission, and in particular on IEC 169-15 (1979) Part 15: R.F. coaxial connectors with inner diameter of outer conductor 4,13 mm (0,163 in) with screw coupling – Characteristic impedance 50 ohms (Type SMA).

The text of this detail specification was circulated to members of CECC WG 22 and was approved for publication under the accelerated procedure for the acceptance of detail specifications in accordance with Decision 10 of CD Minutes document CECC(Secretariat)1838.

Document

WG22(Bosshard)802

Approval Date

August 1986

CECC 22 111-816 Issue 1

[1]	Page 1 of 6	[2] CECC 22 111 - 816	
ELECTRONIC COMPONENT OF ASSESSED QUALITY IN ACCORDANCE WITH GENERIC SPECIFICATION 22 000 SECTIONAL SPECIFICATION 22 110	[3]	[4]	


[5] DETAIL SPECIFICATION for
RADIO FREQUENCY COAXIAL CONNECTOR OF ASSESSED QUALITY : SERIES

SMA

Style: Straight plug for semi-rigid cable Specials Features + Markings:
Method of cable/wire* attachment:
centre conductor - ~~solder/crimp/double contact~~
outer conductor - ~~solder/crimp or clamp~~
Mass: 3.5 g (Max.) Solderless connection to
semi-rigid cable

[6] Assessment level .. H .. Characteristic Impedance 50 Ω Climatic category: 55 / 115 / 21

[7] Outline and maximum dimensions Panel piercing and mounting details



Assembly tools and stripping
dimensions to conform with the
instructions supplied by the
manufacturers

For mating interface and position of reference plane see CECC 22 110

Maximum panel thickness: for front mounting mm
for rear mounting mm

The outline dimensions meet the requirements of

[8] Variants

Variant No.	Description of Variant	IEC 96-2	Relevant Cables RG	National Cables
-01.....	Connector passivated..... stainless steel.....		RG 4Q2/4.....	..(F).. KS 2.....
-02.....	Connector passivated..... stainless steel.....		RG 4Q5/4.....	 KS 1.....
.....				
.....				
.....				

Notes: 1. *Delete as appropriate

Information about manufacturers who have components qualified to this details specification
is available in the current CECC 00 200: Qualified Products List.

[9] PERFORMANCE - (including limiting conditions of use)

RATINGS + CHARACTERISTICS		CECC 22 110 Clause	VALUE	REMARKS
ELECTRICAL				
	Variant No./ Designation			Measurement freq. range
*Reflection factor	-01	4.4.1	$\leq 0.034 + 0.004f$	... f $\pm$ 2 - 18 GHz ...
	-02			(VSWR $\leq 1.07 + 0.009f$)
	-03			
	-04			
	-05			
	-06			
Centre contact resistance		4.4.2	3,0 m Ω	Initial
Outer conductor continuity		4.4.3	2,5 m Ω	After conditioning
Insulation resistance		4.4.4	2,5 G Ω	Initial
			200 M Ω	After conditioning
+Proof voltage at sea level	-01	4.4.5	1,0 kV	860 to 1060 mbar
	-02		0,75 kV	(86 to 106 kPa)
	-03			
	-04			
	-05			
	-06			
+Proof voltage at 20 km altitude	-01	4.6.5	200 V	44 mbar
	-02		150 V	(4,4 kPa)
	-03			
	-04			
	-05			
	-06			
+Working voltage at sea level	-01		335 V	860 to 1060 mbar
	-02		250 V	(86 to 106 kPa)
	-03			
	-04			
	-05			
	-06			
+Working voltage at 20 km altitude	-01		85 V	44 mbar
	-02		65 V	(4,4 kPa)
	-03			
	-04			
	-05			
	-06			
Screening effec- tiveness	-01	4.4.8	$z_t \leq 1,6 \times 10^{-3} \Omega$	Equivalent to .90. dB
	-02			
	-03			
	-04			
	-05			
	-06			
ADDITIONAL ELECTRICAL CHARACTERISTICS				

* f = Frequency in GHz

+ Voltage values are r.m.s values of a.c. at 50-60 Hz unless otherwise stated.

RATINGS + CHARACTERISTICS		CECC 22 110 Clause	VALUE	REMARKS
MECHANICAL				
Contact captivation		4.5.2	22.....N	CECC 22 000 method (or as specified)
- axial force			0,028.....Nm	
- torque				
Engagement + separation		4.5.4	0,25.....Nm max.	
- torque				
	Variant No./ Designation			
Effectiveness of	-01	4.5.5	267.....N	
clamping device	-02	(1)	134.....N	
against cable pulling	-03			
	-04			
	-05			
	-06			
				
Effectiveness of	-01	4.5.5	0,30.....Nm	Relative to reference plane
clamping device	-02	(2)	0,12.....Nm	
against cable torsion	-03			
	-04			
	-05			
	-06			
				
				
				
				
Tensile strength of		4.5.6	180.....N	
coupling mechanism				
Coupling torque				
- normal			0,8 - 1,1.....Nm	
- proof			1,7.....Nm	
Bending moment		4.5.9	0a.....Nm	
ADDITIONAL MECHANICAL CHARACTERISTICS				
ENVIRONMENTAL				
Bump		4.6.2	390.....m/s ²	(.40.g acceleration)
Vibration		4.6.3	4'000.....bumps	(10.g acceleration)
			98.....m/s ²	
Shock		4.6.4	10 - 2'000.Hz	(50.g acceleration)
			490.....m/s ²	
Climatic category		4.6.5	1/2 Sine 11 ms	
			50./115./21..	
Sealing (panel + barrier sealed connectors)		4.6.8	na.....	100 to 110 kPa pressure differential (1000 to 1100 mbar)
Sealing (hermetically sealed connectors)		4.6.9	na.....	100 to 110 kPa pressure differential (1000 to 1100 mbar)
ADDITIONAL ENVIRONMENTAL CHARACTERISTICS				
ENDURANCE				
Mechanical		4.7.1	.. 500...operat.	
High temperature		4.7.2	1'000...h at ..115....°C	
ADDITIONAL ENDURANCE CHARACTERISTICS				

[10] Supplementary Information

- marking of the component : in accordance with 2.4 of CECC 22 000, in the following order of precedence :

i) Component identification	Variant No./ Designation	Identification
	-01	..22.111-816/Q1..
	-02	..22.111-816/Q2..
	-03	
	-04	
	-05	
	-06	
		
		
ii) Identity of manufacturer		
iii) Manufacturing date code, year/week		

- marking and contents of package : in accordance with 2.5 and 2.5.1 of CECC 22 000 as follows :

- i) Information prescribed in 2.4 of CECC 22 0000 detailed above
- ii) Nominal characteristic impedance 50 Ω
- iii) Assessment level code letter H.....
- iv) Any additional marking required

- ordering information : in accordance with 2.6 of CECC 22 000 as follows :

- i) Number of the detail specification CECC 22 111-816-xx (No. of Variant)
- ii) Assessment level code letter H.....
- iii) Body finish (if more than one listed) see variant numbers in [8]
- iv) Any additional information or special requirements

- related documents :

CECC 22 000	Generic Specification for radio frequency connectors of assessed quality (and related documents, see 2.1 of CECC 22 000)
CECC 22 110	Sectional Specification for r.f. connectors Series SMA

- certified test records (RCE) : In accordance with 3.7 of CECC 22 000 (when applicable) (requirements to be included later)

- structural similarity : In accordance with 3.2 and 3.4 of CECC 22 000.

[11] TEST SCHEDULE AND INSPECTION REQUIREMENTS - SERIES SMA

Details of tests and quality assessment inspection requirements for levels H and U are given in 5.1 of CECC 22 110.

ACCEPTANCE TESTS**GROUP A1**

Visual examination

GROUP B1

Outline dimensions

Compatability mechanical

Engagement + separation

Gauge retention force

(resilient contacts)

Sealing (panel + barrier seal)

Sealing (hermetic)

Voltage proof

CECC 22 110 Clause	LEVEL H			
	Test Requir.	I.L.	AQL	Period
4.2	a	S 3	1,5 %	Lot by Lot
4.3.1	a	S 3	4 %	
4.5.7	a	S 3	1,5 %	
4.5.4	a	S 3	1,5 %	
4.5.1	na			
4.6.8	na			
4.6.9	na			Lot
4.4.5	a	S 3	4 %	

PERIODIC TESTS**GROUP C1 (d)**

Soldering

Insulation resistance

CECC 22 110 Clause	Test	I.L.	AQL	Period
4.6.1	na			
4.4.4	a	S 3	4 %	1 year

GROUP D1 (d)Mechanical tests on cable
clamping device

Bending moment

Tensile strength of
coupling mechanism

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.5.5	a	3 mated pairs or sets min.	1	3 yearly
4.5.9	na			
4.5.6	a			

GROUP D2 (d)

Contact resistance

Outer conductor continuity

Bump

Vibration

Shock

Damp heat, steady state

Salt mist

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.4.2	a	3 mated pairs or sets min.	1	3 yearly
4.4.3	a			
4.6.2	a			
4.6.3	a			
4.6.4	a			
4.6.6	a			
4.6.10	a			

GROUP D3Dimensions and materials
(piece parts)

Mass

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.3.2	a	1 set of piece parts each style	1	3 yearly
4.3.1	a			

GROUP D4 (d)

Mechanical endurance

High temperature endurance

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.7.1	a	3 mated pairs or sets min.	1	3 yearly
4.7.2	a			

GROUP D5 (d)

Reflection factor

Screening effectiveness

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.4.1	a	3 mated pairs or sets min.	1	3 yearly
4.4.8	a			

GROUP D6 (d)

Contact captivation

Rapid change of temperature

Climatic sequence

CECC 22 110 Clause	Test Requir.	Specimens (May be from C1)	Permitted Failures † per Group	Period
4.5.2	a	3 mated pairs or sets min.	1	3 yearly
4.6.7	a			
4.6.5	a			

PROCEDURES

Quality Conformance Inspection

This shall consist of Test Groups A1 and B1 on a lot-by-lot basis and C1 on a periodic basis.

Qualification Approval and its Maintenance

This shall consist of three consecutive lots passing Test Groups A1 and B1 followed by selection of specimens from lots as appropriate. These specimens shall successfully pass the specified periodic C1 and D tests.

NOTES

I.L.	=	Inspection Level
AQL	=	Acceptabel Quality Level
a	=	applicable
†	=	for Qualification Approval (QA) a total of 2 failures only permitted
(d)	=	destructive test - specimens shall not be returned to stock
na	=	not applicable