

Förderverein für Elektrotechnische Normung (FEN) e. V.
Cenelec Electronic Components Committee

CECC



Système Harmonisé d'Assurance de la Qualité des Composants Electroniques

SPECIFICATION PARTICULIERE:

CONNECTEURS COAXIAUX POUR FREQUENCE RADIOELECTRIQUE Série SSMA

Harmonized System of Quality Assessment for Electronic Components

DETAIL SPECIFICATION:

RADIO FREQUENCY COAXIAL CONNECTORS Series SSMA

Harmonisiertes Gütebestätigungssystem für Bauelemente der Elektronik

BAUARTSPEZIFIKATION:

HOCHFREQUENZ- KOAXIAL-STECKVERBINDER Serie SSMA

1 Edition
Issue
Ausgabe

CECC 22161-814

1987

AVA Documents
Document Sharing Hub

**Copyright – all rights reserved**

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Droits de reproduction réservés

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

Alle Rechte vorbehalten

Insbesondere darf kein Teil dieser Veröffentlichung in irgend einer Form oder nach irgendeinem Verfahren, elektronisch oder mechanisch, einschließlich Fotokopieren und Mikrofilm, ohne schriftliche Einwilligung des Herausgebers vervielfältigt oder verwertet werden.

PREFACE

This detail specification (DS) was prepared by CECC Working Group 22: 'RF Connectors'.

It relates to Series SSMA connectors covered by sectional specification CECC 22 160 and by blank detail specification CECC 22 161. These in turn are related to the generic specification CECC 22 000.

The text of this DS was circulated to the CECC for voting in the documents detailed below and was ratified by the President of the CECC for printing as a CECC specification.

<u>Document</u>	<u>Voting Date</u>	<u>Report on the Voting</u>
CECC(Secretariat)1769	July 1985	CECC(Secretariat)1851

CECC 22 161-814 Issue 1

[1]	page 1 of 9	[2] CECC 22 161 - 814. ..	
ELECTRONIC COMPONENT OF ASSESSED [3] QUALITY IN ACCORDANCE WITH GENERIC SPECIFICATION ..22.000..... SECTIONAL SPECIFICATION 22.160.....	[4]	Issue	1

[5] DETAIL SPECIFICATION for

RADIO FREQUENCY COAXIAL CONNECTOR OF ASSESSED QUALITY:

SERIES

SSMA

Style: Adaptor straight, two female centre contacts.....

Special Features & Markings:


Method of cable/wire* attachment: centre conductor - ~~solder~~/crimp*: outer conductor - ~~solder~~/clamp/crimp*

Mass: 1.1 g.....(Max.) *Delete as appropriate

[6] Assessment level ...H... Characteristic impedance 50 Ω Climatic category ...55/155/21...

[7] Outline and maximum dimensions

Panel piercing and mounting details



For mating interface dimensions and position of reference plane see CECC 22 160

Maximum panel thickness: for front mounting mm, for rear mounting mm

The outline dimensions meet the requirements of

[8] Variants

Variant No.	Description of Variant	Relevant Cables		
		IEC 96	RG	National Cables
.....-01	GOLD PLATED			
.....-02	PASSIVATED STAINLESS			
.....	STEEL			
.....				
.....				
.....				
.....				

Information about manufacturers who have components qualified to this detail specification is available in the current CECC 00 200: Qualified Products List.

+ Voltage values are r.m.s. values of a.c. at 50 to 60 Hz unless otherwise stated.
* f = Frequency in GHz

RATINGS AND CHARACTERISTICS		CECC 22 160 CLAUSE	VALUE	REMARKS
ELECTRICAL				
+ Working voltage at sea level	Variant No./ Designation			
	-01-02.....		250 V	86 to 106 kPa
				
				
				
				
				
				
				
				
+ Working voltage at 20 km altitude	-01-02.....		75 V	4,4 kPa
				
				
				
				
				
				
				
				
				
Screening effectiveness	-01-02.....	4.4.8	$Z_t \leq 10 \text{ m}\Omega$	Providing $\geq 80 \text{ dB}$
				
				
				
				
				
				
				
				
				
ADDITIONAL ELECTRICAL CHARACTERISTICS				
MECHANICAL				
Contact captivation: - axial force - torque		4.5.2	22 N	CECC 22 000 method
			3... Nm	

+ Voltage values are r.m.s. values of a.c. at 50 to 60 Hz unless otherwise stated.

RATINGS AND CHARACTERISTICS		CECC 22 160 CLAUSE	VALUE	REMARKS
MECHANICAL				
Engagement and separation - torque		4.5.4	 Nm max.	(to overcome friction of coupling nut)
Effectiveness of clamping device against cable pulling	Variant No./ Designation	4.5.5 (1)	na N	
Effectiveness of clamping device against cable torsion		4.5.5 (2)	na Nm	
Tensile strength of coupling mechanism		4.5.6	na..... N	
Coupling torque - normal			na..... Nm	
- proof			na..... Nm	
Bending moment		4.5.9	na..... Nm	Relative to reference plane
ADDITIONAL MECHANICAL CHARACTERISTICS				

RATINGS AND CHARACTERISTICS	CECC 22 160 CLAUSE	VALUE	REMARKS
ENVIRONMENTAL			
Bump	4.6.2	390. m/s ² ...4000.bumps	(40g acceleration)
Vibration	4.6.3	98. m/s ² ..10.to.500 Hz	(10g acceleration)
Shock	4.6.4	490. m/s ² ½ sine .11. ms	(50g acceleration)
Climatic category	4.6.5	.55/155/21.	
Sealing (panel and barrier sealed connectors)	4.6.8	na.....	100 to 110 kPa pressure differential
Sealing (hermetically sealed connectors)	4.6.9	na.....	100 to 110 kPa pressure differential
ADDITIONAL ENVIRONMENTAL CHARACTERISTICS			
ENDURANCE			
Mechanical	4.7.1	500 operations	
High temperature	4.7.2	1000 155 h at..... °C	
ADDITIONAL ENDURANCE CHARACTERISTICS			

[10] SUPPLEMENTARY INFORMATION

- marking of the component: in accordance with 2.4 of CECC 22 000, in the following order of precedence:

(1) Component identification	Variant No./ Designation	Identification
	-01	22 161-814 -01
	-02	22 161-814 -02
		
		
		
		
		
		
		
(2) Identification of manufacturer:		
(3) Manufacturing date code; year/week.		

- marking and contents of package: in accordance with 2.5 and 2.5.1 of CECC 22 000 as follows:

- (1) Information prescribed in 2.4 of CECC 22 000 detailed above
- (2) Nominal characteristics impedance ^{50 Ω}
- (3) Assessment level code letter ^H
- (4) Any additional marking required

- ordering information: in accordance with 2.6 of CECC 22 000 as follows:

- (1) Number of the detail specification CECC 22 161-814/Variant code
- (2) Assessment level code letter ^H
- (3) Body finish (if more than one listed) ^{See variant number in [8]}
- (4) Any additional information or special requirements

- related documents (if not included in CECC 22 000 or CECC 22 160):

.....

.....

- certified test records (RCE): in accordance with 3.7 of CECC 22 000 (when applicable) (requirements to be included later)

- structural similarity: in accordance with 3.2 and 3.4 of CECC 22 000.

NOTE: Relevant information on a basic style should be entered as Variant 01.

[11] TEST SCHEDULES AND INSPECTION REQUIREMENTS - SERIES SSMA

ACCEPTANCE TESTS

GROUP A1

Visual examination

CECC 22 160 Clause	Level H			
	Test Required	IL	AQL	Period
4.2	a	S3	1,5 %	lot by lot
4.3.1	a	S3	4 %	lot by lot
4.5.7	a	S3	1,5 %	
4.5.4	na			
4.5.1	a	S3	1,5 %	
4.6.8	na			
4.6.9	na			
4.4.5	a	S3	4 %	

GROUP B1

Outline dimensions

Compatibility mechanical

Engagement and
separationGauge retention force
(resilient contacts)

Sealing (panel and barrier)

Sealing (hermetic)

Voltage proof

PERIODIC TESTS

GROUP C1(d)

Soldering

Insulation resistance

CECC 22 160 Clause	Test Required	IL	AQL	Period
4.6.1	na			
4.4.4	a	S3	4 %	1 yearly

For notes relating to symbols: See page 9.

	CECC 22 160 Clause	Test Required	Specimens (may be from Cl)	Permitted Failures per group†	Period
GROUP D1(d)					
Mechanical tests on cable clamping device	4.5.5	na	3 mated pairs or sets min.	1	3 yearly
Bending moment	4.5.9	a			
Tensile strenght of coupling mechanism	4.5.6	na			
GROUP D2(d)					
Contact resistance	4.4.2	a	3 mated pairs or sets min.	1	3 yearly
Outer conductor continuity	4.4.3	a			
Bump	4.6.2	a			
Vibration	4.6.3	a			
Shock	4.6.4	a			
Damp heat, steady state	4.6.6	a			
Salt mist	4.6.10	a			
GROUP D3					
Dimensions and materials (piece parts)*	4.3.2	a	1 set of piece parts each style	1	3 yearly
Mass	4.3.1	a			
GROUP D4(d)					
Mechanical endurance	4.7.1	a	3 mated pairs or sets min.	1	3 yearly
High temperature endurance	4.7.2	a			

For Notes relating to symbols: See page 9.