



CGA P-59—2023

PREVENTION OF EXCESSIVE PRESSURE DURING FILLING OF CRYOGENIC VESSELS

THIRD EDITION

This document licensed for the sole use of the purchaser. It may not be shared with any other person or used after the expiration date without the express written permission of the CGA. Any unauthorized use, reproduction, distribution, or modification of this printed page will result in a \$5,000 liquidated damages fee plus loss of access to CGA publications for one year for your company.

Full document details: CGA P-59-2023

PREFACE

As part of a program of harmonization of industry standards, the Compressed Gas Association (CGA) has issued CGA P-59, *Prevention of Excessive Pressure During Filling of Cryogenic Vessels* jointly produced by members of the International Harmonization Council and originally published by the European Industrial Gases Association (EIGA) as EIGA Doc 151, *Prevention of Excessive Pressure During Filling of Cryogenic Vessels*.

This publication is intended as an international harmonized standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association (EIGA), and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 19-012
Bulk Distribution Equipment and Standards Committee

NOTE—Technical changes from the previous edition are underlined.

THIRD EDITION: 2023
SECOND EDITION: 2015
FIRST EDITION: 2008

© – Reproduced with permission from, the European Industrial Gases Association. All rights reserved.

Contents	Page
1 Introduction.....	1
2 Scope and purpose	1
2.1 Scope	1
2.2 Purpose	1
3 Definitions.....	2
4 Background	3
4.1 Background transport tanks	3
4.2 Background static vessels	3
5 Transport tanks	3
5.1 Filling operation	3
5.2 Recommendations.....	5
6 Static tanks	5
6.1 Equipment and procedures	5
6.2 Principles for overpressure protection	6
6.3 Examples of overpressure protection systems.....	6
6.4 Limiting pressure	8
7 General recommendations	8
7.1 Existing installations	8
7.2 Applicable principles and techniques	8
7.3 Role of driver-monitored procedures	8
8 References	9

1 Introduction

This publication details the methods that can be used to prevent the overpressurization of both transportable and static pressure vessels during filling.

2 Scope and purpose

2.1 Scope

This publication is intended to provide guidance to the filler/owner of either transportable or static cryogenic tanks, detailing the systems and procedures that can be used to prevent them being overpressurized during filling (i.e., causing a catastrophic failure by excessive pressure). Vessels for which the upper pressure limit (UPL) cannot be exceeded by the maximum allowable pump feed pressure (MAPFP) do not require any additional protection.

This publication is intended to address the issue of transportable or static cryogenic tanks greater than 264 gal (1000 L) water capacity for liquefied cryogenic gases and refrigerated liquids such as nitrous oxide and carbon dioxide. This publication should also be used for receiving vessels under 264 gal (1000 L) that are not designed for transport when full. This publication can also be used as guidance for other products and other transfer systems. It does not consider the hazardous nature of any product release, only the prevention of a failure of the tank due to pressure. This does not apply to cryogenic tanks with flat bottoms. For flat bottomed cryogenic tanks, refer to CGA P-8.9, Bulk Liquid Oxygen, Nitrogen, and Argon Storage Systems at Production Sites [1].¹

Protective measures that prevent the overpressurization of receiving vessels in service (e.g., by failure of the vacuum, pressure raising, flame engulfment, etc.) are detailed in other codes and standards, and are not considered further here.

2.2 Purpose

In 1996, a serious incident focused the attention of the gas industry on the fact that a cryogenic storage tank can be pressurized greater than its bursting pressure during filling. If a high pressure or high flow pump is used to fill a low pressure tank and if the safety measures are not appropriate or do not work, then an unsafe situation can arise.

This was the first significant incident of this type in an industry that has operated safely and reliably with an estimated several million filling operations carried out per year. However, due to technical developments in pumping equipment (increasing delivery pressures and flow rates), the safety margin the tanks have against failure can be reduced unless the protective measures against such an event occurring have not been upgraded simultaneously.

It is an essential management task to systematically control any changes to product transfer systems to ensure that the integrity of the tanks being filled is not jeopardized.

Pressure vessels are used in the distribution and site storage of cryogenic liquids on customer sites. This includes those involved in the transport of cryogenic fluids (transportable pressure vessels), such as road tankers, railroad tank cars transferring product from the production facility to the customers site, and those on the customer site itself (static pressure vessels) that provide on-site storage for the cryogenic fluids.

The primary means of controlling vessel pressure during an operator-attended fill is by a trained and qualified operator, making it a manually controlled process. The case for the overpressurization scenario during operator-attended filling is often outside the pressure vessel design code for sizing of pressure relief devices.

Overpressurization avoidance has been achieved through operator procedures and training. This training includes, for example:

- initial and practical training verified by a qualification test; and
- re-examination and requalification verified by a driver trainer or supervisor.

¹ References are shown in bracketed numbers and are listed in order of appearance in the reference section.