



CGA P-8.8—2021

SAFE DESIGN AND OPERATION OF CRYOGENIC ENCLOSURES

THIRD EDITION

This document licensed for the sole use of the purchaser. It may not be shared with any other person or used after the expiration date without the express written permission of the CGA. Any unauthorized use, reproduction, distribution, or modification of this printed page will result in a \$5,000 liquidated damages fee plus loss of access to CGA publications for one year for your company.

Full document details: CGA P-8.8-2021



Documents
Document Sharing Hub

PREFACE:

As part of a program of harmonization of industry standards, the Compressed Gas Association (CGA) has issued CGA P-8.8, *Safe Design and Operation of Cryogenic Enclosures*, jointly produced by members of the International Harmonization Council and originally published by the European Industrial Gases Association (EIGA) as EIGA Doc 170, *Safe Design and Operation of Cryogenic Enclosures*.

This publication is intended as an international harmonized standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association (EIGA), and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 23-020
Atmospheric Gases and Equipment Committee

NOTE—Technical changes from the previous edition are underlined.

THIRD EDITION: 2021
SECOND EDITION: 2017
FIRST EDITION: 2012

© 2021 Reproduced with permission from, the European Industrial Gases Association. All rights reserved.

Contents	Page
1 Introduction.....	1
2 Scope and purpose	1
3 Definitions.....	1
4 Design considerations	2
4.1 Types of insulation.....	2
4.2 Enclosure casing	3
4.3 Piping design.....	4
4.4 Enclosure materials of construction.....	5
4.5 Load calculation.....	6
4.6 Structure beams and process equipment support.....	6
4.7 Foundations.....	7
4.8 Enclosure bottom.....	7
4.9 Maintenance facilities	8
4.10 Protection of small bore lines	8
4.11 Protection from cryogenic embrittlement	8
4.12 General design considerations for equipment aging	9
4.13 Special considerations for flammable and toxic fluids.....	9
5 Construction	10
6 Operation of cryogenic enclosures	11
6.1 Purge gas—Air separation unit processes	11
6.2 Purge gas—Processes with flammable or toxic gases.....	13
6.3 Maintenance	15
7 Enclosure hazards.....	15
7.1 General hazards.....	15
7.2 Overpressure.....	16
7.3 Unsafe compositions	18
7.4 Cold temperatures	19
7.5 Equipment erosion	19
7.6 Feed stocks containing oxides of nitrogen	19
8 Troubleshooting.....	20
8.1 Process leaks and detection	22
8.2 Ice on enclosure external surfaces and piping	24
8.3 Purge gas sampling.....	24
8.4 Purge gas flow and pressure changes	25
8.5 Operating with process leaks	25
8.6 Emergency condition guidance	26
9 Changes, modifications, and repairs to cryogenic enclosures	26
9.1 Management of change.....	26
9.2 Structural members and panels.....	27
9.3 Insulation removal	27
9.4 Confined space entry.....	27
9.5 Equipment isolation	27
9.6 Perlite removal from piping and process equipment	27
9.7 Piping and equipment.....	28
10 Training	28
11 Quality assurance.....	29
12 References	29



Figures

Figure 1—Casing pressure versus time..... 17

Tables

Table 1—Enclosure upset scenarios symptoms and consequences 20

Appendix Tables

Table A1—Example of a coldbox located pressure equipment annual inspection checklist..... 32
Table A2—Example of a coldbox located pressure equipment inspection checklist 34

1 Introduction

Cryogenic processes often operate inside enclosures that insulate the process equipment and interconnecting piping from ambient air and temperature. This prevents many problems, including excessive heat leak into the process and water freezing around the equipment. In many cases, the enclosure is purged with a dry gas to prevent ambient air from entering the enclosure and creating hazardous mixtures.

2 Scope and purpose

Cryogenic enclosures can create potential process safety hazards. This publication identifies general hazards and provides guidance to reduce their frequency and consequences. It provides safety guidance and addresses design and operating practices only as they affect safety.

This publication addresses both cryogenic air separation unit (ASU) and hydrogen/carbon monoxide (HYCO) processes. A number of existing publications cover special requirements of these processes and their equipment [1, 2, 3, 4].

This publication is primarily to document current practices and is intended to apply to new facilities. It is recognized that some existing plants may not meet all recommendations or requirements from this publication. This publication is not intended to be applied retroactively, including where this publication uses the word "shall".

This publication does not cover the following:

- generally accepted engineering practices for structures and process equipment. Only those issues that are specific to cryogenic enclosures are included;
- enclosures for processes producing liquid hydrogen or helium. The extreme cold temperatures of these processes require specialized knowledge and practices that are beyond the scope of this publication; and
- external structures on/attached to the cryogenic enclosure for example, platforms, ladders, vents, lightning arrestors, etc. For more information on the safe location of oxygen and nitrogen vents relative to the location of platforms and ladders, see CGA P-8.7, *Safe Location of Oxygen and Inert Gas Vents* [5].

3 Definitions

For the purpose of this publication, the following definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

3.1.5 Can

Indicates a possibility or ability.

3.2 Technical definitions

3.2.1 Air separation unit

Separates air into its components. An ASU is assumed to operate at cryogenic temperatures.

3.2.2 Coldbox and cylindrical enclosure

Enclosure containing insulation that separates a cryogenic process from the surrounding environment. The terms coldbox or box are often used to refer to an enclosure with a rectangular cross section, and the term cylindrical enclosure to refer to an enclosure with a cylindrical cross section. However, the term coldbox is sometimes used to refer to all enclosures, regardless of cross section shape.

3.2.3 Cryogenic

Temperatures less than approximately -130°F (-90°C) [6].

NOTE—Cryogenic processes require insulation to reduce heat transfer from the surrounding environment.

3.2.4 Derime

Periodic preventive maintenance procedure where the process equipment is warmed up while simultaneously being swept with clean dry gas to remove any accumulated moisture, carbon dioxide, and atmospheric impurities.

NOTE—Also known as defrosting, de-icing, and thawing.

3.2.5 Enclosure

Structure that retains the insulation and surrounds the equipment.

NOTE—Cryogenic processes are often insulated by placing the cryogenic equipment and piping in one or more enclosures that are filled with insulation.

3.2.6 HYCO

Processes that cryogenically process gaseous mixtures containing hydrogen (H_2) and/or carbon monoxide (CO).

3.2.7 Perlite eruption

Rapid, uncontrolled displacement of perlite within the insulation space that can result in a violent perlite release. It is commonly caused by the rapid vaporization of pooled cryogenic liquid in the perlite that has suddenly been warmed, moved, or physically disturbed.

3.2.8 Perlite release

Uncontrolled spillage of perlite to the environment.

4 Design considerations

The cryogenic enclosure shall be designed and constructed in accordance with the applicable national and local building code including seismic and wind loads for the installation location. If there is no national or local building code, an internationally accepted building code shall be applied by the manufacturer.

4.1 Types of insulation

The enclosure has one or more types of insulation to reduce heat leak into the process piping and equipment. The most common insulation methods used are perlite, mineral wool, and vacuum.

4.1.1 Perlite

Perlite is an inert volcanic glass that forms an odorless, nonflammable, nontoxic lightweight powder aggregate when expanded by heat. It is a highly effective insulating material used to reduce refrigeration losses or heat leak into the cryogenic enclosure.

CAUTION: *Since it is a lightweight powder, it can become an asphyxiation hazard if inhaled or if a person becomes submerged in perlite, which can result in death or serious injury.*

4.1.2 Mineral wool

Mineral wool is a wool-like inorganic material produced by blowing steam or air through molten slag or rock. Mineral wool shall be noncombustible and contain less than 0.5% by weight of organic material [7]. Industry experience has shown that this level of organic material is operationally acceptable. One test for combustibility of materials is addressed in ISO 1182, *Reaction to fire tests for products-Non-combustibility test*, which may be used to test for organic materials [8].

Mineral wool should have a pH between 6 and 9.5. If the pH is outside of this range and the mineral wool becomes wet, it becomes corrosive to piping and equipment.

4.1.3 Vacuum

With vacuum insulation, the item to be insulated is placed within some type of enclosure. A vacuum is pulled on the annular space between the item and the enclosure, which reduces heat transfer by convection. The heat leak can be further reduced by placing insulation (typically perlite, metal foils, or other super insulation) within the space to further reduce heat leak through conduction or radiation.

Vacuum insulation provides more resistance to heat leak than mineral wool or perlite. Vacuum insulation may be considered, particularly for small coldboxes or piping. Such insulation leads to a better insulation and more compact enclosures, which are convenient for transport and on-site erection.

With vacuum insulation, no nitrogen purge is needed. For enclosures with vacuum insulation, the vessel walls shall be designed to withstand full vacuum conditions. Helium leak tests are generally required during assembly to detect small leaks.

If the filling of insulating material (for example, perlite) is performed by vacuum suction, precautions shall be taken to avoid damaging piping lines or connections in the annular space, for example, controlling the rate of filling, reinforcing the supports of small lines or connections.

Vacuum gauge or fittings should be installed to verify the vacuum level within the annular space, which will allow the insulating properties to be confirmed during operation.

Relief devices (rupture disks and/or lift plates that can be maintained by vacuum suction) shall be installed to protect the annular space against overpressure. When an insulation barrier is placed upstream of the relieving device, it shall be designed not to restrict the relieving capacity.

Getters or adsorbents may be used in the annular space to trap various gases, which can be released in the annular space. Because oxygen can enter the annular space inadvertently (for example, leaks from ambient air), the compatibility of these getters or adsorbents with oxygen shall be considered [9, 6].

Superinsulation typically consists of thin metal foils to reduce radiant heat transfer. The thin metals can be combustible in oxygen. A risk assessment shall be performed when using super insulation.

4.2 Enclosure casing

The enclosure casing is typically made from carbon steel plates. The plates can be bolted or welded together to enclose the insulation. The plates can then be attached to a frame or support structure, or the plates can be self-supporting. Damage to the enclosure beam structure could damage equipment or reduce the support to process equipment and piping.

The enclosure cross section can be rectangular or cylindrical. The enclosure can be overpressurized in case of leaks or higher purge gas pressure (see 7.2).

4.2.1 Cylindrical enclosures

Cylindrical enclosures surround the cryogenic equipment and piping. Equipment is typically not supported from the enclosure structure; rather it is supported with a separate support system.

If a cylindrical enclosure is pressurized to the point of failure, the pressure-volume (PV) energy will likely be significantly larger than a similarly sized rectangular enclosure. This is particularly true if the enclosure is designed for vacuum insulation. The possibility of higher stored PV energy shall be considered in the design of cylindrical enclosures (see 7.2).

4.2.2 Rectangular enclosures

Rectangular enclosures have a structural skeleton of beams, and some or all equipment and piping are supported from these beams. Metal plates are attached to structural frame. The plates can be attached to the frame on either the inside (towards the insulation) or the outside (towards the ambient).

Rectangular enclosures can contain less pressure before failure. Damage to the enclosure beam structure could damage equipment or reduce the support to process equipment and piping.

4.2.3 Perlite filling/removal nozzles

Perlite filling/removal nozzles should be located to allow safe access for adding and removing perlite. Nozzles may be added to the coldbox at multiple levels including the roof. It is recommended to locate removal nozzle(s) at the platform levels for access. The distance between nozzles is typically 32 ft to 39 ft (10 m to 12 m). Details of perlite filling and removal procedures are given in CGA P-8.3, *Perlite Management* [10].

4.2.4 Enclosures with multiple sections

Enclosures may have multiple sections depending on process and equipment layout. Design consideration should be given to installation of isolation barriers between enclosure sections that would prevent perlite from flowing from one section to another. Isolation barriers reduce the possibility of perlite bridging that can lead to collapse when removing perlite from adjacent sections. Isolation barriers should allow for purge gas flow. See 6.1.3.

4.2.5 Overpressure protection

The cryogenic enclosure shall be equipped with overpressure protection device(s). The number, size, and location of the overpressure protection device(s) shall take into account, at a minimum, the dimensions of the cryogenic enclosure, the presence of internal partitions, and/or potential leak points such as flange connections (see 7.2). When an insulation barrier is placed upstream of the relieving device, it shall be designed not to restrict the relieving capacity.

4.3 Piping design

Piping shall be designed and manufactured to a recognized piping code such as American Society of Mechanical Engineers (ASME) B31.3, *Process Piping* that takes into account temperature, pressure, fluid, and service conditions to which the piping will be operated [11].

Piping and vessels shall be protected by overpressure relief devices in accordance with the applicable code.

Leaks from process equipment and piping, whether large or small, can overpressure the enclosure and/or create hazardous atmospheres. Therefore, design and construction methods shall be used to reduce the probability of leaks.

Piping within the perlite insulation space should have welded joints because these joints significantly reduce the possibility of leaks. Butt welds are preferred as these joints can have improved nondestructive testing (NDT) such as full radiographic examination. Mechanical joints (such as bolted flanges or threaded connections) shall be avoided, where feasible. Where mechanical joints are used, a blanket or stuffing box of mineral wool shall be used to isolate a potential mechanical joint leak. Cryogenic pump and turbine boxes that are segregated from the main cryogenic enclosure may be insulated with perlite without blankets or stuffing boxes on mechanical joints, if the consequences from a leak are assessed to be low. The mineral wool stuffing box prevents a leak from causing perlite erosion of the equipment (see 7.5) and also allows for easier maintenance. These isolated small enclosures should have their base or floor sloped above perlite's angle of repose. This ensures that perlite will naturally fill underneath and around these enclosures and insulate the enclosures [10].

All process pipes and utility lines shall be designed so that the thermal and mechanical stresses are less than the maximum allowable for the design life of the plant, which minimizes the risk of line failure. Taking into account the piping support system including pipe penetrations, stresses shall be considered for the following:

- nozzles;
- transition joints;
- process bellows, flexible joints, or braided hose;
- valve or other piping equipment weaker than connected pipes, and
- flanges.

All instrument tubing shall be installed so that the thermal and mechanical stresses are acceptable for the design life of the plant.

All operating modes shall be considered in the design, including:

- expected number of cooldown and warm-up cycles such as startup with or without liquid injection, shutdown and deriming for the design life of the enclosure;
- relative movement of small bore lines attached to larger bore lines during cooldown, warm up, and thaw cycles, which can cause high stresses leading to failure; and
- piping that cycles as part of normal operation such as piping for cryogenic adsorbers.

Dead-ended, nonflowing piping requires seal loops to prevent cryogenic liquids from flowing by gravity towards the enclosure surface. Seal loops should be routed to provide adequate vaporization of cryogenic liquid to form a vapor lock. Omitting the seal loops will result in excessive process heat leak, boiling of the cryogenic liquid, and potential accumulation of unsafe mixtures. This excessive heat leak can result in ice forming on the enclosure surface (see 8.2). Some examples of this piping are drains from cryogenic equipment and the high pressure side of liquid level taps [2].

Other piping design items that shall be considered are:

- protection of small bore lines (see 4.10);
- free movement of tubing within pipe supports;
- piping loads from perlite insulation;
- supporting process piping that operates with two phase flow during any mode of operation to prevent excessive vibration from causing cyclic fatigue cracking;
- design and selection of specialized joints used to join dissimilar metals such as those utilizing explosion-bonded material; and
- if the piping can be exposed to oxygen-enriched fluids, it shall be designed for oxygen service [4, 5, 12].

4.4 Enclosure materials of construction

Structural elements shall be manufactured from materials compatible with the temperature that they are exposed to during normal operations. See 4.6. Due to low temperature embrittlement, the temperature rating of the specific carbon steel grade used shall be confirmed for the normal operating temperature.

Bolted panels on the cryogenic enclosure shall be sealed using a gasket, mastic, or other sealant to prevent water from entering the enclosure.

When constructing the enclosure, materials such as valve boots, wiring insulation, and sealants that are not oxygen compatible may be used in small amounts.

Enclosures surfaces shall be protected from corrosion due to atmospheric conditions. Areas that are particularly susceptible to atmospheric corrosion are:

- flat horizontal sections such as roofs or the top of horizontal ducts; and
- areas where the enclosure surface can have water trapped against it such as the contact zone between plates and external beams.

Corrosion can eventually lead to a breach in the enclosure surface, potentially causing three problems:

- Moisture/rainwater can enter the enclosure, which will reduce insulation effectiveness and create ice. The ice can restrict the movement of piping or equipment as the process cools down or warms up. Restricting the movement can damage the piping or equipment, in turn leading to process leaks;
- Release of purge gas; and
- Release of perlite.

Corrosion protection can be provided by painting, other surface treatment, or material selection. Corrosion protection is usually only provided on the external enclosure surface. Internal corrosion protection is typically not needed because the enclosure is purged with dry nitrogen. Internal corrosion protection is only used if extensive corrosion is anticipated during construction.

Elastomer sealants and metal bolts shall be appropriate for the expected atmospheric corrosion environment to which they will be exposed. This design precaution will avoid a possible breach in the enclosure from a corrosion failure.

Top horizontal plates (such as the roof) shall be designed to provide natural drainage of rainwater. A welded roof provides the maximum protection from rainwater ingress or ice damage. Any penetrations, access panels, or elastomeric boots can be prone to water leakage. These shall be designed and maintained to prevent water ingress.

The enclosure shall be periodically inspected and maintained. Particular care should be taken in case the coldbox is located in areas with potentially corrosive atmospheres such as a heavy industrial area or in the proximity to the sea.

4.5 Load calculation

The design of the enclosure shall consider the expected loads imposed during the life of the enclosure. These include, but are not limited to, the following:

- Transportation (if any), which can include road, rail, and ship;
- Lifting (if any);
- Erection;
- Fluid pressure from the purge gas or fluidized perlite (see 7.2);
- Different operating modes, both warm and cold. Both shall include the cases with and without process fluid, and also if the system is pressurized or not. Any transient modes shall also be considered (see 4.3);
- Perlite load on piping, equipment, enclosure and foundations, and
- Environmental conditions on-site such as snow, wind, and earthquakes.

4.6 Structure beams and process equipment support

The main part of the support structure is usually constructed of carbon steel. However, portions of the support structure can become colder than the embrittlement temperature of carbon steel. These supports shall be made of materials compatible for the anticipated temperatures.

Consideration shall be given to reducing cold conduction between the cryogenic and noncryogenic portions of the enclosure, particularly through the equipment support structures. This may require placing distance between the process pipes or equipment, coldbox structure members, and/or the enclosures surfaces to prevent cold migration.

Structural members in the cold zone of the enclosure will contract if they become cold. The loads that this contraction imposes on the outer structure and plates shall be considered in the enclosure design.

Combustible material shall be avoided for any supports.

4.7 Foundations

Foundations for cryogenic equipment have the potential for the lower side of the concrete to reach a temperature of 32 °F (0 °C) or less, resulting in the freezing of the subsurface and subsequent frost heaving effects. Frost heaving generally depends on soil conditions, ambient temperatures, and the amount of water available in the soil. The buildup of large layers of ice under cold foundations can take years. To prevent frost heaving at coldbox foundations, the soil under the foundations shall be kept from freezing. A site-specific evaluation should be performed to rate the potential for this effect to occur. Where such a possibility exists, consideration shall be given to one of the following mitigation techniques:

- On small foundations, the heat leak into the area from the atmosphere can cancel the cooling effect through the foundation;
- Provide an air circulation space that is open to atmosphere between the cold equipment or enclosure bottom and the top of the concrete;
- Provide an elevated foundation that has an air circulation space between the top of the soil and the bottom of the concrete foundation slab;
- Provide electric heating cables in the concrete foundation. The heaters and junction boxes should be accessible for periodic checks and maintenance; and
- Install open air conduits in the foundation that rely on convection.

Installation of a temperature sensor(s) on the foundation should be considered to measure the cooling of the soil. If installed, this temperature sensor can also provide information if internal leaks have collected at the bottom of cryogenic enclosure being exposed to low temperatures.

The equipment anchors from within the cryogenic enclosure to the foundation shall be manufactured from material compatible with the anticipated low temperatures such as stainless steel. Cryogenic enclosure casing anchors to the foundation and any rebar within the concrete shall use materials compatible with the foundation's minimum anticipated low temperature at the installation site.

4.8 Enclosure bottom

Typically, industry practice for ASUs is to construct the lower enclosure sections from carbon steel. The floor is either carbon steel or concrete. It is recognized that carbon steel will crack and release small amounts of fluids and (in some cases) perlite, if it comes into contact with cryogenic liquid(s). Industry experience shows that small leaks do not immediately affect the structural integrity of the overall enclosure and do not pose a significant risk to personnel. Cryogenic enclosures that are not directly mounted on a concrete foundation, but elevated by legs, plinths, or other structural columns require a solid enclosure bottom. The enclosure bottom material selection shall be based on the minimum ambient temperature and the minimum expected operating temperature of the insulation material adjacent to the enclosure bottom. This enclosure bottom may be fitted with temperature probes to alarm on temperatures lower than the expected operation conditions, which can indicate there is an internal leak. It should be noted that cold spots can be very localized and the installed temperature elements might not detect all leaks, so they should not be seen as a replacement of regular visual checks for cold spots. The elevated enclosure bottom should not be operated at temperatures less than the materials minimum allowable design temperature.

See 8.1 for the procedures that should be used to determine the risk of such a leak and the time period in which the leak shall be repaired.

For HYCO boxes, see 4.13.

Cryogenic pumps are more susceptible to liquid leaks because:

- they are often installed with bolted flanges for maintenance;
- they have rotating parts that require seals, which can develop leaks; and
- their motion creates vibrations, which can lead to leaks.

Therefore, for pumps installed in enclosures, one or more of the following leak detection methods may be installed:

- temperature detector(s) below the pumps (typically near the enclosure floor);
- seal leak detectors; or
- temperature switch on the pump shaft.

These leak detection methods may trigger one or more of the following:

- shutdown of the pump;
- closing pump isolation valves; or
- alarm to alert the operator of an abnormal situation.

4.9 Maintenance facilities

During enclosure design, consideration should be given to what sections could need maintenance access. If the enclosure is insulated with perlite, sections that need access should have means provided to be isolated without removing perlite from the entire enclosure. Ducts or stuffing boxes may be installed to allow removal of insulation at the local area rather than the entire box.

Some of the process equipment requires regular maintenance, such as expansion turbines and pumps. Typically, this equipment is installed in a separate section and has its own isolated and dedicated enclosure, which is insulated. An enclosure with separate sections has special considerations for its purge gas system; these are described in 6.1.3. Where possible, these dedicated enclosures shall be designed so that maintenance work can be performed by personnel working outside the enclosure. This eliminates the need for personnel to physically enter the enclosure.

Ladders may be installed inside the enclosure for construction or to allow repair of equipment and piping. These ladders shall either have safety cages or safety cable to prevent falls.

4.10 Protection of small bore lines

Small bore lines, particularly instrument tubes, are susceptible to damage in the construction phase, cooling down and warming up, and maintenance of the enclosure equipment. Consideration shall be given to protecting these lines from damage due to falling objects or inadvertent construction climbing. Any protection support shall account for the expansion and contraction of these lines during operation.

4.11 Protection from cryogenic embrittlement

When valves and cryogenic piping are installed adjacent to or penetrating the cryogenic enclosure, consideration shall be given to preventing cold migration from the valves and piping to the coldbox cladding that could result in cold embrittlement. Vents from the coldbox shall be directed away from the cladding to a safe location.