

POSITION STATEMENT

INSPECTION REQUIREMENTS OF AIR SEPARATION UNIT COLDBOX INTERNAL COMPONENTS

Question

Should the internal components of an air separation unit (ASU) coldbox be subjected to periodic inspection?

Answer

The Compressed Gas Association *does not recommend* that the internal components of an ASU coldbox be subjected to periodic inspections.

Reasons

An ASU coldbox is the cylindrical or rectangular metal enclosure surrounding the cryogenic equipment (internal components) such as distillation columns, exchangers, separators, vessels, associated piping, instrumentation with an annular space that is insulated and purged with dry, clean, noncorrosive gas or kept under vacuum.

Based on more than 60 years of industry operating experience, the industrial gases industry does not carry out periodic inspections of cryogenic equipment within an ASU coldbox for the following reasons:

- Cryogenic plants are constructed from materials that have low corrosion potential. These materials retain their corrosion resistance at temperatures lower than ambient and experience shows that corrosion at cryogenic temperatures is negligible;
- Process fluids are dry, clean, and noncorrosive;
- The ASU coldbox annular space is purged with dry, clean, and noncorrosive gas or kept under vacuum, which minimizes the risk of corrosion;
- Limited presence of the traditional failure mechanisms for such equipment—namely erosion and fatigue due to the external cryogenic ASU coldbox enclosure;
- Design and construction are carried out to well established and internationally recognized codes and standards. Design takes into account pressures, loadings, temperature changes, and movements expected during normal operation, startup, and shutdown;
- Operating mode of a cryogenic ASU is generally steady state with few pressure and temperature variations;
- Materials used in the construction of ASU coldbox internal components, typically austenitic stainless steel and aluminum, have significantly enhanced yield and ultimate tensile strengths at cryogenic operating temperatures; and
- Materials used in the construction of ASU coldbox internal components have high fracture toughness characteristics. The critical defect size for the initiation of an unstable fracture can allow a defect to be detected from an increase in the ASU coldbox pressure or from the presence of cold patches well before the critical defect size is reached.

Periodic inspection and maintenance of the ASU coldbox enclosure are used to ensure its integrity (for example, tightness, purge gas, perlite level, vacuum, absence of embrittlement and corrosion of the carbon steel structure, icing). These inspections are intended to confirm that the environment within the ASU coldbox is dry and inert, and that there are no indications of cryogenic and/or pressure leaks.

The ASU coldbox enclosure's exterior inspection includes actions to manage the risk of pressure release and loss of cryogenic inventory from ASU coldbox located pressure equipment. Guidance on ASU coldbox design, operation, and inspection is given in CGA P-8.8, *Safe Design and Operation of Cryogenic Enclosures* [1].

References

Unless otherwise specified, the latest edition shall apply.

[1] CGA P-8.8, *Safe Design and Operation of Cryogenic Enclosures*, Compressed Gas Association, Inc.
www.cganet.com

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.


A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 22-82
Atmospheric Gases and Equipment Committee

FIRST EDITION: 2024

© 2024 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean, VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.



This document licensed for the sole use of the purchaser. It may not be shared with any other person or used after the expiration date without the express written permission of the CGA. Any unauthorized use, reproduction, distribution, or modification of this printed page will result in a \$5,000 liquidated damages fee plus loss of access to CGA publications for one year for your company.