



BSI Standards Publication

Electromagnetic compatibility (EMC) —

Part 5-8: Installation and mitigation guidelines — HEMP protection methods for the distributed infrastructure

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

raising standards worldwide™

National foreword

This Draft for Development is the UK implementation of IEC/TS 61000-5-8:2009.

This publication is not to be regarded as a British Standard.

It is being issued in the Draft for Development series of publications and is of a provisional nature. It should be applied on this provisional basis, so that information and experience of its practical application can be obtained.

Comments arising from the use of this Draft for Development are requested so that UK experience can be reported to the international organization responsible for its conversion to an international standard. A review of this publication will be initiated not later than three years after its publication by the international organization so that a decision can be taken on its status. Notification of the start of the review period will be made in an announcement in the appropriate issue of Update Standards.

According to the replies received by the end of the review period, the responsible BSI Committee will decide whether to support the conversion into an international Standard, to extend the life of the Technical Specification or to withdraw it. Comments should be sent to the Secretary of the responsible BSI Technical Committee at British Standards House, 389 Chiswick High Road, London W4 4AL.

The UK participation in its preparation was entrusted by Technical Committee GEL/210, EMC - Policy committee, to Subcommittee GEL/210/12, EMC basic, generic and low frequency phenomena Standardization.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© BSI 2010

ISBN 978 0 580 62924 2

ICS 33.100.20

Compliance with a British Standard cannot confer immunity from legal obligations.

This Draft for Development was published under the authority of the Standards Policy and Strategy Committee on 28 February 2010

Amendments issued since publication

Amd. No.	Date	Text affected
----------	------	---------------



TECHNICAL SPECIFICATION



BASIC EMC PUBLICATION

**Electromagnetic compatibility (EMC) –
Part 5-8: Installation and mitigation guidelines – HEMP protection methods for
the distributed infrastructure**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

U

ICS 33.100.20

ISBN 2-8318-1060-3

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	8
4 General introduction	10
5 Description of the distributed infrastructure	10
6 Spatial variation of HEMP environments.....	11
6.1 Early-time (E1) HEMP spatial variations	11
6.2 Intermediate-time (E2) HEMP spatial variations.....	13
6.3 Late-time (E3) HEMP spatial variations	13
7 Implications for HEMP coupling to extended conductors.....	13
7.1 General.....	13
7.2 Early-time (E1) conducted environments	13
7.3 Intermediate-time (E2) conducted environments.....	14
7.4 Late-time (E3) conducted environments	15
8 Relation of HEMP disturbances to natural EM environments.....	16
8.1 General.....	16
8.2 Comparison of HEMP E1 to EFT and surge	16
8.3 Comparison of HEMP E3 to currents induced by geomagnetic storms	17
9 Protection strategy	18
9.1 General.....	18
9.2 Electric power	18
9.2.1 Background	18
9.2.2 Emergency planning, operating procedures and restoration.....	20
9.2.3 HEMP immunity standards for new equipment	20
9.2.4 Selected retrofit protection.....	21
9.2.5 Application to a high-voltage power substation	22
9.3 Telecommunication centres	25
9.4 Other infrastructures	25
Bibliography.....	26
Figure 1 – Simplified depiction of the interdependency of critical infrastructures [4]	11
Figure 2 – E1 HEMP tangent radius as a function of the height of burst	12
Figure 3 – An example of the area covered by the early-time (E1) HEMP by a 170 km burst over the United States	12
Figure 4 – Late-time (E3) electric field waveform from IEC 61000-2-9.....	17
Figure 5 – Vertical conduit geometry for a current transformer (CT)	23
Figure 6 – Covered shallow trench for control cables	23
Figure 7 – Grounding of control cables at junction box.....	24
Figure 8 – Control cable access to equipment.....	24
Table 1 – Peak currents induced by the E1 HEMP on above-ground and buried conductors.....	14

Table 2 – Peak currents induced by the E2 HEMP on above-ground and buried conductors	15
Table 3 – Minimum required attenuation of peak time domain external environments for the six principal protection concepts	21

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTROMAGNETIC COMPATIBILITY (EMC) –**Part 5-8: Installation and mitigation guidelines –
HEMP protection methods for the distributed infrastructure**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC/TS 61000-5-8, which is a technical specification, has been prepared by subcommittee 77C: High power transient phenomena, of IEC technical committee 77: Electromagnetic compatibility.

This Technical Specification forms Part 5-8 of IEC 61000. It has the status of a basic EMC publication in accordance with IEC Guide 107 [1]¹⁾.

This document is being issued in the Technical Specification series of publications (according to the ISO/IEC Directives, Part 1, 3.1.1.1) as a “prospective standard for provisional application” in the field of protection of the infrastructure against HEMP because there is an urgent need for guidance on how standards in this field should be used to meet an identified need.

This document is not to be regarded as an “International Standard”. It is proposed for provisional application so that information and experience of its use in practice may be gathered. Comments on the content of this document should be sent to the IEC Central Office.

A review of this Technical Specification will be carried out not later than 3 years after its publication with the options of: extension for another 3 years; conversion into an International Standard; or withdrawal.

The text of this standard is based on the following documents:

Enquiry draft	Report on voting
77C/192/DTS	77C/196/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

¹⁾ Figures in square brackets refer to the Bibliography.

INTRODUCTION

IEC 61000 is published in separate parts according to the following structure:

Part 1: General

General considerations (introduction, fundamental principles)

Definitions, terminology

Part 2: Environment

Description of the environment

Classification of the environment

Compatibility levels

Part 3: Limits

Emission limits

Immunity limits (in so far as they do not fall under the responsibility of the product committees)

Part 4: Testing and measurement techniques

Measurement techniques

Testing techniques

Part 5: Installation and mitigation guidelines

Installation guidelines

Mitigation methods and devices

Part 6: Generic standards

Part 9: Miscellaneous

Each part is further subdivided into several parts and published either as International Standards or as technical specifications or technical reports, some of which have already been published as sections. Others will be published with the part number followed by a dash and a second number identifying the subdivision (example: 61000-6-1).

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 5-8: Installation and mitigation guidelines – HEMP protection methods for the distributed infrastructure

1 Scope

The aim of this part of IEC 61000 is to provide guidance on how to protect the distributed infrastructure (power, telecommunications, transportation and pipeline networks, etc.) from the threat of a high altitude electromagnetic pulse (HEMP). In order to accomplish this goal, it is necessary to describe the special aspects of the HEMP threat to electrical/electronic systems that are connected and distributed in nature. In particular a nuclear burst at a typical altitude of 100 km will illuminate the Earth to a ground radius from the point directly under the burst to a range of 1 100 km. This means that any distributed and connected infrastructure such as power or telecommunications will observe disturbances simultaneously over a wide area. This type of situation is not normally considered in the EMC or HEMP protection of facilities that are part of a distributed network as the impact of a local disturbance is usually evaluated only locally.

This publication provides general information concerning the disturbance levels and protection methods for all types of distributed infrastructures. Due to its importance to all other parts of the infrastructure, the distributed electric power system (power substations, generation plants and control centres) and its protection are described in more detail. While the telecommunication system is also critical to most of the other distributed infrastructures, the protection of the telecommunication network from HEMP and other electromagnetic threats is covered by the work done by ITU-T.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(161), *International Electrotechnical Vocabulary – Chapter 161: Electromagnetic compatibility*

IEC 61000-2-9, *Electromagnetic compatibility (EMC) – Part 2: Environment – Section 9: Description of HEMP environment – Radiated disturbance*

IEC 61000-2-10, *Electromagnetic compatibility (EMC) – Part 2-10: Environment – Description of HEMP environment – Conducted disturbance*

IEC 61000-2-11, *Electromagnetic compatibility (EMC) – Part 2-11: Environment – Classification of HEMP environments*

IEC 61000-4-4, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical fast transient/burst immunity test*

IEC 61000-4-5, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-23, *Electromagnetic compatibility (EMC) – Part 4-23: Testing and measurement techniques – Test methods for protective devices for HEMP and other radiated disturbances*

IEC 61000-4-24, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 24: Test methods for protective devices for HEMP conducted disturbance*

IEC 61000-4-25, *Electromagnetic compatibility (EMC) – Part 4-25: Testing and measurement techniques – HEMP immunity test methods for equipment and systems*

IEC/TR 61000-5-3, *Electromagnetic compatibility (EMC) – Part 5-3: Installation and mitigation guidelines – HEMP protection concepts*

IEC/TR 61000-5-6, *Electromagnetic compatibility (EMC) – Part 5-6: Installation and mitigation guidelines – Mitigation of external EM influences*

IEC/TS 61000-5-9, *Electromagnetic compatibility (EMC) – Part 5-9: Installation and mitigation guidelines – System-level susceptibility assessments for HEMP and HPEM*

IEC 61000-6-6, *Electromagnetic compatibility (EMC) – Part 6-6: Generic standards – HEMP immunity for indoor equipment*

IEC 61850 (all parts), *Communication networks and systems in substations*

3 Terms and definitions

For the purposes of this document, the definitions contained in IEC 60050(161) as well as the following apply.

3.1

distributed infrastructure

the portions of the infrastructure of a society that are connected either physically or through real-time communications over distances of hundreds of kilometres, and include electrical and electronic controls to operate that infrastructure

NOTE This normally includes the electric power system, the telecommunications system, pipeline networks, and the transportation system.

3.2

E1, E2, E3

terminology for the early, intermediate and late-time HEMP electric fields. E1 is for times less than 1 microsecond, E2 for times between 1 microsecond and 1 second and E3 is for times greater than 1 second.

NOTE See IEC 61000-2-9 for additional information.

3.3

equipment

this term is not limited and includes modules, devices, apparatuses, subsystems, complete systems and installations

[IEV 151-11-25, modified]

3.4

HEMP

high-altitude electromagnetic pulse

3.5

HEMP coupling

interaction of the HEMP field with a system to produce currents and voltages on system surfaces and cables. Voltages result from the induced charges and are only defined at low frequencies with wavelengths larger than the surface or gap dimensions