

DIN EN 62769-109-1

ICS 35.240.50

**Feldgeräteintegration (FDI) –
Teil 109-1: Profile –
HART® und WirelessHART®
(IEC 62769-109-1:2015);
Englische Fassung EN 62769-109-1:2015**

Field Device Integration (FDI) –
Part 109-1: Profiles –
HART® and WirelessHART®
(IEC 62769-109-1:2015);
English version EN 62769-109-1:2015

Intégration des appareils de terrain (FDI) –
Partie 109-1: Profils –
HART® et WirelessHART®
(IEC 62769-109-1:2015);
Version anglaise EN 62769-109-1:2015

Gesamtumfang 46 Seiten

DKE Deutsche Kommission Elektrotechnik Elektronik Informationstechnik in DIN und VDE

Anwendungsbeginn

Anwendungsbeginn für die von CENELEC am 2015-06-23 angenommene Europäische Norm als DIN-Norm ist 2016-03-01.

Nationales Vorwort

Vorausgegangener Norm-Entwurf: E DIN EN 62769-109-1:2014-05.

Für dieses Dokument ist das nationale Arbeitsgremium K 956 „Feldbus“ der DKE Deutsche Kommission Elektrotechnik Elektronik Informationstechnik in DIN und VDE (www.dke.de) zuständig.

Die enthaltene IEC-Publikation wurde vom SC 65E „Devices and integration in enterprise systems“ erarbeitet.

Das IEC-Komitee hat entschieden, dass der Inhalt dieser Publikation bis zu dem Datum (stability date) unverändert bleiben soll, das auf der IEC-Website unter „<http://webstore.iec.ch>“ zu dieser Publikation angegeben ist. Zu diesem Zeitpunkt wird entsprechend der Entscheidung des Komitees die Publikation

- bestätigt,
- zurückgezogen,
- durch eine Folgeausgabe ersetzt oder
- geändert.

Für den Fall einer undatierten Verweisung im normativen Text (Verweisung auf ein Dokument ohne Angabe des Ausgabedatums und ohne Hinweis auf eine Abschnittsnummer, eine Tabelle, ein Bild usw.) bezieht sich die Verweisung auf die jeweils aktuellste Ausgabe des in Bezug genommenen Dokuments.

Für den Fall einer datierten Verweisung im normativen Text bezieht sich die Verweisung immer auf die in Bezug genommene Ausgabe des Dokuments.

Der Zusammenhang der zitierten Dokumente mit den entsprechenden Deutschen Dokumenten ergibt sich, soweit ein Zusammenhang besteht, grundsätzlich über die Nummer der entsprechenden IEC-Publikation. Beispiel: IEC 60068 ist als EN 60068 als Europäische Norm durch CENELEC übernommen und als DIN EN 60068 ins Deutsche Normenwerk aufgenommen.

Das Präsidium des DIN hat mit Präsidialbeschluss 1/2004 festgelegt, dass DIN-Normen, deren Inhalt sich auf internationale Arbeitsergebnisse der Informationsverarbeitung gründet, unter bestimmten Bedingungen allein in englischer Sprache veröffentlicht werden dürfen. Diese Bedingungen sind für die vorliegende Norm erfüllt.

Da sich die Benutzer der vorliegenden Norm der englischen Sprache als Fachsprache bedienen, wird die Englische Fassung der EN 62769-109-1 veröffentlicht. Zu deren Abschnitt 1, der den Anwendungsbereich festlegt, und deren Abschnitt 3 (teilweise), der die Begriffe festlegt, wurde eine Übersetzung angefertigt und als informativer Nationaler Anhang NA der vorliegenden Norm hinzugefügt. Für die meisten der verwendeten Begriffe existieren keine gebräuchlichen deutschen Benennungen, da sich die deutschen Anwender in der Regel ebenfalls der englischen Benennungen bedienen. Diese Norm steht nicht in unmittelbarem Zusammenhang mit Rechtsvorschriften und ist nicht als Sicherheitsnorm anzusehen.

Nationaler Anhang NA (informativ)

1 Anwendungsbereich^{N1)}

Dieser Teil von IEC 62769 legt ein FDI-Profil nach IEC 62769 für IEC 61784-1_CP 9/1 (HART[®])¹⁾ und IEC 61784-2_CP 9/2 (WirelessHART[®])¹⁾ fest.

3 Begriffe, Abkürzungen und Konventionen

3.1 Begriffe

Für die Anwendung dieses Dokuments gelten die Begriffe nach IEC 62541-100, IEC 62769-4, IEC 62769-5 und IEC 62769-7.

^{N1)} Nationale Fußnote: Die Nummerierung der IEC 62769-109-1:2015 wurde beibehalten.

¹⁾ HART und WirelessHART sind die Handelsnamen des gemeinnützigen Konsortiums HART Communication Foundation, Austin, Texas, USA. Diese Angabe dient nur der Unterrichtung der Anwender dieser Norm und bedeutet keine Anerkennung des Inhabers des Warenzeichens oder eines seiner Produkte durch die IEC. Die Übereinstimmung mit dieser Norm erfordert nicht die Verwendung der Handelsnamen. Die Verwendung dieser Handelsnamen erfordert die Erlaubnis seines Inhabers.

– Leerseite –

English Version

Field Device Integration (FDI) - Part 109-1: Profiles - HART®
and WirelessHART®
(IEC 62769-109-1:2015)

Intégration des appareils de terrain (FDI) - Partie 109-1:
Profils - HART® et WirelessHART®
(IEC 62769-109-1:2015)

Feldgeräteintegration (FDI) - Teil 109-1: Profile -HART®
und WirelessHART®
(IEC 62769-109-1:2015)

This European Standard was approved by CENELEC on 2015-06-23. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Foreword

The text of document 65E/356/CDV, future edition 1 of IEC 62769-109-1, prepared by SC 65E "Devices and integration in enterprise systems", of IEC/TC 65 "Industrial-process measurement, control and automation" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62769-109-1:2015.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2016-03-23
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2018-06-23

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62769-109-1:2015 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated :

IEC 61784-1	NOTE	Harmonized as EN 61784-1.
IEC 61784-2	NOTE	Harmonized as EN 61784-2.
IEC 61804 (series)	NOTE	Harmonized as EN 61804 (series).
IEC 62769-1	NOTE	Harmonized as EN 62769-1.
IEC 62769-2	NOTE	Harmonized as EN 62769-2.
IEC 62769-3	NOTE	Harmonized as EN 62769-3 ¹⁾
IEC 62769-6	NOTE	Harmonized as EN 62769-6.

1) To be published.

CONTENTS

INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms, definitions, abbreviated terms and acronyms	6
3.1 Terms and definitions	6
3.2 Abbreviated terms and acronyms.....	6
4 Conventions	7
4.1 EDDL syntax	7
4.2 XML syntax.....	7
4.3 Capitalizations	7
5 Profile for CP 9/1 (HART®) or CP 9/2 (WirelessHART®)	8
5.1 General.....	8
5.2 Catalog profile	8
5.2.1 Protocol support file	8
5.2.2 CommunicationProfile definition	8
5.2.3 Profile device	8
5.2.4 Protocol version information	8
5.3 Associating a Package with a CP 9/1 device	9
5.3.1 Device type identification mapping	9
5.3.2 Device type revision mapping.....	9
5.4 Information Model mapping	9
5.4.1 ProtocolType definition.....	9
5.4.2 DeviceType mapping.....	10
5.4.3 FunctionalGroup Identification definition	10
5.5 Topology elements	11
5.5.1 ConnectionPoint definition.....	11
5.5.2 Communication Device definition.....	16
5.5.3 Communication service provider definition	17
5.5.4 Network definition	18
5.6 Methods.....	19
5.6.1 Methods for FDI Communication Servers.....	19
5.6.2 Methods for Gateways.....	23
Annex A (normative) Topology scan schema	32
A.1 General.....	32
A.2 IdentificationType.....	32
A.3 AddressTypeTP	34
A.4 AddressTypeIP	35
A.5 AddressTypeTDMA	35
A.6 AddressType.....	36
A.7 ConnectionPointType	37
A.8 NetworkType.....	37
A.9 Network	38
Annex B (normative) Transfer service parameters	39
B.1 General.....	39

B.2	receiveData	39
B.3	sendData	39
B.4	TransferResultDataT	39
B.5	TransferSendDataT	40
Bibliography		41
Annex ZA (normative) Normative references to international publications with their corresponding European publications.....		42
Table 1 – CommunicationProfile definition.....		8
Table 2 – Catalog values for profile devices		8
Table 3 – Protocol Version Information.....		9
Table 4 – Device type catalog mapping		9
Table 5 – ProtocolType HART definition		10
Table 6 – Inherited DeviceType Property mapping		10
Table 7 – Identification parameters		10
Table 8 – ConnectionPointType HART_TP definition		12
Table 9 – ConnectionPointType HART_IP Definition		14
Table 10 – ConnectionPointType HART_TDMA Definition		16
Table 11 – Method Connect arguments		20
Table 12 – Method Disconnect arguments		20
Table 13 – Method Transfer arguments		21
Table 14 – Method GetPublishedData arguments		22
Table 15 – Method SetAddress arguments		22
Table 16 – Method Connect arguments		24
Table 17 – Method Disconnect arguments		25
Table 18 – Method Transfer arguments		26
Table 19 – Method GetPublishedData arguments		28
Table 20 – Method SetAddress arguments		29
Table A.1 – Attributes of IdentificationT.....		34
Table A.2 – Elements of AddressTypeTP		34
Table A.3 – Elements of AddressTypeIP		35
Table A.4 – Elements of AddressTypeTDMA		36
Table A.5 – Elements of AddressT		36
Table A.6 – Elements of ConnectionPointT.....		37
Table A.7 – Elements of NetworkT		37
Table B.1 – Attributes of TransferResultDataT.....		39
Table B.2 – Attributes of TransferSendDataT		40

INTRODUCTION

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of patents concerning

- a) method for the supplying and installation of device-specific functionalities, see Patent Family DE10357276;
- b) method and device for accessing a functional module of automation system, see Patent Family EP2182418;
- c) methods and apparatus to reduce memory requirements for process control system software applications, see Patent Family US2013232186;
- d) extensible device object model, see Patent Family US12/893,680.

IEC takes no position concerning the evidence, validity and scope of this patent right.

The holders of these patent rights have assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information may be obtained from:

- a) ABB Research Ltd
Claes Ryttoft
Affolterstrasse 4
Zurich, 8050
Switzerland
- b) Phoenix Contact GmbH & Co KG
Intellectual Property, Licenses & Standards
Flachsmarktstrasse 8, 32825 Blomberg
Germany
- c) Fisher Controls International LLC
John Dilger, Emerson Process Management LLLP
301 S. 1st Avenue, Marshalltown, Iowa 50158
USA
- d) Rockwell Automation Technologies, Inc.
1 Allen-Bradley Drive
Mayfield Heights, Ohio 44124
USA

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (<http://patents.iec.ch>) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

FIELD DEVICE INTEGRATION (FDI) –

Part 109-1: Profiles – HART® and WirelessHART®

1 Scope

This part of IEC 62769 specifies an FDI profile of IEC 62769 for IEC 61784-1_CP 9/1 (HART®)¹ and IEC 61784-1_CP 9/2 (WirelessHART®)¹.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62541-100, *OPC unified architecture – Part 100: Device Interface*

IEC 62769-4:2015, *Field Device Integration (FDI) – Part 4: FDI Packages*

NOTE IEC 62769-4 is technically identical to FDI-2024.

IEC 62769-5, *Field Device Integration (FDI) – Part 5: FDI Information Model*

NOTE IEC 62769-5 is technically identical to FDI-2025.

IEC 62769-7, *Field Device Integration (FDI) – Part 7: Communication Devices*

NOTE IEC 62769-7 is technically identical to FDI-2027.

3 Terms, definitions, abbreviated terms and acronyms

3.1 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 62541-100, IEC 62769-4, IEC 62769-5 and IEC 62769-7 apply.

3.2 Abbreviated terms and acronyms

For the purposes of this document, the following abbreviations apply:

CP	Communication profile (see IEC 61784-1 or IEC 61784-2)
CPF	Communication profile family (see IEC 61784-1 or IEC 61784-2)
EDD	Electronic Device Description (see IEC 61804)
EDDL	Electronic Device Description Language (see IEC 61804)

¹ HART and WirelessHART are the trade names of the non-profit consortium HART Communication Foundation, Austin, Texas, USA. This information is given for the convenience of users of this document and does not constitute an endorsement by IEC of the trademark holder or any of its products. Compliance does not require use of the trade names. Use of the trade names requires permission of the trade name holder.

FDI	Field Device Integration
FSK	Frequency-Shift-Keying
HCF	HART Communication Foundation
ID	Identification
IM	Information Model
IP	Internet protocol
PDU	Protocol data unit
PSK	Phase-Shift-Keying
TCP	Transmission Control Protocol (see IETF RFC 793)
UDP	User Datagram Protocol (see IETF RFC 768)
XML	Extended markup language

4 Conventions

4.1 EDDL syntax

This document specifies content for the EDD component that is part of FDI Communication Packages. EDDL syntax uses the font `Courier New`. EDDL syntax is used for method signature, variable, data structure and component declarations.

4.2 XML syntax

XML syntax examples use font `Courier New`. The XML syntax is used to describe XML document schema.

Example: `<xs:simpleType name="ExampleT">`

4.3 Capitalizations

The IEC 62769 series uses capitalized terms to emphasize that these terms have an FDI specific meaning.

Some of these terms using an acronym as a prefix, for example

- FDI Client, or
- FDI Server.

Some of these terms are compound terms such as:

- FDI Communication Servers, or
- Profile Package.

Parameter names or attributes are concatenated to a single term, where the original terms start in this term with a capital letter such as:

- ProtocolSupportFile, or
- ProtocolType.

Parameter names or attributes can also be constructed by using an underscore character to concatenate two or more terms such as:

- PROFILE_ID, or

- HART_Network.

5 Profile for CP 9/1 (HART®) or CP 9/2 (WirelessHART®)

5.1 General

This profile document to the FDI specification in IEC 62769 specifies the protocol specifics needed for FDI Packages describing FDI Communication Servers, gateways and devices.

5.2 Catalog profile

5.2.1 Protocol support file

No additional file is required for CP 9/1 or CP 9/2 FDI Device Packages.

5.2.2 CommunicationProfile definition

IEC 62769-4 defines a CommunicationProfileT enumeration type for the Catalog XML schema. Table 1 defines the CP 9/1 specific values for this enumeration.

Table 1 – CommunicationProfile definition

CommunicationProfile	Description
hart_fsk	CP 9/1 device type that supports an FSK physical layer (Frequency-Shift-Keying on a pair of wires).
hart_psk	CP 9/1 device type that supports a PSK physical layer (Phase-Shift-Keying on a pair of wires). Devices supporting PSK are required to also inherently support FSK, and therefore PSK will always be used only in combination with at least FSK.
hart_wirelesshart	CP 9/2 device type that supports a wireless physical layer (communication between device and gateway).
hart_ip	CP 9/1 device type that supports Internet Protocol (these devices support both TCP and UDP).
hart_rs485	CP 9/1 device type that supports EIA-485 digital communication.
hart_ir	CP 9/1 device type that supports an Infrared physical layer (designed to be transparent to FSK masters – included only as information to indicate that the device supports IR connection).
NOTE It is possible for a single CP 9/1 device to support more than one CP.	

5.2.3 Profile device

A Profile Package shall provide the catalog values for profile devices, enabling the FDI Server to leverage a generic device description, if a specific one is not available. The definitions in Table 2 focus on catalog content that is vendor independent.

Table 2 – Catalog values for profile devices

Element	Attribute	Content
PackageType	—	Profile
DeviceModel	—	Empty
Manufacturer	—	Empty

5.2.4 Protocol version information

IEC 62769-4 defines an element type named InterfaceT for the Catalog XML Schema. The element type InterfaceT contains an element named Version which is supposed to provide version

information about the applied communication protocol profile. The value has to follow the IEC 62769-4 defined version information schema defined in element type VersionT. Subclause 5.2.4 describes how to apply the currently known protocol versions for CP 9/1 or CP 9/2 entries in the device catalog. The general rule is to use the Universal Revision of the protocol for the major version part of VersionT, and the value "0" for the minor version and build parts. Table 3 shows the Protocol Version Information.

Table 3 – Protocol Version Information

Protocol Version	InterfaceT Version value
HART Universal Revision 5	5.0.0
HART Universal Revision 6	6.0.0
HART Universal Revision 7	7.0.0
The Protocol Version defined in a package is provided for informational purposes only, and shall not be used to determine the compatibility or applicability of a package to a device.	

5.3 Associating a Package with a CP 9/1 device

5.3.1 Device type identification mapping

CP 9/1 device types are uniquely identified by parameters Manufacturer, Model and DeviceRevision. These parameters are used to associate a given device instance to an FDI Device Package. These parameters are mapped to the FDI Device Package Catalog according to Table 4.

Table 4 – Device type catalog mapping

Catalog element	CP mapping (see 5.4.2)
Manufacturer element of InterfaceT (IEC 62769-4:2015, Clause E.11)	Manufacturer String format "0xdddd" where dddd is the Manufacturer number in hexadecimal format.
DeviceModel element of InterfaceT (IEC 62769-4:2015, Clause E.11)	Model String format "0xdddd" where dddd is the Model number in hexadecimal format.
DeviceRevision element ListOfSupportedDeviceRevisionsT (IEC 62769-4:2015, Clause E.21)	DeviceRevision String format "x.0.0" where x is the DeviceRevision in decimal format (no leading zeros).

5.3.2 Device type revision mapping

Each device type is identified as per 5.3.1. If a package with matching DeviceRevision is not available, any CP 9/1 FDI package for a corresponding manufacturer and model shall always be compatible with a field device as long as the device revision of the field device is equal to or greater than the device revision specified in the FDI package.

5.4 Information Model mapping

5.4.1 ProtocolType definition

Table 5 defines the ProtocolType used to identify CP 9/1 network communications.

Table 5 – ProtocolType HART definition

Attribute	Value				
BrowseName	HART				
IsAbstract	False				
References	NodeClass	BrowseName	DataType	TypeDefinition	ModellingRule
Inherits the properties of ProtocolType defined in IEC 62541-100.					

5.4.2 DeviceType mapping

Each device type inherits the properties of DeviceType. The mapping of the inherited properties from DeviceType is defined in Table 6.

Table 6 – Inherited DeviceType Property mapping

Property	Foundation mapping
SerialNumber	3-byte unique ID of a device, returned in bytes 9 to 11 of Command 0 or Command 11 or Command 21
RevisionCounter	2-byte configuration change counter, returned in bytes 14 and 15 of Command 0 or Command 11 or Command 21. -1 (not defined) for HART revision 5 devices
Manufacturer	For HART revision 7 or higher devices: 2-byte manufacturer code of a device, returned in bytes 17 and 18 of Command 0 or Command 11 or Command 21. For HART revision 6 or lower devices: Most significant byte shall be fixed to 0, and the least significant byte is returned in byte 1 of Command 0 or Command 11 or Command 21
Model	2-byte extended device type of a device, returned in bytes 1 and 2 of Command 0 or Command 11 or Command 21
DeviceManual	Entry text string (not supported) ^a
DeviceRevision	1-byte device revision level of a device, returned in byte 5 of Command 0 or Command 11 or Command 21
SoftwareRevision	1-byte software revision level of a device, returned in byte 6 of Command 0 or Command 11 or Command 21
HardwareRevision	1-byte hardware revision level of a device, returned in byte 7 (only 5 most significant bits) of Command 0 or Command 11 or Command 21
^a Device manuals are exposed as attachments of the FDI Device Package.	

5.4.3 FunctionalGroup Identification definition

As defined in IEC 62541-100, each device representation in the FDI Server hosted Information Model shall contain a protocol specific FunctionalGroup called Identification. This FunctionalGroup organizes variables found in the device type instance. The FunctionalGroup Identification for CP 9/1 is defined in Table 7.

Table 7 – Identification parameters

BrowseName	DataType	Optional/Mandatory
MANUFACTURER_ID	UInt16	Mandatory
DEVICE_TYPE	UInt16	Mandatory
DEVICE_REVISION	UInt8	Mandatory
UNIVERSAL_REVISION	UInt8	Optional
SERIAL_NUMBER	UInt24	Optional
HARDWARE_REVISION	UInt8	Optional
SOFTWARE_REVISION	UInt8	Optional
REVISION_COUNTER	UInt16	Optional