

DIN EN 2665-001



ICS 49.060

Entwurf

Einsprüche bis 2020-11-04
Vorgesehen als Ersatz für
DIN EN 2665-001:2014-05

**Luft- und Raumfahrt –
Schutzschalter, dreipolig, temperaturkompensiert, Nennströme von 20 A
bis 50 A –**

**Teil 001: Technische Lieferbedingungen;
Englische Fassung prEN 2665-001:2020**

Aerospace series –

Circuit breakers, three-pole, temperature compensated, rated currents 20 A to 50 A –

Part 001: Technical specification;

English version prEN 2665-001:2020

Série aérospatiale –

Disjoncteurs tripolaires compensés en température, intensités nominales 20 A à 50 A –

Partie 001: Spécification technique;

Version anglaise prEN 2665-001:2020

Anwendungswarnvermerk

Dieser Norm-Entwurf mit Erscheinungsdatum 2020-09-04 wird der Öffentlichkeit zur Prüfung und Stellungnahme vorgelegt.

Weil die beabsichtigte Norm von der vorliegenden Fassung abweichen kann, ist die Anwendung dieses Entwurfs besonders zu vereinbaren.

Stellungnahmen werden erbeten

- vorzugsweise online im Norm-Entwurfs-Portal von DIN unter www.din.de/go/entwuerfe bzw. für Norm-Entwürfe der DKE auch im Norm-Entwurfs-Portal der DKE unter www.entwuerfe.normenbibliothek.de, sofern dort wiedergegeben;
- oder als Datei per E-Mail an nl@din.de möglichst in Form einer Tabelle. Die Vorlage dieser Tabelle kann im Internet unter www.din.de/go/stellungnahmen-norm-entwuerfe oder für Stellungnahmen zu Norm-Entwürfen der DKE unter www.dke.de/stellungnahme abgerufen werden;
- oder in Papierform an den DIN-Normenausschuss Luft- und Raumfahrt (NL), 10772 Berlin oder Saatwinkler Damm 42/43, 13627 Berlin.

Die Empfänger dieses Norm-Entwurfs werden gebeten, mit ihren Kommentaren jegliche relevanten Patentrechte, die sie kennen, mitzuteilen und unterstützende Dokumentationen zur Verfügung zu stellen.

Gesamtumfang 24 Seiten

DIN-Normenausschuss Luft- und Raumfahrt (NL)

Nationales Vorwort

Der Verband der Europäischen Luft-, Raumfahrt- und Verteidigungsindustrie – Normung (ASD-STAN) ist vom Europäischen Komitee für Normung (CEN) für zuständig erklärt worden, Europäische Normen (EN) für das Gebiet der Luft- und Raumfahrt auszuarbeiten. Durch die Vereinbarung vom 3. Oktober 1986 wurde ASD Assoziierte Organisation (ASB) des CEN.

Das vorliegende Dokument (prEN 2665-001:2020) wurde von ASD-STAN, Fachbereich Elektrotechnik, unter Mitwirkung deutscher Experten des DIN-Normenausschusses Luft- und Raumfahrt (NL) erarbeitet.

Das zuständige deutsche Normungsgremium ist der Arbeitsausschuss NA 131-04-05 AA „Schalter, Relais und Schutzgeräte“ im DIN-Normenausschuss Luft- und Raumfahrt (NL).

Der vorliegende Norm-Entwurf enthält zur technischen Kommentierung einen Europäischen Norm-Entwurf (prEN) ausschließlich in Englischer Fassung aus der CEN-Umfrage.

Ein zweiter Norm-Entwurf wird nur die Deutsche Fassung der veröffentlichten ASD-STAN prEN enthalten. Es wird darauf hingewiesen, dass auf Grund der Verfahrensweise zur Normenerstellung bei ASD-STAN der zweite Norm-Entwurf ausschließlich der redaktionellen Prüfung der deutschen Sprachfassung dienen wird.

Entsprechend Beschluss 57/9 des Technischen Ausschusses des Beirats des DIN-Normenausschusses Luft- und Raumfahrt (NL) sind die europäischen Luft- und Raumfahrt-Normungsergebnisse zweisprachig, in Deutsch und Englisch, in das Deutsche Normenwerk zu überführen. Aus diesem Grund wird die Norm beide Sprachfassungen enthalten.

Aktuelle Informationen zu diesem Dokument können über die Internetseiten von DIN (www.din.de) durch eine Suche nach der Dokumentennummer aufgerufen werden.

Änderungen

Gegenüber DIN EN 2665-001:2014-05 wurden folgende Änderungen vorgenommen:

- a) Aktualisierung der normativen Verweisungen;
- b) Eigenschaften in Abschnitt 6 genauer spezifiziert;
- c) Tabellen zu den Prüfungen in Abschnitt 7 wurden geändert;
- d) Abschnitt 8 „Qualitätsprüfung“ wurde angepasst;
- e) Norm redaktionell überarbeitet.

English Version

Aerospace series - Circuit breakers, three-pole,
temperature compensated, rated currents 20 A to 50 A -
Part 001: Technical specification

Série aérospatiale - Disjoncteurs tripolaires compensés
en température, intensités nominales 20 A à 50 A -
Partie 001 : Spécification technique

Luft- und Raumfahrt - Schutzschalter, dreipolig,
temperaturkompensiert, Nennströme von 20 A bis 50
A - Teil 001: Technische Lieferbedingungen

This draft European Standard is submitted to CEN members for enquiry. It has been drawn up by the Technical Committee ASD-STAN.

If this draft becomes a European Standard, CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

This draft European Standard was established by CEN in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Republic of North Macedonia, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.

Recipients of this draft are invited to submit, with their comments, notification of any relevant patent rights of which they are aware and to provide supporting documentation.

Warning : This document is not a European Standard. It is distributed for review and comments. It is subject to change without notice and shall not be referred to as a European Standard.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Rue de la Science 23, B-1040 Brussels

Contents

Page

European foreword	4
1 Scope.....	5
2 Normative references.....	5
3 Terms and definitions	5
4 Description.....	5
5 Design.....	6
5.1 Materials	6
5.1.1 Metallic materials	6
5.1.2 Insulation materials.....	6
5.2 Design.....	6
5.2.1 Insulating box.....	6
5.2.2 Free release mechanism.....	6
5.2.3 Attachment.....	6
5.2.4 Electrical connection units	6
5.2.5 Control actuator	6
5.2.6 Rating inviolability	7
5.2.7 Leakage lines	7
5.2.8 Protection against non-release	7
6 Characteristics	7
6.1 General characteristics.....	7
6.2 Ratings	7
6.3 Nominal voltage of operational circuits	7
6.4 Dimensional characteristics	7
6.5 Recommended panel mounting dimensions.....	8
7 Tests.....	8
7.1 Mechanical tests	8
7.2 Environmental tests.....	9
7.3 Electrical tests	14
8 Qualification tests	16
8.1 Sampling.....	16
8.2 Material tests.....	20
8.3 Periodic checks for qualification maintenance.....	20
9 Quality assurance.....	20
10 Marking.....	20
11 Delivery conditions	20
12 Packaging.....	21
13 Storage	21
13.1 Definition	21
13.2 Storage conditions.....	21
13.3 Storage duration.....	21

Bibliography	22
---------------------------	-----------

European foreword

This document (prEN 2665-001:2020) has been prepared by the Aerospace and Defence Industries Association of Europe — Standardization (ASD-STAN).

After enquiries and votes carried out in accordance with the rules of this Association, this Standard has received the approval of the National Associations and the Official Services of the member countries of ASD-STAN, prior to its presentation to CEN.

This document is currently submitted to the CEN Enquiry.

This document will supersede EN 2665-001:2013.

1 Scope

This document specifies the three-pole temperature compensated circuit breakers without signal contacts, rated from 20 A to 50 A and used in aircraft on-board circuits. It describes specific environmental, electrical and mechanical characteristics and the stringency of tests to be applied according to test methods of EN 3841-100.

These circuit breakers are intended for use in aircraft with electrical supplies in accordance with EN 2282.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 2083, *Aerospace series - Copper and copper alloys conductors for electrical cables - Product standard*

EN 2665-004, *Aerospace series - Circuit breakers, three-pole, temperature compensated, rated current 20 A to 50 A - Part 004: UNC thread terminals - Product standard*

EN 2825, *Aerospace series - Burning behaviour of non metallic materials under the influence of radiating heat and flames - Determination of smoke density*

EN 2826, *Aerospace series - Burning behaviour of non metallic materials under the influence of radiating heat and flames - Determination of gas components in the smoke*

EN 3841,¹ *Aerospace series - Circuit breakers - Test Methods*

EN 3844-1, *Aerospace series - Flammability of non-metallic materials - Part 1: Small burner test, vertical - Determination of the vertical flame propagation*

TR 6083,² *Aerospace series - Cut-outs for installation of electrical components*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in EN 3841-100 apply.

ISO and IEC maintain terminological databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <http://www.electropedia.org/>

4 Description

These circuit breakers are operated by a “push-pull” type single push button (actuator) and with delayed action “trip-free” tripping. Their function is ensured up to the short-circuit current.

¹ And all its parts quoted in this document.

² Published as ASD-STAN Technical Report at the date of publication of this document. <http://www.asd-stan.org/>

5 Design

5.1 Materials

5.1.1 Metallic materials

All metallic parts shall be resistant to corrosion or finished against corrosion. When dissimilar materials are in close contact, an adequate protection against corrosion shall be used so that the electromotive force of the galvanic couple does not exceed 0,25 V.

When bimetals are used, an eventual corrosion shall not affect the good operation of the circuit breaker.

5.1.2 Insulation materials

The insulating parts shall be made of auto-extinguishing or non-flammable materials; they shall not emit damaging or explosive vapours, even in presence of fire or internal electric arc.

They shall be insensitive to moulds and microorganisms action.

Application of any material or protective coating, which might crack, break or flake shall be forbidden.

Materials which are not specified, or which are not specially described shall be as light as possible for the requested use.

Materials shall be selected according to security criteria (toxicity, smoke density) as defined in contractual documents.

5.2 Design

5.2.1 Insulating box

The insulating box shall integrate besides the mechanism, the connection and attachment unit.

5.2.2 Free release mechanism

Design of circuit breaker mechanism shall allow free release; i.e. the circuit breaker cuts out in case of overload, and remains cut out even if the actuator is kept by force in engaged position.

A new engagement of circuit breaker is only possible after a first total release of the control actuator.

The operation in these conditions shall not affect further performances of the circuit breaker.

5.2.3 Attachment

All visible parts shall be black coloured and non-reflective.

5.2.4 Electrical connection units

They shall be able to receive the lugs.

5.2.5 Control actuator

In engaged position, the visible part of the control actuator shall be of the colour stated in the product standard. In disengaged (or opened) position, the control actuator shall show a white strip.

The outer part of this actuator shall be isolated from all under voltage parts.

The control actuator shall not stay in a transition position or give a false indication about the circuit breaker condition. It shall not be removable.

When pushing it, power contacts of the circuit breaker engage.

When pulling it, power contacts of the circuit breaker open.