



PREVENTION OF EXCESSIVE PRESSURE DURING FILLING OF CRYOGENIC VESSELS

Doc 151/23

Revision of Doc 151/15

EUROPEAN INDUSTRIAL GASES ASSOCIATION AISBL

AVENUE DE L'ASTRONOMIE 30 • B – 1210 BRUSSELS

Tel: +32 2 217 70 98

E-mail: info@eiga.eu • Internet: www.eiga.eu



Documents

Document Sharing Hub



PREVENTION OF EXCESSIVE PRESSURE DURING FILLING OF CRYOGENIC VESSELS

As part of a programme of harmonisation of industry standards, the European Industrial Gases Association (EIGA), publication, *Prevention of Excessive Pressure during Filling of Cryogenic Vessels*, has been used as the basis of an internationally harmonised gas association's publication on this subject.

This publication is intended as an international harmonised standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association (EIGA), and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

Disclaimer

All technical publications of EIGA or under EIGA's name, including Codes of practice, Safety procedures and any other technical information contained in such publications were obtained from sources believed to be reliable and are based on technical information and experience currently available from members of EIGA and others at the date of their issuance.

While EIGA recommends reference to or use of its publications by its members, such reference to or use of EIGA's publications by its members or third parties are purely voluntary and not binding.

Therefore, EIGA or its members make no guarantee of the results and assume no liability or responsibility in connection with the reference to or use of information or suggestions contained in EIGA's publications.

EIGA has no control whatsoever as regards, performance or non performance, misinterpretation, proper or improper use of any information or suggestions contained in EIGA's publications by any person or entity (including EIGA members) and EIGA expressly disclaims any liability in connection thereto.

EIGA's publications are subject to periodic review and users are cautioned to obtain the latest edition.

Table of Contents

1	Introduction	1
2	Scope and purpose	1
2.1	Scope	1
2.2	Purpose	1
3	Definitions	2
3.1	Publication terminology	2
	Indicates a possibility or ability.	2
3.2	Technical definitions	2
4.	Background	3
4.1	Background transport tanks	3
4.2	Background static vessels	3
5	Transport tanks	4
5.1	Filling operation	4
5.2	Recommendations	6
6	Static tanks	6
6.1	Equipment and procedures	6
6.2	Principles for overpressure protection	6
6.3	Examples of overpressure protection systems	7
6.4	Limiting pressure	8
7	General recommendations	9
7.1	Existing installations	9
7.2	Applicable principles and techniques	9
7.3	Role of driver-monitored procedures	9
8.	References	10

Amendments to 151/15

Section	Change
2.1	Clarifications added to the Scope
4	Minor changes added
5	Minor changes added
6.3.7	Added
6.4	Clarification on 'Limiting pressure'
7	Minor changes added
8	Adapted as per the core text
Appendix A	Deleted

Note: Technical changes from the previous edition are underlined

1 Introduction

This publication details the methods that can be used to prevent the over-pressurisation of both transportable and static pressure vessels during filling.

2 Scope and purpose

2.1 Scope

This publication is intended to provide guidance to the filler/owner of either transportable or static cryogenic tanks, detailing the systems and procedures that can be used to prevent them being over-pressurized during filling (i.e., causing a catastrophic failure by excessive pressure). Vessels for which the upper pressure limit (UPL) cannot be exceeded by the maximum allowable pump feed pressure (MAPFP) do not require any additional protection.

This publication is intended to address the issue of transportable or static cryogenic tanks greater than 1000 L (264 gal) water capacity for liquefied cryogenic gases and refrigerated liquids such as nitrous oxide and carbon dioxide. This publication should also be used for receiving vessels under 1000 L (264 gal) that are not designed for transport when full. This publication can also be used as guidance for other products and other transfer systems. It does not consider the hazardous nature of any product release, only the prevention of a failure of the tank due to pressure. This does not apply to cryogenic tanks with flat bottoms. For flat bottomed cryogenic tanks, refer to EIGA Doc 127, *Bulk Liquid Oxygen, Nitrogen and Argon Storage Systems at Production Sites* [1].¹

Protective measures that prevent the over-pressurisation of receiving vessels in service (for example, by failure of the vacuum, pressure raising, flame engulfment, etc.) are detailed in other codes and standards, and are not considered further here.

2.2 Purpose

In 1996, a serious incident focused the attention of the gas industry on the fact that a cryogenic storage tank can be pressurized greater than its bursting pressure during filling. If a high pressure or high flow pump is used to fill a low pressure tank and if the safety measures are not appropriate or do not work, then an unsafe situation can arise.

This was the first significant incident of this type in an industry that has operated safely and reliably with an estimated several million filling operations carried out per year. However, due to technical developments in pumping equipment (increasing delivery pressures and flow rates), the safety margin the tanks have against failure can be reduced unless the protective measures against such an event occurring have not been upgraded simultaneously.

It is an essential management task to systematically control any changes to product transfer systems to ensure that the integrity of the tanks being filled is not jeopardized.

Pressure vessels are used in the distribution and site storage of cryogenic liquids on customer sites. This includes those involved in the transport of cryogenic fluids (transportable pressure vessels) such as road tankers, rail tank cars transferring product from the production facility to the customers site, and those on the customer site itself (static pressure vessels) that provide on-site storage for the cryogenic fluids.

The primary means of controlling vessel pressure during an operator attended fill is by a trained and qualified operator, making it a manually controlled process. The case for the over pressurization scenario during operator attended filling is often outside the pressure vessel design code for sizing of pressure relief devices.

¹ References are shown in bracketed numbers and are listed in order of appearance in the reference section.