



HYCO PLANT GAS LEAK DETECTION AND RESPONSE PRACTICES

Doc 215/18

EUROPEAN INDUSTRIAL GASES ASSOCIATION AISBL



AVENUE DES ARTS 3-5 • B – 1210 BRUSSELS
Tel: +32 2 217 70 98 • Fax: +32 2 219 85 14
E-mail: info@eiga.eu • Internet: www.eiga.eu





HYCO PLANT GAS LEAK DETECTION AND RESPONSE PRACTICES

As part of a programme of harmonisation of industry standards, the European Industrial Gases Association, (EIGA) has published EIGA Doc 215, *HYCO Plant Gas Leak Detection and Response Practices*, jointly produced by members of the International Harmonisation Council, and originally published by the Compressed Gas Association as CGA H-14, *HYCO Plant Gas Leak Detection and Response Practices*.

This publication is intended as an international harmonised standard for the worldwide use and application of all members of the Asia Industrial Gases Association (AIGA), Compressed Gas Association (CGA), European Industrial Gases Association, and Japan Industrial and Medical Gases Association (JIMGA). Each association's technical content is identical, except for regional regulatory requirements and minor changes in formatting and spelling.

Disclaimer

All technical publications of EIGA or under EIGA's name, including Codes of practice, Safety procedures and any other technical information contained in such publications were obtained from sources believed to be reliable and are based on technical information and experience currently available from members of EIGA and others at the date of their issuance.

While EIGA recommends reference to or use of its publications by its members, such reference to or use of EIGA's publications by its members or third parties are purely voluntary and not binding.

Therefore, EIGA or its members make no guarantee of the results and assume no liability or responsibility in connection with the reference to or use of information or suggestions contained in EIGA's publications.

EIGA has no control whatsoever as regards, performance or non performance, misinterpretation, proper or improper use of any information or suggestions contained in EIGA's publications by any person or entity (including EIGA members) and EIGA expressly disclaims any liability in connection thereto.

EIGA's publications are subject to periodic review and users are cautioned to obtain the latest edition.

© Reproduced with permission from the Compressed Gas Association. All rights reserved

EUROPEAN INDUSTRIAL GASES ASSOCIATION AISBL
Avenue des Arts 3-5 B 1210 Brussels Tel +32 2 217 70 98 Fax +32 2 219 85 14
E-mail: info@eiga.eu Internet: www.eiga.eu



Table of Contents

1	Introduction	1
2	Scope	1
3	Definitions	1
3.1	Publication terminology	1
3.2	Technical definitions	2
4	Safety considerations.....	3
5	Monitoring	5
5.1	Guidelines	5
5.2	Sensor types.....	6
5.3	Monitoring and alarms	8
6	Leak detection.....	9
6.1	Leak detection during maintenance.....	11
6.2	Leak scenarios.....	11
7	Leak assessment and response	12
7.1	Initial leak response	12
7.2	Leak estimation and characterization	12
7.3	Subsequent leak response	13
7.4	Online leak repair.....	14
7.5	Environmental considerations	16
8	Operational and design recommendations to avoid potential leaks	16
9	References.....	17
	Table 1 Key properties of common HYCO plant chemicals.....	4
	Table 2 Guidance for placement of fixed monitors	10

1 Introduction

HYCO plants are facilities that produce hydrogen, carbon monoxide, or mixtures thereof. These plants are typically operated with feed stocks such as natural gas, refinery off gas, naphtha, and other light hydrocarbons.

Gases from HYCO plants are flammable and can be toxic; therefore, appropriate leak prevention design, monitoring, and response practices shall be applied to ensure personnel and public safety. Leak detection is part of an overall system comprising design aspects, leak detection devices, operating practices and the response to leak indications.

2 Scope

This publication applies to HYCO plants. Information in this publication may also be applied to facilities, such as trailer fill stations, cylinder fill stations, electrolytic production facilities, or vehicle fuelling stations.

This publication covers methodologies for prevention of, detection of, and response to flammable and/or toxic gas leaks that occur within the fence line of these facilities. Typical leak detection technologies are discussed including personal monitoring, fixed monitoring, and specialized detectors for identifying leak location. This publication also addresses the specifics of gas leaks occurring at unmanned or remotely monitored sites.

The leaks discussed in this publication are due to a loss of containment in process piping and equipment. A loss of containment is an unexpected release of process fluid to the atmosphere. A leak of this type is typically through a failed sealing device (e.g., stem packing, flange gasket) or a failure of the pressure boundary (e.g., crack in a weld). Many jurisdictions use the concept of fugitive emissions for leaks that are too small to repair, which are not covered in any detail in this publication due to jurisdictional variances.

This publication does not cover leaks from transportation piping or components leading to flares or process vents. It does not address routine oxygen deficiency and enrichment as these are covered in other harmonized publications (EIGA Doc 23, *Safety Training of Employees*; EIGA Doc 44, *Hazards of Inert Gases and Oxygen Depletion*) [1, 2]. It also does not address fire and smoke detection in buildings as these are covered in National Fire Protection Association (NFPA) standards and local building codes.

The reader should determine applicability for facilities other than those described in this publication or for leaks entering the facility from outside of the perimeter.

3 Definitions

For the purpose of this publication, the following definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

3.1.5 Can

Indicates a possibility or ability.

3.2 Technical definitions

3.2.1 Action level

Condition in which the atmosphere is outside the acceptable range and an operator shall take action to prevent the hazard from escalating.

3.2.2 Alarm level

Condition that results in a warning (alarm) indicating that the atmosphere is outside of the range of normal.

3.2.3 Cross header

Refractory lined pipe that connects the reformer outlet manifold to the inlet of the waste heat boiler.

NOTE Also known as a transfer header.

3.2.4 Cross-sensitive

Situation in which a sensor designed for a particular target gas reacts to another gas as if that gas were the target (e.g., a carbon monoxide sensor that is cross-sensitive to hydrogen will interpret a hydrogen leak as carbon monoxide).

3.2.5 Fugitive emissions

Emissions that cannot reasonably pass through a stack, chimney, or vent or other functionally equivalent opening [3].

3.2.6 HYCO plant

Facilities which produce hydrogen, carbon monoxide, or mixtures thereof.

3.2.7 Immediately dangerous to life or health (IDLH)

Maximum concentration from which unprotected persons are able to escape within 30 minutes without escape-impairing symptoms or irreversible health effects.

3.2.8 Line stop

Plug that is installed in plant piping, typically while the plant is in operation.

3.2.9 Lower flammability limit (LFL)

Minimum concentration in air of a gas that would burn when ignited.

NOTE Also known as the lower explosive limit (LEL).

3.2.10 Monitors

3.2.10.1 Fixed monitor

Detection device that is permanently mounted in one (fixed) location and that can be used for detection of one or more fires or gas leaks.

3.2.10.2 Personal monitor

Gas detection device that is worn by personnel or visitors at an operating facility and that transmits warnings via audible and visible signals, such as alarms and flashing lights, when dangerous levels of gas vapours are detected.

3.2.10.3 Portable monitor

Handheld gas detection device that transmits warnings via audible and visible signals, such as alarms and flashing lights, when dangerous levels of gas vapours are detected.

3.2.11 Permissible exposure limits (PEL)

8-hour time weighted average exposure set by the U.S. Occupational Safety and Health Administration (OSHA).

3.2.12 Reportable quantity

Minimum amount of hazardous substance which, when known to have been discharged into the environment within a prescribed time limit, is required to be reported to the authority having jurisdiction.

NOTE In the United States the prescribed time limit is 24 hours and reports are made to the National Response Center in Washington, DC.

3.2.13 Upper flammability limit (UFL)

Maximum concentration in air of a gas that would burn when ignited.

NOTE Also known as upper explosive limit (UEL).

4 Safety considerations

A HYCO plant produces hydrogen and/or carbon monoxide as products. The feed stocks for a HYCO plant are a variety of light hydrocarbon gases or liquids and sometimes ammonia. These colourless gases or liquids can be flammable and/or toxic. Toxic and flammable gas detectors are commonly used throughout a HYCO plant to warn of potentially dangerous gas leaks or harmful exposure to personnel; they play a valuable role in risk mitigation. Selection of appropriate gas detectors will depend on the gas being detected. Table 1 identifies the key properties of some of the substances most commonly found in HYCO plants. The basic physical characteristics listed in the table affect sensor selection and placement, leak detection, and required personnel behaviour in the area of the leak. The operator shall review the safety data sheet (SDS) to understand all of the hazards associated with a specific gas.

Diffusion governs the behaviour of gases leaking into the atmosphere. Wind direction, turbulence, leak rate, and the temperature and specific gravity of the leaking gas all have an effect on how the vapor cloud moves away from the leak source. Sensor placement shall take all of these factors into account. In the case of an enclosed space such as a building, the impact of these parameters is obvious. However, some plant areas with limited ventilation can offer similar risk regarding a gas leak. The proximity to occupied buildings should be considered, for guidance see EIGA Doc 187, *Guideline for the Location of Occupied Buildings in Industrial Gas Plants* [4]

Attention shall be paid to the impact of the temperature of the fluid on vapor cloud behaviour when assessing the hazards associated with a leak. Cryogenic gases or cryogenic liquid boil off that have specific gravities that are lighter than air can drop due to their low temperatures. Conversely, gases