



VACUUM INSULATED CRYOGENIC STORAGE TANK SYSTEMS PRESSURE PROTECTION DEVICES

Doc 24/18

Revision of Doc 24/08

EUROPEAN INDUSTRIAL GASES ASSOCIATION AISBL



AVENUE DES ARTS 3-5 • B – 1210 BRUSSELS
Tel: +32 2 217 70 98 • Fax: +32 2 219 85 14
E-mail: info@eiga.eu • Internet: www.eiga.eu





VACUUM INSULATED CRYOGENIC STORAGE TANK SYSTEMS PRESSURE PROTECTION DEVICES

Prepared by WG-6 Cryogenic vessels

Disclaimer

All technical publications of EIGA or under EIGA's name, including Codes of practice, Safety procedures and any other technical information contained in such publications were obtained from sources believed to be reliable and are based on technical information and experience currently available from members of EIGA and others at the date of their issuance.

While EIGA recommends reference to or use of its publications by its members, such reference to or use of EIGA's publications by its members or third parties are purely voluntary and not binding.

Therefore, EIGA or its members make no guarantee of the results and assume no liability or responsibility in connection with the reference to or use of information or suggestions contained in EIGA's publications.

EIGA has no control whatsoever as regards, performance or non performance, misinterpretation, proper or improper use of any information or suggestions contained in EIGA's publications by any person or entity (including EIGA members) and EIGA expressly disclaims any liability in connection thereto.

EIGA's publications are subject to periodic review and users are cautioned to obtain the latest edition.

© EIGA 2018 - EIGA grants permission to reproduce this publication provided the Association is acknowledged as the source

EUROPEAN INDUSTRIAL GASES ASSOCIATION AISBL
Avenue des Arts 3-5 B 1210 Brussels Tel +32 2 217 70 98 Fax +32 2 219 85 14
E-mail: info@eiga.eu Internet: www.eiga.eu




Table of Contents

1	Introduction	1
2	Scope and Purpose	1
2.1	Scope.....	1
2.2	Purpose	1
3	Definitions	1
3.1	Publication terminology	2
3.2	Technical definitions	2
4	Type of pressure protection devices	3
4.1	General	3
4.2	Relief valves (spring loaded)	3
4.3	Pilot operated relief valves	5
4.4	Outer vacuum jacket relief devices.....	6
4.5	Bursting discs	8
5	Installation of pressure protection devices.....	11
6	Pressure protection systems.....	11
6.1	Pressure protection.....	11
6.2	Vacuum protection.....	14
7	Design, manufacturing and testing	14
7.1	Flow test	14
7.2	Seat leak test (re-closable devices).....	15
7.3	Identification and documentation	15
7.4	Periodic inspection and test pressure protection devices	15
8	References.....	16
9	Other references	17
	Figure 1 Example of typical relief valve	4
	Figure 2 Example of typical pilot operated relief valve	6
	Figure 3 Example of typical plate type relief valve.....	7
	Figure 4 Example of plate type relief valve	7
	Figure 5 Example of typical plug relief valve.....	8
	Figure 6 Example of a typical bursting disc general assembly	9
	Figure 7 Example of typical integral bursting disc assembly	10
	Figure 8 Typical pressure protection systems for vacuum insulated storage tanks	12
	Figure 9 Examples of pressure protection devices with burst discs	13
	Figure 10 Example of pressure protection devices without burst disc.....	13

Amendments from 24/08

Section	Change
	Editorial to align style with EIGA Style Manual
3	Publications terminology added, and technical definitions updated and reordered.
4.1	Notes added
4.2.1.1	New section gas discharge added
4.2.1.3	Liquid discharge section expanded
6.1.3	New paragraph added
6.1.4	New sentence on capacity design basis warm fill
8 and 9	Updating of references

Technical changes are shown underlined

1 Introduction

This publication provides recommendations for pressure protection devices for static cryogenic vacuum insulated storage tanks used in the industrial gas industry. The principles of protection are identified, and the requirements of the protection devices are defined. A variety of devices are available to meet these requirements and each of these is considered from the point of view of design, construction, installation and periodic inspection and testing.

National legislation and practices currently vary considerably between European countries. The Pressure Equipment Directive 2014/68/EU¹ [1] and harmonised European Standards for example EN 13458 - 1 *Cryogenic Vessels – Static vacuum insulated vessels fundamental requirements* [2] provide recommendations for the pressure protection of cryogenic storage tank systems. EN 13458-3 *Cryogenic vessels. Static vacuum insulated vessels. Operational requirements* [3] also details operational requirements including inspection periodicities that provides a standardised approach.

National regulations can replace the relevant parts of this publication where they exist and are more stringent.

The study of reliability data and current practices relating to pressure protection devices in cryogenic pressure systems, and the preparation of recommendations, arose from experience in applying available pressure protection devices for cryogenic duty. Therefore, recommendations are made for the design, construction, installation, periodic inspection and testing of the pressure protection devices fitted to vessels and piping for the storage of atmospheric gases. This excludes vessels and equipment for the production and transport of atmospheric gases, although it may be used as a guide for those devices.

2 Scope and Purpose

2.1 Scope

This publication provides guidance for pressure protection devices for static cryogenic vacuum insulated storage tanks.

It may also be used as a guide for non-vacuum insulated storage tanks, for example for the carbon dioxide and other cryogenic liquids including helium. Specific operating conditions such as temperatures and material compatibility shall be considered.

Flat bottom tanks used for bulk storage of cryogenic gases at air separation plants are excluded from this publication.

NOTE For protection against overfilling of storage tank see EIGA Doc 151 *Prevention of Excessive Pressure During Filling of Cryogenic Vessels*. [4]

2.2 Purpose

To provide guidance on the pressure protection for static cryogenic vacuum insulated storage tanks. against abnormal conditions. The protection against over pressure has two purposes:

- Reducing the risk to personnel; and
- Ensuring integrity of equipment.

3 Definitions

For the purpose of this publication the following definitions apply.

¹ References are shown by bracketed numbers and are listed in order of appearance in the reference section

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory; it is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Will is used only to indicate the future, not a degree of requirement.

3.1.5 Can

Indicates a possibility or ability.

3.2 Technical definitions

3.2.1 Calculated pressure

Maximum pressure the equipment will be exposed to and includes additional factors for example, temperature, fatigue and liquid head, as well as the maximum stresses permitted during both operation and testing.

NOTE The calculated pressure shall not be less than the maximum allowable pressure PS. In the case of EN 13458-3 [3], liquid head pressure not exceeding 5% of the maximum allowable pressure PS may be discounted

3.2.2 Leak test pressure

Pressure to which the equipment is subjected when a leak test is made separately from the strength test. The value is defined by the constructor's own rules, by a code or any other regulation

3.2.3 Maximum allowable pressure PS

Gauge pressure as defined by the manufacturer and used in the formulae for calculating the pressure containing parts. This definition is compatible with that used in Directive 2014/68/EU [1].

NOTE This is the same as maximum allowable working pressure (MAWP).

3.2.4 Pressure

Bar shall indicate gauge pressure.

3.2.5 Pressure system

Any group of components designed to a common pressure and protected by the same pressure protection system.

3.2.6 Strength test pressure

Pressure to which the equipment is subjected for testing at the time of manufacture and/or before going into service.

3.2.7 Operating pressure

Pressure at which the equipment normally operates.

3.2.8 Working temperature range

Temperature range at which the equipment normally operates.

4 Type of pressure protection devices

4.1 General

Commonly used pressure protection devices are described below. The selection of a device for a particular duty depends on a number of parameters, but the following shall be considered.

Each device shall be sized in accordance with EN ISO 21013-3 *Cryogenic vessels -- Pressure-relief accessories for cryogenic service -- Part 3: Sizing and capacity determination* [5].

NOTE Additional protection devices could be required to account for all over pressure scenarios, for example, overpressure during filling of the vessel. EIGA Doc 151 details the methods that can be used to prevent the over pressurisation of both transportable and static cryogenic pressure vessels during filling., [4].

The pressure drop in piping to and from the device shall be low enough to ensure accurate and stable operation. Permissible pressure drops are stated in the relevant ISO standard.

The device shall be mounted in the orientation intended by the manufacturer and be supported to resist the exhaust thrust when the device operates.

The device shall be protected from external factors that could cause damage or impair operation.

NOTE For terminology relating to safety valves, see ISO 4126 *Safety devices for protection against excessive pressure -- Part 1: Safety valves* [6]

4.2 Relief valves (spring loaded)

This section provides a summary of requirements, components, and features of a relief valve. A typical relief valve is shown in Figure 1.