



Member of the FM Global Group

Examination Standard for Centrifugal Fire Pumps (Horizontal, End Suction Type)

Class Number 1319

December 2020

Foreword

This standard is intended to verify that the products and services described will meet stated conditions of performance, safety and quality useful to the ends of property conservation. The purpose of this standards is to present the criteria for examination of various types of products and services.

Examination in accordance with this standard shall demonstrate compliance and verify that quality control in manufacturing shall ensure a consistent and reliable product.

Table of Contents

1. INTRODUCTION	1
1.1 Purpose	1
1.2 Scope	1
1.3 Basis for Requirements	1
1.4 Basis for Certification	2
1.5 Basis for Continued Certification	2
1.6 Effective Date	2
1.7 System of Units	2
1.8 Normative References	2
1.9 Terms and Definitions	3
2. GENERAL INFORMATION	6
2.1 Product Information	6
2.2 Application Requirements	6
2.3 Requirements for Samples for Examination	6
3. GENERAL REQUIREMENTS	2
3.1 Review of Documentation	2
3.2 Physical or Structural Features	2
3.2.1 Pump	2
3.2.2 Pump Casing	2
3.2.3 Water Passages	2
3.2.4 Impeller	2
3.2.5 Shaft	2
3.2.6 Shaft Seals	3
3.2.7 Bearings	5
3.2.8 Coupling	6
3.2.9 Circulation Relief Valve	6
3.2.10 Electric Motor	6
3.2.11 Miscellaneous Components	6
3.3 Pump Package	7
3.4 Materials	7
3.5 Markings	7
3.6 Manufacturer's Installation and Operation Instructions	8
3.7 Calibration	8
3.8 Tolerances	8
4. PERFORMANCE REQUIREMENTS	9
4.1 Design and Calculation Review	9
4.2 Performance	9
4.3 Suction Lift	9
4.4 Flange and Gasket Tightness	10
4.5 Hydrostatic Strength	10
4.6 One Hour Test (Mechanical Seal Pumps Only)	10
4.7 Test Procedure	11
4.8 Additional Tests	11
5. OPERATIONS REQUIREMENTS	12
5.1 Demonstrated Quality Control Program	12
5.2 Surveillance Audit	12
5.3 Manufacturer's Responsibilities	13
5.4 Manufacturing and Production Tests	13
APPENDIX A:	1
Appendix A is left intentionally blank	1

Appendix B is intentionally blank	1
APPENDIX C: Test Procedures	24
C.1 Capacity Measurements	24
C.2 Head Measurements	26
C.3 Power Measurements	26
C.4 Speed Measurement	27
C.5 Time Measurement	27
APPENDIX D: Fire Pump Unit (Packages)	28
APPENDIX E: Tolerance	29
APPENDIX F: Figures	30
Figure F-1, End Suction Centrifugal Fire Pump, Overhung Impeller, Single Stage	30

1. INTRODUCTION

1.1 Purpose

- 1.1.1 This standard states testing and certification requirements for horizontal, end suction type, centrifugal fire pumps that supply water to fire protection systems. These pumps must be available for many years to operate reliably at rated capacities and pressures during emergency fire incidents, despite being idle for extended periods.
- 1.1.2 Testing and certification criteria may include, but are not limited to, performance requirements, marking requirements, examination of manufacturing facility(ies), audit of quality assurance procedures, and a surveillance audit program.

1.2 Scope

- 1.2.1 This standard encompasses the design and performance requirements for horizontal, end suction type, centrifugal fire pumps for use in fire protection systems. Certification is limited to horizontal, end suction type, centrifugal pumps which have a rated pressure of at least 40 psi (275 kPa). In cases where metric sized horizontal, end suction type, centrifugal fire pumps are to be examined for certification, test criteria comparable to the United States equivalent size shall be used. This standard encompasses the requirements for single and multistage end suction fire pumps.
- 1.2.2 Requirements for other types of centrifugal fire pumps are detailed in the following standards:

<i>Class</i>	<i>Centrifugal Fire Pump Type</i>
1310	Multi Stage, Multi Outlet
1311	Split-Case Type, (Axial or Radial)
1312	Vertical Shaft Turbine Type
1370	Vertical Turbine Barrel Type
1371	In-Line Type

- 1.2.3 Requirements for other major components in the pump package are detailed in the following standards:

<i>Class</i>	<i>Equipment</i>
1046	Fire Pump Flowmeter Systems
1321/1323	Controllers for Electric Motor Driven and Diesel Engine Driven Fire Pumps
1333	Diesel Engine Fire Pump Drivers
1336	Fire Pump Couplings and Flexible Connecting Shafts for Fire Protection Service
1359	Trim Water Pressure Relief Valves
2311	Pressure Gauges for Fire Protection Systems

1.3 Basis for Requirements

- 1.3.1 The requirements of this standard are based on experience, research and testing, and/or the standards of other organizations. The advice of manufacturers, users, trade associations, jurisdictions and/or loss control specialists was also considered.
- 1.3.2 The requirements of this standard reflect tests and practices used to examine characteristics of horizontal, end suction type, centrifugal fire pumps for the purpose of obtaining certification. Horizontal, end suction type, centrifugal fire pumps having characteristics not anticipated by this standard may be certified if performance equal, or superior, to that required by this standard is demonstrated.

1.4 Basis for Certification

Certification is based upon satisfactory evaluation of the product and the manufacturer in the following major areas:

1.4.1 Examination and tests on production samples shall be performed to evaluate

- The suitability of the product;
- The performance of the product as specified by the manufacturer and required for certification; and as far as practical,
- The durability and reliability of the product.

1.4.2 An examination of the manufacturing facilities and audit of quality control procedures shall be made to evaluate the manufacturer's ability to consistently produce the product which was examined and tested, and the marking procedures used to identify the product. Subsequent surveillance may be required by the certification agency in accordance with the certification scheme to ensure ongoing compliance.

1.5 Basis for Continued Certification

1.5.1 Continued certification is based upon:

- Production or availability of the product as currently certified;
- The continued use of acceptable quality assurance procedures;
- Satisfactory field experience;
- Compliance with the terms stipulated in the certification;
- Satisfactory re-examination of production samples for continued conformity to requirements; and
- Satisfactory surveillance audits conducted as part of the certification agency's product surveillance program.

1.6 Effective Date

The effective date of this examination standard mandates that all products tested for certification after the effective date shall satisfy the requirements of this standard.

The effective date of this standard is eighteen (18) months after the publication date of the standard for full compliance with all requirements.

1.7 System of Units

Units of measurement used in this Standard are United States (U.S.) customary units. These are followed by their arithmetic equivalents in International System (SI) units, enclosed in parentheses. The first value stated shall be regarded as the requirement. The converted equivalent value may be approximate. Conversion of U.S. customary units is in accordance with the American National Standards Institute (ANSI)/Institute of Electrical and Electronics Engineers (IEEE)/American Society for Testing Materials (ASTM) SI 10.

Two units of measurement (liter and bar), outside of but recognized by SI, are commonly used in international fire protection and are used in this standard.

1.8 Normative References

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the cited edition applies.

ANSI/IEEE/ASTM SI 10, *American National Standard for Metric Practice*
API Standard 682, *Pumps - Shaft Sealing Systems for Centrifugal and Rotary Pumps*
IEC 60034-1, *Rotating electrical machines - Part 1: Rating and Performance*

NEMA MG 1, *Motors and Generators***1.9 Terms and Definitions**

For purposes of this standard, the following terms apply:

Accepted

Installations acceptable to the authority having jurisdiction and enforcing the applicable installation rules. Acceptance is not a characteristic of a product. It is installation specific. A product accepted for one installation may not be acceptable elsewhere.

Corrosion Resistant

Having resistance to corrosion equal to or exceeding that of bronze alloy having a minimum copper content of 80 percent, or constructed of Series 300 Stainless Steel.

Design Working Pressure

The maximum pressure for which a pump component is designed. This pressure is equal to or greater than the maximum pressure developed by the pump at shut off or churn conditions with the largest impeller available, plus the maximum suction pressure for the pump.

Dynamic Shaft Deflection

Dynamic condition where the axial centerline of the shaft does not coincide with the axial centerline of the bearings.

Efficiency

The ratio of the energy delivered by the pump to the energy supplied to the pump shaft (liquid power divided by applied power).

Enclosed Impeller

An impeller in which the pumped liquid is confined by the sidewalls (shrouds) and vanes of the impeller.

End Suction Pump

Pump having its suction nozzle on the opposite side of the casing from the stuffing box and having the face of the suction nozzle perpendicular to the longitudinal axis of the shaft.

Fire Pump Alternate Manufacturing Location

A location that manufactures a complete pump to the design requirements of the Fire Pump Manufacturer (OEM) or modifies (i.e. trimming of a pump impeller) an OEM supplied (bare-shafted) fire pump.

The Fire Pump Alternate Manufacturing Location may be an alternate facility owned and operated by the OEM or a facility owned by others that performs the complete, or partial, manufacturing of the complete fire pump and/or package under direct control of the OEM.

Fire Pump Manufacturer

The manufacturer of the certified fire pump, is also referred to as the Original Equipment Manufacturer (OEM) of the fire pump.

Fire Pump Package

An assembled fire pump, driver, controller and components, see Appendix D, necessary to provide a complete pump installation.

Fire Pump Packager

The Fire Pump Manufacturer can delegate, through a legal agreement, the function of assembling the fire pump package to a third party known as the fire pump packager. Alternatively, or in addition to, a Fire Pump Packager may package or just distribute complete private labeled fire pump packages.

The Fire Pump Packager may be a facility owned and operated by the Fire Pump Manufacturer or a facility owned by others that performs the assembly of the complete fire pump package under direct control of the OEM.

Fire Pump Private Labeler

A company, other than the Fire Pump Manufacturer (OEM), that has a legal agreement with the OEM whereby the pump is manufactured and labeled by the OEM in the name of the Private Labeler.

In order to enter into a Fire Pump Private Label agreement, a Fire Pump Private Labeler must be one of the following entities:

- Fire Pump Manufacturer
- Fire Pump Alternate Manufacturer
- Fire Pump Packager

Maximum Power

The greatest speed-corrected power required to drive the pump at rated speed and at any point along its characteristic curve, and through the pumps total run out condition. This is determined under conditions of increasing positive suction head.

Mechanical Seals

A sealing device which forms a running seal between the rotating and stationary components. They may be used in place of compression (soft) packing. All mechanical seals are constructed of three basic sets of parts:

- A set of primary seal faces: one rotary and one stationary
- A set of secondary seals known as shaft packings and insert mountings such as O-rings, wedges and V-rings
- Mechanical seal hardware including gland rings, collars, compression rings, pins, springs and bellows

The primary seal is achieved by two very flat, lapped faces perpendicular to the shaft. The rubbing contact between these two flat mating surfaces minimizes leakage. One face is held stationary in a housing and the other face is fixed to, and rotates with, the shaft. Dissimilar materials are usually used for the stationary insert and the rotating seal ring face in order to prevent adhesion of the two faces.

Cartridge Seal Type

This type of mechanical seal is a completely self-contained unit (including stationary and rotating seal faces, gland sleeve, mating ring, etc.) which is pre-assembled and preset before installation by the mechanical seal manufacturer.

Component Type

This type of mechanical seal is assembled from the individual components directly onto the shaft. The components usually consist of a rotating unit with a mating face which is in contact with a stationary unit. The rotating unit seals in two places, at the interface between the rotating face and stationary and between the shaft and the seal body. The stationary unit seals against the pump body.

Split Seal Type

This type of mechanical seal has its primary sealing elements and other components split parallel to the axis of the pump shaft. The seal can be mounted on a pump with out removing the impeller.

Multiple Stage Pumps

Horizontal end suction, centrifugal fire pumps with more than one impeller on the same shaft. The number of stages is determined by the number of impellers.

Rated Capacity

Capacity in gallons per minute - gal/min (liter/min - L/min), at rated pressure and speed.

Rated Pressure

Pressure in pounds per square inch - psi (kilopascals - kPa) developed by the pump when operating at rated capacity and speed.

Shaft Runout

Static condition where the axial centerline of the shaft does not coincide with the axial centerline of the bearings.

Shutoff or Churn Pressure

The net pressure in psi (kPa) developed by the pump at rated speed with zero flow.

Single Stage Pump

A pump in which the total head is developed by one impeller.

Stuffing Box Packing

Typically, an arrangement consisting of rings of packing, a lantern ring for the injection of a lubricating and/or flushing liquid, and a gland to hold the packing and maintain the desired compression for a proper seal. The function of packing is to control leakage; it is not intended to eliminate it completely. The packing is lubricated by the pumped liquid. The lantern ring is supplied for situations where the stuffing box pressure is below atmospheric pressure, to inject lubrication into the stuffing box by the use of a bypass line from the pump discharge to the lantern ring connection.

Stuffing Box Runout

Static condition where the axial centerline of the shaft is not perpendicular to the face of the stuffing box.

Total Discharge Head

The gauge reading in psi (kPa) at the discharge flange of the pump, referred to the pump centerline, plus the velocity head at the point of gauge attachment.

Total Suction Head

The condition when the suction pressure is above atmospheric. The total suction head is the algebraic sum of the gauge reading in psi (kPa) at the pump suction flange, referred to the pump centerline, and the velocity head at the point of gauge attachment. Also called "positive suction pressure."

Total Suction Lift

The condition when suction pressure is below atmospheric. The total suction lift is the algebraic sum of the gauge reading in psi (kPa) at the suction flange of the pump, referred to the pump centerline, and the velocity head at the point of gauge attachment.

Total Head

The algebraic difference between the total discharge head and the total suction head. Where suction head exists, total head equals total discharge head minus total suction head. Where suction lift exists, total head equals total discharge head plus total suction lift.