



Member of the FM Global Group

Approval Standard for Telescoping Sprinkler Assemblies for Use in Fire Protection Systems for Anechoic Chambers

Class Number 1632

April 2003

©2003 FM Approvals LLC. All rights reserved.

Foreword

The FM Approvals certification mark is intended to verify that the products and services described will meet FM Approvals' stated conditions of performance, safety and quality useful to the ends of property conservation. The purpose of Approval Standards is to present the criteria for FM Approval of various types of products and services, as guidance for FM Approvals personnel, manufacturers, users and authorities having jurisdiction.

Products submitted for certification by FM Approvals shall demonstrate that they meet the intent of the Approval Standard, and that quality control in manufacturing shall ensure a consistently uniform and reliable product. Approval Standards strive to be performance-oriented. They are intended to facilitate technological development.

For examining equipment, materials and services, Approval Standards:

- a) must be useful to the ends of property conservation by preventing, limiting or not causing damage under the conditions stated by the Approval listing; and
- b) must be readily identifiable.

Continuance of Approval and listing depends on compliance with the Approval Agreement, satisfactory performance in the field, on successful re-examinations of equipment, materials, and services as appropriate, and on periodic follow-up audits of the manufacturing facility.

FM Approvals LLC reserves the right in its sole judgment to change or revise its standards, criteria, methods, or procedures.

TABLE OF CONTENTS

1. INTRODUCTION	1
1.1 Purpose	1
1.2 Scope	1
1.3 Basis for Requirements	1
1.4 Basis for FM Approval	1
1.5 Basis for Continued Approval	2
1.6 Effective Date	2
1.7 System of Units	2
1.8 Applicable Documents	2
1.9 Definitions	3
2. GENERAL INFORMATION	4
2.1 Product Information	4
2.2 Approval Application Requirements	4
2.3 Requirements for Samples for Examination	5
3. GENERAL REQUIREMENTS	5
3.1 Review of Documentation	5
3.2 Physical or Structural Features	5
3.3 Materials	6
3.4 Markings	6
3.5 Manufacturer's Installation and Operation Instructions	6
3.6 Calibration	6
4. PERFORMANCE REQUIREMENTS	7
4.1 Examination	7
4.2 Friction Loss (Equivalent Length of Pipe)	7
4.3 Minimum Operating Pressure	8
4.4 Leakage	8
4.5 Hydrostatic	8
4.6 High Pressure Operating (Strength)	8
4.7 Humidity	9
4.8 Exposure To Maximum Installation Temperature	9
4.9 Friction Fit (Vertical Position Only)	9
4.10 Additional Tests	10
5. OPERATIONS REQUIREMENTS	10
5.1 Demonstrated Quality Control Program	10
5.2 Facilities and Procedures Audit (F&PA)	11
5.3 Manufacturer's Responsibilities	11
5.4 Manufacturing and Production Tests	11
APPENDIX A: UNITS OF MEASUREMENT	12
APPENDIX B: APPROVAL MARKS:	13
APPENDIX C: DRAWINGS	14

1. INTRODUCTION

1.1 Purpose

- 1.1.1 This standard states FM Approvals criteria for telescoping sprinkler assemblies for use in fire protection systems for anechoic chambers.
- 1.1.2 FM Approval criteria may include, but are not limited to, performance requirements, marking requirements, examination of manufacturing facility(ies), audit of quality assurance procedures, and a follow-up program.

1.2 Scope

- 1.2.1 This standard encompasses the design and performance requirements for telescoping sprinkler assemblies for use in fire protection systems for anechoic chambers. In cases where metric sized telescoping sprinkler assemblies are to be examined for Approval, test criteria comparable to the equivalent nominal inch size shall be used.
- 1.2.2 Other types of telescoping sprinkler assemblies for use in fire protection systems for anechoic chambers may be Approved if they meet the requirements and intent of this standard. Telescoping sprinkler assemblies of unusual design may be subjected to special tests to determine their suitability.
- 1.2.3 FM Approval Standards are intended to verify that the product described will meet stated conditions of performance, safety and quality useful to the ends of property conservation.

1.3 Basis for Requirements

- 1.3.1 The requirements of this standard are based on experience, research and testing, and/or the standards of other organizations. The advice of manufacturers, users, trade associations, jurisdictions and/or loss control specialists was also considered.
- 1.3.2 The requirements of this standard reflect tests and practices used to examine characteristics of telescoping sprinkler assemblies for the purpose of obtaining FM Approval. Telescoping sprinkler assemblies having characteristics not anticipated by this standard may be Approved if performance equal, or superior to, that required by this standard is demonstrated or if the intent of the standard is met. Alternatively, telescoping sprinkler assemblies which meet all of the requirements identified in this standard may not be Approved if other conditions which adversely affect performance exist or if the intent of this standard is not met.

1.4 Basis for FM Approval

FM Approval is based upon satisfactory evaluation of the product and the manufacturer in the following major areas:

- 1.4.1 Examination and tests on production samples shall be performed to evaluate:
 - the suitability of the product
 - the performance of the product as specified by the manufacturer and required by FM Approvals; and, as far as practical,
 - the durability and reliability of the product.

1.4.2 An examination of the manufacturing facilities and audit of quality control procedures shall be made to evaluate the manufacturer's ability to consistently produce the product which was examined and tested, and the marking procedures used to identify the product. These examinations are repeated as part of FM Approvals product follow-up program.

1.5 Basis for Continued Approval

Continued Approval is based upon:

- production or availability of the product as currently Approved;
- the continued use of acceptable quality assurance procedures;
- satisfactory field experience;
- compliance with the terms stipulated in the Approval Agreement;
- satisfactory re-examination of production samples for continued conformity to requirements; and
- satisfactory Facilities and Procedures Audits (F&PAs) conducted as part of FM Approvals product follow-up program.

Also, as a condition of retaining Approval, manufacturers may not change a product or service without prior authorization by FM Approvals.

1.6 Effective Date

The effective date of an Approval Standard mandates that all products tested for Approval after the effective date shall satisfy the requirements of that standard. Products Approved under a previous edition shall comply with the new version by the effective date or forfeit Approval.

The effective date of this standard is **June 1, 2003** for compliance with all requirements.

1.7 System of Units

Units of measurement used in this standard are United States (U.S.) customary units. These are followed by their arithmetic equivalents in International System (SI) units, enclosed in parentheses. The first value stated shall be regarded as the requirement. The converted equivalent value may be approximate. Appendix A lists the selected units and conversions to SI units for measures appearing in this standard. Conversion of U.S. customary units is in accordance with the American National Standards Institute (ANSI)/Institute of Electrical and Electronics Engineers (IEEE)/American Society for Testing Materials (ASTM) SI 10-97, "*Standard for Use of the International System of Units (SI): The Modern Metric System.*"

1.8 Applicable Documents

The following standards, test methods, and practices are referenced in this standard:

ANSI/IEEE/ASTM SI 10-97, Standard for Use of the International System of Units (SI):
The Modern Metric System.

FM Global Property Loss Prevention Data Sheets.

1.9 Definitions

For purposes of this standard, the following terms apply:

Accepted

This term refers to installations acceptable to the authority enforcing the applicable installation rules. When the authority is the FM Global, such locations are termed “FM Global Accepted.” Acceptance is based upon an overall evaluation of the installation. Factors other than the use of Approved equipment impact upon the decision to accept, or not to accept, the product. Acceptance is not a characteristic of a product. It is installation and site specific. A product accepted for one installation may not be acceptable elsewhere. (Contrast with Approved.)

Approval Mark

The FM Approval Mark is detailed in Appendix B. Its use is mandatory on all units of Approved telescoping sprinkler assemblies. These registered marks cannot be used except as authorized by FM Approvals via the granting of Approval to a specific product.

Approved

This term refers to products Approved by FM Approvals. Such products are listed in the Approval Guide, a publication of FM Approvals, issued annually, or one of the supplements. All products so listed have been successfully examined by FM Approvals and their manufacturers have signed and returned a Master Agreement or an Approval Agreement (Form L-15) to FM Approvals. This form obligates the manufacturer to allow re-examination of the product and audit of facilities and procedures at FM Approvals discretion. It further requires the manufacturer not to deviate from the as-Approved configuration of the product without review by and agreement of FM Approvals. Approval is product specific.

Anechoic Chambers

Enclosures designed to provide test regions that simulate free space for a variety of measurements including antenna pattern, radar backscatter tests, soundproof measurements, etc. The chambers may also be shielded to provide RF isolation from undesirable external signals as well as to prevent internally generated RF energy from radiating outside the enclosure.

Assembly

A complete unit which can be installed in an anechoic chamber fire protection system and has the ability to extend an appropriate distance into the chamber. These devices have the following: an inlet mounting assembly for attachment to the sprinkler system; an outer tube and an inner tube which gives the assembly “stroke”; and an upright sprinkler at the outlet end of the device.

Corrosion Resistant

Having resistance to corrosion equal to or exceeding that of bronze alloy having a minimum copper content of 80 percent, or constructed of Series 300 Stainless Steel.

End Connections

The method of connecting components of a pipe system to the telescoping sprinkler assemblies.

Extension

See Stroke

Operating Pressure

The pressure required to move the piston tube from the fully retracted to the fully extended position in the intended installation position.