



Member of the FM Global Group

Examination Standard for Flow and Pressure Safety Switches

Class Number 3510

May 2021

Foreword

This standard is intended to verify that the products and services described will meet stated conditions of performance, safety and quality useful to the ends of property conservation. The purpose of this standard is to present the criteria for examination of various types of products and services.

Examination in accordance with this standard shall demonstrate compliance and verify that quality control in manufacturing shall ensure a consistent and reliable product.

TABLE OF CONTENTS

1. INTRODUCTION	1
1.1 Purpose.....	1
1.2 Scope.....	1
1.3 Basis for Requirements.....	1
1.4 Basis for Certification	1
1.5 Basis for Continued Certification	2
1.6 Effective Date.....	2
1.7 System of Units.....	2
1.8 Normative References	2
1.9 Terms Definitions.....	2
2. GENERAL INFORMATION.....	3
2.1 Product Information.....	3
2.2 Certification Application Requirements	3
2.3 Requirements for Samples for Examination (as appropriate).....	3
3. GENERAL REQUIREMENTS.....	4
3.1 Review of Documentation	4
3.2 Physical or Structural Features.....	4
3.3 Markings	4
3.4 Manufacturer's Installation and Operation Instructions	5
3.5 Calibration.....	5
4. PERFORMANCE REQUIREMENTS.....	6
4.1 Operating Characteristics.....	6
4.2 Actuation Point Accuracy and Repeatability.....	6
4.3 Ambient Temperature Effects.....	6
4.4 Pressure Capability.....	6
4.5 Endurance.....	7
4.6 Dielectric Strength	7
5. OPERATIONS REQUIREMENTS.....	8
5.1 Demonstrated Quality Control Program	8
5.2 Surveillance Audit	9
5.3 Manufacturer's Responsibilities.....	9
5.4 Manufacturing and Production Tests	Error! Bookmark not defined.
BIBLIOGRAPHY	9

1. INTRODUCTION

1.1 Purpose

- 1.1.1 This standard states testing and certification requirements for flow and pressure safety switches. These switches include, but are not limited to, those used as airflow interlock, pressure limit, or pressure supervisory devices for combustion air, fuel gas, fuel oil, and ventilation air.
- 1.1.2 Testing and certification criteria may include, but are not limited to, performance requirements, marking requirements, examination of manufacturing facility(ies), audit of quality assurance procedures, and a surveillance program.

1.2 Scope

- 1.2.1 This standard sets performance requirements for switches used as safety devices in combustion, process, and ventilation control systems. They are intended to operate electrical switching devices in order to prevent unsafe startup, initiate a safety shutdown, or initiate an alarm under abnormal conditions.
- 1.2.2 The requirements of this standard shall be used to measure and describe the performance of these switches in response to input signals, changes in ambient temperature, and hydrostatic pressure. Dielectric strength and durability are also assessed.

1.3 Basis for Requirements

- 1.3.1 The requirements of this standard are based on experience, research and testing, and/or the standards of other organizations. The advice of manufacturers, users, trade associations, and loss control specialists was also considered.
- 1.3.2 The requirements of this standard reflect tests and practices used to examine characteristics of safety switches for the purpose of obtaining certification. Safety switches having characteristics not anticipated by this standard may be certified if performance equal, or superior, to that required by this standard is demonstrated.

1.4 Basis for Certification

Certification is based upon satisfactory evaluation of the product and the manufacturer in the following major areas:

- 1.4.1 Examination and tests on production samples shall be performed to evaluate
 - the suitability of the product;
 - the performance of the product as specified by the manufacturer and required for certification; and as far as practical,
 - the durability and reliability of the product.
- 1.4.2 An examination of the manufacturing facilities and audit of quality control procedures may be made to evaluate the manufacturer's ability to consistently produce the product which is examined and tested, and the marking procedures used to identify the product. Subsequent surveillance may be required by the certification agency in accordance with the certification scheme to ensure ongoing compliance.