

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 0: Equipment – General requirements**

**Atmosphères explosives –
Partie 0: Matériel – Exigences générales**

Withdrawing



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 0: Equipment – General requirements**

**Atmosphères explosives –
Partie 0: Matériel – Exigences générales**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XD

ICS 29.260.20

ISBN 978-2-88912-519-7

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

INTERPRETATION SHEET 1

This interpretation sheet has been prepared by technical committee 31: Equipment for explosive atmospheres, of IEC.

The text of this interpretation sheet is based on the following documents.

ISH	Report on voting
31/1085/ISH	31/1095/RVD

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

Interpretation of Annex A

Questions:

Is the torque used for the tensile test of A.3.1.4 required to be the same torque as the initial torque determined in A.3.1.1?

At what point in the testing sequence is the thermal endurance to heat test conducted?

Interpretation:

In A.3.1.1, a torque is applied to either the screws of a flanged compression element or the nut of a screwed compression element to compress the sealing ring to secure the mandrel. A tensile force is then applied to the mandrel to confirm the securement. The tensile force is applied for not less than 6 h. The test is carried out at an ambient temperature of $(20 \pm 5) ^\circ\text{C}$. The torque value needed for clamping to be assured by the sealing ring is acceptable if the slippage of the mandrel or cable sample as a result of the tensile force is not more than 6 mm.

Subsequently, either the complete cable gland and mandrel assembly used for the determination described above, or a new sample prepared using the same torque values, is then to be subjected to the thermal endurance tests. The maximum service temperature is considered to be $75 ^\circ\text{C}$ unless otherwise specified by the manufacturer.

NOTE 1 The $75 ^\circ\text{C}$ service temperature is the median of the branching point and entry point temperatures.

NOTE 2 Cable glands employing only metallic sealing rings and metallic parts do not require thermal endurance tests.

The subsequent test conditions and acceptance criteria are given in A.3.1.4. Prior to the application of the tensile force, the gland may be re-tightened in accordance with the manufacturer's instructions.

NOTE The torque applied to the screws or nut during retightening is not required to be the same as the initial torque applied in A.3.1.1.

In A.3.1.5, the “value needed to prevent slipping” is the torque required for A.3.1.4.

It is intended that this interpretation will be introduced in IEC 60079-0 Edition 7 and therefore an Interpretation Sheet will not be required for this or future editions.

Withdrawn

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

INTERPRETATION SHEET 2

This interpretation sheet has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

The text of this interpretation sheet is based on the following documents:

ISH	Report on voting
31/1132/ISH	31/1153/RVISH

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

Following decision No 16 of the TC 31 meeting in Melbourne in 2011, the issuing of an Interpretation Sheet for IEC 60079-0:2011 (6th edition) was requested, in order to clarify the significance of the changes with respect to the 5th edition.

Question

What are the minor editorial, extensions, and major technical changes of the 6th edition with respect to the 5th edition?

Answer

The following table shows the significance of the changes.

The significance of the changes between IEC Standard, IEC 60079-0, Edition 5, 2007-10 (Including Corrigendum No.1 and Interpretation Sheet I-SH 01) and IEC 60079-0, Edition 6, 2011-06 are as listed below:

Explanation of the significance of the changes	Clause	Type		
		Minor and editorial changes	Extension	Major technical changes
Expansion of material specification data for plastics and elastomers, including UV resistance	7.1.2		x	
Addition of alternative qualification for O-rings	7.2.3		x	
Addition of alternative criteria for surface resistance	7.4.2 a)		x	
Addition of alternative breakdown voltage limit for non-metallic layers applied to metallic enclosures	7.4.2 c)		x	
Expansion of "X" marking options for non-metallic enclosure materials not meeting basic electrostatic requirements	7.4.2 d) 7.4.2 e)		x	
Clarification that non-metallic enclosure requirements also apply to painted or coated metal enclosures	7.4.3		x	
Clarification of test to determine capacitance of accessible metal parts with reduction in acceptable capacitance	7.5 Table 9			C1
Addition of limits on zirconium content for Group III and Group II (Gb only) enclosures	8.3 8.4		x	
Introduction of "X" marking for Group III enclosures not complying with basic material requirements, similar to that existing for Group II	8.4	x		
Addition of button-head cap screws to permitted "Special Fasteners"	9.2		x	
Reference for protective earthing (PE) requirements for electrical machines to IEC 60034-1	15.3	x		
Addition of requirements for ventilating fans	17.1.5			C2
Addition of requirement for temperature rating of bearing lubricants	17.2	x		
Addition of alternative construction for disconnectors	18.2		x	
Removal of voltage limits on plugs and sockets	20.2		x	
Addition of test requirements for arc-quenching test on plugs and sockets	20.2			C3
Additional information on cell voltages	23.3 Table 12			C4
Revision to impact test of glass parts	26.4.2	x		
Revision to impact test procedure to address "bounce" of impact head	26.4.2		x	
Clarification of the test requirements for "service" and "surface" temperature	26.5.1.2 26.5.1.3	x		
Clarification of temperature rise tests for converter-fed motors	26.5.1.3		x	
Addition of alternative test method for thermal endurance	26.8 Table 15		x	
Removal of "charging test" and addition of note providing guidance	Formerly 26.14			C5
Clarification of test for the measurement of capacitance, revision of maximum capacitance	26.14			C6
Addition of tests for ventilating fans	26.15			C2
Addition of alternative o-ring testing	26.16		x	
Addition of a "Schedule of Limitations" to	28.2	x		

		Type		
Explanation of the significance of the changes	Clause	Minor and editorial changes	Extension	Major technical changes
certificates for Ex Components				
Clarification of the marking for multiple temperature classes	29.4 d) 29.5 d)	x		
Addition of marking for converter-fed motors	29.15		x	
Removal of IP marking for Group III	29.5	x		
Addition of specific instructions for electrical machines and for ventilating fans	30.3 30.4		x	

NOTE The technical changes referred to include the significance of technical changes in the revised IEC Standard, but they do not form an exhaustive list of all modifications from the previous version. More guidance may be found by referring to the Redline Version of the standard.

Explanation of the Types of Changes:

A) Definitions

1. Minor and editorial changes:

- Clarification
- Decrease of technical requirements
- Minor technical change
- Editorial corrections

These are changes which modify requirements in an editorial or a minor technical way. They include changes of the wording to clarify technical requirements without any technical change, or a reduction in level of existing requirement.

2. Extension:

Addition of technical options

These are changes which add new or modify existing technical requirements, in a way that new options are given, but without increasing requirements for equipment that was fully compliant with the previous standard. Therefore, these will not have to be considered for products in conformity with the preceding edition.

3. Major technical changes:

- addition of technical requirements
- increase of technical requirements

These are changes to technical requirements (addition, increase of the level or removal) made in a way that a product in conformity with the preceding edition will not always be able to fulfil the requirements given in the later edition. These changes have to be considered for products in conformity with the preceding edition. For these changes additional information is provided in clause B) below.

NOTE These changes represent current technological knowledge. However, these changes should not normally have an influence on equipment already placed on the market.

B) Information about the background of 'Major technical changes'

C1 – The values in the table have been significantly reduced based on information that is intended to be published in IEC TS 60079-32-1 (currently in preparation).

C2 – The requirements for fans was added at the request of the IECEx International Product Certification Scheme.

C3 – The test has been introduced for all disconnectors as an alternative to the voltage and current restrictions in the previous standard which were considered to be arbitrary.

C4 – There has been a slight increase in some cell voltages. This is a minor change for most protection concepts but should be regarded as a major change for equipment having a type of protection relying on energy limitation, e.g. IEC 60079-11

C5 – The charging test was removed as it had been found to be not repeatable. Guidance will be given in IEC TS 60079-32-1 (currently in preparation).

C6 – The limits for capacitance have been decreased based on technical information in CLC/TR 50404.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC 60079-0
Edition 6.0 2011-06

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

INTERPRETATION SHEET 3

This interpretation sheet has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

The text of this interpretation sheet is based on the following documents:

FDIS	Report on voting
31/1376/FDIS	31/1386/RVD

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

Question:

How shall marking be shown for equipment covered by both the electrical and non-electrical standards (IEC 60079 and ISO 80079 series)?

Answer:

Equipment which includes both an electrical part and a non-electrical part shall have combined marking. For example:

Ex db h IIA T4 Gb

Ex h tb IIIC T135 °C Db

It will be clearer for the user that the combined risk of the electrical part and the non-electrical part, covered by a single certificate, has been assessed for the complete equipment, stating one EPL, one equipment Group and one temperature class for Gas and the same for Dust (but showing a maximum surface temperature instead of a temperature class). It is also noted that Ex Components are not marked with either a temperature class (Group II) or a maximum surface temperature (Group III).

For equipment where separate certificates have been prepared, with one for the electrical parts, and one for the non-electrical parts, it is appropriate to have separate electrical and non-electrical marking strings, each with its own associated certificate number.

NOTE Additional guidance on the marking of assemblies is given in IEC TS 60079-46.

Withdrawn

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC 60079-0 Edition 6.0 2011-06

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

INTERPRETATION SHEET 4

This interpretation sheet has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

The text of this interpretation sheet is based on the following documents:

DISH	Report on voting
31/1454/DISH	31/1465/RVDISH

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

Interpretation sheet of Subclause 16.6 of IEC 60079-0:2011

The TC 31/CAG requested (Resolution 2 of 2018-04-19) that WG 22 prepare an interpretation sheet based on IECEx Decision Sheet DS2018/002 addressing the assignment of entry point and branching point temperatures of electrical rotating machines.

This interpretation is made available for Edition 6 of this standard due to the current use of that standard by manufacturers, conformity assessment schemes and national bodies by means of this “Interpretation Sheet” as follows:

Details of interpretation:

IEC 60079-0:2011 (Ed. 6), *Explosive atmospheres – Part 0: Equipment – General requirements*

Interpretation of Subclause 16.6, Temperature at branching point and entry point:

Question: Subclause 16.6 of IEC 60079-0:2011 (Ed. 6) states “When the temperature under rated conditions is higher than 70 °C at the entry point or 80 °C at the branching point of the conductors, information shall be marked on the equipment exterior to provide guidance to the user on the proper selection of cable and cable gland or conductors in conduit.”

It is not normal practice for electrical rotating machines to be tested with the cable entry devices and cables that might be used in an actual installation, but with the cables available at the manufacturer’s test area. In many cases, there will be no formal entry device as the cables will enter via the space reserved for fixing of a gland plate.

How shall the relevant entry point and branching point temperatures be determined?

Interpretation: *The use of the maximum internal air space temperature to represent the maximum service temperature of terminal box gaskets and seals, the cable branching point temperature, and the entry point temperature reflects the normal practice of testing electrical rotating machines without prior knowledge of the actual glands and cables to be used for installation. The production of heat from the electrical rotating machine connections is generally insignificant with respect to the production of heat from the machine windings and core.*

Further amplification:

- 1) The entry point of the cable where the temperature is measured should be sealed so far as possible to ensure that there is minimum air-circulation which can reduce the measured temperature.
- 2) This is not intended to apply to any gasket between the terminal box and the frame of the electrical rotating machine, where higher temperatures may be recorded, but only to the gasket between the terminal box and its lid.

Although written in the context of electrical rotating machines, there may be other types of equipment where an equivalent approach is applicable.

Withdrawn

CONTENTS

FOREWORD.....	7
1 Scope.....	10
2 Normative references	11
3 Terms and definitions	14
4 Equipment grouping	26
4.1 Group I.....	26
4.2 Group II.....	26
4.3 Group III.....	26
4.4 Equipment for a particular explosive atmosphere.....	27
5 Temperatures.....	27
5.1 Environmental influences	27
5.1.1 Ambient temperature	27
5.1.2 External source of heating or cooling.....	27
5.2 Service temperature	27
5.3 Maximum surface temperature	28
5.3.1 Determination of maximum surface temperature.....	28
5.3.2 Limitation of maximum surface temperature.....	28
5.3.3 Small component temperature for Group I or Group II electrical equipment	29
6 Requirements for all electrical equipment.....	30
6.1 General.....	30
6.2 Mechanical strength of equipment.....	30
6.3 Opening times.....	30
6.4 Circulating currents in enclosures (e.g. of large electrical machines).....	31
6.5 Gasket retention.....	31
6.6 Electromagnetic and ultrasonic energy radiating equipment	31
6.6.1 Radio frequency sources	31
6.6.2 Lasers or other continuous wave sources	32
6.6.3 Ultrasonic sources	33
7 Non-metallic enclosures and non-metallic parts of enclosures	33
7.1 General.....	33
7.1.1 Applicability.....	33
7.1.2 Specification of materials.....	33
7.2 Thermal endurance	34
7.2.1 Tests for thermal endurance	34
7.2.2 Material selection	34
7.2.3 Alternative qualification of elastomeric sealing O-rings	34
7.3 Resistance to light.....	34
7.4 Electrostatic charges on external non-metallic materials.....	35
7.4.1 Applicability.....	35
7.4.2 Avoidance of a build-up of electrostatic charge on Group I or Group II electrical equipment	35
7.4.3 Avoidance of a build-up of electrostatic charge on equipment for Group III.....	37
7.5 Accessible metal parts	37
8 Metallic enclosures and metallic parts of enclosures.....	38

8.1	Material composition	38
8.2	Group I.....	38
8.3	Group II.....	38
8.4	Group III.....	39
9	Fasteners	39
9.1	General	39
9.2	Special fasteners.....	39
9.3	Holes for special fasteners	40
9.3.1	Thread engagement	40
9.3.2	Tolerance and clearance	40
9.3.3	Hexagon socket set screws	41
10	Interlocking devices.....	41
11	Bushings	41
12	Materials used for cementing.....	41
13	Ex Components	42
13.1	General	42
13.2	Mounting	42
13.3	Internal mounting	42
13.4	External mounting	42
13.5	Ex Component certificate	42
14	Connection facilities and termination compartments	43
14.1	General	43
14.2	Termination compartment.....	43
14.3	Type of protection	43
14.4	Creepage and clearance	43
15	Connection facilities for earthing or bonding conductors	43
15.1	Equipment requiring earthing.....	43
15.1.1	Internal.....	43
15.1.2	External.....	43
15.2	Equipment not requiring earthing.....	43
15.3	Size of conductor connection.....	44
15.4	Protection against corrosion	44
15.5	Secureness of electrical connections.....	44
16	Entries into enclosures	44
16.1	General	44
16.2	Identification of entries	44
16.3	Cable glands	45
16.4	Blanking elements	45
16.5	Thread adapters	45
16.6	Temperature at branching point and entry point.....	45
16.7	Electrostatic charges of cable sheaths	46
17	Supplementary requirements for rotating machines	46
17.1	Ventilation	46
17.1.1	Ventilation openings	46
17.1.2	Materials for external fans	47
17.1.3	Cooling fans of rotating machines.....	47
17.1.4	Auxiliary motor cooling fans.....	47
17.1.5	Ventilating fans.....	47

17.2	Bearings.....	48
18	Supplementary requirements for switchgear	48
18.1	Flammable dielectric	48
18.2	Disconnectors	49
18.3	Group I – Provisions for locking.....	49
18.4	Doors and covers	49
19	Supplementary requirements for fuses	49
20	Supplementary requirements for plugs, socket outlets and connectors	50
20.1	General.....	50
20.2	Explosive gas atmospheres	50
20.3	Explosive dust atmospheres	50
20.4	Energized plugs	50
21	Supplementary requirements for luminaires	50
21.1	General.....	50
21.2	Covers for luminaires of EPL Mb, EPL Gb, or EPL Db	51
21.3	Covers for luminaires of EPL Gc or EPL Dc.....	51
21.4	Sodium lamps	51
22	Supplementary requirements for caplights and handlights	52
22.1	Group I caplights.....	52
22.2	Group II and Group III caplights and handlights	52
23	Equipment incorporating cells and batteries	52
23.1	General	52
23.2	Batteries.....	52
23.3	Cell types	52
23.4	Cells in a battery	54
23.5	Ratings of batteries	54
23.6	Interchangeability	54
23.7	Charging of primary batteries.....	54
23.8	Leakage.....	54
23.9	Connections	54
23.10	Orientation.....	54
23.11	Replacement of cells or batteries.....	54
23.12	Replaceable battery pack	55
24	Documentation	55
25	Compliance of prototype or sample with documents	55
26	Type tests	55
26.1	General.....	55
26.2	Test configuration.....	55
26.3	Tests in explosive test mixtures.....	55
26.4	Tests of enclosures	56
26.4.1	Order of tests	56
26.4.2	Resistance to impact	57
26.4.3	Drop test	59
26.4.4	Acceptance criteria.....	59
26.4.5	Degree of protection (IP) by enclosures.....	59
26.5	Thermal tests	60
26.5.1	Temperature measurement.....	60
26.5.2	Thermal shock test	61

26.5.3	Small component ignition test (Group I and Group II).....	62
26.6	Torque test for bushings.....	62
26.6.1	Test procedure.....	62
26.6.2	Acceptance criteria.....	63
26.7	Non-metallic enclosures or non-metallic parts of enclosures.....	63
26.7.1	General.....	63
26.7.2	Test temperatures.....	63
26.8	Thermal endurance to heat.....	63
26.9	Thermal endurance to cold.....	64
26.10	Resistance to light.....	64
26.10.1	Test procedure.....	64
26.10.2	Acceptance criteria.....	65
26.11	Resistance to chemical agents for Group I electrical equipment.....	65
26.12	Earth continuity.....	65
26.13	Surface resistance test of parts of enclosures of non-metallic materials.....	67
26.14	Measurement of capacitance.....	68
26.14.1	General.....	68
26.14.2	Test procedure.....	68
26.15	Verification of ratings of ventilating fans.....	69
26.16	Alternative qualification of elastomeric sealing O-rings.....	69
27	Routine tests.....	69
28	Manufacturer's responsibility.....	70
28.1	Conformity with the documentation.....	70
28.2	Certificate.....	70
28.3	Responsibility for marking.....	70
29	Marking.....	70
29.1	Applicability.....	70
29.2	Location.....	70
29.3	General.....	70
29.4	Ex marking for explosive gas atmospheres.....	71
29.5	Ex marking for explosive dust atmospheres.....	73
29.6	Combined types (or levels) of protection.....	74
29.7	Multiple types of protection.....	74
29.8	Ga equipment using two independent Gb types (or levels) of protection.....	75
29.9	Ex Components.....	75
29.10	Small equipment and small Ex Components.....	75
29.11	Extremely small equipment and extremely small Ex Components.....	76
29.12	Warning markings.....	76
29.13	Alternate marking of equipment protection levels (EPLs).....	76
29.13.1	Alternate marking of type of protection for explosive gas atmospheres.....	77
29.13.2	Alternate marking of type of protection for explosive dust atmospheres.....	77
29.14	Cells and batteries.....	77
29.15	Converter-fed electrical machines.....	78
29.16	Examples of marking.....	78
30	Instructions.....	81
30.1	General.....	81
30.2	Cells and batteries.....	

30.3 Electrical machines	82
30.4 Ventilating fans	82
Annex A (normative) Supplementary requirements for cable glands	83
Annex B (normative) Requirements for Ex Components	90
Annex C (informative) Example of rig for resistance to impact test	92
Annex D (informative) Motors supplied by converters	93
Annex E (informative) Temperature rise testing of electric machines	94
Annex F (informative) Guideline flowchart for tests of non-metallic enclosures or non-metallic parts of enclosures (26.4)	96
Bibliography	97
Figure 1 – Tolerances and clearance for threaded fasteners	40
Figure 2 – Contact surface under head of fastener with a reduced shank	41
Figure 3 – Illustration of entry points and branching points	46
Figure 4 – Assembly of test sample for earth-continuity test	67
Figure 5 – Test piece with painted electrodes	68
Figure 6 – Compression set of an O-ring	69
Figure A.1 – Illustration of the terms used for cable glands	84
Figure A.2 – Rounded edge of the point of entry of the flexible cable	85
Figure C.1 – Example of rig for resistance to impact test	92
Figure F.1 – Non-metallic enclosures or non-metallic parts of enclosures	96
Table 1 – Ambient temperatures in service and additional marking	27
Table 2 – Classification of maximum surface temperatures for Group II electrical equipment	28
Table 3a – Assessment of temperature classification according to component size at 40 °C ambient temperature	29
Table 3b – Assessment of temperature classification Component surface area ≥ 20 mm ² Variation in maximum power dissipation with ambient temperature	29
Table 4 – Radio frequency power thresholds	32
Table 5 – Radio-frequency energy thresholds	32
Table 6 – Limitation of surface areas	36
Table 7 – Maximum diameter or width	36
Table 8 – Limitation of thickness of non-metallic layer	37
Table 9 – Maximum capacitance of unearthed metal parts	38
Table 10 – Minimum cross-sectional area of PE conductors	44
Table 11 – Primary cells	53
Table 12 – Secondary cells	53
Table 13 – Tests for resistance to impact	58
Table 14 – Torque to be applied to the stem of bushing used for connection facilities	63
Table 15 – Thermal endurance test	64
Table 16 – Text of warning markings	76
Table B.1 – Clauses with which Ex Components shall comply	90

INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –**Part 0: Equipment – General requirements****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-0 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This sixth edition cancels and replaces the fifth edition, published in 2007, and constitutes a full technical revision.

The significant changes with respect to the previous edition are listed below:

- Relocation of definitions for energy limitation parameters to IEC 60079-11
- Addition of note to clarify that the non-metallic “enclosure” requirements are applied to other than “enclosures” by some of the subparts
- Expansion of material specification data for plastics and elastomers, including UV resistance
- Addition of alternative qualification for O-rings
- Addition of alternative criteria for surface resistance

- Addition of breakdown voltage limit for non-metallic layers applied to metallic enclosures
- Expansion of “X” marking options for non-metallic enclosure materials not meeting basic electrostatic requirements
- Clarification that non-metallic enclosure requirements also apply to painted or coated metal enclosures
- Clarification of test to determine capacitance of accessible metal parts with reduction in acceptable capacitance
- Addition of limits on zirconium content for Group III and Group II (Gb only) enclosures
- Introduction of “X” marking for Group III enclosures not complying with basic material requirements, similar to that existing for Group II
- Addition of button-head cap screws to permitted “Special Fasteners”
- Reference for protective earthing (PE) requirements for electrical machines to IEC 60034-1
- Clarification of terminology for cable glands, blanking elements, and thread adapters
- Addition of requirements for ventilating fans
- Addition of alternative construction for disconnectors
- Removal of voltage limits on plugs and sockets
- Addition of test requirements for arc-quenching test on plugs and sockets
- Update of cell and battery information to reflect latest standards
- Revision to impact test of glass parts
- Revision to impact test procedure to address “bounce” of impact head
- Clarification of the test requirements for “service” and “surface” temperature
- Addition of temperature rise tests for converter-fed motors
- Addition of alternative test method for thermal endurance
- Removal of “charging test” and addition of note providing guidance
- Clarification of test for the measurement of capacitance
- Addition of a “Schedule of Limitations” to certificates for Ex Components
- Clarification of the marking for multiple temperature classes
- Addition of marking for converter-fed motors
- Removal of IP marking for Group III
- Addition of specific instructions for electrical machines
- Addition of specific instructions for ventilating fans
- Update to informative Annex D on converter-fed motors
- Update to informative Annex E on temperature testing of motors
- Addition of informative Annex F, flowchart for testing of non-metallic enclosures and non-metallic parts of enclosures

The text of this standard is based on the following documents:

FDIS	Report on voting
31/922/FDIS	31/939/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60079 series, under the general title *Explosive atmospheres*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of a new edition.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigenda of November 2012 and December 2013, and the interpretation sheets of November 2013, October 2014, June 2018 and April 2019 have been included in this copy.

Withdrawn

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

1 Scope

This part of IEC 60079 specifies the general requirements for construction, testing and marking of electrical equipment and Ex Components intended for use in explosive atmospheres.

The standard atmospheric conditions (relating to the explosion characteristics of the atmosphere) under which it may be assumed that electrical equipment can be operated are:

- temperature -20 °C to $+60\text{ °C}$;
- pressure 80 kPa (0,8 bar) to 110 kPa (1,1 bar); and
- air with normal oxygen content, typically 21 % v/v.

This standard and other standards supplementing this standard specify additional test requirements for equipment operating outside the standard temperature range, but further additional consideration and additional testing may be required for equipment operating outside the standard atmospheric pressure range and standard oxygen content, particularly with respect to types of protection that depend on quenching of a flame such as 'flameproof enclosure "d"' (IEC 60079-1) or limitation of energy, 'intrinsic safety "i"' (IEC 60079-11).

NOTE 1 Although the standard atmospheric conditions above give a temperature range for the atmosphere of -20 °C to $+60\text{ °C}$, the normal ambient temperature range for the equipment is -20 °C to $+40\text{ °C}$, unless otherwise specified and marked. See 5.1.1. It is considered that -20 °C to $+40\text{ °C}$ is appropriate for most equipment and that to manufacture all equipment to be suitable for a standard atmosphere upper ambient temperature of $+60\text{ °C}$ would place unnecessary design constraints.

NOTE 2 Requirements given in this standard result from an ignition hazard assessment made on electrical equipment. The ignition sources taken into account are those found associated with this type of equipment, such as hot surfaces, mechanically generated sparks, mechanical impacts resulting in thermite reactions, electrical arcing and static electric discharge in normal industrial environments.

NOTE 3 It is acknowledged that, with developments in technology, it may be possible to achieve the objectives of the IEC 60079 series of standards in respect of explosion prevention by methods that are not yet fully defined. Where a manufacturer wishes to take advantage of such developments, this International Standard, as well as other standards in the IEC 60079 series, may be applied in part. It is intended that the manufacturer prepare documentation that clearly defines how the IEC 60079 series of standards has been applied, together with a full explanation of the additional techniques employed. The designation "Ex s" has been reserved to indicate special protection. A standard for special protection "s", IEC 60079-33, is in preparation.

NOTE 4 Where an explosive gas atmosphere and a combustible dust atmosphere are, or may be, present at the same time, the simultaneous presence of both should be considered and may require additional protective measures.

This standard does not specify requirements for safety, other than those directly related to the explosion risk. Ignition sources like adiabatic compression, shock waves, exothermic chemical reaction, self ignition of dust, naked flames and hot gases/liquids, are not addressed by this standard.

NOTE 5 Such equipment should be subjected to a hazard analysis that identifies and lists all of the potential sources of ignition by the electrical equipment and the measures to be applied to prevent them becoming effective.

This standard is supplemented or modified by the following standards concerning specific types of protection:

- IEC 60079-1: Gas – Flameproof enclosures "d";
- IEC 60079-2: Gas – Pressurized enclosures "p";

- IEC 60079-5: Gas – Powder filling "q";
- IEC 60079-6: Gas – Oil immersion "o";
- IEC 60079-7: Gas – Increased safety "e";
- IEC 60079-11: Gas – Intrinsic safety "i";
- IEC 60079-15: Gas – Type of protection "n";
- IEC 60079-18: Gas and dust – Encapsulation "m";
- IEC 60079-31: Dust – Protection by enclosure "t"
- IEC 61241-4: Dust – Pressurization "pD".

NOTE 6 Additional information on types of protection for non-electrical equipment can be found in ISO/IEC 80079-36 (to be published).

This standard is supplemented or modified by the following equipment standards:

IEC 60079-13: Explosive atmospheres – Part 13: Equipment protection by pressurized room "p"

IEC 60079-25: Explosive atmospheres – Part 25: Intrinsically safe electrical systems

IEC 60079-26: Explosive atmospheres – Part 26: Equipment with equipment protection level (EPL) Ga

IEC 60079-28: Explosive atmospheres – Part 28: Protection of equipment and transmission systems using optical radiation

IEC 62013-1: Caplights for use in mines susceptible to firedamp – Part 1: General requirements – Construction and testing in relation to the risk of explosion

IEC 60079-30-1: Explosive atmospheres – Part 30-1: Electrical resistance trace heating – General and testing requirements.

This standard with the additional standards mentioned above, are not applicable to the construction of

- electromedical apparatus,
- shot-firing exploders,
- test devices for exploders, and
- shot-firing circuits.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60034-1, *Rotating electrical machines – Part 1: Rating and performance*

IEC 60034-5, *Rotating electrical machines – Part 5: Classification of degrees of protection provided by the enclosures of rotating electrical machines (IP Code)*

IEC 60050-426, *International Electrotechnical Vocabulary (IEV) – Chapter 426: Electrical apparatus for explosive atmospheres*

IEC 60079-1, *Explosive atmospheres – Part 1: Equipment protection by flameproof enclosure "d"*

IEC 60079-2, *Explosive atmospheres – Part 2: Equipment protection by pressurized enclosures "p"*

IEC 60079-5, *Explosive atmospheres – Part 5: Equipment protection by powder filling "q"*

IEC 60079-6, *Explosive atmospheres – Part 6: Equipment protection by oil-immersion "o"*

IEC 60079-7, *Explosive atmospheres – Part 7: Equipment protection by increased safety "e"*

IEC 60079-11, *Explosive atmospheres – Part 11: Equipment protection by intrinsic safety "i"*

IEC 60079-15, *Explosive atmospheres – Part 15: Equipment protection by type of protection "n"*

IEC 60079-18, *Explosive atmospheres – Part 18: Equipment protection by encapsulation "m"*

IEC 60079-20-1, *Explosive Atmosphere – Part 20-1: Material characteristics for gas and vapour classification, test methods and data*

IEC 60079-25: *Explosive atmospheres – Part 25: Intrinsically safe systems*

IEC 60079-26: *Explosive atmospheres – Part 26: Equipment with equipment protection level (EPL) Ga*

IEC 60079-28: *Explosive atmospheres – Part 28: Protection of equipment and transmission systems using optical radiation*

IEC 60079-30-1: *Explosive atmospheres – Part 30-1: Electrical resistance trace heating – General and testing requirements*

IEC 60079-31, *Explosive atmospheres – Part 31: Equipment dust ignition protection by enclosures "t"*

IEC 60086-1, *Primary batteries – Part 1: General*

IEC 60095-1, *Lead-acid starter batteries – Part 1: General requirements and methods of test*

IEC 60192, *Low-pressure sodium vapour lamps – Performance specifications*

IEC 60216-1, *Electrical insulating materials – Properties of thermal endurance – Part 1: Ageing procedures and evaluation of test results*

IEC 60216-2, *Electrical insulating materials – Thermal endurance properties – Part 2: Determination of thermal endurance properties of electrical insulating materials – Choice of test criteria*

IEC 60243-1, *Electrical strength of insulating materials – Test methods – Part 1: Tests at power frequencies*

IEC 60254 (all parts), *Lead-acid traction batteries*

IEC 60423, *Conduits for electrical purposes – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60622, *Secondary cells and batteries containing alkaline or other non-acid electrolytes – Sealed nickel-cadmium prismatic rechargeable single cells*

IEC 60623, *Secondary cells and batteries containing alkaline or other non-acid electrolytes – Vented nickel-cadmium prismatic rechargeable single cells*

IEC 60662, *High-pressure sodium vapour lamps*

IEC 60664-1, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60947-1, *Low-voltage switchgear and controlgear – Part 1: General rules*

IEC 60896-11, *Stationary lead-acid batteries – Part 11: Vented types – General requirements and methods of tests*

IEC 60896-21, *Stationary lead-acid batteries – Part 21: Valve regulated types – Methods of test*

IEC 60952 (all parts), *Aircraft batteries*

IEC 61056-1, *General purpose lead-acid batteries (valve-regulated types) – Part 1: General requirements, functional characteristics – Methods of tests*

IEC 61241-4, *Electrical apparatus for use in the presence of combustible dust – Part 4: Type of protection “pD”*

IEC 61427, *Secondary cells and batteries for photovoltaic energy systems (PVES) – General requirements and methods of test*

IEC 61951-1, *Secondary cells and batteries containing alkaline and other non-acid electrolytes – Portable sealed rechargeable single cells – Part 1: Nickel-cadmium*

IEC 61951-2, *Secondary cells and batteries containing alkaline and other non-acid electrolytes – Portable sealed rechargeable single cells – Part 2: Nickel-metal hydride*

IEC 61960, *Secondary cells and batteries containing alkaline or other non-acid electrolytes – Secondary lithium cells and batteries for portable applications*

IEC 62013-1, *Caplights for use in mines susceptible to firedamp – Part 1: General requirements – Construction and testing in relation to the risk of explosion*

ISO 178, *Plastics – Determination of flexural properties*

ISO 179 (all parts), *Plastics – Determination of Charpy impact properties*

ISO 262, *ISO general-purpose metric screw threads – Selected sizes for screws, bolts and nuts*

ISO 273, *Fasteners – Clearance holes for bolts and screws*

ISO 286-2, *ISO system of limits and fits – Part 2: Tables of standard tolerance grades and limit deviations for holes and shafts*

ISO 527-2, *Plastics – Determination of tensile properties – Part 2: Test conditions for moulding and extrusion plastics*

ISO 965-1, *ISO general-purpose metric screw threads – Tolerances – Part 1: Principles and basic data*

ISO 965-3, *ISO general-purpose metric screw threads – Tolerances – Part 3: Deviations for constructional screw threads*

ISO 1817, *Rubber, vulcanized – Determination of the effect of liquids*

ISO 3601-1, *Fluid power systems – O-rings – Part 1: Inside diameters, cross-sections, tolerances and designation codes*

ISO 3601-2, *Fluid power systems – O-rings – Part 2: Housing dimensions for general applications*

ISO 4014, *Hexagon head bolts – Product grades A and B*

ISO 4017, *Hexagon head screws – Product grades A and B*

ISO 4026, *Hexagon socket set screws with flat point*

ISO 4027, *Hexagon socket set screws with cone point*

ISO 4028, *Hexagon socket set screws with dog point*

ISO 4029, *Hexagon socket set screws with cup point*

ISO 4032, *Hexagon nuts, style 1 – Product grades A and B*

ISO 4762, *Hexagon socket head cap screws*

ISO 4892-2, *Plastics – Methods of exposure to laboratory light sources – Part 2: Xenon-arc lamps*

ISO 7380, *Hexagon socket button head screws*

ISO 14583, *Hexalobular socket pan head screws*

ANSI/UL 746B, *Polymeric Materials – Long-Term Property Evaluations*

ANSI/UL 746C, *Polymeric Materials – Used in Electrical Equipment Evaluations*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

NOTE For the definitions of any other terms, particularly those of a more general nature, reference should be made to IEC 60050(426) or other appropriate parts of the IEC (International Electrotechnical Vocabulary).

3.1**ambient temperature**

temperature of the air or other media, in the immediate vicinity of the equipment or component

NOTE This does not refer to the temperature of any process media, unless the equipment or component is totally immersed in the process media. See 5.1.1.

3.2**area, hazardous**

area in which an explosive atmosphere is present, or may be expected to be present, in quantities such as to require special precautions for the construction, installation and use of electrical apparatus

3.3**area, non-hazardous**

area in which an explosive atmosphere is not expected to be present in quantities such as to require special precautions for the construction, installation and use of electrical apparatus

3.4**associated apparatus**

electrical apparatus which contains both energy-limited and non-energy-limited circuits and is constructed so that the non-energy-limited circuits cannot adversely affect the energy-limited circuits

NOTE Associated apparatus may be either:

- a) electrical apparatus which has an alternative type of protection included in this standard for use in the appropriate explosive atmosphere;
- b) electrical apparatus not so protected and which therefore is not to be used within an explosive atmosphere, for example, a recorder which is not of itself in an explosive atmosphere but is connected to a thermocouple situated within an explosive atmosphere where only the recorder input circuit is energy limited.

3.5**cells and batteries****3.5.1****battery**

assembly of two or more cells electrically connected to each other to increase the voltage or capacity

3.5.2**capacity**

quantity of electricity or electric charge, which a fully charged battery can deliver under specified conditions

3.5.3**cell**

assembly of electrodes and electrolyte which constitutes the smallest electrical unit of a battery

3.5.4**charging**

act of forcing current through a secondary cell or battery in the opposite direction to the normal flow to restore the energy

3.5.5**deep discharge**

event which reduces a cell voltage below that recommended by the cell or battery manufacturer

3.5.6

maximum open-circuit voltage (of a cell or battery)

maximum attainable voltage under normal conditions, that is, from either a new primary cell, or a secondary cell just after a full charge

NOTE See Tables 11 and 12 which show the maximum open-circuit voltage for acceptable cells.

3.5.7

nominal voltage

(of a cell or battery) is that specified by the manufacturer

3.5.8

vented cell or battery

secondary cell, or battery, having a cover provided with an opening through which gaseous products may escape

3.5.9

primary cell or battery

electrochemical system capable of producing electrical energy by chemical reaction

3.5.10

reverse charging

act of forcing current through either a primary cell or secondary cell in the same direction as the normal flow, for example, in an expired battery

3.5.11

sealed gas-tight cell or battery

cell or battery which remains closed and does not release either gas or liquid when operated within the limits of charge or temperature specified by the manufacturer

NOTE 1 Such cells and batteries may be equipped with a safety device to prevent dangerously high internal pressure. The cell or battery does not require addition to the electrolyte and is designed to operate during its life in its original sealed state.

NOTE 2 The above definition is taken from IEC 60079-11. It differs from the definitions in IEC 486-01-20 and IEC 486-01-21 by virtue of the fact that it applies to either a cell or battery.

3.5.12

sealed valve-regulated cell or battery

cell or battery which is closed under normal conditions but which has an arrangement which allows the escape of gas if the internal pressure exceeds a pre-determined value. The cell cannot normally receive an addition to the electrolyte

3.5.13

secondary cell or battery

electrically rechargeable electrochemical system capable of storing electrical energy and delivering it by chemical reaction

3.5.14

container (battery)

enclosure to contain the battery

NOTE The cover is a part of the battery container.

3.6

bushing

insulating device carrying one or more conductors through an internal or external wall of an enclosure

3.7

cable gland

device permitting the introduction of one or more electric and/or fibre optic cables into an electrical equipment so as to maintain the relevant type of protection

3.7.1

clamping device

element of a cable gland for preventing tension or torsion in the cable from being transmitted to the connections

3.7.2

compression element

element of a cable gland acting on the sealing ring to enable the latter to fulfil its function

3.7.3

sealing ring

ring used in a cable gland to ensure the sealing between the cable gland and the cable

3.7.4

Ex Equipment cable gland

cable gland tested separately from the equipment enclosure but certified as equipment and which can be fitted to the equipment enclosure during installation.

3.7.5

cable transit device

an entry device, intended for one or more cables, with a seal made up of one or more separate elastomeric modules or parts of modules (modular internal seal), which are compressed together when the device is assembled and mounted as intended.

NOTE Cable transit devices can also serve as Ex blanking Elements when the elastomeric modules provided allow for this function.

3.8

certificate

document that assures the conformity of a product, process, system, person, or organization with specified requirements

NOTE The certificate may be either the supplier's declaration of conformity or the purchaser's recognition of conformity or certification (as a result of action by a third party) as defined in ISO/IEC 17000.

3.8.1

Ex Component Certificate

a certificate prepared for an Ex Component. See 3.28.

3.8.2

Equipment Certificate

A certificate prepared for equipment other than an Ex Component. Such equipment may include Ex Components, but additional evaluation is always required as part of their incorporation into equipment. See 3.7.4, 3.25, 3.27, 3.28, and 3.29.

3.9

compound (for encapsulation)

any thermosetting, thermoplastic, epoxy resin or elastomeric materials with or without fillers and/or additives, in their solid state; used for encapsulation

3.10

conduit entry

means of introducing a conduit into electrical equipment so as to maintain the relevant type of protection

3.11

connection facilities

terminals, screws or other parts, used for the electrical connection of conductors of external circuits

3.12

connections, factory

terminations intended for connection during a manufacturing process under controlled conditions

3.13

connections, field-wiring

terminations intended for connection by the installer in the field

3.14

continuous operating temperature

COT

temperature range which ensures the stability and integrity of the material for the expected life of the equipment, or part, in its intended application

3.15

converter (for use with electrical machines)

unit for electronic power conversion, changing one or more electrical characteristics and comprising one or more electronic switching devices and associated components, such as transformers, filters, commutation aids, controls, protections, and auxiliaries, if any

NOTE A Converter may also be known as a frequency converter, a converter drive, an inverter drive, a variable speed drive, or a variable frequency drive.

3.16

converter, soft-start

converter which limits the input current to the electrical machine during the starting process.

NOTE It is intended that the soft-start converter is used only during the starting process and is then isolated from the power system when the electrical machine is running.

3.17

degree of protection of enclosure

IP

numerical classification according to IEC 60529 preceded by the symbol IP applied to the enclosure of electrical equipment to provide

- protection of persons against contact with, or approach to, live parts and against contact with moving parts (other than smooth rotating shafts and the like) inside the enclosure,
- protection of the electrical equipment against ingress of solid foreign objects, and
- where indicated by the classification, protection of the electrical equipment against harmful ingress of water

NOTE 1 The detailed test requirements for rotating electrical machines are in IEC 60034-5.

NOTE 2 The enclosure which provides the degree of protection IP is not necessarily identical to the equipment enclosure for the types of protection listed in the Foreword.

3.18

dust

generic term including both combustible dust and combustible flyings

3.18.1**combustible dust**

finely divided solid particles, 500 µm or less in nominal size, which may be suspended in air, may settle out of the atmosphere under their own weight, may burn or glow in air, and may form explosive mixtures with air at atmospheric pressure and normal temperatures

NOTE 1 This includes dust and grit as defined in ISO 4225.

NOTE 2 The term solid particles is intended to address particles in the solid phase and not the gaseous or liquid phase, but does not preclude a hollow particle.

3.18.1.1**conductive dust**

combustible dust with electrical resistivity equal to or less than $10^3 \Omega\cdot\text{m}$

NOTE IEC 61241-2-2 contains the test method for determining the electrical resistivity of dusts.

3.18.1.2**non-conductive dust**

combustible dust with electrical resistivity greater than $10^3 \Omega\cdot\text{m}$

NOTE IEC 61241-2-2 contains the test method for determining the electrical resistivity of dusts.

3.18.2**combustible flyings**

solid particles, including fibres, greater than 500 µm in nominal size which may be suspended in air and could settle out of the atmosphere under their own weight

NOTE Examples of flyings include rayon, cotton (including cotton linters and cotton waste), sisal, jute, hemp, cocoa fibre, oakum, and baled waste kapok.

3.19**dust-tight enclosure**

enclosure capable of excluding the ingress of observable dust particle deposits

3.20**dust-protected enclosure**

enclosure in which the ingress of dust is not totally excluded, but is unlikely to enter in sufficient quantity to interfere with the safe operation of the equipment and does not accumulate in a position within the enclosure where it is liable to cause an ignition hazard

3.21**elastomer**

a macromolecular material which returns rapidly to approximately its initial dimensions and shape after substantial deformation by a weak stress and release of the stress (IEV 212-04-05)

NOTE The definition applies to room temperature test conditions.

3.22**electrical equipment**

items applied as a whole or in part for the utilization of electrical energy

NOTE These include, amongst others, items for the generation, transmission, distribution, storage, measurement, regulation, conversion and consumption of electrical energy and items for telecommunications.

3.23**encapsulation**

process of applying a compound to enclose an electrical device(s) by suitable means

3.24

enclosure

all the walls, doors, covers, cable glands, rods, spindles, shafts, etc. which contribute to the type of protection and/or the degree of protection IP of the electrical equipment

3.25

equipment (for explosive atmospheres)

general term including apparatus, fittings, devices, components, and the like used as a part of, or in connection with, an electrical installation in an explosive atmosphere

3.26

equipment protection level

EPL

level of protection assigned to equipment based on its likelihood of becoming a source of ignition and distinguishing the differences between explosive gas atmospheres, explosive dust atmospheres, and the explosive atmospheres in mines susceptible to firedamp

NOTE The equipment protection level may optionally be employed as part of a complete risk assessment of an installation, see IEC 60079-14.

3.26.1

EPL Ma

equipment for installation in a mine susceptible to firedamp, having a "very high" level of protection, which has sufficient security that it is unlikely to become an ignition source in normal operation, during expected malfunctions or during rare malfunctions, even when left energized in the presence of an outbreak of gas

3.26.2

EPL Mb

equipment for installation in a mine susceptible to firedamp, having a "high" level of protection, which has sufficient security that it is unlikely to become a source of ignition in normal operation or during expected malfunctions in the time span between there being an outbreak of gas and the equipment being de-energized

3.26.3

EPL Ga

equipment for explosive gas atmospheres, having a "very high" level of protection, which is not a source of ignition in normal operation, during expected malfunctions or during rare malfunctions

3.26.4

EPL Gb

equipment for explosive gas atmospheres, having a "high" level of protection, which is not a source of ignition in normal operation or during expected malfunctions

3.26.5

EPL Gc

equipment for explosive gas atmospheres, having an "enhanced" level of protection, which is not a source of ignition in normal operation and which may have some additional protection to ensure that it remains inactive as an ignition source in the case of regular expected occurrences (for example failure of a lamp)

3.26.6

EPL Da

equipment for explosive dust atmospheres, having a "very high" level of protection, which is not a source of ignition in normal operation, during expected malfunctions, or during rare malfunctions

3.26.7**EPL Db**

equipment for explosive dust atmospheres, having a "high" level of protection, which is not a source of ignition in normal operation or during expected malfunctions

3.26.8**EPL Dc**

equipment for explosive dust atmospheres, having an "enhanced" level of protection, which is not a source of ignition in normal operation and which may have some additional protection to ensure that it remains inactive as an ignition source in the case of regular expected occurrences (for example failure of a lamp)

3.27**Ex blanking element**

threaded blanking element tested separately from the equipment enclosure but having an equipment certificate and which is intended to be fitted to the equipment enclosure without further consideration

NOTE 1 This does not preclude an Ex Component certificate for blanking elements

NOTE 2 Non-threaded blanking elements are not equipment.

3.28**Ex Component**

part of electrical equipment or a module, marked with the symbol "U", which is not intended to be used alone and requires additional consideration when incorporated into electrical equipment or systems for use in explosive atmospheres

3.29**Ex thread adapter**

thread adapter tested separately from the enclosure but having an equipment certificate and which is intended to be fitted to the equipment enclosure without further consideration

NOTE This does not preclude an Ex Component certificate for thread adapters.

3.30**explosive atmosphere**

mixture with air, under atmospheric conditions, of flammable substances in the form of gas, vapour, dust, fibres, or flyings which, after ignition, permits self-sustaining propagation

3.31**explosive dust atmosphere**

mixture with air, under atmospheric conditions, of flammable substances in the form of dust, fibres, or flyings which, after ignition, permits self-sustaining propagation

3.32**explosive gas atmosphere**

mixture with air, under atmospheric conditions, of flammable substances in the form of gas or vapour, which, after ignition, permits self-sustaining flame propagation

3.33**explosive test mixture**

specified explosive mixture used for the testing of electrical equipment for explosive gas atmospheres

3.34**firedamp**

flammable mixture of gases naturally occurring in a mine

NOTE Firedamp consists mainly of methane, but always contains small quantities of other gases, such as nitrogen, carbon dioxide, and hydrogen, and sometimes ethane and carbon monoxide. The terms firedamp and methane are used frequently in mining practice as synonyms.

3.35

free space

intentionally created space surrounding components or space inside components

3.36

galvanic isolation

arrangement within equipment which permits the transfer of signals or power between two circuits without any direct electrical connection between the two

NOTE Galvanic isolation frequently utilizes either magnetic (transformer or relay) or opto-coupled elements.

3.37

ignition temperature of an explosive gas atmosphere

lowest temperature of a heated surface which, under specified conditions according to IEC 60079-20-1, will ignite a flammable substance in the form of a gas or vapour mixture with air

3.38

ignition temperature of a dust layer

lowest temperature of a hot surface at which ignition occurs in a dust layer of specified thickness on a hot surface

NOTE The ignition temperature of a dust layer may be determined by the test method given in IEC 61241-2-1.

3.39

ignition temperature of a dust cloud

lowest temperature of the hot inner wall of a furnace at which ignition occurs in a dust cloud in air contained therein

NOTE The ignition temperature of a dust cloud may be determined by the test method given in IEC 61241-2-1.

3.40

limiting temperature

maximum permissible temperature for equipment or parts of equipment equal to the lower of the two temperatures determined by:

- a) the danger of ignition of the explosive atmosphere;
- b) the thermal stability of the materials used

3.41

malfunction

equipment or components which do not perform their intended function with respect to explosion protection

NOTE For the purposes of this standard this can happen due to a variety of reasons, including:

- failure of one (or more) of the component parts of the equipment or components;
- external disturbances (e.g. shocks, vibration, electromagnetic fields);
- design error or deficiency (e.g. software errors);
- disturbance of the power supply or other services;
- loss of control by the operator (especially for handheld equipment).

3.41.1

expected malfunction

disturbances or equipment malfunctions which normally occur in practice

3.41.2**rare malfunction**

type of malfunction, which may happen, but only in rare instances. Two independent expected malfunctions which, separately, would not create a source of ignition, but which, in combination, do create a source of ignition, are regarded as a single rare malfunction

3.42**maximum surface temperature**

highest temperature which is attained in service under the most adverse conditions (but within the specified tolerances) by any part or surface of electrical equipment

NOTE 1 For electrical equipment in an explosive gas atmosphere, this temperature may occur on an internal component or on the external surface of the enclosure, depending upon the type of protection employed.

NOTE 2 For electrical equipment in an explosive dust atmosphere, this temperature occurs on the external surface of the enclosure and may include a defined dust layer condition.

3.43**normal operation**

operation of equipment conforming electrically and mechanically with its design specification and used within the limits specified by the manufacturer

NOTE 1 The limits specified by the manufacturer may include persistent operational conditions, e.g. operation of a motor on a duty cycle.

NOTE 2 Variation of the supply voltage within stated limits and any other operational tolerance is part of normal operation.

3.44**level of protection**

subdivision of a Type of Protection, correlating with the Equipment Protection Level, that differentiates the likelihood of the equipment becoming a source of ignition

NOTE For example, Type of Protection intrinsic safety "i" is subdivided into Levels of Protection "ia", "ib", and "ic; which correlate with Equipment Protection Levels Ga, Gb, and Gc (for explosive gas atmospheres).

3.45**plastic**

a material which contains as an essential ingredient a high polymer and which at some stage in its processing into finished products can be shaped by flow

[IEV 212-04-02]

NOTE Elastomers, which are also shaped by flow, are not considered as plastics.

3.46**radio frequency**

electromagnetic waves from 9 kHz to 60 GHz

3.46.1**continuous transmission**

transmission where the duration of the pulse is greater than the half of the thermal initiation time

3.46.2**pulsed transmission**

transmission where the duration of the pulse is shorter than the half of the thermal initiation time, but the time between two consecutive pulses, however, is longer than three times the thermal initiation time

3.46.3

thermal initiation time

time (over which the threshold power is averaged) during which energy deposited by the spark accumulates in a small volume of gas around it without significant thermal dissipation

NOTE For times shorter than the thermal initiation time the total energy deposited by the spark will determine whether or not ignition occurs. For increasingly longer times, the power or rate at which energy is deposited becomes the determining factor for ignition.

3.46.4

threshold energy

Z_{th}

for a pulsed radio-frequency discharge, the maximum energy of the single pulse which can be extracted from the receiving body

3.46.5

threshold power

P_{th}

product of the effective output power of the transmitter multiplied by the antenna gain

NOTE The gain is produced by an antenna concentrating radiation in a particular direction and is always related to a specified reference antenna

3.47

rated value

quantity value, assigned generally by the manufacturer, for a specified operating condition of a component, device or apparatus

3.48

rating

set of rated values and operating conditions

3.49

replaceable battery pack

assembly consisting of one or more interconnected cells, along with any integrated protective components, which form a complete replaceable battery

3.50

service temperature

maximum or minimum temperature reached at specific points of the equipment when the equipment is operating at rated conditions, including ambient temperature and any external sources of heating or cooling. See 5.2

NOTE Equipment may reach different service temperatures in different parts.

3.51

spacings, electrical

separation distances between conductive parts at different electrical potentials

3.51.1

clearance

shortest distance in air between two conductive parts

3.51.2

creepage distance

shortest distance along the surface of a solid insulating material between two conductive parts

3.51.3**distance through casting compound**

shortest distance through a casting compound between two conductive parts

3.51.4**distance through solid insulation**

shortest distance through solid insulation between two conductive parts

3.51.5**distance under coating**

shortest distance between conductive parts along the surface of an insulating medium covered with insulating coating

3.52**symbol “U”**

symbol used to denote an Ex Component

NOTE The symbol “U” is used to identify that the equipment is incomplete and is not suitable for installation without further evaluation.

3.53**symbol “X”**

symbol used to denote specific conditions of use

NOTE The symbol “X” is used to provide a means of identifying that essential information for the installation, use, and maintenance of the equipment is contained within the certificate.

3.54**termination compartment**

separate compartment, or part of a main enclosure, communicating or not with the main enclosure, and containing connection facilities

3.55**test, routine**

test to which each individual device is subjected during or after manufacture to ascertain whether it complies with certain criteria

3.56**test, type**

test of one or more devices made to a certain design to show that the design meets certain specifications

3.57**type of protection**

specific measures applied to electrical equipment to avoid ignition of a surrounding explosive atmosphere

3.58**void**

unintentional space created as a consequence of the encapsulation process

3.59**working voltage**

highest r.m.s. value of the a.c. or d.c. voltage across any particular insulation which can occur when the equipment is supplied at rated voltage

NOTE 1 Transients are disregarded.

NOTE 2 Both open-circuit conditions and normal operating conditions are taken into account.

4 Equipment grouping

Electrical equipment for explosive atmospheres is divided into the following groups:

4.1 Group I

Electrical equipment of Group I is intended for use in mines susceptible to firedamp.

NOTE The types of protection for Group I take into account the ignition of both firedamp and coal dust along with enhanced physical protection for equipment used underground.

Electrical equipment intended for mines where the atmosphere, in addition to firedamp, may contain significant proportions of other flammable gases (i.e. other than methane), shall be constructed and tested in accordance with the requirements relating to Group I and also to the subdivision of Group II corresponding to the other significant flammable gases. This electrical equipment shall then be marked appropriately (for example, "Ex d I/IIB T3" or "Ex d I/II (NH₃)").

4.2 Group II

Electrical equipment of Group II is intended for use in places with an explosive gas atmosphere other than mines susceptible to firedamp.

Electrical equipment of Group II is subdivided according to the nature of the explosive gas atmosphere for which it is intended.

Group II subdivisions

- IIA, a typical gas is propane
- IIB, a typical gas is ethylene
- IIC, a typical gas is hydrogen

NOTE 1 This subdivision is based on the maximum experimental safe gap (MESG) or the minimum ignition current ratio (MIC ratio) of the explosive gas atmosphere in which the equipment may be installed. (See IEC 60079-20-1).

NOTE 2 Equipment marked IIB is suitable for applications requiring Group IIA equipment. Similarly, equipment marked IIC is suitable for applications requiring Group IIA or Group IIB equipment.

4.3 Group III

Electrical equipment of Group III is intended for use in places with an explosive dust atmosphere other than mines susceptible to firedamp.

Electrical equipment of Group III is subdivided according to the nature of the explosive dust atmosphere for which it is intended.

Group III subdivisions:

- IIIA: combustible flyings
- IIIB: non-conductive dust
- IIIC: conductive dust

NOTE Equipment marked IIIB is suitable for applications requiring Group IIIA equipment. Similarly, equipment marked IIIC is suitable for applications requiring Group IIIA or Group IIIB equipment.

4.4 Equipment for a particular explosive atmosphere

The electrical equipment may be tested for a particular explosive atmosphere. In this case, the information shall be recorded on the certificate and the electrical equipment marked accordingly.

5 Temperatures

5.1 Environmental influences

5.1.1 Ambient temperature

Electrical equipment designed for use in a normal ambient temperature range of -20 °C to $+40\text{ °C}$ does not require marking of the ambient temperature range. However, electrical equipment designed for use in other than this normal ambient temperature range is considered to be special. The marking shall then include either the symbol T_a or T_{amb} together with both the upper and lower ambient temperatures or, if this is impracticable, the symbol “X” shall be used to indicate specific conditions of use that include the upper and lower ambient temperatures. See item e) of 29.3 and Table 1.

NOTE The ambient temperature range may be a reduced range, e.g. $-5\text{ °C} \leq T_{amb} \leq 15\text{ °C}$.

Table 1 – Ambient temperatures in service and additional marking

Electrical equipment	Ambient temperature in service	Additional marking
Normal	Maximum: $+40\text{ °C}$ Minimum: -20 °C	None
Special	Specified by the manufacturer	T_a or T_{amb} with the special range, for example, $-30\text{ °C} \leq T_a \leq +40\text{ °C}$ or the symbol “X”

5.1.2 External source of heating or cooling

Where the electrical equipment is intended to be physically connected to a separate external source of heating or cooling, such as a heated or cooled process vessel or pipeline, the ratings of the external source shall be specified in the certificate and in the manufacturer's instructions.

NOTE 1 The external source of heating or cooling is frequently referred to as the “process temperature”.

NOTE 2 The way in which these ratings are expressed will vary according to the nature of the source. For sources generally larger than the equipment, the maximum or minimum temperature will usually be sufficient. For sources generally smaller than the equipment, or for heat conduction through thermal insulation, the rate of heat flow may be appropriate.

NOTE 3 The influence of radiated heat may need to be considered on the final installation. See IEC 60079-14.

5.2 Service temperature

Where this standard, or the standard for the specific type of protection, requires the service temperature to be determined at any place in the equipment, the temperature shall be determined for the rating of the electrical equipment when the equipment is subjected to maximum or minimum ambient temperature and, where relevant, the maximum rated external source of heating or cooling. Service temperature testing, when required, shall be in accordance with 26.5.1.

NOTE The rating of the electrical equipment includes the ambient temperature, the electrical supply and load, duty cycle or duty type, as assigned by the manufacturer, typically as shown in the marking.

5.3 Maximum surface temperature

5.3.1 Determination of maximum surface temperature

Maximum surface temperature shall be determined according to 26.5.1 considering the maximum ambient temperature and, where relevant, the maximum rated external source of heating.

5.3.2 Limitation of maximum surface temperature

5.3.2.1 Group I electrical equipment

For electrical equipment of Group I, the maximum surface temperature shall be specified in relevant documentation according to Clause 24.

This maximum surface temperature shall not exceed

- 150 °C on any surface where coal dust can form a layer,
- 450 °C where coal dust is not likely to form a layer (i.e., inside of a dust-protected enclosure).

NOTE When choosing Group I electrical equipment, the user should take into account the influence and the smouldering temperature of coal dusts if they are likely to be deposited in a layer on surfaces with temperatures above 150 °C.

5.3.2.2 Group II electrical equipment

The maximum surface temperature determined (see 26.5.1) shall not exceed:

- the temperature class assigned (see Table 2), or
- the maximum surface temperature assigned, or
- if appropriate, the ignition temperature of the specific gas for which it is intended.

Table 2 – Classification of maximum surface temperatures for Group II electrical equipment

Temperature class	Maximum surface temperature °C
T1	450
T2	300
T3	200
T4	135
T5	100
T6	85

NOTE More than one temperature class may be established for different ambient temperatures and different external sources of heating and cooling.

5.3.2.3 Group III electrical equipment

5.3.2.3.1 Maximum surface temperature determined without a dust layer

The maximum surface temperature determined (see 26.5.1) shall not exceed the maximum surface temperature assigned.

5.3.2.3.2 Maximum surface temperature with respect to dust layers

In addition to the maximum surface temperature required in 5.3.2.3.1, the maximum surface temperature may also be determined for a given depth of layer, T_L , of dust surrounding all sides of the equipment, unless otherwise specified in the documentation, and marked with the symbol “X” to indicate this specific condition of use in accordance with item d) of 29.5.

NOTE 1 A maximum depth of layer, T_L , may be specified by the manufacturer.

NOTE 2 Additional information on the application of equipment where dust layers up to 50 mm may accumulate on the equipment is given in IEC 60079-14.

5.3.3 Small component temperature for Group I or Group II electrical equipment

NOTE There is both theoretical and practical evidence to show that the smaller the heated surface, the higher the surface temperature required to ignite a given explosive atmosphere.

Small components, for example transistors or resistors, whose temperature exceeds that permitted for the temperature classification, shall be acceptable providing that they conform to one of the following:

- when tested in accordance with 26.5.3, small components shall not cause ignition of the flammable mixture and any deformation or deterioration caused by the higher temperature shall not impair the type of protection; or
- for T4 and Group I classification, small components shall conform to Table 3a and Table 3b; or
- for T5 classification, the surface temperature of a component with a surface area smaller than 1 000 mm² (excluding lead wires) shall not exceed 150 °C.

Table 3a – Assessment of temperature classification according to component size at 40 °C ambient temperature

Total surface area excluding lead wires	Equipment Group II		Equipment Group I	
	With temperature class T4		Dust excluded	
	Maximum surface temperature	Maximum power dissipation	Maximum surface temperature	Maximum power dissipation
	°C	W	°C	W
<20 mm ²	275		950	
≥20 mm ² ≤1 000 mm ²	200, or	1,3		3,3
>1 000 mm ²		1,3		3,3

**Table 3b – Assessment of temperature classification
Component surface area ≥ 20 mm²
Variation in maximum power dissipation with ambient temperature**

Maximum ambient temperature	°C	Equipment group	40	50	60	70	80
Maximum power dissipation	W	Group II	1,3	1,25	1,2	1,1	1,0
		Group I	3,3	3,22	3,15	3,07	3,0

For potentiometers, the surface to be considered shall be that of the resistance element and not the external surface of the component. The mounting arrangement and the heat-sinking and cooling effect of the overall potentiometer construction shall be taken into consideration during the test. Temperature shall be measured on the track with that current which flows under the test conditions required by the standard for the specific type of protection. If this results in a resistance value of less than 10 % of the track resistance value, the measurements shall be carried out at 10 % of the track resistance value.

For surface areas of not more than 1 000 mm², the surface temperature may exceed that for the temperature class marked on the Group II electrical equipment or the corresponding

maximum surface temperature for Group I electrical equipment, if there is no risk of ignition from these surfaces, with a safety margin of

- 50 K for T1, T2 and T3,
- 25 K for T4, T5 and T6 and Group I.

This safety margin shall be ensured by experience of similar components or by tests of the electrical equipment itself in representative explosive mixtures.

NOTE During the tests, the safety margin may be provided by increasing the ambient temperature or by increasing the power dissipation of the component. For methane, the second option is recommended.

6 Requirements for all electrical equipment

6.1 General

Electrical equipment and Ex Components shall

- a) comply with the requirements of this standard, together with one or more of the specific standards listed in Clause 1, and

NOTE 1 These specific standards may vary the requirements of this standard.

NOTE 2 All of the requirements for cable glands marked as type of protection "e" are located in IEC 60079-0.

- b) be constructed in accordance with the applicable safety requirements of the relevant industrial standards.

NOTE 3 It is not a requirement of this standard that compliance with these industrial standards be verified.

NOTE 4 If the electrical equipment or Ex Component is intended to withstand particularly adverse service conditions (for example, rough handling, humidity effects, ambient temperature variations, effects of chemical agents, corrosion), these should be specified to the manufacturer by the user. If certification is sought, it is not a requirement of this standard that the certification body confirm suitability for the adverse conditions. Special precautions should be taken when vibration effects on terminals, fuse holders, lampholders and current-carrying connections in general may impair safety, unless they comply with specific standards.

6.2 Mechanical strength of equipment

The equipment shall be subjected to the tests of 26.4. Guards relied upon to provide protection from impact shall be removable only by the use of a tool and shall remain in place for the required impact tests.

6.3 Opening times

Enclosures which can be opened more quickly than

- a) any incorporated capacitors, charged by a voltage of 200 V or more, to discharge to a value of residual energy of
 - 0,2 mJ for electrical equipment of Group I or Group IIA,
 - 0,06 mJ for electrical equipment of Group IIB,
 - 0,02 mJ for electrical equipment of Group IIC, including equipment marked Group II only,
 - 0,2 mJ for electrical equipment of Group III,

or double the above energy levels if the charging voltage is less than 200 V, or

- b) the surface temperature of enclosed hot components reduces to below the assigned maximum surface temperature of the electrical equipment

shall be marked with one of the following warning markings:

- an enclosure opening delay marking as specified in item a) of 29.12; or
- an enclosure opening marking as specified in item b) of 29.12.

6.4 Circulating currents in enclosures (e.g. of large electrical machines)

Where necessary, precautions shall be taken to guard against any effect due to the presence of circulating currents caused by stray magnetic fields, and the arcs or sparks that may occur as a result of interrupting such currents, or excessive temperatures caused by such currents.

NOTE 1 Stray magnetic fields can result in significant currents flowing both within and between bolted sections of multi-section enclosures often employed for large rotating electrical machines. This is most likely to occur during the starting of motors. It is important to avoid sparking from intermittent interruption of these currents.

NOTE 2 Although primarily a concern with large rotating machines, the same situation can occur in other equipment with large stray magnetic fields interacting with bolted sections of multi-section enclosures.

NOTE 3 Examples of precautions that can be taken include:

- the provision of equipotential bonding; or
- the provision of an adequate quantity of fasteners.

Where equipotential bonding conductors are employed, they shall be adequately rated for the anticipated currents and they shall be arranged to ensure reliable current transfer without the risk of sparking under adverse operating conditions, such as vibration or corrosion. The bonds shall be protected against corrosion and loosening in accordance with 15.4 and 15.5. Particular care shall be taken with bare flexible conductors in close proximity to the bonded parts.

Bonding conductors are not required where insulation ensures that circulating currents cannot flow between parts. The insulation of such parts shall be capable of withstanding a voltage of 100 V r.m.s for 1 min. However, provision shall be made for adequate earthing of isolated exposed conductive parts.

6.5 Gasket retention

Where the degree of protection provided by the enclosure depends on a gasketed joint which is intended to be opened for installation or maintenance purposes, gaskets shall be attached or secured to one of the mating faces to prevent loss, damage or incorrect assembly. The gasket material shall not itself adhere to the other joint face. When the joint is opened and re-closed prior to the tests for degree of protection by enclosure, it shall be verified that the gasket material has not adhered to the other joint face. (See 26.4.1.2).

NOTE An adhesive may be used for attaching a gasket to one of the mating faces.

6.6 Electromagnetic and ultrasonic energy radiating equipment

The energy levels shall not exceed the values given below.

NOTE Additional information on the application of higher power radiating sources can be found, for Group I and Group II, in CLC/TR50427. The results of the TR are based on far field conditions.

6.6.1 Radio frequency sources

The threshold power of radio frequency (9 kHz to 60 GHz) for continuous transmissions and for pulsed transmissions whose pulse durations exceed the thermal initiation time shall not exceed the values shown in Table 4. Programmable or software control intended for setting by the user shall not be permitted.

Table 4 – Radio frequency power thresholds

Equipment for	Threshold power W	Thermal initiation time
		μs
Group I	6	200
Group IIA	6	100
Group IIB	3,5	80
Group IIC	2	20
Group III	6	200

For pulsed radar and other transmissions where the pulses are short compared with the thermal initiation time, the threshold energy values Z_{th} shall not exceed those given in Table 5.

Table 5 – Radio-frequency energy thresholds

Equipment for	Threshold energy Z_{th}
	μJ
Group I	1 500
Group IIA	950
Group IIB	250
Group IIC	50
Group III	1 500

NOTE 1 In Tables 4 and 5, the same values are applied for Ma, Mb, Ga, Gb, Gc, Da, Db, or Dc equipment due to the large safety factors involved.

NOTE 2 In Tables 4 and 5, the values for Group III are adopted from Group I and not based on experimental results.

NOTE 3 In Tables 4 and 5, the values apply in normal operation, provided that the user of the equipment does not have access to adjust the equipment to give higher values. It is not necessary to consider possible increases in power caused by faults, due to the large safety margins involved and the strong likelihood that RF amplifiers will rapidly fail if a fault occurs that significantly increases the output power.

6.6.2 Lasers or other continuous wave sources

NOTE The values for Ga, Gb, and Gc can be found in IEC 60079-28.

The output parameters of lasers or other continuous wave sources of electrical equipment of EPL Ma or Mb shall not exceed the following values:

- 20 mW/mm² or 150 mW for continuous wave lasers and other continuous wave sources, and
- 0,1 mJ/mm² for pulse lasers or pulse light sources with pulse intervals of at least 5 s.

The output parameters of lasers or other continuous wave sources of electrical equipment of EPL Da or Db shall not exceed the following values:

- 5 mW/mm² or 35 mW for continuous wave lasers and other continuous wave sources, and
- 0,1 mJ/mm² for pulse lasers or pulse light sources with pulse intervals of at least 5 s.

The output parameters of lasers or other continuous wave sources of electrical equipment of EPL Dc shall not exceed the following:

- 10 mW/mm² or 35 mW for continuous wave lasers and other continuous wave sources, and
- 0,5 mJ/mm² for pulse lasers or pulse light sources.

Radiation sources with pulse intervals of less than 5 s are regarded as continuous wave sources.

6.6.3 Ultrasonic sources

The output parameters from ultrasonic sources of electrical equipment of EPL Ma, Mb, Ga, Gb, Gc, Da, Db, or Dc shall not exceed the following values:

- 0,1 W/cm² and 10 MHz for continuous sources,
- average power density 0,1 W/cm² and 2 mJ/cm² for pulse sources.

7 Non-metallic enclosures and non-metallic parts of enclosures

7.1 General

7.1.1 Applicability

The requirements given in this clause and in 26.7 shall apply to non-metallic enclosures and non-metallic parts of enclosures, on which the type of protection depends.

NOTE 1 Some examples of non-metallic parts of enclosures upon which the type of protection depends include cover sealing rings of an “e” or “t” enclosure, filling compounds of a “d” or “e” cable gland, sealing rings of cable glands, seals of switch actuators for an “e” enclosure, etc.

NOTE 2 Some of the subparts of this standard may make the “non-metallic parts of enclosures” requirements given in this clause applicable to parts, which are not enclosures, but on which the type of protection depends, e.g. “d” bushings, “e” terminals.

7.1.2 Specification of materials

7.1.2.1 General

The documents according to Clause 24 shall specify the material of the enclosure or part of the enclosure.

7.1.2.2 Plastic materials

The specification for plastic materials shall include the following:

- a) the name or registered trademark of the resin manufacturer or compounder;
- b) the identification of the material, including its
 - type designation,
 - colour,
 - type and percentage of fillers and other additives, if used;
- c) the possible surface treatments, such as varnishes, etc.;
- d) the temperature index TI, corresponding to the 20 000 h point on the thermal endurance graph without loss of flexural strength exceeding 50 %, determined in accordance with IEC 60216-1 and IEC 60216-2 and based on the flexing property in accordance with ISO 178. If the material does not break in this test before exposure to the heat, the index shall be based on the tensile strength in accordance with ISO 527-2 with test bars of Type 1A or 1B. As an alternative to the TI, the relative thermal index (RTI – mechanical) may be determined in accordance with ANSI/UL 746B.
- e) when applicable, data supporting compliance with 7.3 (resistance to ultraviolet light).

The source of the test data for these characteristics shall be identified.

NOTE It is not a requirement of this standard that conformity to the specification of the plastic material be verified.

7.1.2.3 Elastomers

The specification for elastomers shall include the following:

- a) the name or registered trademark of the resin manufacturer or compounder;
- b) the identification of the material, including its
 - type designation,
 - colour,
 - type and percentage of fillers and other additives, if used;
- c) the possible surface treatments, such as varnishes, etc.;
- d) the continuous operating temperature (COT);
- e) when applicable, data supporting compliance with 7.3 (resistance to ultraviolet light).

The source of the test data for these characteristics shall be identified.

NOTE It is not a requirement of this standard that conformity to the manufacturer's specification of the elastomer be verified.

7.2 Thermal endurance

7.2.1 Tests for thermal endurance

The tests for endurance to heat and to cold shall be conducted in accordance with 26.8 and 26.9.

7.2.2 Material selection

The plastic materials shall have a temperature index "TI" or RTI – mechanical (according to 7.1.2) of at least 20 K greater than the maximum service temperature of the enclosure or the part of the enclosure (see 26.5.1).

The elastomers shall have a continuous operating temperature (COT) range that includes a minimum temperature that is below, or equal to, the minimum service temperature and a maximum temperature that is at least 20 K above the maximum service temperature.

NOTE Equipment may have different service temperatures on different parts of the equipment. Selection and testing of individual materials is based on the specific service temperature of that part, but may alternatively be based on the maximum (or minimum) service temperature of the complete equipment.

7.2.3 Alternative qualification of elastomeric sealing O-rings

Elastomeric sealing O-rings are normally qualified as a part of the complete equipment enclosure when the ingress protection of the enclosure (IP) is required by the type of protection. Alternatively, a metal enclosure incorporating elastomeric sealing O-rings, according to ISO 3601-1, used in defined mounting conditions according to ISO 3601-2, is permitted to be evaluated using a test fixture instead of testing the O-ring assembled in the complete equipment enclosure. The test fixture shall replicate the dimensions of the complete equipment enclosure O-ring mounting. The tests shall be conducted according 26.16. The O-ring is then mounted in the complete equipment enclosure and subjected to the required IP tests of 26.4.5.

NOTE The compression set value determined after the tests of 26.16 is necessary for subsequent comparison to O-rings of alternative materials for the same application.

For the qualification of additional O-ring materials, the IP tests are not required if, subsequent to the tests of 26.16, the compression set of the alternative O-ring is less than or equal to that of the originally tested O-ring.

7.3 Resistance to light

The resistance to light of the enclosures, or parts of enclosures, of non-metallic materials shall be satisfactory (see 26.10). Materials meeting the ultraviolet light exposure requirements (f1) in ANSI/UL 746C are considered satisfactory.

Where not otherwise protected from exposure to light, a test of resistance of the material to ultraviolet light shall be made if the enclosure or parts of the enclosure, upon which the type of protection depends, are made of non-metallic materials. For Group I equipment, the test applies only to luminaires.

If the equipment is protected from light (for example, daylight or light from luminaires) when installed, and, in consequence, the test is not carried out, the equipment shall be marked by the symbol "X" to indicate this specific condition of use according to item e) of 29.3.

NOTE 1 It is generally acknowledged that glass and ceramic materials are not adversely affected by the resistance to light test, and testing may not be necessary.

NOTE 2 The tests for resistance to light are conducted on special test bars and not on the enclosure. Therefore, the special test bars are not required to be subjected to the tests of enclosures (26.4) prior to the tests for resistance to light.

7.4 Electrostatic charges on external non-metallic materials

7.4.1 Applicability

The requirements of this subclause only apply to external non-metallic materials of electrical equipment.

The requirements of 7.4 also apply to non-metallic parts which are applied to the external surface of an enclosure.

NOTE 1 Non-metallic paints, films, foils, and plates are typically attached to external surfaces of enclosures to provide additional environmental protection. Their ability to store an electrostatic charge is addressed by this clause.

NOTE 2 It is generally acknowledged that glass is not susceptible to storing an electrostatic charge.

7.4.2 Avoidance of a build-up of electrostatic charge on Group I or Group II electrical equipment

Electrical equipment shall be so designed that under normal conditions of use, maintenance and cleaning, danger of ignition due to electrostatic charges shall be avoided. This requirement shall be satisfied by one of the following:

- a) by suitable selection of the material so that surface resistance complies with either of the limits given below when measured in accordance with 26.13;
 $10^9 \Omega$ measured at $(50 \pm 5) \%$ relative humidity; or
 $10^{11} \Omega$ measured at $(30 \pm 5) \%$ relative humidity
- b) by limitation of the surface area of non-metallic parts of enclosures as shown in Table 6.

The surface area is defined as follows:

- for sheet materials, the area shall be the exposed (chargeable) area;
- for curved objects, the area shall be the projection of the object giving the maximum area;
- for individual non-metallic parts, the area shall be evaluated independently if they are separated by conductive earthed frames.

The values for surface area can be increased by a factor of four if the exposed area of non-metallic material is surrounded by and in contact with conductive earthed frames.

Alternatively, for long parts with non-metallic surfaces, such as tubes, bars, or ropes, the surface area need not be considered, but the diameters or widths shall not exceed the values shown in Table 7. Cables for connection of external circuits are not considered to fall under this requirement. See 16.7.

- c) by limitation of a non-metallic layer bonded to a conductive surface. The thickness of the non-metallic layer shall not exceed the values shown in Table 8 or the breakdown voltage shall be ≤ 4 kV (measured across the thickness of the insulating material according to the method described in IEC 60243-1);
- d) by provision of a conductive coating. Non-metallic surfaces may be covered with a bonded durable conductive coating. The resistance between coating and either the point of bond (in the case of equipment for fixed installations) or the farthest point of potential contact with the enclosure (in the case of portable equipment) shall not exceed $10^9 \Omega$. The resistance shall be measured in accordance with 26.13 but using a 100 mm^2 electrode at the worst case position of the surface and either the bond or the farthest point of potential contact. The equipment shall be marked "X" in accordance with item e) of 29.3 and the documentation shall provide guidance on the use of the bonding connection (for fixed equipment) and provide information to enable the user to decide on the durability of the coating material with respect to the environmental conditions;

NOTE 1 The environmental conditions that have an effect on the coating material may include influences from small particles in an air stream, solvent vapours, and the like.

- e) for fixed installations where the installation is intended to minimize the risk from electrostatic discharge, by marking the equipment "X" in accordance with item e) of 29.3. The instructions shall provide guidance for the user to minimize the risk from electrostatic discharge. Where practicable, the equipment shall also be marked with the electrostatic charge warning given in item g) of 29.12.

NOTE 2 Guidance on the risk of ignition from electrostatic discharge can be found in EN TR50404 and future IEC/TS 60079-32.

NOTE 3 Care should be taken when selecting the use of a warning label for static risk control. In many industrial applications, especially coal mining, it is highly likely that warning labels may become illegible through the deposition of dusts. If this is the case, it is possible that the act of cleaning the label may cause a static discharge.

NOTE 4 When selecting electrical insulating materials, attention should be paid to maintaining a minimum insulation resistance to avoid problems arising from touching exposed non-metallic parts that are in contact with live parts.

Table 6 – Limitation of surface areas

Maximum surface area mm ²				
Group I equipment	Group II equipment			
	Equipment protection level	Group IIA	Group IIB	Group IIC
10 000	EPL Ga	5 000	2 500	400
	EPL Gb	10 000	10 000	2 000
	EPL Gc	10 000	10 000	2 000

Table 7 – Maximum diameter or width

Maximum diameter or width mm				
Group I equipment	Group II equipment			
	Equipment protection level	Group IIA	Group IIB	Group IIC
30	EPL Ga	3	3	1
	EPL Gb	30	30	20
	EPL Gc	30	30	20

Table 8 – Limitation of thickness of non-metallic layer

Maximum thickness mm				
Group I equipment	Group II equipment			
	Equipment protection level	Group IIA	Group IIB	Group IIC
2	EPL Ga	2	2	0,2
	EPL Gb	2	2	0,2
	EPL Gc	2	2	0,2

NOTE 5 These thickness limitations do not apply to non-metallic layers that have a surface resistance of less than $10^9 \Omega$ or $10^{11} \Omega$, as applicable. See 7.4.2 a).

NOTE 6 One of main reasons for the thickness limitation is that the maximum thickness of non-metallic layer is intended to permit dissipation of charge through the insulation to earth. By this means the static charge is not able to build up to incandescence levels.

7.4.3 Avoidance of a build-up of electrostatic charge on equipment for Group III

Painted/coated metal equipment and equipment of plastic material shall be so designed that under normal conditions of use, danger of ignition due to propagating brush discharges is avoided.

Enclosures of plastic material cannot be charged to such a critical charge density that propagating brush discharges can be generated. However, no extended flat conductive surfaces shall be installed inside the enclosure within a distance of 8 mm to the outer surface.

NOTE 1 An internal printed circuit board may be considered to be an extended flat conductive surface, though this need not be applied in small hand-held equipment unless the equipment is likely to be subjected to a prolific charge generating mechanism (such as might occur in pneumatic transfer of powders or charge spraying in a powder coating process). Charging through normal handling of hand-held equipment is not considered to lead to a prolific charge generating mechanism and therefore would not lead to a situation where a propagating brush discharge might occur.

NOTE 2 A single flat conductive surface not exceeding 500 mm^2 is not considered to be an extended flat surface. This allows for the standoffs or brackets used for the mounting of conductive flat plates inside of an enclosure.

If plastic with a surface area exceeding 500 mm^2 is employed as a covering on a conductive material, the plastic shall have one or more of the following characteristics:

- by suitable selection of the material so that surface resistance complies with the limits given in 26.13;
- a breakdown voltage $\leq 4 \text{ kV}$ (measured across the thickness of the insulating material according to the method described in IEC 60243-1);
- a thickness $\geq 8 \text{ mm}$ of the external insulation on metal parts;

NOTE 3 External insulation of 8 mm and greater on metal parts such as measurement probes or similar components make propagating brush discharges unlikely to occur. When evaluating the minimum thickness of the insulation to be used or specified it is necessary to allow for any expected wear under normal usage.

- by marking the equipment "X" in accordance with item e) of 29.3. This is only applicable to electrical equipment intended for fixed installations where the installation is intended to minimize the risk from electrostatic discharge. The instructions shall provide guidance for the user to minimize the risk from electrostatic discharge.

7.5 Accessible metal parts

Accessible, metal parts with a resistance to earth of more than $10^9 \Omega$ could be susceptible to electrostatic charges that could become a source of ignition and shall be tested in accordance with the test method in 26.14. If the measured capacitance of each metal part exceeds the value shown in Table 9, the equipment shall be marked "X" in accordance with item a) of 29.3.

and the specific condition of use shall specify the value of capacitance determined to allow the user to determine suitability in the specific application.

NOTE 1 Guidance on the risk of ignition from electrostatic discharge can be found in EN TR50404 and IEC/TR60079-32 (in preparation).

Table 9 – Maximum capacitance of unearthed metal parts

Maximum capacitance pF				
Group I or Group III equipment	Group II equipment			
	Equipment protection level	Group IIA	Group IIB	Group IIC
10	EPL Ga	3	3	3
	EPL Gb	10	10	3
	EPL Gc	10	10	3

NOTE 2 It is generally accepted that an unearthed metal fastener such as a cover screw will present a capacitance of not more than 3 pF.

NOTE 3 For Group III equipment intended for use in ducts or pipes subject to the presence of fast moving dust, a lower limiting value for capacitance is under consideration.

8 Metallic enclosures and metallic parts of enclosures

8.1 Material composition

The documents according to Clause 24 shall specify the material of the enclosure or part of the enclosure.

NOTE 1 It is not a requirement of this standard that the chemical composition of material be verified by test.

NOTE 2 Paint or coatings applied to metallic enclosures may also have to be considered as non-metallic parts of an enclosure and the requirements of Clause 7 apply.

8.2 Group I

Materials used in the construction of enclosures of Group I electrical equipment of EPL Ma or Mb shall not contain, by mass, more than

- 15 % in total of aluminium, magnesium, titanium and zirconium, and
- 7,5 % in total of magnesium, titanium and zirconium.

The above requirement need not apply to Group I portable measuring equipment, but this equipment shall then be marked “X” in accordance with item e) of 29.3 and the specific condition of use shall indicate the special precautions to be applied during storage, transportation and use.

8.3 Group II

Materials used in the construction of enclosures of Group II electrical equipment for the identified equipment protection levels shall not contain, by mass, more than:

- for EPL Ga
10 % in total of aluminium, magnesium, titanium and zirconium, and
7,5 % in total of magnesium, titanium and zirconium;
- for EPL Gb
7,5 % in total of magnesium, titanium and zirconium;