

INTERNATIONAL STANDARD



**Electric cables – Calculation of the current rating –
Part 2-1: Thermal resistance – Calculation of thermal resistance**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2023 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Secretariat
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigendum or an amendment might have been published.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee, ...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and once a month by email.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

IEC Products & Services Portal - products.iec.ch

Discover our powerful search engine and read freely all the publications previews. With a subscription you will always have access to up to date content tailored to your needs.

Electropedia - www.electropedia.org

The world's leading online dictionary on electrotechnology, containing more than 22 300 terminological entries in English and French, with equivalent terms in 19 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.



IEC 60287-2-1

Edition 3.0 2023-05
COMMENTED VERSION

INTERNATIONAL STANDARD



**Electric cables – Calculation of the current rating –
Part 2-1: Thermal resistance – Calculation of thermal resistance**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-7061-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD	4
INTRODUCTION	7
1 Scope	8
2 Normative references	8
3 Terms, definitions and symbols	9
3.1 Terms and definitions	9
3.2 Symbols	9
4 Calculation of thermal resistances	12
4.1 Thermal resistance of the constituent parts of a cable, T_1 , T_2 and T_3	12
4.1.1 General	12
4.1.2 Thermal resistance between one conductor and sheath T_1	12
4.1.3 Thermal resistance of any generic annular layer	16
4.1.4 Thermal resistance between sheath and armour T_2	17
4.1.5 Thermal resistance of outer covering (serving) T_3	17
4.1.6 Pipe-type cables	18
4.2 External thermal resistance T_4	18
4.2.1 Cables laid in free air	18
4.2.2 Single isolated buried cable	20
4.2.3 Groups of buried cables (not touching)	21
4.2.4 Groups of buried cables (touching) equally loaded	24
~~4.2.5 Buried pipes~~	~~26~~
4.2.5 Cables in buried troughs	26
4.2.6 Cables in ducts or pipes	27
4.2.7 Cables or conduits laid in a medium of different thermal resistivity	28
5 Digital calculation of quantities given graphically	30
5.1 General	30
5.2 Geometric factor G for two-core belted cables with circular conductors	30
5.3 Geometric factor G for three-core belted cables with circular conductors	32
5.4 Thermal resistance of three-core screened cables with circular conductors compared to that of a corresponding unscreened cable	33
5.5 Thermal resistance of three-core screened cables with sector-shaped conductors compared to that of a corresponding unscreened cable	35
5.6 Curve for $\bar{G}$ for obtaining the thermal resistance of the filling material between the sheaths and armour of SL and SA type cables	36
5.7 Calculation of $\Delta\theta_s$ by means of a diagram	37
Annex A (informative) Correction factor for increased lengths of individual cores within multicore cables	52
Bibliography	53
List of comments	54
Figure 1 – Diagram showing a group of q cables and their reflection in the ground-air surface	42

Figure 2 – Geometric factor G for two-core belted cables with circular conductors (see 4.1.2.2.2)	43
Figure 3 – Geometric factor G for three-core belted cables with circular conductors (see 4.1.2.2.4)	44
Figure 4 – Thermal resistance of three-core screened cables with circular conductors compared to that of a corresponding unscreened cable (see 4.1.2.3.1)	45
Figure 5 – Thermal resistance of three-core screened cables with sector-shaped conductors compared to that of a corresponding unscreened cable (see 4.1.2.3.3)	46
Figure 6 – Geometric factor $\bar{G}$ for obtaining the thermal resistances of the filling material between the sheaths and armour of SL and SA type cables (see 4.1.2.5)	47
Figure 7 – Heat dissipation coefficient for black surfaces of cables in free air, laying conditions 1 to 4	48
Figure 8 – Heat dissipation coefficient for black surfaces of cables in free air, laying conditions 5 to 8	49
Figure 9 – Heat dissipation coefficient for black surfaces of cables in free air, laying conditions 9 and 10	50
Figure 10 – Graph for the calculation of external thermal resistance of cables in air	51
Table 1 – Thermal resistivities of materials	39
Table 2 – Extended values of the geometric factor for duct banks and backfills	40
Table 3 – Values for constants Z , E and gC_g for black surfaces of cables in free air	40
Table 4 – Absorption coefficient of solar radiation for cable surfaces	41
Table 5 – Values of constants U , V and Y	42
Table A.1 – Values of C_{fL} for different cases	52

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRIC CABLES –
CALCULATION OF THE CURRENT RATING –****Part 2-1: Thermal resistance –
Calculation of thermal resistance****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This commented version (CMV) of the official standard IEC 60287-2-1:2023 edition 3.0 allows the user to identify the changes made to the previous IEC 60287-2-1:2015 edition 2.0. Furthermore, comments from IEC TC 20 experts are provided to explain the reasons of the most relevant changes, or to clarify any part of the content.

A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text. Experts' comments are identified by a blue-background number. Mouse over a number to display a pop-up note with the comment.

This publication contains the CMV and the official standard. The full list of comments is available at the end of the CMV.

IEC 60287-2-1 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This third edition cancels and replaces the second edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) thorough redefinition of symbols used across the IEC 60287 and IEC 60853 series to realign and unify definitions, eliminate inconsistencies and to improve cross-use of the different parts of both IEC 60287 and IEC 60853 series; **1**
- b) improvement in the identification of tabulated materials and introduction of new materials in the tables;
- c) introduction of generic annular layers to improve thermal modelling of existing and future cables designs;
- d) improved calculation of T_4 in the case of directly buried cables;
- e) introduction of corrective factors, on relevant calculated physical characteristics to take into account the effect of multicore lay-lengths; a dedicated annex to highlight correction factors for different number of cores has been introduced (Annex A);
- f) improved description and formulation for the case of cables in pipe and backfill;
- g) redefinition of the calculation method of T_4 for duct banks where $y/x > 3$, the new table based method eliminates errors, extends the usability of the new formulation while keeping a suitable conservative margin in the calculation.

The text of this International Standard is based on the following documents:

Draft	Report on voting
20/2099/FDIS	20/2106/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60287 series, published under the general title *Electric cables – Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC 60287 series has been divided into three parts so that revisions of, and additions to the document can be carried out more conveniently.

Each part is subdivided into subparts which are published as separate standards.

Part 1: Formulae of ratings and power losses;

Part 2: Formulae for thermal resistance;

Part 3: Operating conditions.

This part of IEC 60287-2 contains methods for calculating the internal thermal resistance of cables and the external thermal resistance for cables laid in free air, ducts and buried.

The formulae in this document contain quantities which vary with cable design and materials used. The values given in the tables are either internationally agreed, for example, electrical resistivities and resistance temperature coefficients, or are those which are generally accepted in practice, for example, thermal resistivities and permittivities of materials. In this latter category, some of the values given are not characteristic of the quality of new cables but are considered to apply to cables after a long period of use. In order that uniform and comparable results ~~may~~ can be obtained, the current ratings should be calculated with the values given in this document. However, where it is known with certainty that other values are more appropriate to the materials and design, then these may be used, and the corresponding current rating declared in addition, provided that the different values are quoted.

Quantities related to the operating conditions of cables are liable to vary considerably from one country to another. For instance, with respect to the ambient temperature and soil thermal resistivity, the values are governed in various countries by different considerations. Superficial comparisons between the values used in the various countries ~~may~~ can lead to erroneous conclusions if they are not based on common criteria: for example, there ~~may~~ can be different expectations for the life of the cables, and in some countries design is based on maximum values of soil thermal resistivity, whereas in others average values are used. Particularly, in the case of soil thermal resistivity, it is well known that this quantity is very sensitive to soil moisture content and ~~may~~ can vary significantly with time, depending on the soil type, the topographical and meteorological conditions, and the cable loading.

The following procedure for choosing the values for the various parameters should, therefore, be adopted:

Numerical values should preferably be based on results of suitable measurements. Often such results are already included in national specifications as recommended values, so that the calculation may be based on these values generally used in the country in question; a survey of such values is given in IEC 60287-3-1.

A suggested list of the information required to select the appropriate type of cable is given in IEC 60287-3-1.

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 2-1: Thermal resistance – Calculation of thermal resistance

1 Scope

This part of IEC 60287 is solely applicable to the conditions of steady-state operation of cables at all alternating voltages, and direct voltages up to 5 kV, buried directly in the ground, in ducts, in troughs or in steel pipes, both with and without partial drying-out of the soil, as well as cables in air. The term "steady state" is intended to mean a continuous constant current (100 % load factor) just sufficient to produce asymptotically the maximum conductor temperature, the surrounding ambient conditions being assumed constant.

This document provides formulae for thermal resistance.

The formulae given are essentially literal and designedly leave open the selection of certain important parameters. These ~~may~~ can be divided into three groups:

- parameters related to construction of a cable (for example, thermal resistivity of insulating material) for which representative values have been selected based on published work;
- parameters related to the surrounding conditions which ~~may~~ can vary widely, the selection of which depends on the country in which the cables are used or ~~are to~~ will be used;
- parameters which result from an agreement between manufacturer and user and which involve a margin for security of service (for example, maximum conductor temperature).

Equations given in this document for calculating the external thermal resistance of a cable buried directly in the ground or in a buried duct are for a limited number of installation conditions. Where analytical methods are not available for calculation of external thermal resistance finite element methods ~~may~~ can be used. Guidance on the use of finite element methods for calculating cable current ratings is given in IEC TR 62095.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60287-1-1:2006/2023, *Electric cables – Calculation of the current rating – Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General*
~~IEC 60287-1-1:2006/AMD1:2014~~

IEC 60853-2, *Calculation of the cyclic and emergency current rating of cables – Part 2: Cyclic rating of cables greater than 18/30 (36) kV and emergency ratings for cables of all voltages*

3 Terms, definitions and symbols

3.1 Terms and definitions

No terms and definitions are listed in this document.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- IEC Electropedia: available at <https://www.electropedia.org/>
- ISO Online browsing platform: available at <https://www.iso.org/obp>

3.2 Symbols

The symbols used in this document and the quantities which they represent are given in the following list:

C_{fL}	factor to take into account the position of the neutral axis of the helically wound cores	
C_{K1}	screening factor for the thermal resistance of screened cables	
C_{LL}	length correction factor for considering laying up of cores	
D'_a	external diameter of armour	mm
D_d	internal diameter of duct	mm
D_e	external diameter of cable, or equivalent diameter of a group of cores in pipe-type cable	mm
D_e^*	external diameter of cable (used in 4.2.1)	m
D_o	external diameter of duct	mm
D_s	external diameter of metal sheath	mm
D_{oc}	diameter of the imaginary coaxial cylinder which just touches the crests of a corrugated sheath	mm
D_{ot}	diameter of the imaginary coaxial cylinder which would just touch the outside surface of the troughs of a corrugated sheath = $D_{it} + 2t_s$	mm
D_{ic}	diameter of the imaginary cylinder which would just touch the inside surface of the crests of a corrugated sheath = $D_{oc} - 2t_s$	mm
D_{it}	diameter of the imaginary cylinder which just touches the inside surface of the troughs of a corrugated sheath	mm
D_l	the inner diameter of any generic annular concentric cable element layer	mm
E	constant used for the heat dissipation in air coefficient in 4.2.1.1	
E_e	intensity of solar radiation	W/m ²
F_1	coefficient for belted cables defined in 4.1.2.2.3	
F_2	coefficient for belted cables defined in 4.1.2.2.6	
G	geometric factor for belted cables	
$\bar{G}$	geometric factor for SL and SA type cables	
~~H~~	~~intensity of solar radiation (see 4.2.1.2)~~	~~W/m²~~
~~K~~	~~screening factor for the thermal resistance of screened cables~~	

K_A	coefficient used in 4.2.1	
L	depth of laying, to cable axis or centre of trefoil	mm
L_G	distance from the soil surface to the centre of a duct bank	mm
L_L^*	axial cable length over which the cores make one full helical turn (m)	
N_L	number of loaded cables in a duct bank (see 4.2.7)	
P_h	part of the perimeter of the cable trough which is effective for heat dissipation (see 4.2.5.2)	m
T_1	thermal resistance per core between conductor and sheath	K · m/W
T_2	thermal resistance between sheath and armour	K · m/W
T_3	thermal resistance of external serving	K · m/W
T_4	thermal resistance of surrounding medium (ratio of cable surface temperature rise above ambient to the losses per unit length)	K · m/W
T_4^*	external thermal resistance in free air, adjusted for solar radiation	K · m/W
T_4'	thermal resistance between cable and duct (or pipe)	K · m/W
T_4''	thermal resistance of the duct (or pipe)	K · m/W
T_4'''	thermal resistance of the medium surrounding the duct (or pipe)	K · m/W
U	constant used in 4.2.6.3	
V	constant used in 4.2.6.3	
W_d	dielectric losses per unit length per phase	W/m
W_k	losses dissipated by cable k	W/m
W_{TOT}	total power dissipated in the trough per unit length	W/m
Y	coefficient used in 4.2.6.3	
Z	coefficient used in 4.2.1.1	
C_g	coefficient used in 4.2.1.1	
d_a	external diameter of belt insulation	mm
d_c	external diameter of conductor	mm
d_{cm}	minor diameter of an oval conductor	mm
d_{cM}	major diameter of an oval conductor	mm
d_M	major diameter of screen or sheath of an oval conductor	mm
d_m	minor diameter of screen or sheath of an oval conductor	mm
d_x	diameter of an equivalent circular conductor having the same cross-sectional area and degree of compactness as the shaped one	mm
~~g~~	~~coefficient used in 4.2.1.1~~	
h	heat dissipation coefficient	W/m ² K ^{5/4}
h_b	height of the duct bank or backfill	mm
$\ln$	natural logarithm (logarithm to base e)	
n	number of conductors in a cable	
~~p~~	~~the part of the perimeter of the cable trough which is effective for heat dissipation (see 4.2.6.2)~~	
r_1	circumscribing radius of two- or three-sector shaped conductors	mm

s_1	axial separation of two adjacent cables in a horizontal group of three, not touching	mm
t	insulation thickness between conductors	mm
t_1	insulation thickness between conductors and sheath	mm
t_2	thickness of the bedding	mm
t_3	thickness of the serving	mm
t_i	thickness of core insulation, including screening tapes plus half the thickness of any non-metallic tapes over the laid-up cores	mm
t_l	thickness of any generic annular concentric cable element layer	mm
t_s	thickness of the sheath	mm
$\frac{2L}{D_e}$	~~in 4.2.~~	
$\frac{L_G}{r_b}$	~~in 4.2.7.4~~	
x, y	~~sides of duct bank ($y > x$) (see 4.2.7.4)~~	~~mm~~
u_1	symbol used throughout the document e.g. in 4.2	
U_2	symbol used throughout the document e.g. in 4.2.6.5	
w_b	width of the duct bank or backfill	mm
θ_m	mean temperature of medium between a cable and duct or pipe	°C
$\Delta\theta$	permissible temperature rise of conductor above ambient temperature	K
$\Delta\theta_{d0}$	factor to account for dielectric loss for calculating T_4 for cables in free air	K
$\Delta\theta_{ds}$	factor to account for both dielectric loss and direct solar radiation for calculating T_4^* for cables in free air using Figure 10	K
$\Delta\theta_{duct}$	difference between the mean temperature of air in a duct and ambient temperature	K
$\Delta\theta_s$	difference between the surface temperature of a cable in air and ambient temperature	K
$\Delta\theta_{tr}$	temperature rise of the air in a cable trough	K
λ_1, λ_2	ratio of the total losses in metallic sheaths ~~and armour respectively~~ to the total conductor losses (or losses in one sheath ~~or armour~~ to the losses in one conductor)	
λ'_{1m}	loss factor for the middle cable	
λ'_{11}	loss factor for the outer cable with the greater losses	Three cables in flat formation without transposition, with sheaths bonded at both ends
λ'_{12}	loss factor for the outer cable with the least losses	
λ_2	ratio of the total losses in armour to the total conductor losses (or losses in one armour to the losses in one conductor)	
ρ	thermal resistivity of the soil	K · m/W
ρ_i	thermal resistivity of the insulation	K · m/W
ρ_f	thermal resistivity of the filler material	K · m/W
ρ_e	thermal resistivity of earth surrounding a duct bank	K · m/W
ρ_c	thermal resistivity of concrete used for a duct bank	K · m/W

ρ_m	thermal resistivity of metallic screens on multicore cables	K · m/W
ρ_T	thermal resistivity of material	K · m/W
$\epsilon\Sigma$	absorption coefficient of solar radiation for the cable surface	

4 Calculation of thermal resistances

4.1 Thermal resistance of the constituent parts of a cable, T_1 , T_2 and T_3

4.1.1 General

Clause 4 gives the formulae for calculating the thermal resistances per unit length of the different parts of the cable T_1 , T_2 and T_3 (see IEC 60287-1-1:2006—and IEC 60287-1-1:2006/AMD1:20142023, Clause 4). The thermal resistivities of materials used for insulation and for protective coverings are given in Table 1.

Subject to agreement between the manufacturer and user, measured values of the thermal resistivities may be used both for tabulated or new materials.

Where screening layers are present, for thermal calculations, metallic tapes are considered to be part of the conductor or sheath while semi-conducting layers (including metallized carbon paper tapes) are considered as part of the insulation. The appropriate component dimensions shall be modified accordingly.

4.1.2 Thermal resistance between one conductor and sheath T_1

4.1.2.1 Single-core cables

The thermal resistance between one conductor and the sheath T_1 is given by:

$$\tau_1 = \frac{\rho_T}{2\pi} \ln \left[1 + \frac{2t_1}{d_c} \right]$$

$$T_1 = \frac{\rho_1}{2\pi} \ln \left(1 + \frac{2t_1}{d_c} \right) \cdot \frac{1}{C_{LL}}$$

where

ρ_1 is the thermal resistivity of insulation (K · m/W);

d_c is the diameter of the conductor (mm);

t_1 is the thickness of insulation between the conductor and sheath (mm);

C_{LL} is the length correction factor for considering laying up cores. A proposal for its calculation is given in Annex A. **2**

In case more detailed evaluation of T_1 is preferred, for concentric annular layers as in the case where the conductor screen and the insulation screen are to be considered separately, the formulation of 4.1.3 should be used for each separate layer. **3**

NOTE For corrugated sheaths, t_1 is based on the mean internal diameter of the sheath which is given by:

$$\left(\frac{D_{it} + D_{oc}}{2} \right) - t_s$$

4.1.2.2 Belted cables

4.1.2.2.1 General

The thermal resistance T_1 between one conductor and sheath is given by:

$$T_1 = \frac{\rho_T}{2\pi} G$$

where

G is the geometric factor.

NOTE For corrugated sheaths, t_1 is based on the mean internal diameter of the sheath which is given by:

$$\left(\frac{D_{it} + D_{oc}}{2} \right) - t_s$$

4.1.2.2.2 Two-core belted cables with circular conductors

The geometric factor G is given in Figure 2.

4.1.2.2.3 Two-core belted cables with sector-shaped conductors

The geometric factor G is given by:

$$G = 2 F_1 \ln \left(\frac{d_a}{2 r_1} \right)$$

where

$$F_1 = 1 + \frac{2,2 t}{2\pi (d_x + t) - t};$$

d_a is the external diameter of the belt insulation (mm);

r_1 is the radius of the circle circumscribing the conductors (mm);

d_x is the diameter of a circular conductor having the same cross-sectional area and degree of compaction as the shaped one (mm);

t is the insulation thickness between conductors (mm).

4.1.2.2.4 Three-core belted cables with circular conductors

For three-core belted cables with circular conductors

$$T_1 = \frac{\rho_i}{2\pi} G + 0,031 (\rho_f - \rho_i) e^{0,67 \frac{t_1}{d_c}} \quad (1)$$

where

ρ_i is the thermal resistivity of the insulation (K · m/W);

ρ_f is the thermal resistivity of the filler material (K · m/W).

The geometric factor G is given in Figure 3.

NOTE—For paper-insulated cables $\rho_f = \rho_i$ and, hence, the second term on the right hand side of Equation (1) can be ignored.

For cables with extruded insulation, the thermal resistivity of the filler material is likely to be between $6 \text{ K} \cdot \text{m/W}$ and $13 \text{ K} \cdot \text{m/W}$, depending on the filler material and its compaction. A value of $10 \text{ K} \cdot \text{m/W}$ is suggested for fibrous polypropylene fillers.

The above Equation (1) is applicable to cables with extruded insulation where each core has an individual screen of spaced wires and to cables with a common metallic screen over all three cores. For unarmoured cables of this design t_1 is taken to be the thickness of the material between the conductors and outer covering (serving).

4.1.2.2.5 Three-core belted cables with oval conductors

The cable shall be treated as an equivalent circular conductor cable with an equivalent diameter

$$d_c = \sqrt{d_{cM} \times d_{cm}} \text{ (mm)}$$

where

d_{cM} is the major diameter of the oval conductor (mm);

d_{cm} is the minor diameter of the oval conductor (mm).

4.1.2.2.6 Three-core belted cables with sector-shaped conductors

The geometric factor G for these cables depends on the shape of the sectors, which varies from one manufacturer to another. A suitable formula is:

$$G = 3 F_2 \ln \left(\frac{d_a}{2 r_1} \right)$$

where

$$F_2 = 1 + \frac{3 t}{2\pi (d_x + t) - t};$$

d_a is the external diameter of the belt insulation (mm);

r_1 is the radius of the circle circumscribing the conductors (mm);

d_x is the diameter of a circular conductor having the same cross-sectional area and degree of compaction as the shaped one (mm);

t is the insulation thickness between conductors (mm).

4.1.2.3 Three-core cables, metal tape screened type

4.1.2.3.1 Screened cables with circular conductors

Paper insulated of this type may be first considered as belted cables for which $\frac{t_1}{t}$ is 0,5. Then,

in order to take account of the thermal conductivity of the metallic screens, the result shall be multiplied by a factor C_{K1} , called the screening factor, which is given in Figure 4 for different

values of $\frac{t_1}{d_c}$ and different cable specifications.

Thus:

$$\cancel{T_1 = K \frac{\rho_T}{2\pi} G}$$

$$T_1 = C_{K1} \frac{\rho_T}{2\pi} G$$

Three-core cables with extruded insulation and individual copper tape screens on each core should be treated as SL type cables (see 4.1.2.5 and 4.1.4.2).

See 4.1.2.2.4 for three-core cables with extruded insulation and an individual screen of spaced copper wires on each core or a common metallic screen over all three cores.

4.1.2.3.2 Screened cables with oval-shaped conductors

The cable shall be treated as an equivalent circular conductor cable with an equivalent diameter

$$d_C = \sqrt{d_{CM} \cdot d_{cm}}.$$

4.1.2.3.3 Screened cables with sector-shaped conductors

T_1 is calculated for these cables in the same way as for belted cables with sector-shaped conductors, but d_a is taken as the diameter of a circle which circumscribes the core assembly. The result is multiplied by a screening factor given in Figure 5.

4.1.2.4 Oil-filled cables

4.1.2.4.1 Three-core cables with circular conductors and metallized paper core screens and circular oil ducts between the cores

The thermal resistance between one conductor and the sheath, T_1 , is given by:

$$T_1 = 0,385 \rho_T \left(\frac{2 t_i}{d_C + 2 t_i} \right)$$

where

d_C is the conductor diameter (mm);

t_i is the thickness of the core insulation including carbon black and metallized paper tapes plus half of any non-metallic tapes over the three laid-up cores (mm);

ρ_T is the thermal resistivity of insulation (K · m/W).

This formula assumes that the space occupied by the metal ducts and the oil inside them has a thermal conductance very high compared with the insulation, it therefore applies irrespective of the metal used to form the duct or its thickness.

4.1.2.4.2 Three-core cables with circular conductors and metal tape core screens and circular oil ducts between the cores

The thermal resistance T_1 between one conductor and the sheath is given by:

$$T_1 = 0,35 \rho_T \left(0,923 - \frac{d_C}{d_C + 2 t_i} \right)$$

where

t_i is the thickness of the core insulation including the metal screening tapes and half on any non-metallic tapes over the three laid-up cores (mm).

NOTE This formula is independent of the metals used for the screens and for the oil ducts.

4.1.2.4.3 Three-core cables with circular conductors, metal tape core screens, without fillers and oil ducts, having a copper woven fabric tape binding the cores together and a corrugated aluminium sheath

The thermal resistance T_1 between one conductor and the sheath is given by:

$$T_1 = \frac{475}{D_c^{1,74}} \left(\frac{t_g}{D_c} \right)^{0,62} + \frac{\rho_T}{2\pi} \ln \left(\frac{d_c - 2 \delta_1}{d_c} \right)$$

where

$$t_g = 0,5 \left[\left(\frac{D_{it} + D_{ic}}{2} \right) - 2,16 D_c \right];$$

D_c is the diameter of a core over its metallic screen tapes (mm);

t_g is the average nominal clearance between the core metallic screen tapes and the average inside diameter of the sheath (mm);

δ_1 is the thickness of the metallic tape core screen (mm).

NOTE The formula is independent of the metal used for the screen tapes.

4.1.2.5 SL and SA type cables

An SL or SA type cable is a three-core cable where each core has an individual lead or aluminium sheath. The sheath is considered to be sufficiently substantial so as to provide an isotherm at the outer surface of the insulation.

The thermal resistance T_1 is calculated in the same way as for single-core cables.

4.1.3 Thermal resistance of any generic annular layer 4

In the general case of any concentric annular layer (e.g. semi-conductive screening elements and single or multiple insulation layers) the thermal resistance of said annular layer can be computed by the generic formula:

$$T_l = \frac{1}{2\pi} \rho_T \ln \left(1 + \frac{2 t_l}{D_l} \right) \cdot \frac{1}{C_{LL}}$$

where

t_l is the thickness of the generic concentric annular layer (mm);

D_l is the internal diameter of the generic concentric annular layer to be evaluated (mm);

C_{LL} is the length correction factor for considering laying up cores. A proposal for its calculation is given in Annex A.

The overall thermal resistance of any cable element composed by several concentric annular layers can be computed as the algebraic sum of each single annular sub-layer thermal resistance evaluated by the above generic formula.

4.1.4 Thermal resistance between sheath and armour T_2

4.1.4.1 Single-core, two-core and three-core cables having a common metallic sheath

The thermal resistance between sheath and armour, T_2 , is given by:

$$T_2 = \frac{1}{2\pi} \rho_T \ln \left(1 + \frac{2 t_2}{D_s} \right)$$

where

t_2 is the thickness of the bedding (mm);

D_s is the external diameter of the sheath (mm).

NOTE For unarmoured cables with extruded insulation where each core has an individual screen of spaced wires and for unarmoured cables with a common metallic screen over all three cores $T_2 = 0$.

4.1.4.2 SL and SA type cables

The thermal resistance of fillers and bedding under the armour is given by:

$$T_2 = \frac{\rho_T}{6\pi} \bar{G}$$

where

$\bar{G}$ is the geometric factor given in Figure 6.

If a protective jacket is applied over the single phase, the additional thermal resistance shall be evaluated as that of an additional generic annular layer (see 4.1.3).

4.1.5 Thermal resistance of outer covering (serving) T_3

4.1.5.1 General case

The external servings are generally in the form of concentric layers and the thermal resistance T_3 is given by:

$$T_3 = \frac{1}{2\pi} \rho_T \ln \left(1 + \frac{2 t_3}{D'_a} \right)$$

where

t_3 is the thickness of the serving (mm);

D'_a is the external diameter of the armour (mm).

NOTE For unarmoured cables D'_a is taken as the external diameter of the component immediately beneath it, i.e. sheath, screen or bedding.

For corrugated sheaths:

$$T_3 = \frac{1}{2\pi} \rho_T \ln \left[\frac{D_{oc} + 2t_3}{\left(\frac{D_{oc} + D_{it}}{2} \right) + t_s} \right]$$

4.1.5.2 Unarmoured three-core cables with extruded insulation and individual copper tape screens on each core

The thermal resistance of the fillers, binder and external serving is given by:

$$T_3 = \frac{\rho_T}{2\pi} \ln \left(1 + \frac{2t_3}{D'_a} \right) + \frac{\rho_f}{6\pi} \bar{G}$$

where

ρ_f is the thermal resistivity of the filler (K · m/W);

$\bar{G}$ is the geometric factor given in Figure 6 based on the thickness of material between the copper tape screen and the outer covering (serving);

D'_a is taken as the diameter over the binder tape.

4.1.6 Pipe-type cables

For these three-core cables, the following are generally present:

- a) The thermal resistance T_1 of the insulation of each core between the conductor and the screen. This is calculated by the method set out in 4.1.2 for single-core cables.
- b) The thermal resistance T_2 is made up of two parts:

- 1) The thermal resistance of any serving over the screen or sheath of each core. The value to be substituted for part of T_2 in the rating equation of IEC 60287-1-1:2006 and IEC 60287-1-1:2006/AMD1:20142023, Clause 4 is the value per cable, i.e. the value for a three-core cable is one-third the value of a single core.

The value per core is calculated by the method given in 4.1.3 for the bedding of single-core cables. For oval cores, the geometric mean of the major and minor diameter $\sqrt{d_M \cdot d_m}$ shall be used in place of the diameter for a circular core assembly.

- 2) The thermal resistance of the gas or oil between the surface of the cores and the pipe. This resistance is calculated in the same way as that part of T_4 which is between a cable and the internal surface of a duct, as given in 4.2.6.3.

The value calculated will be per cable and should be added to the quantity calculated in 4.1.6 b)1) above, before substituting for T_2 in the rating equation of IEC 60287-1-1:2006 and IEC 60287-1-1:2006/AMD1:20142023, Clause 4.

- c) The thermal resistance T_3 of any external covering on the pipe is dealt with as in 4.1.4. The thermal resistance of the metallic pipe itself is negligible.

4.2 External thermal resistance T_4

4.2.1 Cables laid in free air

4.2.1.1 Cables protected from direct solar radiation

The thermal resistance T_4 of the surroundings of a cable in air and protected from solar radiation is given by the formula:

$$T_4 = \frac{1}{\pi D_e^* h (\Delta\theta_s)^{1/4}}$$

where with

$$\frac{h - \frac{Z}{(D_e^*)^g} + E}{(D_e^*)^g}$$

$$h = \frac{Z}{(D_e^*)^{C_g}} + E \quad (2)$$

where

D_e^* is the external diameter of the cable (m)
for corrugated sheaths $D_e^* = (D_{oc} + 2 t_3) \cdot 10^{-3}$ (m);

NOTE Throughout 4.2.1 D_e^* is expressed in metres.

h is the heat dissipation coefficient obtained either from Formula (2) using the appropriate values of constants Z , E and C_g given in Table 3, or from the curves in Figure 7, Figure 8 and Figure 9, which are reproduced for convenience ($W/m^2 (K)^{5/4}$);

Served cables and cables having a non-metallic surface should be considered to have a black surface. Unserved cables, either plain lead or armoured should be given a value of h equal to 88 % of the value for a black surface;

$\Delta\theta_s$ is the excess of the cable surface temperature above the ambient temperature (see hereinafter for method of calculation) (K).

For cables in unfilled troughs, see 4.2.5.2

Calculation of $(\Delta\theta_s)^{1/4}$:

A simple iterative method of calculating $(\Delta\theta_s)^{1/4}$ is given below. The alternative graphical method is described in 5.7.

Calculate

$$K_A = \frac{\pi D_e^* h}{(1 + \lambda_1 + \lambda_2)} \left[\frac{T_1}{n} + T_2 (1 + \lambda_1) + T_3 (1 + \lambda_1 + \lambda_2) \right]$$

then

$$(\Delta\theta_s)_{n+1}^{1/4} = \left[\frac{\Delta\theta + \Delta\theta_d}{1 + K_A (\Delta\theta_s)_n^{1/4}} \right]^{0,25}$$

Set the initial value of $(\Delta\theta_s)^{1/4} = 2$ and reiterate until $(\Delta\theta_s)_{n+1}^{1/4} - (\Delta\theta_s)_n^{1/4} \leq 0,001$

where

$$\Delta\theta_d = W_d \left[\left(\frac{1}{1 + \lambda_1 + \lambda_2} - \frac{1}{2} \right) T_1 - \frac{n \lambda_2 T_2}{1 + \lambda_1 + \lambda_2} \right].$$

This is a factor **which**, having the dimensions of temperature difference, accounts for the dielectric losses. If the dielectric losses are neglected, $\Delta\theta_d = 0$.

$\Delta\theta$ is the permissible conductor temperature rise above the ambient temperature.

4.2.1.2 Cables directly exposed to solar radiation – External thermal resistance T_4^*

Where cables are directly exposed to solar radiation, T_4^* is calculated by the method given in 4.2.1.1 except that in the iterative method $(\Delta\theta_s)^{1/4}$ is calculated using the following formula:

$$(\Delta\theta_s)_{n+1}^{1/4} = \left[\frac{\Delta\theta + \Delta\theta_d + \Delta\theta_{ds}}{1 + K_A (\Delta\theta_s)_n^{1/4}} \right]^{0,25}$$

Where

~~$$\Delta\theta_{ds} = \frac{\sigma D_e^* H}{(1 + \lambda_1 + \lambda_2)} \left[\frac{T_1}{n} + T_2 (1 + \lambda_1) + T_3 (1 + \lambda_1 + \lambda_2) \right]$$~~

$$\Delta\theta_{ds} = \frac{\sigma D_e^* E_e}{(1 + \lambda_1 + \lambda_2)} \left[\frac{T_1}{n} + T_2 (1 + \lambda_1) + T_3 (1 + \lambda_1 + \lambda_2) \right].$$

This is a factor which, having the dimensions of temperature difference, accounts for direct solar radiation.

where

σ is the absorption coefficient of solar radiation for the cable surface (see Table 4);

~~H~~ E_e is the intensity of solar radiation which should be taken as 10^3 W/m² for most latitudes; it is recommended that the local value should be obtained where possible;

D_e^* is the external diameter of the cable (m)
for corrugated sheaths $D_e^* = (D_{oc} + 2 t_3) \cdot 10^{-3}$ (m).

The alternative graphical method is included in Figure 10.

4.2.2 Single isolated buried cable

~~$$T_4 = \frac{1}{2\pi \rho_1} \ln \left(u_1 + \sqrt{u_1^2 - 1} \right)$$~~

$$T_4 = \frac{1}{2\pi} \rho \ln \left(u_1 + \sqrt{u_1^2 - 1} \right)$$

where

ρ is the thermal resistivity of the soil (K · m/W);

$$u = \frac{2L}{D_e} \quad u_1 = \frac{2L}{D_e};$$

L is the distance from the surface of the ground to the cable axis (mm);

D_e is the external diameter of the cable (mm)

for corrugated sheaths $D_e = D_{oc} + 2 t_3$.

~~When the value of u exceeds 10, a good approximation (closer than 1 part in 1 000) is:~~

~~$$T_4 = \frac{1}{2\pi} \rho_T \ln(2u)$$~~

The previously accepted approximation for values of u_1 exceeding 10:

$$T_4 = \frac{1}{2\pi} \rho_T \ln(2u_1)$$

is considered no longer necessary and it is preferred to avoid its use in future calculations.

For cable circuits installed at laying depths of more than 10 m, an alternative approach for calculating the current rating is to determine the continuous current rating for a designated time period (usually 40 years) by applying the formulae given in IEC 60853-2, taking into account as far as is practical seasonal variations in load and ground conditions, if any. Finite element modelling ~~may can~~ provide a more versatile model for such a lifetime assessment. ~~This subject is under consideration.~~

4.2.3 Groups of buried cables (not touching)

4.2.3.1 General

Such cases ~~may can~~ be solved by using superposition, assuming that each cable acts as a line source and does not distort the heat field due to the other cables.

These cables are of two main types: the first, and most general type, is a group of unequally loaded cables of different construction, and for this problem a general indication of the method only can be given. The second type, which is a more particular one, is a group of equally loaded identical cables, and for this problem a fairly simple solution can be derived.

4.2.3.2 Unequally loaded cables

The method suggested for groups of unequally loaded dissimilar cables is to calculate the temperature rise at the surface of the cable under consideration caused by the other cables of the group, and to subtract this rise from the value of $\Delta\theta$ used in the equation for the rated current in IEC 60287-1-1: ~~2006 and IEC 60287-1-1:2006/AMD1:2014~~ 2023, Clause 4. An estimate of the power dissipated per unit length of each cable shall be made beforehand, and this can be subsequently amended as a result of the calculation where this becomes necessary.

Thus, the temperature rise $\Delta\theta_p$ above ambient at the surface of the p^{th} cable, whose rating is being determined, caused by the power dissipated by the other $(q - 1)$ cables in the group, is given by:

$$\Delta\theta_p = \Delta\theta_{1p} + \Delta\theta_{2p} + \dots \Delta\theta_{kp} + \dots \Delta\theta_{qp}$$

(the term $\Delta\theta_{pp}$ is excluded from the summation)

where

$\Delta\theta_{kp}$ is the temperature rise at the surface of the cable produced by the power W_k watt per unit length dissipated in cable k:

$$\Delta\theta_{kp} = \frac{1}{2\pi} \rho T W_k \ln \left(\frac{d'_{pk}}{d_{pk}} \right)$$

$$\Delta\theta_{kp} = \frac{1}{2\pi} \rho W_k \ln \left(\frac{d'_{pk}}{d_{pk}} \right)$$

The distances d_{pk} and d'_{pk} are measured from the centre of the p^{th} cable to the centre of cable k, and to the centre of the reflection of cable k in the ground-air surface respectively (see Figure 1).

The value of $\Delta\theta$ in the equation for the rated current in IEC 60287-1-1:2006 and IEC 60287-1-1:2006/AMD1:2014:2023, Clause 4 is then reduced by the amount $\Delta\theta_p$ and the rating of the p^{th} cable is determined using a value T_4 corresponding to an isolated cable at position p .

This calculation is performed for all cables in the group and is repeated where necessary to avoid the possibility of overheating any cable.

4.2.3.3 Equally loaded identical cables

4.2.3.3.1 General

The second type of grouping is where the rating of a number of equally loaded identical cables is determined by the rating of the hottest cable. It is usually possible to decide from the configuration of the installation which cable will be the hottest, and to calculate the rating for this one. In case of difficulty, a further calculation for another cable ~~may~~ can be necessary. The method is to calculate a modified value of T_4 which takes into account the mutual heating of the group and to leave unaltered the value of $\Delta\theta$ used in the rating equation of IEC 60287-1-1:2006 and IEC 60287-1-1:2006/AMD1:2014:2023, Clause 4.

The modified value of the external thermal resistance T_4 of the p^{th} cable is given by:

$$T_4 = \frac{1}{2\pi} \rho \ln \left\{ \left(u_1 + \sqrt{u_1^2 - 1} \right) \left[\left(\frac{d'_{p1}}{d_{p1}} \right) \left(\frac{d'_{p2}}{d_{p2}} \right) \dots \left(\frac{d'_{pk}}{d_{pk}} \right) \dots \left(\frac{d'_{pq}}{d_{pq}} \right) \right] \right\}$$

$$T_4 = \frac{1}{2\pi} \rho \ln \left\{ \left(u_1 + \sqrt{u_1^2 - 1} \right) \left[\left(\frac{d'_{p1}}{d_{p1}} \right) \left(\frac{d'_{p2}}{d_{p2}} \right) \dots \left(\frac{d'_{pk}}{d_{pk}} \right) \dots \left(\frac{d'_{pq}}{d_{pq}} \right) \right] \right\}$$

There are $(q - 1)$ terms, with the term $\frac{d'_{pp}}{d_{pp}}$ excluded.

The distances d_{pk} , etc., are the same as those shown in Figure 1, for the first method.

~~The simpler version 2 u may be used instead of $u_1 + \sqrt{u_1^2 - 1}$ if suitable (see 4.2.2).~~

The simpler version 2 u_1 instead of $u_1 + \sqrt{u_1^2 - 1}$ is considered no longer suitable and should be discontinued (see 4.2.2). **5**

For simple configurations of cables, this formula may be simplified considerably. The following examples were obtained by the use of superposition.

4.2.3.3.2 Two cables having equal losses, laid in a horizontal plane, spaced apart

$$\cancel{T_4 = \frac{1}{2\pi} \rho \left[\ln(u + \sqrt{u^2 - 1}) + \ln \left[1 + \left(\frac{2L}{s_1} \right)^2 \right] \right]}$$

$$T_4 = \frac{1}{2\pi} \rho \left\{ \ln(u_1 + \sqrt{u_1^2 - 1}) + \frac{1}{2} \ln \left[1 + \left(\frac{2L}{s_1} \right)^2 \right] \right\}$$

where

$$\cancel{u = \frac{2L}{D_e}} \quad u_1 = \frac{2L}{D_e};$$

L is the distance from the surface of the ground to the cables axis (mm);

D_e is the external diameter of one cable (mm);

s_1 is the axial separation between two adjacent cables (mm).

~~When the value of u exceeds 10, the term $(u + \sqrt{u^2 - 1})$ may be replaced by $(2u)$.~~

The approximation suggested when the value of u exceeds 10, utilizing the term $u_1 + \sqrt{u_1^2 - 1}$, is considered no longer suitable and should be discontinued (see 4.2.2). **5**

4.2.3.3.3 Three cables having approximately equal losses, laid in a horizontal plane, equally spaced apart

$$\cancel{T_4 = \frac{1}{2\pi} \rho \left[\ln(u + \sqrt{u^2 - 1}) + \ln \left[1 + \left(\frac{2L}{s_1} \right)^2 \right] \right]}$$

$$T_4 = \frac{1}{2\pi} \rho \left\{ \ln(u_1 + \sqrt{u_1^2 - 1}) + \ln \left[1 + \left(\frac{2L}{s_1} \right)^2 \right] \right\}$$

The value T_4 is that of the centre cable of the group and is used directly in the equation of IEC 60287-1-1:2006/2023, 4.2.

4.2.3.3.4 Three cables having unequal sheath losses, laid in a horizontal plane, equally spaced apart

When the losses in the sheaths of single-core cables laid in a horizontal plane are appreciable, and the sheaths are laid either without transposition and/or where the sheaths are bonded at all joints, their inequality affects the external thermal resistances of the hottest cable. In such cases the value of T_4 to be used in the numerator of the rating equation in IEC 60287-1-1:2006/2023, 4.2 is as given in 4.2.3.3.3, but a modified value of T_4 shall be used in the denominator, and is given by:

$$\cancel{T_4 = \frac{1}{2\pi} \rho_T \left\{ \ln(u + \sqrt{u^2 - 1}) + \left[\frac{1 + 0,5(\lambda'_{11} + \lambda'_{12})}{1 + \lambda'_{lm}} \right] \ln \left[1 + \left(\frac{2L}{s_1} \right)^2 \right] \right\}}$$

$$T_4 = \frac{1}{2\pi} \rho \left\{ \ln(u_1 + \sqrt{u_1^2 - 1}) + \left[\frac{1 + 0,5(\lambda'_{11} + \lambda'_{12})}{1 + \lambda'_{lm}} \right] \ln \left[1 + \left(\frac{2L}{s_1} \right)^2 \right] \right\}$$

This assumes that the centre cable is the hottest cable. The value of λ_1 to be used in the rating equation of IEC 60287-1-1:20062023, 4.2 is that for the centre cable,

where

$$\cancel{u = \frac{2L}{D_e}} \quad u_1 = \frac{2L}{D_e};$$

L is the distance from the surface of the ground to the cables axis (mm);

D_e is the external diameter of one cable (mm);

s_1 is the axial separation between two adjacent cables (mm);

λ'_{11} is the sheath loss factor for an outer cable of the group;

λ'_{12} is the sheath loss factor for the other outer cable of the group;

λ'_{lm} is the sheath loss factor for the middle cable of the group.

~~When the value of u exceeds 10, the term $(u + \sqrt{u^2 - 1})$ may be replaced by $(2u)$.~~

The approximation suggested when the value of u exceeds 10, utilizing the term $u + \sqrt{u^2 - 1}$, is considered no longer suitable and should be discontinued (see 4.2.2). **5**

4.2.4 Groups of buried cables (touching) equally loaded

4.2.4.1 Two single-core cables, flat formation

4.2.4.1.1 Metallic sheathed cables

Metallic sheathed cables are taken to be cables where it can be assumed that there is a metallic layer that provides an isotherm at, or immediately under, the outer sheath of the cable.

$$\cancel{T_4 = \frac{\rho_T}{\pi} (\ln(2u) - 0,451)} \quad \text{for } u \geq 5$$

$$T_4 = \frac{\rho}{\pi} \left(\ln(u_1 + \sqrt{u_1^2 - 1}) - 0,451 \right) \text{ for } u_1 \geq 5$$

4.2.4.1.2 Non-metallic sheathed cables

Non-metallic sheathed cables are taken to be cables where any metallic layer at, or immediately under, the outer sheath of the cable is not sufficient to provide an isotherm.

~~$$T_4 = \frac{\rho_T}{\pi} (\ln(2u) - 0,295) \text{ for } u \geq 5$$~~

$$T_4 = \frac{\rho}{\pi} \left(\ln \left(u_1 + \sqrt{u_1^2 - 1} \right) - 0,295 \right) \text{ for } u_1 \geq 5$$

This formula is used for non-metallic sheathed cables having a copper wire screen and for the external thermal resistance of non-metallic touching ducts (see 4.2.6.4).

4.2.4.2 Three single-core cables, flat formation

4.2.4.2.1 Metallic sheathed cables

Metallic sheathed cables are taken to be cables where it can be assumed that there is a metallic layer that provides an isotherm at, or immediately under, the outer sheath of the cable. The value of λ_1 used in the rating equation of IEC 60287-1-1:2006/2023, 4.2.1 is the average of the λ_1 values for the three cables.

~~$$T_4 = \frac{\rho_T}{\pi} (0,475 \ln(2u) - 0,346) \text{ for } u \geq 5$$~~

$$T_4 = \rho \left(0,475 \ln \left(u_1 + \sqrt{u_1^2 - 1} \right) - 0,346 \right) \text{ for } u_1 \geq 5$$

4.2.4.2.2 Non-metallic sheathed cables

Non-metallic sheathed cables are taken to be cables where any metallic layer at, or immediately under, the outer sheath of the cable is not sufficient to provide an isotherm.

~~$$T_4 = \frac{\rho_T}{\pi} (0,475 \ln(2u) - 0,142) \text{ for } u \geq 5$$~~

$$T_4 = \rho \left(0,475 \ln \left(u_1 + \sqrt{u_1^2 - 1} \right) - 0,142 \right) \text{ for } u_1 \geq 5$$

This formula is used for non-metallic sheathed cables having a copper wire screen and for the external thermal resistance of non-metallic touching ducts (see 4.2.6.4).

4.2.4.3 Three single-core cables, trefoil formation

4.2.4.3.1 General

For this configuration, L is measured to the centre of the trefoil group and D_e is the diameter of one cable. T_4 is the external thermal resistance of any one of the cables and the configuration may be with the apex either at the top or at the bottom of the group.

For corrugated sheaths, $D_e = D_{oc} + 2 t_3$.

4.2.4.3.2 Metallic sheathed cables

~~$$T_4 = \frac{1,5}{\pi} \rho_T [\ln(2u) - 0,630]$$~~

$$T_4 = \frac{1,5}{\pi} \rho \left[\ln \left(u_1 + \sqrt{u_1^2 - 1} \right) - 0,630 \right]$$

In this case, the thermal resistance of the serving over the sheath or armour, T_3 , as calculated by the method given in 4.1.4 shall be multiplied by a factor of 1,6.

4.2.4.3.3 Part-metallic covered cables (where helically laid armour or screen wires cover from 20 % to 50 % of the cable circumference)

This formula is based on a long lay (15 times the diameter under the wire screen) 0,7 mm diameter, individual copper wires having a total cross-sectional area of between 15 mm² and 35 mm².

~~$$T_4 = \frac{1,5}{\pi} \rho_1 \left[\ln(2u) - 0,630 \right]$$~~

$$T_4 = \frac{1,5}{\pi} \rho \left[\ln \left(u_1 + \sqrt{u_1^2 - 1} \right) - 0,630 \right]$$

In this case, the thermal resistance of the insulation T_1 , as calculated by the method given in 4.1.2.1 and the thermal resistance of the serving T_3 , as calculated by the method given in 4.1.3 shall be multiplied by the following factors:

- T_1 : by 1,07 for cables up to 35 kV;
by 1,16 for cables from 35 kV to 150 kV;
 T_3 : by 1,6.

4.2.4.3.4 Non-metallic sheathed cables

~~$$T_4 = \frac{1}{2\pi} \rho_1 \left[\ln(2u) + 2 \ln(u) \right]$$~~

$$T_4 = \frac{1}{2\pi} \rho \ln \left[\left(u_1 + \sqrt{u_1^2 - 1} \right) + 2 \ln(u_1) \right]$$

This formula is used for non-metallic sheathed cables having a screen of spaced copper wires and for the external thermal resistance of touching ducts (see 4.2.6.4).

~~4.2.5 Buried pipes~~

~~The external thermal resistance of buried pipes used for pipe-type cables is calculated as for ordinary cables, using the formula in 4.2.2. In this case, the depth of laying L is measured to the centre of the pipe and D_e is the external diameter of the pipe, including anti-corrosion covering.~~

4.2.5 Cables in buried troughs

4.2.5.1 Buried troughs filled with sand

Where cables are installed in sand-filled troughs, either completely buried or with the cover flush with the ground surface, there is danger that the sand will dry out and remain dry for long periods. The cable external thermal resistance ~~may~~ can then be very high and the cable ~~may~~ can reach undesirably high temperatures. It is advisable to calculate the cable rating using a value of 2,5 K · m/W for the thermal resistivity of the sand filling unless a specially selected filling has been used for which the dry resistivity is known.

4.2.5.2 Unfilled troughs of any type, with the top flush with the soil surface and exposed to free air

An empirical formula is used which gives the temperature rise of the air in the trough above the air ambient as:

$$\Delta\theta_{tr} = \frac{W_{TOT}}{3p}$$

$$\Delta\theta_{tr} = \frac{W_{TOT}}{3P_h}$$

where

W_{TOT} is the total power dissipated in the trough per metre length (W/m);

P_h is that part of the trough perimeter which is effective for heat dissipation (m).

Any portion of the perimeter, which is exposed to sunlight, is therefore not included in the value of P_h . The rating of a particular cable in the trough is then calculated as for a cable in free air (see 4.2.1), but the ambient temperature shall be increased by $\Delta\theta_{tr}$.

4.2.6 Cables in ducts or pipes

4.2.6.1 Overview

The external thermal resistance of buried pipes used for pipe-type cables is calculated as for ordinary cables, using the formula in 4.2.2. In this case, the depth of laying L is measured to the centre of the pipe and D_e is the external diameter of the pipe, including anti-corrosion covering.

4.2.6.2 General

The external thermal resistance of a cable in a duct consists of three parts:

- the thermal resistance of the air space between the cable surface and duct internal surface T'_4 ;
- the thermal resistance of the duct itself, T''_4 . The thermal resistance of a metal pipe is negligible;
- the external thermal resistance of the duct T'''_4 .

The value of T_4 to be substituted in the equation for the permissible current rating in IEC 60287-1-1:2006 and IEC 60287-1-1:2006/AMD1:2014 2023, Clause 4 will be the sum of the individual parts, i.e.:

$$T_4 = T'_4 + T''_4 + T'''_4$$

~~Cables in ducts which have been completely filled with a pumpable material having a thermal resistivity not exceeding that of the surrounding soil, either in the dry state or when sealed to preserve the moisture content of the filling material, may be treated as directly buried cables.~~ 6

4.2.6.3 Thermal resistance between cable and duct (or pipe) T'_4

For the cable diameters in the range 25 mm to 100 mm the following formula shall be used for ducted cables. It shall also be used for the thermal resistance of the space between the cores and pipe surface of a pipe-type cable (see 4.1.6), when the equivalent diameter of the three

cores in the pipe is within the range 75 mm to 125 mm. The equivalent diameter is defined below:

$$T_4' = \frac{U}{1 + 0,1(V + Y\theta_m) D_e}$$

where

U , V , Y are constants, depending on the installations the values of which are given in Table 5;

D_e is the external diameter of the cable (mm);
when the formula is used for pipe-type cables (see 4.1.6 b)), D_e becomes the equivalent diameter of the group of cores as follows:

- two cores: $D_e = 1,65 \times \text{core outside diameter (mm)}$;
- three cores: $D_e = 2,15 \times \text{core outside diameter (mm)}$;
- four cores: $D_e = 2,50 \times \text{core outside diameter (mm)}$;

θ_m is the mean temperature of the medium filling the space between the cable and duct. An assumed value ~~has to~~ shall be used initially and the calculation repeated with a modified value if necessary ($^{\circ}\text{C}$).

4.2.6.4 Thermal resistance of the duct (or pipe) itself T_4''

The thermal resistance (T_4'') across the wall of a duct shall be calculated from:

$$T_4'' = \frac{1}{2\pi} \rho_T \ln \left(\frac{D_o}{D_d} \right)$$

where

D_o is the outside diameter of the duct (mm);

D_d is the inside diameter of the duct (mm);

ρ_T is the thermal resistivity of the duct material ($\text{K} \cdot \text{m/W}$).

The value of ρ_T can be taken as zero for metal ducts, for other materials, see Table 1.

4.2.6.5 External thermal resistance of the duct (or pipe) T_4'''

This shall be determined for single-way duct(s) not embedded in concrete in the same way as for a cable, using the appropriate formulae given in 4.2.1, 4.2.2, 4.2.3 or 4.2.4, and the external radius of the duct or pipe including any protective covering thereon, replacing the external radius of the cable. ~~When the ducts are embedded in concrete, the calculation of the thermal resistance outside the ducts is first of all made assuming a uniform medium outside the ducts having a thermal resistivity equal to the concrete. A correction is then added algebraically to take account of the difference, if any, between the thermal resistivities of concrete and soil for that part of the thermal circuit exterior to the duct bank.~~

4.2.7 Cables or conduits laid in a medium of different thermal resistivity

When the cables or conduits (ducts or pipes) are embedded in a medium whose thermal resistivity differs from the one of the surrounding soil (backfill or concrete), the calculation of the thermal resistance outside the cables or conduits is performed in two steps:

- first of all, the external thermal resistance shall be determined using the appropriate formulae given in 4.2.2, 4.2.3 or 4.2.4 assuming a uniform medium outside the cables or conduits having a thermal resistivity equal to the backfill or concrete;
- a correction is then added algebraically to take account of the difference between the thermal resistivities of backfill or concrete and soil for that part of the thermal circuit exterior to the bank.

The correction to the thermal resistance is given by:

~~$$\frac{N}{2\pi} (\rho_e - \rho_c) \ln(u + \sqrt{u^2 - 1})$$~~

$$\frac{N_L}{2\pi} (\rho_e - \rho_c) \ln(u_2 + \sqrt{u_2^2 - 1})$$

where

N_L is the number of loaded cables in the duct bank;

ρ_e is the thermal resistivity of earth around the bank (K · m/W);

ρ_c is the thermal resistivity of concrete (K · m/W);

~~$$u = \frac{L_G}{r_b}$$~~
$$u_2 = \frac{L_G}{r_b};$$

L_G is the depth of laying to the centre of the duct bank (mm);

r_b is the equivalent radius of the concrete bank (mm).

In the previous editions of this standard the formulation utilized to evaluate r_b , the equivalent radius of concrete bank (mm), was given by:

$$\ln r_b = \frac{1}{2} \frac{x}{y} \left(\frac{4}{\pi} - \frac{x}{y} \right) \ln \left(1 + \frac{y^2}{x^2} \right) + \ln \frac{x}{2}$$

The quantities x and y are the shorter and longer sides, respectively, of the duct bank section irrespective of its position, in millimetres.

~~This formula is only valid for ratios of $\frac{y}{x}$ less than 3.~~

This formulation was considered valid for ratios between the longer and shorter sides of a rectangular duct bank that are less than 3.

This old formulation is considered no longer suitable for use and shall be entirely superseded by the new methodology based on tabulated values.

The equivalent duct-bank radius is given by:

$$r_b = \frac{L_G}{e^{G_b}}$$

where the geometric factor G_b is obtained from Table 2, values are tabulated for suitable values of the ratio L_G/h_b and the ratio h_b/w_b where:

L_G is the depth of laying to the centre of the duct bank (mm);

h_b is the height of the duct bank (mm);

w_b is the width of the duct bank (mm).

Such tabulated values are valid for the table range. Intermediate values shall be obtained by linear interpolation. **7**

5 Digital calculation of quantities given graphically

5.1 General

Clause 5 gives formulae and methods suitable for digital calculation for those quantities given in Figure 2 to Figure 6 and the procedure for calculating $\Delta\theta_s$ by means of Figure 10. The method used is approximation by algebraic expressions, followed by quadratic or linear interpolation where necessary. The maximum percentage error prior to interpolation is given for each case.

5.2 Geometric factor G for two-core belted cables with circular conductors

See Figure 2.

Denote $X = t_1/d_c$

$Y = (2t_1/t) - 1$

then $G = MG_s$

where

$$M = \ln \left[\frac{1 - \alpha\beta + \left[(1 - \alpha^2)(1 - \beta^2) \right]^{0.5}}{\alpha - \beta} \right]$$

$$\alpha = \frac{1}{\left[1 + \frac{X}{1 + X/(1 + Y)} \right]^2}$$

$$\beta = \frac{X}{1 + Y} - \frac{1}{2}$$

$$\alpha = \frac{X}{1 + Y} + \frac{3}{2}$$

$G_s = G_s(X, Y)$, i.e. is a function of both X and Y .

Calculate the three quantities $G_s(X, 0)$, $G_s(X, 0.5)$ and $G_s(X, 1)$

where:

$$G_s(X, 0) = 1,060\,19 - 0,067\,177\,8\,X + 0,017\,952\,1\,X^2$$

$$G_s(X, 0.5) = 1,067\,98 - 0,065\,164\,8\,X + 0,015\,812\,5\,X^2$$

$$G_s(X, 1) = 1,067\,00 - 0,055\,715\,6\,X + 0,012\,321\,2\,X^2$$

$G_s(X, Y)$ may be obtained by quadratic interpolation using the following formula:

$$G_s(X, Y) = G_s(X, 0) + Y \left[3 G_s(X, 0) + 4 G_s(X, 0.5) - G_s(X, 1) \right] + Y^2 \left[2 G_s(X, 0) - 4 G_s(X, 0.5) + 2 G_s(X, 1) \right]$$