IEC 60358-2

Edition 1.0 2013-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Coupling capacitors and capacitor dividers – Part 2: AC or DC single-phase coupling capacitor connected between line and ground for power line carrier-frequency (PLC) application

Condensateurs de couplage et diviseurs capacitifs – Partie 2: Condensateur de couplage monophasé à courant alternatif ou à courant continu connecté entre la ligne et la terre pour application aux liaisons à courant porteur sur lignes d'énergie (CPL)

IEC 60358-2:2013

Documents
Document Sharing Hub

Full document details: IEC 60358-2 2013

THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2013 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.
If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.
Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,…).
It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,…).
Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

Documents
Document Sharing Hub

Full document details: IEC 60358-2 2013

IEC 60358-2

Edition 1.0 2013-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Coupling capacitors and capacitor dividers – Part 2: AC or DC single-phase coupling capacitor connected between line and ground for power line carrier-frequency (PLC) application

Condensateurs de couplage et diviseurs capacitifs – Partie 2: Condensateur de couplage monophasé à courant alternatif ou à courant continu connecté entre la ligne et la terre pour application aux liaisons à courant porteur sur lignes d'énergie (CPL)

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

PRICE CODE
CODE PRIX R

ICS 29.120.99; 29.240.99; 31.060.70

ISBN 978-2-8322-1038-3

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

AVA Documents
Document Sharing Hub

® Registered trademark of the International Electrotechnical Commission
Marque déposée de la Commission Electrotechnique Internationale

Full document details: IEC 60358-2 2013

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms and definitions 7
3.200 Carrier-frequency accessories definitions 8
4 Service conditions 8
5 Ratings 8
6 Design requirements 8
6.200 Design requirements for coupling capacitor and carrier-frequency accessories 8
6.200.1 Design requirements for coupling capacitor 8
6.200.2 Design requirements for carrier-frequency accessories 9
7 Test conditions 10
8 Classification of tests 10
8.1 General 10
8.2 Routine tests 10
8.2.200 General 10
8.2.201 Routine tests for carrier frequency accessories 10
8.3 Type tests 10
8.3.200 Type test for coupling capacitor and carrier-frequency accessories 10
8.4 Special tests 11
9 Routine tests 11
9.1 Tightness of the liquid-filled equipment 11
9.2 Electrical routine tests 11
9.2.200 Electrical tests for coupling capacitor and carrier frequency accessories 11
10 Type tests 12
10.200 Test on capacitor 12
10.200.1 High frequency capacitance and equivalent series resistance 12
10.200.2 Measurement of the stray capacitance and stray conductance of the low voltage terminal 12
10.201 Type test on carrier frequency accessories 13
10.201.1 General 13
10.201.2 Type tests for drain coil 13
10.201.3 Type test for voltage limitation device together with drain coil: Impulse voltage test 14
11 Special tests 14
12 Marking 15
12.1 General 15
12.2 Marking of capacitor 15
12.200 Marking of the carrier-frequency accessories 15
Annexes 15
Annex A (informative) Typical diagram of an equipment 16

AVA Documents
Document Sharing Hub

Annex AA (informative) High-frequency characteristics of coupling capacitors for power line carrier circuits 17
Bibliography 19

Figure A.200.1 – Example of a diagram for a coupling capacitor with carrier-frequency accessories (see IEC 60481) 16
Figure AA.1 – Wiring diagram of the measuring circuit for the high-frequency capacitance and equivalent series resistance of a coupling capacitor 18
Figure AA.2 – Relation between length and capacitance where capacitive deviation – 20 % to +50 % can be fulfilled up to 500 kHz 18

Table 200 – Limits of temperature rise of windings 14

Documents
Document Sharing Hub

Full document details: IEC 60358-2 2013

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COUPLING CAPACITORS AND CAPACITOR DIVIDERS –

Part 2: AC or DC single-phase coupling capacitor connected between line and ground for power line carrier-frequency (PLC) application

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60358-2 has been prepared by IEC technical committee 33: Power capacitors and their applications.

The text of this standard is based on the following documents:

FDIS	Report on voting
33/531/FDIS	33/537/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60358 series, published under the general title *Coupling capacitors and capacitor dividers*, can be found on the IEC website.

Documents
Document Sharing Hub

Full document details: IEC 60358-2 2013

This International Standard is to be used in conjunction with the latest edition of IEC 60358-1 and its amendments. It was established on the basis of the first edition (2012) of that standard.

This Part 2 supplements or modifies the corresponding clauses in IEC 60358-1.

When a particular subclause of Part 1 is not mentioned in this Part 2, that subclause applies as far as is reasonable. Where this Part 2 states “addition” or “replacement”, the relevant text in Part 1 is to be adapted accordingly.

For additional clauses, subclauses, figures, tables or annexes, the following numbering system is used:

– subclauses, tables and figures which are additional to those in Part 1 are numbered starting from 200;
– additional annexes are lettered AA, BB etc.
– as the notes are integrated into the clauses, their numbering starts from 1 as usual.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: IEC 60358-2 2013

INTRODUCTION

This series consists of the following parts:

IEC 60358-1, *Coupling capacitors and capacitor dividers – Part 1: General rules*

IEC 60358-2, *Coupling capacitors and capacitor dividers – Part 2: AC or DC single-phase coupling capacitor connected between line and ground for power line carrier-frequency (PLC) application*

IEC 60358-3[1], *Coupling capacitors and capacitor dividers – Part 3: AC or DC single-phase coupling capacitor connected between line and ground for harmonic-filters applications*

IEC 60358-4[2], *Coupling capacitors and capacitor dividers – Part 4: AC or DC single-phase capacitor-divider and RC-divider connected between line and ground (except for CVT's which belong to IEC 61869 series)*

[1] Under consideration.

[2] Under consideration.

Documents
Document Sharing Hub

Full document details: IEC 60358-2 2013

COUPLING CAPACITORS AND CAPACITOR DIVIDERS –

Part 2: AC or DC single-phase coupling capacitor connected between line and ground for power line carrier-frequency (PLC) application

1 Scope

Clause 1 of IEC 60358-1:2012 is applicable with the following additions:

This part of the IEC 60358 series applies to AC or DC single-phase coupling capacitors, with rated voltage > 1 000 V, connected between line and ground with a low voltage terminal either permanently earthed or connected to a device for power line carrier-frequency (PLC) applications at frequencies from 30 kHz to 500 kHz or similar applications (DC or AC) at power frequencies from 15 Hz to 60 Hz.

The transmission requirements for coupling devices for power line carrier (PLC) systems are defined in IEC 60481.

NOTE Diagrams of coupling capacitors to which this standard applies are given in Figure A.1.

2 Normative references

Clause 2 of IEC 60358-1:2012 is replaced by the following:

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60060-2, *High-voltage test techniques – Part 2: Measuring systems*

IEC 60358-1:2012, *Coupling capacitors and capacitor dividers. – Part 1: General rules*

IEC 60481, *Coupling devices for power line carrier systems*

IEC 61869-5, *Instrument transformers – Part 5: Additional requirements for capacitor voltage transformers*

3 Terms and definitions

Clause 3 of IEC 60358-1:2012 is applicable with the following additions:

For the purposes of this document, the terms and definitions given in Clause 3 of IEC 60358-1:2012, as well as the following apply.

Documents
Document Sharing Hub

Full document details: IEC 60358-2 2013

3.200 Carrier-frequency accessories definitions

3.200.1
coupling device
arrangement of elements which contribute to ensure, together with one or more associated coupling capacitors, the transmission, under prescribed conditions, of carrier-frequency signals between one or more conductors of the power line and the carrier-frequency connection

3.200.2
carrier-frequency accessories
circuit element intended to permit the injection of carrier frequency signal and which is connected between the low voltage terminal of a coupling capacitor unit and earth, and having an impedance which is insignificant at the power frequency, but appreciable at carrier frequency

Note 1 to entry: See Figure A.1.

3.200.3
drain coil
inductance which is connected between the low voltage terminal of a coupling capacitor and earth, and whose impedance is insignificant at the power frequency, but has a high value at the carrier frequency

3.200.4
voltage limitation device
element connected between the coupling capacitor and earth to limit the overvoltages which appear across the coupling device.

Note 1 to entry: Overvoltages appear in case of:

a) a short circuit between the high-voltage terminal and earth;

b) where an impulse voltage is applied between the high voltage terminal and earth.

3.200.5
carrier earthing switch
switch for earthing the low voltage terminal

4 Service conditions

Clause 4 of IEC 60358-1:2012 is applicable.

5 Ratings

Clause 5 of IEC 60358-1:2012 is applicable.

6 Design requirements

Clause 6 of IEC 60358-1:2012 is applicable with the following additions:

6.200 Design requirements for coupling capacitor and carrier-frequency accessories

6.200.1 Design requirements for coupling capacitor

Coupling capacitors shall be designed to withstand an additional steady high frequency current of at least 1 A (r.m.s. value of current equivalent to a power of 400 W for a terminal resistance of 400 Ω), without any damage or deterioration.

Documents
Document Sharing Hub
Full document details: IEC 60358-2 2013

6.200.2 Design requirements for carrier-frequency accessories

6.200.2.1 General

The carrier-frequency accessories, comprising a drain coil and a protective device, shall be connected between the low voltage terminal of the coupling capacitor and the earth terminal. The connections are typically as shown in Figure A.1.

The requirements for the complete coupling device are specified in IEC 60481.

6.200.2.2 Drain coil

The drain coil shall be designed in such a way, that:

a) for an AC application, the impedance should be as low as possible and in no case exceed 20 Ω at power frequency;

   for a DC application, no standard value is defined; manufacturer and purchaser shall define the impedance value;

b) the current-carrying capability at power frequency is as follows:
   - continuous operation: rated current of capacitor, but not less than 1 A r.m.s.;
   - short-time current: 30 A r.m.s. for 0,2 s;

c) the drain coil shall be able to withstand a 1,2/50 µs impulse voltage whose peak value is twice the value of the impulse spark voltage of the voltage limitation device, but the minimum value should be 10 kV peak (see 10.201.2.2)

d) for a drain coil with iron core, the insulation between winding and iron core shall support 3 kV for 60 s (see 9.2.200.2.1.3).

e) If the maximum fundamental frequency current of the capacitor is higher than 1 A, the continuous operation current for the drain coil should be increased accordingly

f) for a DC application, the grading current of the coupling capacitor shall not saturate the drain coil.

6.200.2.3 Voltage limitation device

A lightning arrester shall be connected as directly as possible between the low voltage terminal of the coupling capacitor and the earth terminals and shall be capable of protecting the coupling device and the carrier-frequency connection.

For AC applications: The AC protection level voltage U_{PL} at power frequency shall be greater than 10 times the maximum AC voltage across the drain coil during rated operation conditions.

The voltage U_{PL} is given by the following formula:

$$U_{PL} \geq 10 \cdot F_V \cdot \frac{U_m}{\sqrt{3}} \cdot (2 \cdot \pi \cdot f_R)^2 \cdot C_R \cdot L_D$$

where

L_D is the value of the drain coil in henry;

F_V is the voltage factor according to IEC 60358-1:2012, Table 2.

NOTE 1 Arresters of the air-gap type or those of the non-linear resistor type are used.

Example:

a) power-frequency withstand test voltage:
   - air-gap arrester: 2 kV r.m.s.,
   - arrester with spark-gap: rated voltage: approx. 1 kV r.m.s.

Documents
Document Sharing Hub
Full document details: IEC 60358-2 2013

b) impulse withstand voltage:

– air-gap arrester and arrester with spark-gap: at test impulse voltage of about 4 kV peak with a wave shape 8/20 µs the arrester are able to sustain the peak current of at least 5 kA.

NOTE 2 It is desirable that the arrester be capable of sustaining a power frequency current of at least 5 kA r.m.s. for a period of 0,2 s while ensuring, even if damaged, that the other parts of the coupling device remain adequately protected.

For DC applications:

The DC protection level voltage U_{PL} shall be:

$$U_{PL} \geq 3{,}5 \text{ kV DC}$$

NOTE 3 3,5 kV coming from 2,5 kV AC × √2.

7 Test conditions

Clause 7 of IEC 60358-1:2012 is applicable.

8 Classification of tests

8.1 General

Subclause 8.1 of IEC 60358-1:2012 is applicable with the following addition:

The tests specified in this standard are classified as routine tests, type tests and special tests.

8.2 Routine tests

Subclause 8.2 of IEC 60358-1:2012 is applicable with the following additions:

8.2.200 General

The tests specified in 8.1 apply to coupling capacitors.

8.2.201 Routine tests for carrier frequency accessories

8.2.201.1 Routine test for drain coil

a) current carrying capability test (9.2.200.2.1.1);

b) measurement of the impedance at power frequency (9.2.200.2.1.2);

c) voltage test between winding and iron core (9.2.200.2.1.3).

8.2.201.2 Routine test for voltage limitation devise

AC or DC voltage test (9.2.200.2.2.1).

8.3 Type tests

Subclause 8.3 of IEC 60358-1:2012 is applicable with the following additions:

8.3.200 Type test for coupling capacitor and carrier-frequency accessories

8.3.200.1 Type test for coupling capacitors

a) high frequency capacitance and equivalent series resistance (10.200.1);

Documents
Document Sharing Hub

Full document details: IEC 60358-2 2013

b) measurement of the stray capacitance and stray conductance of the low voltage terminal (10.200.2).

8.3.200.2 Type tests for carrier-frequency accessories

8.3.200.2.1 Type tests for drain coil

a) impedance measurement (10.201.2.1);

b) impulse voltage test (10.201.2.2);

c) current capability test (10.201.2.3);

d) short time current test (10.201.2.4).

8.3.200.2.2 Type test for voltage limitation device together with drain coil

a) impulse voltage test (10.201.2.2).

8.4 Special tests

Subclause 8.4 of IEC 60358-1:2012 is applicable.

9 Routine tests

9.1 Tightness of the liquid-filled equipment

Subclause 9.1 of IEC 60358-1:2012 is applicable.

9.2 Electrical routine tests

Subclause 9.2 of IEC 60358-1:2012 is applicable with the following additions:

9.2.200 Electrical tests for coupling capacitor and carrier frequency accessories

9.2.200.1 Routine tests for coupling capacitor

The routine tests on the coupling capacitor are specified in IEC 60358-12012, 8.1. No supplementary test is specified for PLC application for coupling capacitors.

9.2.200.2 Routine tests for carrier frequency accessories

9.2.200.2.1 Routine tests for drain coil

9.2.200.2.1.1 Current carrying capability test

The test shall be carried out, applying for 1 min a power frequency voltage between the terminals of the drain coil. The test voltage shall be adjusted to achieve a current twice the rated current of the capacitor, but not less than 1 A (r.m.s.). No damage shall occur.

9.2.200.2.1.2 Measurement of the impedance at power frequency

The measured value shall be within the range specified by the manufacturer. This test shall be performed after the current carrying capability test.

9.2.200.2.1.3 Voltage test between winding and iron core

The test shall be carried out, applying a 3 kV power frequency voltage between the terminals of the winding and the iron core for 1 min.

9.2.200.2.2 Routine test for voltage limitation devices

The following routine test is specified according to the cases below:

Documents
Document Sharing Hub

Full document details: IEC 60358-2 2013