

SC 77A/Publication 61000-4-11 (2004), Second edition/I-SH 01

ELECTROMAGNETIC COMPATIBILITY (EMC) –

Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests

INTERPRETATION SHEET 1

This interpretation sheet has been prepared by subcommittee 77A: Low frequency phenomena, of IEC technical committee 77: Electromagnetic compatibility

The text of this interpretation sheet is based on the following documents:

ISH	Report on voting
77A/726/ISH	77A/731/RVD

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

Interpretation of the rise-time and fall-time requirements during EUT testing in IEC 61000-4-11:2004: Electromagnetic compatibility (EMC) – Part 4-11: Testing and measurement techniques – Voltage dips, short interruptions and voltage variations immunity tests.

- 1) In IEC 61000-4-11:2004, Table 4 does not apply to EUT (equipment under test) testing. Table 4 is for generator calibration and design only.
- 2) With reference to Table 1 and Table 2, there is no requirement in 61000-4-11:2004 for rise-time and fall-time when testing EUT; therefore, it is not necessary to measure these parameters during tests.
- 3) With reference to Table 4, all of the requirements apply to design and calibration of the generator. The requirements of Table 4 only apply when the load is a non-inductive 100 Ω resistor. The requirements of Table 4 do not apply during EUT testing.

SC 77A/Publication 61000-4-11 (2004), Deuxième édition/I-SH 01

COMPATIBILITE ELECTROMAGNETIQUE (CEM) –

Partie 4-11: Techniques d'essai et de mesure – Essais d'immunité aux creux de tension, coupures brèves et variations de tension

FEUILLE D'INTERPRÉTATION 1

Cette feuille d'interprétation a été établie par le sous-comité 77A: Phénomènes basse fréquence, du comité d'études 77 de la CEI: Compatibilité électromagnétique.

Le texte de cette feuille d'interprétation est issue des documents suivants:

ISH	Rapport de vote
77A/726/FDIS	77A/731/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette feuille d'interprétation.

Interprétation des exigences pour les temps de montée et des temps de descente pendant les essais d'EST dans la CEI 61000-4-11:2004: Compatibilité électromagnétique (CEM) – Partie 4-11: Techniques d'essai et de mesure – Essais d'immunité aux creux de tension, coupures brèves et variations de tension.

- 1) Dans la CEI 61000-4-11:2004, le Tableau 4 ne s'applique pas à l'essai sur l'EST (équipement soumis au test). Le Tableau 4 est seulement pour l'étalonnage et la conception du générateur.
- 2) En ce qui concerne le Tableau 1 et le Tableau 2, il n'y a pas d'exigence dans la CEI 61000-4-11:2004 pour le temps de montée et le temps de descente lorsque l'on essaie l'EST; c'est pourquoi, il n'est pas nécessaire de mesurer ces paramètres pendant les essais.
- 3) En ce qui concerne le Tableau 4, toutes les exigences s'appliquent à la conception et à l'étalonnage du générateur. Les exigences du Tableau 4 s'appliquent seulement quand la charge est une résistance non-inductive de 100 Ω . Les exigences du Tableau 4 ne s'appliquent pas pendant l'essai de l'EST.