IEC 61158-5-19

Edition 3.0 2014-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Withdrawn

Industrial communication networks – Fieldbus specifications – Part 5-19: Application layer service definition – Type 19 elements

Réseaux de communication industriels – Spécifications des bus de terrain – Partie 5-19: Définition des services de la couche application – Eléments de type 19

IEC 61158-5-19:2014-08(en-fr)

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue
The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,…). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org
The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary
More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC
La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC
Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue
Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,…). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary
Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

Withdrawn

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

IEC 61158-5-19

Edition 3.0 2014-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

withdrawn

Industrial communication networks – Fieldbus specifications – Part 5-19: Application layer service definition – Type 19 elements

Réseaux de communication industriels – Spécifications des bus de terrain – Partie 5-19: Définition des services de la couche application – Eléments de type 19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

PRICE CODE
CODE PRIX

V

ICS 25.040.40; 35.100.70; 35.110

ISBN 978-2-8322-1740-5

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

AVA Documents
Document Sharing Hub

® Registered trademark of the International Electrotechnical Commission
Marque déposée de la Commission Electrotechnique Internationale

Full document details: IEC 61158-5-19 2014

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
1.1 General 7
1.2 Specifications 8
1.3 Conformance 8
2 Normative references 8
3 Terms, definitions, abbreviations, symbols and conventions 9
3.1 ISO/IEC 7498-1 terms 9
3.2 ISO/IEC 8822 terms 9
3.3 ISO/IEC 9545 terms 9
3.4 ISO/IEC 8824-1 terms 9
3.5 Fieldbus application-layer specific definitions 10
3.6 Abbreviations and symbols 11
3.7 Conventions 12
4 Concepts 14
5 Data type ASE 14
5.1 Bitstring types 15
5.2 Unsigned types 16
5.3 Integer types 16
5.4 Floating Point types 17
5.5 Structure types 17
6 Communication model specification 18
6.1 Concepts 18
6.2 ASEs 18
6.3 ARs 30
6.4 Summary of AR classes 32
6.5 Permitted FAL services by AREP role 32
Bibliography 34

Table 1 – Read service parameters 20
Table 2 – Write service parameters 21
Table 3 – Read service parameters 22
Table 4 – Write service parameters 23
Table 5 – Notify service parameters 23
Table 6 – Get network status service parameters 25
Table 7 – Get device status service parameters 25
Table 8 – Network status change report service parameters 26
Table 9 – Station status change report service parameters 26
Table 10 – Set device status service parameters 27
Table 11 – Enable RTC service parameters 28
Table 12 – Enable hotplug service parameters 29
Table 13 – Notify RTC service parameters 29
Table 14 – Disable RTC service parameters 30

Withdrawn

AVA Documents
Document Sharing Hub

Table 15 – AREP (SVC) class summary 32
Table 16 – AREP (RTC-MS) class summary 32
Table 17 – AREP (RTC-CC) class summary 32
Table 18 – FAL services by AR type 33

withdrawn

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-19: Application layer service definition – Type 19 elements

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

Attention is drawn to the fact that the use of the associated protocol type is restricted by its intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a layer protocol type to be used with other layer protocols of the same type, or in other type combinations explicitly authorized by its intellectual-property-right holders.

NOTE Combinations of protocol types are specified in IEC 61784-1 and IEC 61784-2.

International Standard IEC 61158-5-19 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This third edition cancels and replaces the second edition published in 2010. This edition constitutes a technical revision.

The main changes with respect to the previous edition are listed below:

Withdrawn

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

- introducing connections based on a producer-consumer model;
- introducing additional mechanisms to realize features such as timestamping and oversampling;
- improving the hotplug and redundancy features;
- improving the phase switching and the error handling;
- editorial improvements.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/763/FDIS	65C/773/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

Withdrawn

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the "three-layer" fieldbus reference model described in IEC 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This standard defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term "service" refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

Withdrawn

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-19: Application layer service definition – Type 19 elements

Withdrawn

1 Scope

1.1 General

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a "window between corresponding application programs."

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 19 fieldbus. The term "time-critical" is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the fieldbus application layer in terms of

a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,

b) the primitive actions and events of the service;

c) the parameters associated with each primitive action and event, and the form which they take; and

d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

a) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and

b) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This standard specifies the structure and services of the fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498-1) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can

AVA Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this standard to provide access to the FAL to control certain aspects of its operation.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This specification may be used as the basis for formal application programming interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

a) the sizes and octet ordering of various multi-octet service parameters, and

b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill the application layer services as defined in this standard.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE All parts of the IEC 61158 series, as well as IEC 61784-1 and IEC 61784-2 are maintained simultaneously. Cross-references to these documents within the text therefore refer to the editions as dated in this list of normative references.

IEC 61131-3, *Programmable controllers – Part 3: Programming languages*

IEC 61158-1:2014, *Industrial communication networks – Fieldbus specifications – Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series*

IEC 61158-3-16:2007, *Industrial communication networks – Fieldbus specifications – Part 3-16: Data-link layer service definition – Type 16 elements*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

Withdrawn

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

ISO/IEC 8824-1, *Information technology – Abstract Syntax Notation One (ASN.1): Specification of basic notation*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 10646, *Information technology – Universal Coded Character Set (UCS)*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC/IEEE 60559, *Information technology – Microprocessor Systems – Floating-Point arithmetic*

3 Terms, definitions, abbreviations, symbols and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviations and conventions as defined in these publications apply:

3.1 ISO/IEC 7498-1 terms

a) application entity
b) application process
c) application protocol data unit
d) application service element
e) application entity invocation
f) application process invocation
g) application transaction
h) real open system
i) transfer syntax

3.2 ISO/IEC 8822 terms

a) abstract syntax
b) presentation context

3.3 ISO/IEC 9545 terms

a) application-association
b) application-context
c) application context name
d) application-entity-invocation
e) application-entity-type
f) application-process-invocation
g) application-process-type
h) application-service-element
i) application control service element

3.4 ISO/IEC 8824-1 terms

a) object identifier
b) type

Withdrawn

AVA Documents Document Sharing Hub

Full document details: IEC 61158-5-19 2014

3.5 Fieldbus application-layer specific definitions

3.5.1
coded character set
code
set of unambiguous rules that establish a character set and one-to-one relationship between the characters of the set and their representation by one or more bit combinations

3.5.2
cross communication
direct data transfer between slave devices (without active involvement of master)

3.5.3
cycle time
duration of a communication cycle

3.5.4
cyclic data
part of a telegram, which does not change its meaning during cyclic operation of the network

3.5.5
device
slave in the communication network

Note 1 to entry: Examples are a power drive system as defined in the IEC 61800 standard family, I/O stations as defined in the IEC 61131 standard family, etc.

3.5.6
device status
four adjacent octets inside the acknowledge telegram containing status information for each device

3.5.7
element
part of IDNs

Note 1 to entry: Each IDN has 7 elements, whereas each one has a specific meaning (e.g., number, name, data).

3.5.8
hot plug
possibility to open the communication network and insert or remove slaves while the network is still in real-time operation

3.5.9
identification number
designation of operating data under which a data block is preserved with its attribute, name, unit, minimum and maximum input values, and the data

3.5.10
loopback
mode by which a device passes on a received telegram to the same port and to the other port, either changed or unchanged

3.5.11
master
node, which assigns the other nodes (i.e., slaves) the right to transmit

Withdrawn

Documents
Document Sharing Hub
Full document details: IEC 61158-5-19 2014

3.5.12
physical layer
first layer of the ISO-OSI reference model

3.5.13
protocol
convention about the data formats, time sequences, and error correction in the data exchange of communication systems

3.5.14
service channel
SVC
non real-time transmission of information upon master request during RT channel

3.5.15
slave
node, which is assigned the right to transmit by the master

3.5.16
station
node

3.5.17
topology
physical network architecture with respect to the connection between the stations of the communication system

3.6 Abbreviations and symbols

AHS	Service transport handshake of the device (acknowledge HS)
AP	Application Process
APO	Application Object
AR	Application Relationship
AREP	Application Relationship End Point
ASE	Application Service Element
CC-data	Cross Communication
Cnf	Confirmation
DA	Destination address
DAT	Duration of acknowledge telegram
FAL	Fieldbus Application Layer
ID	Identification Number
IDN	Identification Number
Ind	Indication
MS	Master Slave
NRC	Non Real Time Channel
NA	Not applicable
Req	Request
Rsp	Response
RTC	Real Time Channel
RTE	Real Time Ethernet

Withdrawn

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

3.7 Conventions

3.7.1 Overview

The FAL is defined as a set of object-oriented ASEs. Each ASE is specified in a separate subclause. Each ASE specification is composed of two parts, its class specification, and its service specification.

The class specification defines the attributes of the class. The attributes are accessible from instances of the class using the Object Management ASE services specified in Clause 5 of this standard. The service specification defines the services that are provided by the ASE.

3.7.2 General conventions

This standard uses the descriptive conventions given in ISO/IEC 10731.

3.7.3 Conventions for class definitions

Class definitions are described using templates. Each template consists of a list of attributes for the class. The general form of the template is shown below:

FAL ASE:			**ASE Name**
CLASS:			**Class name**
CLASS ID:			**#**
PARENT CLASS:			Parent class name
ATTRIBUTES:			
1	(o)	Key Attribute:	numeric identifier
2	(o)	Key Attribute:	name
3	(m)	Attribute:	attribute name(values)
4	(m)	Attribute:	attribute name(values)
4.1	(s)	Attribute:	attribute name(values)
4.2	(s)	Attribute:	attribute name(values)
4.3	(s)	Attribute:	attribute name(values)
5.	(c)	Constraint:	constraint expression
5.1	(m)	Attribute:	attribute name(values)
5.2	(o)	Attribute:	attribute name(values)
6	(m)	Attribute:	attribute name(values)
6.1	(s)	Attribute:	attribute name(values)
6.2	(s)	Attribute:	attribute name(values)
SERVICES:			
1	(o)	OpsService:	service name
2.	(c)	Constraint:	constraint expression
2.1	(o)	OpsService:	service name
3	(m)	MgtService:	service name

(1) The "FAL ASE:" entry is the name of the FAL ASE that provides the services for the class being specified.

(2) The "CLASS:" entry is the name of the class being specified. All objects defined using this template will be an instance of this class. The class may be specified by this standard, or by a user of this standard.

(3) The "CLASS ID:" entry is a number that identifies the class being specified. This number is unique within the FAL ASE that will provide the services for this class. When qualified by the identity of its FAL ASE, it unambiguously identifies the class within the scope of the FAL. The value "NULL" indicates that the class cannot be instantiated. Class IDs between 1 and 255 are reserved by this standard to identify standardized classes. They have been

Withdrawn

AVA Documents Document Sharing Hub

Full document details: IEC 61158-5-19 2014

assigned to maintain compatibility with existing national standards. CLASS IDs between 256 and 2048 are allocated for identifying user defined classes.

(4) The "PARENT CLASS:" entry is the name of the parent class for the class being specified. All attributes defined for the parent class and inherited by it are inherited for the class being defined, and therefore do not have to be redefined in the template for this class.

NOTE The parent-class "TOP" indicates that the class being defined is an initial class definition. The parent class TOP is used as a starting point from which all other classes are defined. The use of TOP is reserved for classes defined by this standard.

(5) The "ATTRIBUTES" label indicate that the following entries are attributes defined for the class.

a) Each of the attribute entries contains a line number in column 1, a mandatory (m) / optional (o) / conditional (c) / selector (s) indicator in column 2, an attribute type label in column 3, a name or a conditional expression in column 4, and optionally a list of enumerated values in column 5. In the column following the list of values, the default value for the attribute may be specified.

b) Objects are normally identified by a numeric identifier or by an object name, or by both. In the class templates, these key attributes are defined under the key attribute.

c) The line number defines the sequence and the level of nesting of the line. Each nesting level is identified by period. Nesting is used to specify

i) fields of a structured attribute (4.1, 4.2, 4.3),

ii) attributes conditional on a constraint statement (Clause 5). Attributes may be mandatory (5.1) or optional (5.2) if the constraint is true. Not all optional attributes require constraint statements as does the attribute defined in (5.2).

iii) the selection fields of a choice type attribute (6.1 and 6.2).

(6) The "SERVICES" label indicates that the following entries are services defined for the class.

a) An (m) in column 2 indicates that the service is mandatory for the class, while an (o) indicates that it is optional. A (c) in this column indicates that the service is conditional. When all services defined for a class are defined as optional, at least one has to be selected when an instance of the class is defined.

b) The label "OpsService" designates an operational service (1).

c) The label "MgtService" designates an management service (2).

d) The line number defines the sequence and the level of nesting of the line. Each nesting level is identified by period. Nesting within the list of services is used to specify services conditional on a constraint statement.

3.7.4 Conventions for service definitions

3.7.4.1 General

The service model, service primitives, and time-sequence diagrams used are entirely abstract descriptions; they do not represent a specification for implementation.

3.7.4.2 Service parameters

Service primitives are used to represent service user/service provider interactions (ISO/IEC 10731). They convey parameters which indicate information available in the user/provider interaction. In any particular interface, not all parameters need be explicitly stated.

The service specifications of this standard uses a tabular format to describe the component parameters of the ASE service primitives. The parameters which apply to each group of service primitives are set out in tables. Each table consists of up to five columns for the

1) Parameter name,

Withdrawn

AVA Documents Document Sharing Hub

Full document details: IEC 61158-5-19 2014

2) request primitive,
3) indication primitive,
4) response primitive, and
5) confirm primitive.

One parameter (or component of it) is listed in each row of each table. Under the appropriate service primitive columns, a code is used to specify the type of usage of the parameter on the primitive specified in the column:

M parameter is mandatory for the primitive

U parameter is a User option, and may or may not be provided depending on dynamic usage of the service user. When not provided, a default value for the parameter is assumed.

C parameter is conditional upon other parameters or upon the environment of the service user.

— (blank) parameter is never present.

S parameter is a selected item.

Some entries are further qualified by items in brackets. These may be

a) a parameter-specific constraint:

"(=)" indicates that the parameter is semantically equivalent to the parameter in the service primitive to its immediate left in the table.

b) an indication that some note applies to the entry:

"(n)" indicates that the following note "n" contains additional information pertaining to the parameter and its use.

3.7.4.3 Service procedures

The procedures are defined in terms of

- the interactions between application entities through the exchange of fieldbus Application Protocol Data Units, and
- the interactions between an application layer service provider and an application layer service user in the same system through the invocation of application layer service primitives.

These procedures are applicable to instances of communication between systems which support time-constrained communications services within the fieldbus application layer.

4 Concepts

The common concepts and templates used to describe the application layer service in this standard are detailed in IEC 61158-1, Clause 9.

5 Data type ASE

Data types as specified in IEC 61158-1, Clause 9 is applied with the following restrictions:

Only nesting level of 1 is supported.

Only the following basic data types are supported:

BitString8

BitString16

BitString32

Withdrawn

Documents
Document Sharing Hub

BitString64
Unsigned16
Unsigned32
Unsigned64
Integer16
Integer32
Integer64
VisibleString1
Float32
Float64

5.1 Bitstring types

5.1.1 BitString8

CLASS: **Data type**
ATTRIBUTES:

1	Data type Numeric Identifier	=	22
2	Data type Name	=	Bitstring8
3	Format	=	FIXED LENGTH
5.1	Octet Length	=	1

This type contains 1 element of type BitString.

5.1.2 BitString16

CLASS: **Data type**
ATTRIBUTES:

1	Data type Numeric Identifier	=	23
2	Data type Name	=	Bitstring16
3	Format	=	FIXED LENGTH
5.1	Octet Length	=	2

This type is a BitString16 and has a length of two octets.

5.1.3 BitString32

CLASS: **Data type**
ATTRIBUTES:

1	Data type Numeric Identifier	=	24
2	Data type Name	=	Bitstring32
3	Format	=	FIXED LENGTH
5.1	Octet Length	=	4

This type is a BitString16 and has a length of four octets.

5.1.4 BitString64

CLASS: **Data type**
ATTRIBUTES:

1	Data type Numeric Identifier	=	57
2	Data type Name	=	Bitstring64
3	Format	=	FIXED LENGTH
5.1	Octet Length	=	8

This type is a BitString16 and has a length of eight octets.

Withdrawn

Documents
Document Sharing Hub

5.2 Unsigned types

5.2.1 Unsigned16

CLASS: **Data type**

ATTRIBUTES:

1	Data type Numeric Identifier	=	6
2	Data type Name	=	Unsigned16
3	Format	=	FIXED LENGTH
4.1	Octet Length	=	2

This type is a binary number. The most significant bit of the most significant octet is always used as the most significant bit of the binary number; no sign bit is included. This unsigned type has a length of two octets.

5.2.2 Unsigned32

CLASS: **Data type**

ATTRIBUTES:

1	Data type Numeric Identifier	=	7
2	Data type Name	=	Unsigned32
3	Format	=	FIXED LENGTH
4.1	Octet Length	=	4

This type is a binary number. The most significant bit of the most significant octet is always used as the most significant bit of the binary number; no sign bit is included. This unsigned type has a length of four octets.

5.2.3 Unsigned64

CLASS: **Data type**

ATTRIBUTES:

1	Data type Numeric Identifier	=	56
2	Data type Name	=	Unsigned64
3	Format	=	FIXED LENGTH
4.1	Octet Length	=	8

This type is a binary number. The most significant bit of the most significant octet is always used as the most significant bit of the binary number; no sign bit is included. This unsigned type has a length of eight octets.

5.3 Integer types

5.3.1 Integer16

CLASS: **Data type**

ATTRIBUTES:

1	Data type Numeric Identifier	=	3
2	Data type Name	=	Integer16
3	Format	=	FIXED LENGTH
4.1	Octet Length	=	2

This integer type is a two's complement binary number with a length of two octets.

5.3.2 Integer32

CLASS: **Data type**

ATTRIBUTES:

1	Data type Numeric Identifier	=	4
2	Data type Name	=	Integer32
3	Format	=	FIXED LENGTH

Withdrawn

Documents
Document Sharing Hub

4.1	Octet Length	=	4

This integer type is a two's complement binary number with a length of four octets.

5.3.3 Integer64

CLASS: **Data type**

ATTRIBUTES:

1	Data type Numeric Identifier	=	55
2	Data type Name	=	Integer64
3	Format	=	FIXED LENGTH
4.1	Octet Length	=	8

This integer type is a two's complement binary number with a length of eight octets.

5.4 Floating Point types

5.4.1 Float32

CLASS: **Data type**

ATTRIBUTES:

1	Data type Numeric Identifier	=	8
2	Data type Name	=	Float32
4	Format	=	FIXED LENGTH
4.1	Octet Length	=	4

This type has a length of four octets. The format for Float32 is that defined by ISO/IEC/IEEE 60559 as single precision.

5.4.2 Float64

CLASS: **Data type**

ATTRIBUTES:

1	Data type Numeric Identifier	=	15
2	Data type Name	=	Float64
3	Format	=	FIXED LENGTH
4.1	Octet Length	=	8

This type has a length of eight octets. The format for Float64 is that defined by ISO/IEC/IEEE 60559 as double precision.

5.5 Structure types

5.5.1 STRING2

CLASS: **Data type**

ATTRIBUTES:

1	Data type Numeric Identifier	=	not used
2	Data type Name	=	STRING2
3	Format	=	STRUCTURE
5.1	Number of Fields	=	2
5.2.1	Field Name	=	Charcount_Element
5.2.2	Field Data type	=	UINT
5.3.1	Field Name	=	String2contents_Element
5.3.2	Field Data type	=	OctetString

This IEC 61131-3 data type extension is composed of two elements. Charcount_Element gives the current number of characters in the String2contents_Element (one UINT per character). Characters are as specified in ISO/IEC 10646.

Withdrawn

AVA Documents Document Sharing Hub

Full document details: IEC 61158-5-19 2014

6 Communication model specification

6.1 Concepts

6.1.1 Communication mechanisms

Two communication mechanisms are supported by devices within the network:

- cyclic transmission of data in a high efficient manner using a publisher subscriber model,
- non-cyclic transmission of data using a client server communication model.

AREPs, which act as push publisher or push subscriber, are used for cyclic transmission.

AREPs, which act as a client or server, are used for non-cyclic data transmission.

6.1.2 IDN concept

The application data which is transmitted cyclically and non-cyclically between FAL users is mapped on so-called identification numbers (IDNs). These IDNs correspond to the APOs as defined and are described in Annex A of IEC 61158-3-16:2007.

6.2 ASEs

6.2.1 Identification number (IDN) ASE

6.2.1.1 Overview

The IDN ASE provides read and write access to the attributes of IDNs provided by a device.

6.2.1.2 IDN class specification

6.2.1.2.1 Formal model

FAL ASE:			IDN ASE
CLASS:			IDN
CLASS ID:			not used
PARENT CLASS:			TOP
ATTRIBUTES:			
1	(m)	Key Attribute:	Identification
1.1	(m)	Key Attribute:	Identification number
1.2	(o)	Key Attribute:	Structure element
1.3	(o)	Key Attribute:	Structure index
2	(o)	Attribute:	Name
3	(m)	Attribute:	Data Attribute
4	(o)	Attribute:	Unit
5	(o)	Attribute:	Minimum value
6	(o)	Attribute:	Maximum value
7	(m)	Attribute:	Operation Data
SERVICES:			
1	(m)	OpsService:	Read
2	(m)	OpsService:	Write

Withdrawn

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014

6.2.1.2.2 Attributes

Identification
This key attribute identifies an instance of this object class. The addressing can be simple or extended.

Identification number
This mandatory attribute is a numerical identifier to address an instance of this object class. In case of a simple addressing scheme, this is the only attribute required for identification.

Structure element
This optional attribute is used in case of an extended addressing.

Structure index
This optional attribute is used in case of an extended addressing.

Name
This optional attribute specifies a symbolic name of this object class.

Data attribute
This mandatory attribute specifies all information which is needed to display or convert the data intelligibly. This includes data type, data length, conversion factor, read/write permission depending on the communication phase and whether the data is associated to a command.

Unit
This optional attribute specifies the unit of the operation data.

Minimum value
This optional attribute specifies the minimum input value for the operation data.

Maximum value
This optional attribute specifies the maximum input value for the operation data.

Operation data
This mandatory attribute specifies the operation data of this instance of the object class.

6.2.1.3 IDN ASE service specification

6.2.1.3.1 Supported services

Subclause 6.2.1.3 specifies the definition of the services that are unique to this ASE. The services defined for this ASE are:

- Read
- Write

6.2.1.3.2 Read service

6.2.1.3.2.1 Service overview

This confirmed service is used to read an element of an IDN on demand.

6.2.1.3.2.2 Service primitives

The service parameters for each primitive are shown in Table 1.

Withdrawn

Documents
Document Sharing Hub
Full document details: IEC 61158-5-19 2014

Table 1 – Read service parameters

Parameter name	Req	Ind	Rsp	Cnf
Argument				
AREP	M	M		
Device Address	M	M (=)		
Identification	M	M (=)		
Attribute	M	M (=)		
Result(+)			S	S (=)
Value			M	M (=)
Result(-)			S	S (=)
Error Info			M	M (=)
NOTE The method by which a confirm primitive is correlated with its corresponding preceding request primitive is a local matter. See 1.2.				

AREP
This parameter is the local identifier for the desired AR.

Device address
This parameter identifies the address of the device.

Identification
This parameter specifies an IDN object to be read by the key attribute.

Attribute
This parameter specifies the element of an IDN object to be read by the key attribute.

Value
This parameter specifies the value read.

Error info
This parameter provides error information for service errors.

6.2.1.3.3 Write service

6.2.1.3.3.1 Service overview

This confirmed service is used to write an element of an IDN.

6.2.1.3.3.2 Service primitives

The service parameters for each primitive are shown in Table 2.

Withdrawn

Documents
Document Sharing Hub
Full document details: IEC 61158-5-19 2014

Table 2 – Write service parameters

Parameter name	Req	Ind	Rsp	Cnf
Argument				
AREP	M	M		
Device Address	M	M (=)		
Identification	M	M (=)		
Attribute	M	M (=)		
Value	M	M (=)		
Result(+)			S	S (=)
Result(-)			S	S (=)
Error Info			M	M (=)
NOTE The method by which a confirm primitive is correlated with its corresponding preceding request primitive is a local matter. See 1.2.				

AREP
This parameter is the local identifier for the desired AR.

Device address
This parameter identifies the address of the device.

Identification
This parameter specifies an IDN object to be written by the key attribute.

Attribute
This parameter specifies the element of an IDN object to be written by the key attribute.

Value
This parameter specifies the value to be written.

Error info
This parameter provides error information for service errors.

6.2.2 CYCIDN ASE

6.2.2.1 Overview

The CYCIDN ASE provides cyclic read and write access to the operation data of IDNs provided by a device.

6.2.2.2 Cyclic Identification Number (CYCIDN) class specification

6.2.2.2.1 Formal model

FAL ASE: CYCIDN ASE
CLASS: CYCIDN
CLASS ID: not used
PARENT CLASS: TOP
ATTRIBUTES:

1	(m)	Key Attribute:	Identification
1.1	(m)	Key Attribute:	Identification Number
1.2	(o)	Key Attribute:	Resource Element
1.3	(o)	Key Attribute:	Subindex
2	(m)	Attribute:	Data

SERVICES:

1	(m)	OpsService:	Read
2	(o)	OpsService:	Write

Withdrawn

Documents
Document Sharing Hub

Full document details: IEC 61158-5-19 2014