IEC 62670-2

Edition 1.0 2015-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Photovoltaic concentrators (CPV) – Performance testing – Part 2: Energy measurement

Concentrateurs photovoltaïques (CPV) – Essai de performances – Partie 2: Mesure de l'énergie

IEC 62670-2:2015-05(en-fr)

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembé
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC
The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications
The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue
The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub
The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,…). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished
Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org
The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary
More than 60 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc
If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC
La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC
Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue
Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,…). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary
Plus de 60 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

IEC 62670-2

Edition 1.0 2015-05

INTERNATIONAL STANDARD

NORME INTERNATIONALE

colour inside

Photovoltaic concentrators (CPV) – Performance testing – Part 2: Energy measurement

Concentrateurs photovoltaïques (CPV) – Essai de performances – Partie 2: Mesure de l'énergie

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 27.160

ISBN 978-2-8322-2627-8

Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.

AVA Documents
Document Sharing Hub

® Registered trademark of the International Electrotechnical Commission
Marque déposée de la Commission Electrotechnique Internationale

Full document details: IEC 62670-2 2015

CONTENTS

FOREWORD 4
INTRODUCTION 6
1 Scope 7
2 Normative references 7
3 Terms and definitions 7
4 Description of the method 9
5 Selection of subset under test 10
6 Operation, maintenance and cleaning 10
7 Downtimes and unavailability 11
8 Parasitic energy 11
9 Data acquisition 11
9.1 General requirements 11
9.1.1 Data acquisition system (DAS) 11
9.1.2 Sampling interval 12
9.2 Mandatory measurements 13
9.2.1 General 13
9.2.2 Direct normal irradiance 13
9.2.3 Global plane of array irradiance 13
9.2.4 Ambient air temperature 14
9.2.5 Wind speed 14
9.2.6 Electrical power or energy 14
9.2.7 Cold source temperature (actively cooled systems only) 14
10 Data post-processing 14
10.1 Calculation of energy from integrated power values 14
10.2 Calculation of energy from discrete power values 15
10.3 Calculation of the DNI time series 15
10.4 Calculation of the active AC or DC energy 17
11 Calculation of the performance ratio 18
11.1 General 18
11.2 AC performance ratio 18
11.3 DC performance ratio 19
12 Derived parameters 20
13 Report 20
Annex A (informative) Some suggested ways to filter data in order to identify incorrect data 22
Annex B (informative) Best practices for power plant energy measurement 23
Annex C (normative) Optionally derived parameters 24
C.1 General 24
C.2 Energy Production Rate (EPR) 24
C.3 Capacity Factor (CF) 24

Figure 1 – Nomenclature of angles used in Formula (2) 17

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

Table 1 – Steps of the energy measurement procedure 10
Table 2 – Mandatory measurements. 13

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PHOTOVOLTAIC CONCENTRATORS (CPV) – PERFORMANCE TESTING –

Part 2: Energy measurement

FOREWORD

1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
6) All users should ensure that they have the latest edition of this publication.
7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62670-2 has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

The text of this standard is based on the following documents:

FDIS	Report on voting
82/940/FDIS	82/969/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

A list of all parts in the IEC 62670 series, published under the general title *Photovoltaic Concentrators (CPV) – Performance testing*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

INTRODUCTION

IEC 62670 series establishes requirements for evaluating concentrator PV performance. It is written to be applicable to all concentrator PV technologies that have a geometric concentration ratio greater than 3× and require tracking.

Included in the IEC 62670 series of standards are definitions of the standard conditions and methods to be used for assessing CPV performance.

IEC 62670-1 defines a standard set of conditions so that power ratings noted on data sheets and nameplates have a standard basis.

IEC 62670-2 describes an on-sun, measurement based method for determining the energy output and performance ratio for CPV arrays, assemblies and power plants.

IEC 62670-3 (under consideration) describes methods for providing a CPV power assessment under a set of standard conditions, enabling assessments both indoors and outdoors.

IEC 62670-4 (under consideration) describes methods for calculating the prospective electrical energy output of CPV modules, arrays, assemblies and power plants based on the measurements carried out in IEC 62670-2.

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

PHOTOVOLTAIC CONCENTRATORS (CPV) – PERFORMANCE TESTING –

Part 2: Energy measurement

1 Scope

This part of IEC 62670 specifies the minimum requirements for determining the energy output and performance ratio for CPV modules, arrays, assemblies and power plants using an on-sun, measurement based method.

The purpose of this International Standard is to define testing methods, to establish a standard energy measurement for CPV modules, arrays, assemblies and power plants, and to specify the minimum reporting information.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62670-1, *Photovoltaic concentrators (CPV) – Performance testing – Part 1: Standard* conditions

ISO/IEC 17025, *General requirements for the competence of testing and calibration laboratories*

ISO 8601:2004, *Data elements and interchange formats – Information interchange – Representation of dates and times*

ISO 9060, *Solar energy – Specification and classification of instruments for measuring hemispherical solar and direct solar radiation*

ISO 9847, *Solar energy – Calibration of field pyranometers by comparison to a reference pyranometer*

JCGM 100:2008, *Evaluation of measurement data – Guide to the expression of uncertainty in measurement*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply:

3.1
active AC energy
real AC energy (excluding reactive energy)

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

3.2
actively cooled
CPV system that requires some type of media (fluid, gas, etc.) to facilitate the transfer of thermal energy from one body to another. This could be by means of force air, pumps, thermo-electric cooler, gas transfer or any other means not covered by passive cooling.

3.3
concentrator
qualifies photovoltaic devices or systems that use concentrated sunlight

Note 1 to entry: Concentrator photovoltaic technology is usually designated as CPV.

3.4
concentrator optics
optical component that performs one or more of the following functions from its input to output: increasing the light intensity, filtering the spectrum, modifying light intensity distribution, or changing light direction

Note 1 to entry: Typically, it is a (refractive) lens or a (reflective) mirror. A primary optic receives un-concentrated sunlight directly from the sun. A secondary optic receives concentrated or modified sunlight from a primary optic and directs it to a cell or a tertiary optic.

3.5
coolant
fluid, gas or other media that is circulated through or around a CPV device and transfers the thermal energy out of the device

3.6
CPV receiver
group of one or more solar cells and secondary optics (if present) that accepts concentrated sunlight and incorporates the means for thermal and electric energy transfer

Note 1 to entry: A receiver can be made of several sub-receivers.

3.7
CPV module
group of receivers, optics, and other related components, such as interconnection and mounting, that accepts un-concentrated sunlight

Note 1 to entry: All above components are usually prefabricated as one unit, and the focus point is not field-adjustable.

3.8
CPV array
group of modules mounted on a tracking device and electrically interconnected

Note 1 to entry: Examples are illustrated in IEC 62108.

3.9
CPV assembly
group of receivers, optics, and other related components, such as interconnects and mounts, that accepts un-concentrated sunlight

Note 1 to entry: All above components would usually be shipped separately and need some field installation, and the focus point is field-adjustable.

3.10
CPV power plant
group of CPV assemblies or CPV arrays electrically interconnected to provide output power to a load

Documents
Document Sharing Hub
Full document details: IEC 62670-2 2015

3.11
data acquisition system
DAS
system that typically measures analog values, converts them to digital values and stores them

3.12
device under test
DUT
CPV module(s), array(s), assembly/assemblies or power plant(s) the procedure described in this International Standard is applied to

3.13
direct normal irradiance
DNI
irradiance received from a small solid angle centered on the sun's disc on a plane perpendicular to the sun's rays

3.14
direct plane of array irradiance
DPOAI
irradiance received from a small solid angle centered on the sun's disc in the plane of the CPV array

3.15
global plane of array irradiance
GPOAI
total irradiance received from the sun as a combination of direct normal irradiance and all forms of diffuse light in the plane of the PV array

3.16
gross power/energy
is equal to the net power/energy plus the parasitic power/energy

3.17
net power/energy
is equal to the gross power/energy minus the parasitic power/energy

3.18
normal incidence pyrheliometer
NIP
radiometer designed for measuring the direct irradiance as described in ISO 9060

3.19
parasitic power/energy
power/energy used by the CPV power plant to operate including, but not restricted to, the power and energy used for tracking, control, cooling, drying, measurement, and data acquisition

3.20
passively cooled
cooling with a device that does not require an active energy supply

4 Description of the method

The method of energy measurement of a CPV system is shown in Table 1.

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

Table 1 – Steps of the energy measurement procedure

Step	Action
1	Select and describe DUT
2	Describe site, location, surroundings
3	Check calibration of DAS, install DAS
4	Start measurements Mandatory: Time, DNI, GPOAI[a], gross power/energy[b], parasitic power/energy[b], net power/energy[b], ambient temperature, wind speed Optionally: Module/receiver temperature, voltage(s), current(s), coolant temperature, wind direction, air humidity
5	Conduct and document operation and maintenance program, e.g. cleaning of modules and NIPs, greasing, tightening of chains Update logbook, e.g. on rainfall events or unscheduled maintenance events
6	Stop measurements
7	Recheck DAS
8	Inspect recorded measurements in order to identify incorrect data, determine DNI time series used to calculate the DNI energy
9	Calculate the DNI energy, gross energy, net energy, uncertainty values, performance ratio, optionally derived parameters
10	Create report

[a] Mandatory for systems that have a geometric concentration ratio of less than 10×.

[b] At least two of the three quantities need to be measured in order to calculate the third quantity.

5 Selection of subset under test

For the energy measurement of a CPV power plant, all components of the system that will be installed with the modules shall be incorporated, so that all parasitic loads of the system are present for the measurement. At times, it may be useful to apply the procedure to a subset of a power plant. In this case, the report shall document the subset that was chosen and the rationale for the choice.

6 Operation, maintenance and cleaning

The CPV modules, arrays, assemblies or power plant shall be operated as suggested by the manufacturer. If the DUT is actively cooled, the flow rate of the coolant and the coolant composition shall be set as suggested by the manufacturer. The flow rate and coolant composition shall be recorded in the testing report.

The scheduled maintenance program as suggested by the manufacturer for all components of the power plant shall be observed, including but not limited to cleaning, greasing, tightening of chains and scheduled change of parts. In particular, cleaning of modules/concentrator optics shall be done at the same frequency as suggested by the manufacturer. In the absence of a suggested frequency, the cleaning of concentrator optics will be performed at a reasonable frequency according to the site conditions.

All scheduled and unscheduled maintenance and cleaning activities shall be noted in the report in detail including time and duration of each event. For each cleaning event it shall be noted whether all of the modules/concentrator optics or only a part thereof were cleaned. In case of a partial cleaning the cleaned part shall be specified unambiguously, e.g. by providing the module or tracker identifiers of the cleaned part.

Documents
Document Sharing Hub
Full document details: IEC 62670-2 2015

The NIPs should be cleaned ideally daily, but shall be cleaned at least once per week and each cleaning event shall be noted including time and duration in the report.

7 Downtimes and unavailability

All periods of non-functionality of either the CPV modules, arrays, assemblies or power plant or the sensors or the DAS shall be noted including time and duration and if possible the cause in the report.

8 Parasitic energy

The measurement shall accurately include the parasitic energy consumed by the DUT. Parasitic energy includes, but is not restricted to:

– Energy consumed by the tracking system, including the energy consumed for coming on track, going to stow, and parking the CPV system at night.
– Energy consumed by the control system.
– Energy consumed by the drying system where relevant.
– Energy consumed by the cooling pumps and cooling fans, including the cooling of the inverters, where relevant.
– Energy consumed by the electrical equipment such as inverters, transformers and switch gear.
– Energy consumed by the air conditioning or cooling system in the control room and in the inverter room of the power plant where relevant.

All energy consumed by monitoring and data acquisition equipment not essential for the operation of the power plant shall be considered part of the load and shall not be considered as parasitic energy. If only one or a few modules, arrays or assemblies within a power plant are tested following this International Standard, the parasitic energy drawn by the complete power plant will be divided by the total number of modules, arrays or assemblies in the power plant and multiplied by the number of modules, arrays or assemblies under test.

In cases where parasitic energy is consumed intermittently, e.g. the energy used by the tracking system, particular attention shall be paid to ensuring accurate measurement. When in doubt, the maximum possible parasitic energy shall be used. Details of the calculation will be included in the testing report.

9 Data acquisition

9.1 General requirements

9.1.1 Data acquisition system (DAS)

9.1.1.1 General

An automatic, microprocessor-based, DAS is required for this standard. The total uncertainty of the DAS shall be determined using JCGM 100:2008 as guidance and by checks as laid out below and detailed in the test report.

The DAS excluding sensors can be checked by applying the simulated input signals specified below, or by other means agreed upon between the manufacturer and the customer. The calibrations shall be checked at the beginning and the end of the test. If the check identifies that the calibration has drifted outside of the specification, an assessment of the associated uncertainty/error shall be completed and included in the report.

The channels of the DAS can be checked separately or at the same time.

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

9.1.1.2 Types of input signals to be checked

- Direct Normal Irradiance power density
- Ambient air temperature
- Wind speed
- Gross power/energy
- Parasitic power/energy
- Net power/energy
- Coolant temperature; only mandatory for actively cooled systems. If optional measurements are taken, the corresponding input signals shall be checked accordingly.

9.1.1.3 Check of linear response

This check is to be performed on analog input channels on which a linear scaling operation is applied. A constant DC or AC (as appropriate) signal shall be applied to the input terminals. The difference between the result measured by the DAS and the products of the input signal value and scaling factor shall be less than ±1 % of the full scale of the DAS. This procedure should be performed at input signals of 0 %, 20 %, 40 %, 60 %, 80 %, and 100 % of full scale. If the inputs are specified for bipolar signals, negative signals shall also be applied in the same way. If errors greater than 1 % of full scale are detected, then the scale factor should be corrected by software or hardware and re-verified.

9.1.1.4 Check of stability

This check is to be performed on all analog input channels. A constant DC signal of 100 % of full scale shall be applied to the input terminals for 6 h. The fluctuation of the measured value of this signal shall be kept within ±1 % of full scale. Should the fluctuation of the input signal exceed ±0,2 %, the results shall be compensated by using a voltmeter with uncertainty of less than ±0,2 %.

9.1.1.5 Check of integration

This check is to be performed on input channels from which measurements are to be processed using an averaging or integrating operation. An input signal of a rectangular wave having an amplitude Z_m shall be applied to the channel and its measured values integrated over time period τ_d (recommended to be at least 6 h). The amplitude Z_m for each channel is recommended to be the maximum input level expected from the sensor. The results obtained shall be equal to $Z_m \times \tau_d \pm 1$ %. The amplitude and time period shall be monitored by measuring instruments with a ±0,5 % precision.

9.1.1.6 Check of zero value integrals

This check is to be performed on input channels from which measurements are to be processed using an averaging or integrating operation. The channel shall be short-circuited, and its measured values integrated over time period τ_d of at least 6 h. The result shall be ±1 % of $Z_m \times \tau_d$ where Z_m is defined in 9.1.1.5.

9.1.2 Sampling interval

The sampling interval for measurands that vary directly with DNI power density shall be 60 s or less. For measurands which have larger time constants, a larger sampling may be selected if necessary, but shall be 5 min or less. For each measured value the time and date shall be recorded in the format defined in the ISO 8601 standard: *YYYY-MM-DDThh:mm:ss.sTZD* (e.g. 1997-07-16T19:20:30.45+01:00)

Where:

YYYY = four-digit year

MM = two-digit month (01=January, etc.)

Documents
Document Sharing Hub

Full document details: IEC 62670-2 2015

DD = two-digit day of month (01 through 31, UTC)

hh = two digits of hour (00 through 23, UTC) (am/pm NOT allowed)

mm = two digits of minute (00 through 59, UTC)

ss = two digits of second (00 through 59)

s = one or more digits representing a decimal fraction of a second

TZD = time zone designator (+hh:mm or -hh:mm offset from UTC for local winter time)

9.2 Mandatory measurements

9.2.1 General

The measurements to be taken with the DAS are given in Table 2.

Table 2 – Mandatory measurements.

Quantity	Unit or format	Comment
Date and time	*YYYY-MM-DDThh:mm:ss.sTZD*	As defined in ISO 8601
Direct Normal Irradiance power density	$W \cdot m^{-2}$	
Global plane of array (GPOAI) power density	$W \cdot m^{-2}$	Only mandatory for systems that have a geometric concentration ratio of less than 10×
Ambient air temperature	°C	
Wind speed	$m \cdot s^{-1}$	
Gross power/energy	W (power) or Wh (energy)	At least two of these three quantities need to be measured in order to calculate the third quantity
Parasitic power/energy	W (power) or Wh (energy)	
Net power/energy	W (power) or Wh (energy)	

Additional measurements may be taken for diagnostic purposes.

9.2.2 Direct normal irradiance

The direct normal irradiance power density shall be measured with at least two calibrated NIPs fulfilling at least the first class requirements according to ISO 9060. The total uncertainty of the Direct Normal Irradiance power density measurements shall be determined. It shall be below 3 %.

The two, or, preferably, more, NIPs shall be mounted in a way to reduce periods of shading to a minimum, for example by mounting one NIP on the east side and the other on the west side. The raw values of all NIPs shall be recorded for determination of the DNI time series in 10.3.

The angular range of the tracker(s) carrying the NIPs should allow for tracking the sun under any elevation and azimuth angle occurring at the site. Any DNI energy not measured due to a possibly limited angular range of the tracker(s) shall be assessed in the report.

9.2.3 Global plane of array irradiance

The global plane of array irradiance power density shall be measured with at least two calibrated pyranometers fulfilling at least the first class requirements according to ISO 9847. The total uncertainty of the global plane of array irradiance power density measurements shall be determined. It shall be below 3 %. It is not necessary to obtain global plane of array irradiance measurements if the geometric concentration ratio of the CPV system being considered is more than 10×.

Documents
Document Sharing Hub
Full document details: IEC 62670-2 2015

The two, or, preferably, more, pyranometers shall be mounted directly into the plane of the CPV array so that it shall not cause shading onto any CPV module.

If the global plane of array irradiance is measured on a 1-axis tracker that is not always aligned with the sun, it shall be assessed whether it is acceptable to use the irradiance data from the stopped tracker. The assessment shall be included in the report.

9.2.4 Ambient air temperature

The ambient air temperature shall be measured at 2 m height above ground with a sensor in the shade or protected from radiation by a reflective shield. The uncertainty of the ambient temperature shall be determined. It shall be ±1 °C or smaller.

9.2.5 Wind speed

Wind speed shall be measured at a height and location that is representative of the conditions of the DUT. The total uncertainty of the wind speed measurements shall be determined. It shall be 0,5 $m \cdot s^{-1}$ or smaller for wind speed <5 $m \cdot s^{-1}$ and 10 % of the reading or smaller for wind speeds greater than 5 $m \cdot s^{-1}$.

9.2.6 Electrical power or energy

At least two quantities of gross, net and parasitic power or energy need to be measured in order to calculate the third quantity.

For the energy measurement the electrical DC energy or active AC energy produced by the DUT needs to be determined. It shall either be measured directly using an energy meter or indirectly by measuring the electrical power and conducting an integration to calculate the electrical energy as described in 10.4. The total uncertainty of the power or energy measurements shall be determined. It shall be below 2 %.

9.2.7 Cold source temperature (actively cooled systems only)

The cold source temperature shall be measured by means of one or more temperature sensor(s) at a location that is representative of the array conditions. The uncertainty of the cold source temperature shall be determined. It shall be ±1 °C or smaller. The cold source temperature shall be recorded during the entire testing period. The cold source temperature to be considered is either:

– the air ambient temperature in the shade if active cooling is used and if the final heat exchange is with air, or
– the water temperature in the reservoir if active cooling is used with a large reservoir (e.g. pond, tank, pool) of water.

If the temperature of the cold source is not accessible, the temperature of the coolant at its coolest point shall be recorded.

10 Data post-processing

10.1 Calculation of energy from integrated power values

In the case that the DAS offers a built in integration routine, the energy E for the period from t_0 to t_n shall be calculated as shown in Formula (1).

$$E = E(t_n) - E(t_0) \quad (1)$$

Documents
Document Sharing Hub
Full document details: IEC 62670-2 2015

If power was generated and recorded by the built in integration routine during a time when irradiance data is unavailable, this shall be documented in the report along with the method that was used to either reduce the output energy or increase the estimated solar resource to most accurately account for this time period.

10.2 Calculation of energy from discrete power values

In case that the DAS does not offer a built in integration routine, the energy E for the period from t_0 to t_n shall be calculated from the discrete power values using a numerical integration algorithm that ensures a small integration error.

Special attention shall be paid to gaps in the power time series. A time interval larger than 150 % of the regular time interval between two data points has been proven as a reasonable criterion for identifying the beginning and the end of a gap. The integration algorithm shall recognize gaps and shall exclude them from the calculation. Gaps shall not be filled with unreasonable values, which could potentially result, e.g. from a linear interpolation between the boundaries of the gap.

For the calculation of the performance ratio as described in Clause 11 it is of high importance to exclude all periods during a gap that occurred either in the DNI time series, or in the AC/DC power time series, or in both, in order to avoid misleading results.

10.3 Calculation of the DNI time series

Before the DNI time series is calculated, all periods during which active AC or DC energy measurements are not available (e.g. due to unavailability of the energy measurement system, outage of the grid, or other event that does not represent failure of the system itself) shall be removed in order to avoid an underestimation of the performance ratio. The effect of the unavailability of the data shall be summarized in the report.

Afterwards, the DNI time series shall be calculated from the two, or, preferably, more, NIPs mounted in a way to reduce periods of shading to a minimum as described in 9.2.2. Every data set is different and the method of identifying problematic data may need to be adjusted. Some strategies are suggested in Annex A. The exact algorithms used for screening/analyzing the data shall be adjusted to attempt to address the following:

– All sensors shall be maintained in calibration. Inaccurate data shall be discarded. Nighttime data shall also be reviewed for evidence of appropriate function of each sensor.
– Similarly, remove any sensor data that was impacted by events such as cleaning of the sensor, tracker failure (if a tracker malfunctions, the loss of electricity production shall be recorded, but the irradiance measurement shall not be reduced; instead, irradiance data shall be taken from a tracker that was functioning correctly), shading, or other maintenance events.
– To define the final irradiance data, either use data from a single sensor, or average all data that has been determined to be uncompromised.
– In general, there will always be some data points that are difficult to identify as reflecting cloud transients or other anomalies. As long as the fraction of data affected in this way is <0,1 % of the total data, these do not need to be fully documented in the report. However, the fraction of the data identified as suspicious shall be identified, and, if the fraction exceeds 0,1 %, then the report shall describe the data that was flagged and possible causes identified.
– Similarly, if 100 % of the irradiance sensors are shaded or not aligned correctly with the sun for more than 15 min within sunrise and sunset, an estimate shall be made of the uncertainty associated with this omission of data.
– Data discrepancies are handled in one of three ways:
  - If the cause of incorrect data can be identified to be sensor malfunction (examples include: loss of electrical connection, evidence of condensation or snow in or on

AVA Documents
Document Sharing Hub
Full document details: IEC 62670-2 2015