

TECHNICAL SPECIFICATION

**Telecontrol equipment and systems –
Part 5-604: Conformance test cases for the IEC 60870-5-104 companion standard**

Withdrawn



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

TECHNICAL SPECIFICATION

**Telecontrol equipment and systems –
Part 5-604: Conformance test cases for the IEC 60870-5-104 companion standard**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

XD

ICS 33.200

ISBN 2-8318-9319-4

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Abbreviated terms	7
5 Conformance testing for IEC 60870-5-104	8
5.1 Overview and legend.....	8
5.2 Configuration parameters IEC 60870-5-104.....	10
5.3 Verification IEC 60870-5-104 communication	11
5.4 Conformance test procedures.....	52
5.5 Test results chart	84
5.6 Test results of command transmission.....	91
5.6.1 Test results of single command transmission.....	91
5.6.2 Test results of double command transmission.....	94
5.6.3 Test results of regulating step command transmission	97
5.6.4 Test results of setpoint command transmission.....	100
Figure 1 – Test procedure.....	9
Table 1 – Tests on transport provider level	11
Table 2 – Tests on data unit identifier	16
Table 3 – Verification of ASDUs for process information in monitor (normal) direction.....	17
Table 4 – Verification of ASDUs for process information in control (normal) direction.....	35
Table 5 – Verification of ASDUs for system information in monitor (normal) direction.....	43
Table 6 – Verification of ASDUs for system information in control (normal) direction.....	43
Table 7 – Verification of ASDUs for parameters in control (normal) direction.....	46
Table 8 – Verification of ASDUs for file transfer (in monitor (normal) and control direction)	48
Table 9 – Data unit identifier conformance test procedures	52
Table 10 – Information object address conformance test procedures	53
Table 11 – Station initialisation function (unbalanced systems) conformance test procedures	54
Table 12 – Redundant link conformance test procedures	57
Table 13 – Cyclic data transmission function conformance test procedures	60
Table 14 – Data acquisition through read function conformance test procedures	61
Table 15 – Acquisition of events function conformance test procedures	62
Table 16 – General interrogation function conformance test procedures	63
Table 17 – Clock synchronisation function conformance test procedures	67
Table 18 – Command transmission function conformance test procedures.....	68
Table 19 – Transmission of integrated totals (telecounting) function conformance test procedures	74
Table 20 – Parameter loading function conformance test procedures.....	77

Table 21 – Test procedure function conformance test procedures.....	78
Table 22 – File transfer procedure function conformance test procedures.....	79
Table 23 – Additional conformance test procedures.....	81
Table 24 – Negative conformance test procedures.....	82
Table 25 – PIXIT related conformance test procedures.....	83
Table 26 – Test results chart	84
Table 27 – Test results of single command transmission.....	91
Table 28 – Test results of double command transmission	94
Table 29 – Test results of regulating step command transmission.....	97
Table 30 – Test results of setpoint command transmission	100

Withdrawn

INTERNATIONAL ELECTROTECHNICAL COMMISSION

TELECONTROL EQUIPMENT AND SYSTEMS –

**Part 5-604: Conformance test cases for
the IEC 60870-5-104 companion standard**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- The subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 60870-5-604, which is a technical specification, has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
57/856/DTS	57/898/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of IEC 60870 series, published under the general title *Telecontrol equipment and systems*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

Withdawn

INTRODUCTION

This technical specification (TS) describes test cases for conformance testing of telecontrol equipment or systems using the IEC 60870-5 companion standard 104 based on the IEC 60870-5-104 companion standard and IEC 60870-5-6, Guidelines for conformance testing for the IEC 60870-5 companion standards.

Withdrawn

TELECONTROL EQUIPMENT AND SYSTEMS –

Part 5-604: Conformance test cases for the IEC 60870-5-104 companion standard

1 Scope

This technical specification which is part of the IEC 60870-5 series describes test cases for conformance testing of telecontrol equipment, Substation Automation Systems [SAS] and telecontrol systems, including front-end functions of SCADA.

The use of this part of IEC 60870 facilitates interoperability by providing a standard method of testing protocol implementations, but it does not guarantee interoperability of devices. It is expected that using this specification during testing will minimize the risk of non-interoperability.

The goal of this part of IEC 60870 is to enable unambiguous and standardised evaluation of IEC 60870-5 companion standard protocol implementations. The guidelines and conditions for the testing environment are described in IEC 60870-5-6. The detailed test cases per companion standard, containing among others mandatory and optional mandatory test cases per Basic Application Function, ASDU and transmission procedure, will become available as a technical specification (TS). Other functionality may need additional test cases but this is outside the scope of this part of IEC 60870. For proper testing, it is recommended to define these additional test cases. This document is such a Technical Specification for the mentioned companion standard.

This part of IEC 60870 deals mainly with communication conformance testing; therefore other requirements, such as safety or EMC are not covered. These requirements are covered by other standards (if applicable) and the proof of compliance for these topics is done according to these standards.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.¹

IEC 60870-5-6, *Telecontrol equipment and systems – Part 5-6: Guidelines for conformance testing for the IEC 60870-5 companion standards*

IETF RFC220, *Internet Official Protocol Standards*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60870-5-6 apply.

4 Abbreviated terms

For the purposes of this document, the abbreviations given in IEC 60870-5-6 apply.

¹ The base standard always takes precedence. In case of ambiguity between this technical specification and the base standards (IEC 60870-5-1 to IEC 60870-5-5, IEC 60870-5-104), this part of IEC 60870 needs to be clarified or amended.

When testing, negative behaviour is not described in the base standard, the behaviour described in this document prevails and should be observed.

The conformance statement produced after testing indicates any lack of conformance to either the test plan or the base standard.

5 Conformance testing for IEC 60870-5-104

5.1 Overview and legend

An overview of tests is given in the tables below. Procedural and functional testing must always start with the Station Initialisation function and proceeds with the next Basic Application Functions. The procedure in each test case must be followed, which means that the DUT is able to function as described in the specific test case.

The test procedures in the tables 0 through 10 must be carried out with no errors detected during testing of all the Basic Application Functions in tables 11 through 25. These tests are preferably automatically performed by the used test platform.

In addition to the performance criteria listed in the test procedures, 5.3 lists the protocol specifications that must be verified automatically by the testing software or verified manually by review of the test history log after execution of the test procedures. The verification must result in no errors detected during the complete test procedure.

This test plan has a direct reference to the PICS and possibly a PIXIT. Without a reference to a PICS or PIXIT this test plan is obsolete.

Test case numbering syntax is subclause number + table number + test case number.

Test cases are mandatory depending on the description in the column 'Required'. The following situations are possible:

M	=	Mandatory test case regardless if enabled in the PICS/PIXIT, not only in one situation but during execution of all the tests as in the PICS and/or PIXIT
PICS, x.x	=	Mandatory test case if the functionality is enabled in the PICS (by marking the applicable check box), with a reference to the section number of the PICS (x.x); note: PICS 8.x always refers to 60870-5-104, Clause 8
PIXIT	=	Mandatory test case if the functionality is enabled/described in the PIXIT. Verification of these test cases by the user/owner of the PIXIT is required before the test is started.

For each test case the test results need to be marked in the appropriate column of the test result chart in 5.5 and 5.6. Each test case can either pass the test (Passed), fail the test (Failed), not applicable, when the configuration value is not supported by the device (N.A.), or the test case was not performed (Empty). Ideally, there should be no empty boxes when testing is complete.

The test tables are divided into 5 subclauses:

- Subclause 5.2 Configuration parameters IEC 60870-5-104
- Subclause 5.3 Verification IEC 60870-5-104 communication
- Subclause 5.4 Conformance test procedures
- Subclause 5.5 Test result chart
- Subclause 5.6 Test results of command transmission

The procedure to perform all the mandatory test cases, according to the PID, is shown in Figure 1.




Figure 1 – Test procedure

5.2 Configuration parameters IEC 60870-5-104

Table 0 Run the Conformance Test Procedures for each of the following supported configuration parameter values

Since IEC 60870-5-104 contains a number of configuration parameters affecting protocol behaviour, the conformance test procedures in 5.4 and verification in 5.3 must be performed at least once for each supported value of the parameters listed in Table 0. Basically the DUT must be tested if the functionality in 5.3 and 5.4 behaviour is correct for the configuration(s) in this table.

No.	Test	Description	Reference	Required
5.2.0.1	System definition	Controlling station test (Master)		PICS, 9.1
5.2.0.2		Controlled station test (Slave)		PICS, 9.1
5.2.0.50	Frame length	Maximum length L (control direction)	IEC 60870-5-101, 6.2	PICS, 9.4
5.2.0.51		Maximum length L (monitor direction)	IEC 60870-5-101, 6.2	PICS, 9.4
5.2.0.70	COMMON ADDRESS of ASDU	Two (2) octets for Common Address of ASDU (CASDU)	IEC 60870-5-101, 7.2.4	PICS, 9.5
5.2.0.80	INFORMATION OBJECT ADDRESS	Three (3) octets for Information Object Address (structured or unstructured)	IEC 60870-5-101, 7.2.5	PICS, 9.5
5.2.0.90	CAUSE OF TRANSMISSION	Two (2) octets for COT field (2 nd octet is Originator address)	IEC 60870-5-101, 7.2.3	PICS, 9.5

5.3 Verification IEC 60870-5-104 communication

This subclause lists the protocol specifications that must be verified automatically by the testing software or verified manually by review of the test history log after execution of the test procedures. Every test case describes functionality that has passed the test if the functionality as in the the description column was shown to be correct. Correct means: the functionality must be checked either automatically or manually, and also be checked by the test engineer in a human readable format log-file. For example to test the IV qualifier of some information elements, the ASDU containing this element must be sent with the IV=1. Every test case marked "Passed", has to be verifiable during testing and archived in log-files for post assessment.

To identify if a test case is mandatory, it is necessary to read 5.1 carefully.

Table 1 – Tests on transport provider level

No.	Test	Description	Reference	Required
5.3.1.1	IP FRAME	IP Header, IP Fragment Re-assembly	IETF RFC2200	M
5.3.1.2		Source Address, Destination address	IETF RFC2200	M
5.3.1.3		TCP Header, TCP Control field (specifically ACK, RST, SYN, FIN), TCP Sequencing	IETF RFC2200	M
5.3.1.4	TCP FRAME	[The server (controlled station) uses the] port number 2404 [(confirmed by IANA) in all cases, both for the listening port and established connections. The client (controlling station) is free to use ephemeral port number, e.g. as allocated by the client's TCP/IP implementation]	IEC 60870-5-104, 5.4 [MOM WG03 15 June 2001 4.2.2.4] (Especially marked because it is not yet in the standard!)	M
5.3.1.5		Actively opening a new TCP connection starts with a TCP frame containing (SYN) from the node that takes the initiative to establish the TCP connection. This is answered by the other node with (SYN, ACK), which in turn is answered by the initiating node with (ACK). Thereinafter the TCP connection is established	IETF RFC2200 IEC 60870-5-104, 7.1	M
5.3.1.6		Actively closing an established TCP connection starts with a TCP frame containing (FIN) from the node that takes the initiative to close the TCP connection. This is answered by the other node (ACK) followed by a TCP frame from this same other node containing also (FIN). This in turn is answered by the initiating node with (ACK). Thereinafter the TCP connection is closed	IETF RFC2200 IEC 60870-5-104, 7.1, Figure 19	M
5.3.1.7	CS104 APDU FRAME LAYOUT	TCP Data stream on an established TCP connection contains APDU's. APDU's are correctly assembled when divided over multiple TCP frames	IEC 60870-5-104, Clause 5	M
5.3.1.10		Start character of APDU: 68 _H	IEC 60870-5-104, Clause 5	M
5.3.1.11		Configured number of octets L as the maximum number of Data octets (ASDU + Control field) in APDU: max. 253	IEC 60870-5-104, Clause 5	PICS, 9.4
5.3.1.12		4-octet Control field	IEC 60870-5-104, Clause 5	M

Table 1 (continued)

No.	Test	Description	Reference	Required
5.3.1.20	CS104 I-FORMAT APDU Information transfer frame	Control field octet 1 bit 1 (LSB) = 0	IEC 60870-5-104, Clause 5	M
5.3.1.21		Control field octets 1-2, bit 2..16 contain end sequence number N(S) range 0..Maximum value 32767	IEC 60870-5-104, Clause 5	M
5.3.1.22		Control field octet 3 bit 1 (bit 17) = 0	IEC 60870-5-104, Clause 5	M
5.3.1.23		Control field octets 3-4, bit 18..32 contain Receive sequence number N(R) range 0..maximum value 32767	IEC 60870-5-104, Clause 5	M
5.3.1.24		I-format frame contains exactly one ASDU	IEC 60870-5-104, Clause 5	M
5.3.1.25	CS104 S-FORMAT APDU Numbered Supervisory function frame	Control field octet 1, bit 1-2 have value 01 ₁₀	IEC 60870-5-104, Clause 5	M
5.3.1.26		Control field octets 1-2, bit 3..16 all contain value 0	IEC 60870-5-104, Clause 5	M
5.3.1.27		Control field octet 3 bit 1 (bit 17) = 0	IEC 60870-5-104, Clause 5	M
5.3.1.28		Control field octets 3-4, bit 18..32 contain Receive sequence number N(R) range 0..maximum value 32767	IEC 60870-5-104, Clause 5	M
5.3.1.29		S-frame APDU only contains a single APCI field	IEC 60870-5-104, Clause 5	M
5.3.1.30	CS104 U-FORMAT APDU Unnumbered Control function frame	Control field octet 1, bit 1-2 have value 11 ₁₀	IEC 60870-5-104, Clause 5	M
5.3.1.31		Control field octet 1, bit 3 used for control function STARTDT Activation	IEC 60870-5-104, Clause 5	M
5.3.1.32		Control field octet 1, bit 4 used for control function STARTDT Confirmation	IEC 60870-5-104, Clause 5	M
5.3.1.33		Control field octet 1, bit 5 used for control function STOPDT Activation	IEC 60870-5-104, Clause 5	M
5.3.1.34		Control field octet 1, bit 6 used for control function STOPDT Confirmation	IEC 60870-5-104, Clause 5	M
5.3.1.35		Control field octet 1, bit 7 used for control function TESTFR Activation	IEC 60870-5-104, Clause 5	M
5.3.1.36		Control field octet 1, bit 8 used for control function TESTFR Confirmation	IEC 60870-5-104, Clause 5	M
5.3.1.37		Control field bit 3..8 contains exactly one active (bit with value 1) Control function (TESTFR, STARTDT, STOPDT, either Activation or Confirmation) per U-frame	IEC 60870-5-104, Clause 5	M
5.3.1.38		Control field octets 2-4, bit 9..32 all contain value 0	IEC 60870-5-104, Clause 5	M
5.3.1.39		U-frame APDU only contains a single APCI field	IEC 60870-5-104, Clause 5	M

Table 1 (continued)

No.	Test	Description	Reference	Required
5.3.1.50	TRANSMISSION PROCEDURE	Balanced transmission (after TCP connection has been established)	IEC 60870-5-104, Introduction	M
		The initial values of the Send sequence number N(S) and the Receive sequence number N(R) are set to 0 (zero) after a new TCP connection is successfully established which is then a Stopped connection	IEC 60870-5-104, 5.1	M
		An I-frame contains the current values of the Send sequence number N(S) and the Receive sequence number N(R)	IEC 60870-5-104, 5.1	M
		After sending an I-frame, the Send sequence number N(S) in the Primary station is incremented with 1	IEC 60870-5-104, 5.1	M
		After receiving a valid I-frame, the Receive sequence number N(R) in the Secondary station is incremented with 1	IEC 60870-5-104, 5.1	M
		Yet unacknowledged I-frames from the Primary station are acknowledged by either an I-frame or an S-frame from the Secondary station	IEC 60870-5-104, 5.1	M
		The Receive sequence number N(R) acknowledges all yet unacknowledged I-frames with $N(S) < N(R)$	IEC 60870-5-104, 5.1	M
		A Primary station sends at most the configured amount of K unacknowledged I-frames before it stops and waits for an acknowledgement	IEC 60870-5-104, 5.5	M
		A Secondary station sends an acknowledgement after receiving at most the configured amount of W I-frames	IEC 60870-5-104, 5.5	M
		An APDU with a Send sequence number N(S) that is higher or lower (called "out of sequence") than the current Receive sequence number N(R), results in [sending an S-frame to confirm the I-frames that it has received (if applicable) after which] a TCP Active close (TCP Control field FIN) is given by the Secondary Station (because one or more previous APDUs may have been lost along the way to their destination due to connection failures)	IEC 60870-5-104, 5.1 [MOM WG03 15 June 2001 4.2.1/4.2.2.3]	M
		U-Frame Control function STARTDT_ACT answered with STARTDT_CON	IEC 60870-5-104, 5.3	M
		U-Frame Control function STOPDT_ACT answered with STOPDT_CON	IEC 60870-5-104, 5.3	M
		U-Frame Control function TESTFR_ACT answered with TESTFR_CON	IEC 60870-5-104, 5.2	M

Table 1 (continued)

No.	Test	Description	Reference	Required
5.3.1.70	TRANSMISSION CONTROL USING START/STOP	After a TCP connection has been established, initially a <i>Stopped connection</i> is created (a <i>Stopped connection</i> is an open ("established") TCP connection that is in confirmed <i>STOPDT</i> state) and allows the exchange of U-frames in controlling and controlled direction Both the Controlling and Controlled station explicitly disable the transfer and do not answer the receipt of I- and S-frames in a <i>Stopped connection</i> The controlling station sends a <i>STARTDT_ACT</i> after which a <i>Pending Started connection</i> is created. The controlling station may send U-, I-, and S- frames immediately after the <i>STARTDT_ACT</i> which will be accepted by the controlled station The controlled station explicitly disables the transfer of I- and S-frames and the controlling station does not accept I- or S-frames in a <i>Pending Started connection</i>, but only U-frames After the controlling station has received <i>STARTDT_CON</i>, the <i>Started connection</i> is created and the controlled station may send U-, I-, and S- frames immediately after the <i>STARTDT_CON</i>. Controlled and controlling stations are allowed to send U-, I-, and S- frames The Controlling station explicitly disables the transfer of I-frames in monitoring direction by sending a <i>STOPDT_ACT</i> to the Controlled station, after which a <i>Pending Stopped connection</i> is created The controlled station disables the transfer of I-frames after the <i>STOPDT_ACT</i> is received. The controlling station may receive I-frames, which are transferred before the receipt of the <i>STOPDT_ACT</i> If unconfirmed I-frames are in the controlled station, the <i>Pending Stopped connection</i> is called the <i>Pending Unconfirmed Stopped connection</i>. If the controlled station receives the S-frame to confirm the I-frames (immediately or after time-out t2 of the controlling station expires) the controlled station sends the <i>STOPDT_CON</i> after the <i>Stopped connection</i> is created If NO unconfirmed I-frames are in the controlled station the controlled station sends a <i>STOPDT_CON</i> to the controlling station after which the <i>Stopped connection</i> is created Send sequence number N(S) and Receive Sequence number N(R) remain unchanged during the use of U-frames with <i>STARTDT</i> / <i>STOPDT</i> indications	IEC 60870-5-104, 5.3 IEC 60870-5-104, 5.3 [MOM WG03 15 June 2001 4.2.2.5] IEC 60870-5-104, 5.3 [MOM WG03 15 June 2001 4.2.2.5] IEC 60870-5-104, 5.3 [MOM WG03 15 June 2001 4.2.2.5] IEC 60870-5-104, 5.3 [MOM WG03 15 June 2001 4.2.2.5] IEC 60870-5-104, 5.3 [MOM WG03 15 June 2001 4.2.2.5] IEC 60870-5-104, 5.3 [MOM WG03 15 June 2001 4.2.2.5] IEC 60870-5-104, 5.3 [MOM WG03 15 June 2001 4.2.2.5] IEC 60870-5-104, 5.3 [MOM WG03 15 June 2001 4.2.2.5]	M M M M M M M M M M

Table 1 (continued)

No.	Test	Description	Reference	Required
5.3.1.90	TIME OUT INTERVALS	An unanswered TCP Active open by the (fixed) Controlling Station (TCP Control field SYN: CONNECTION REQUEST) is actually cancelled after the configured time out t_0 (range 1..255 s) and subsequently restarted. It is highly recommended to cancel the current timed out TCP Active open, to prevent against an increasing number of "not cancelled" TCP connections because of the limited number of available open connections in a system A TCP Passive open by the Controlled Station (LISTEN) remains active infinitely until a CONNECT is received An I-frame from the Primary Station that is not acknowledged within the configured time out t_1 (range 1..255 s) results in a TCP Active close (TCP Control field FIN) by the Primary Station. [The time out t_1 runs for every I-frame individually and is cancelled if that particular I-frame has been confirmed.] A U-frame from the Primary Station that is not confirmed within the configured time out t_1 (range 1..255 s) results in a TCP Active close (TCP Control field FIN) by the Primary Station After the configured time period t_2 (range 1..254 s) of transmitting I-frames, [which starts after the first unconfirmed frame is received], from the Primary Station in one direction only, an S-frame is sent by the Secondary Station to acknowledge the last I-frame $t_2 < t_1$ After the configured time period t_3 (range 1..255 s) of inactivity (no transmission of I-, S- or U-frames on the connection by either Primary or Secondary station), a U-frame with TESTFR_ACT is sent. All time out interval rules apply $t_3 > t_1$	IEC 60870-5-104, 7.1, Figure 19 IEC 60870-5-104, 7.1 IEC 60870-5-104, 5.1, Figure 12 IEC 60870-5-104, 5.2 IEC 60870-5-104, 5.3 [MOM WG03 15 June 2001 4.2.1/4.2.2.3] IEC 60870-5-104, 5.1 IEC 60870-5-104, 5.2 IEC 60870-5-104, 5.1, Figure 10 [MOM WG03 15 June 2001 4.2.1/4.2.2.3] IEC 60870-5-104, 9.6 IEC 60870-5-104, 5.2 IEC 60870-5-104, 9.6	M M M M M M M M

Table 2 – Tests on data unit identifier

No.	Test	Description	Reference	Required
5.3.2.1	TYPE IDENTIFICATION	Compatible ASDU type used/accepted for all ASDU's as in the PICS	IEC 60870-5-101, 7.2.1.1 IEC 60870-5-101, 7.3.1 IEC 60870-5-104, Clause 8 PID	PICS, 9.5
5.3.2.2		Variable structure qualifier SQ (Sequence or Set) as defined for each ASDU	IEC 60870-5-101, 7.2.2 IEC 60870-5-101, 7.3.1	M
5.3.2.3		SQ:=1 only for COT Spontaneous (3), Cyclic/Periodic (1), Requested (5) or Interrogation (20..36). Check the PICS for the supported COT values	IEC 60870-5-101, 7.2.2	PIXIT
5.3.2.4		Variable structure qualifier i (Number of elements) according to transmitted number of information elements	IEC 60870-5-101, 7.2.2	M
5.3.2.5		Defined number of octets for ASDU	IEC 60870-5-101, 7.2	M
5.3.2.10	CAUSE OF TRANSMISSION	Originator address identifies source application of Primary station or 0 if present but not used	IEC 60870-5-101, 7.2.3 IEC 60870-5-104, 9.5	PIXIT
5.3.2.11		Compatible Cause Of Transmission (COT) used/accepted. Check the PICS for the supported COT values	IEC 60870-5-101, 7.2.3 IEC 60870-5-101, 7.2.3	PICS, 9.5
5.3.2.12		P/N bit = 0: positive confirmation of activation	IEC 60870-5-101, 7.2.3	M
5.3.2.13		P/N bit = 1: negative confirmation of activation	IEC 60870-5-101, 7.2.3	M
5.3.2.14		Test bit = 0: ASDU generated during normal conditions	IEC 60870-5-101, 7.2.3	M
5.3.2.15		Test bit = 1: ASDU generated during test conditions	IEC 60870-5-101, 7.2.3	PIXIT

Table 3 – Verification of ASDUs for process information in monitor (normal) direction

No.	Test	Description	Reference	Required
5.3.3.10	M_SP_NA_1 ASDU 1	SIQ with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.1	PICS, 9.5
5.3.3.11	Single-point information	SIQ with SQ = 1, with only the IOA of the 1 st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.1	PIXIT
5.3.3.12		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.1	PICS, 9.5
5.3.3.13	SIQ	SPI = 0 (OFF), 1 (ON)	IEC 60870-5-101, 7.2.6.1	PICS, 9.5
5.3.3.14		RES = 0	IEC 60870-5-101, 7.2.6.1	PICS, 9.5
5.3.3.15		BL = 0,1	IEC 60870-5-101, 7.2.6.1	PIXIT
5.3.3.16		SB = 0,1	IEC 60870-5-101, 7.2.6.1	PIXIT
5.3.3.17		NT = 0,1	IEC 60870-5-101, 7.2.6.1	PIXIT
5.3.3.18		IV = 0,1	IEC 60870-5-101, 7.2.6.1	PICS, 9.5
5.3.3.30	M_DP_NA_1 ASDU 3	DIQ with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.3	PICS, 9.5
5.3.3.31	Double-point information	DIQ with SQ = 1, with only the IOA of the 1 st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.3	PIXIT
5.3.3.32		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.3	PICS, 9.5
5.3.3.33	DIQ	DPI = 0 (indeterminate or intermediate state), 1 (OFF), 2 (ON), 3 (indeterminate state)	IEC 60870-5-101, 7.2.6.2	PICS, 9.5
5.3.3.34		RES = 0	IEC 60870-5-101, 7.2.6.2	PICS, 9.5
5.3.3.35		BL = 0,1	IEC 60870-5-101, 7.2.6.2	PIXIT
5.3.3.36		SB = 0,1	IEC 60870-5-101, 7.2.6.2	PIXIT
5.3.3.37		NT = 0,1	IEC 60870-5-101, 7.2.6.2	PIXIT
5.3.3.38		IV = 0,1	IEC 60870-5-101, 7.2.6.2	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.50	M_ST_NA_1	VTI with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.5	PICS, 9.5
5.3.3.51	ASDU 5 Step-position information	VTI with SQ = 1, with only the IOA of the 1st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.5	PIXIT
5.3.3.52		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.5	PICS, 9.5
5.3.3.53	VTI	Value valid range -64...+63	IEC 60870-5-101, 7.2.6.5	PICS, 9.5
5.3.3.54		Transient = 0,1	IEC 60870-5-101, 7.2.6.5	PICS, 9.5
5.3.3.55	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.56		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.57		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.58		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.59		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.60		OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.70	M_BO_NA_1	BSI with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.7	PICS, 9.5
5.3.3.71	ASDU 7 Bitstring of 32 bit	BSI with SQ = 1, with only the IOA of the 1st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.7	PIXIT
5.3.3.72		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.7	PICS, 9.5
5.3.3.73	BSI	BSI = 0,1	IEC 60870-5-101, 7.2.6.13	PICS, 9.5
5.3.3.74	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.75		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.76		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.77		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.78		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.79		OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.90	M_ME_NA_1 ASDU 9 Measured value, normalised value	NVA with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.9	PICS, 9.5
5.3.3.91		NVA with SQ = 1, with only the IOA of the 1st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.9	PIXIT
5.3.3.92	NVA	COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.9	PICS, 9.5
5.3.3.93		Value (translation considering the scaling factor)	IEC 60870-5-101, 7.2.6.6	PICS, 9.5 PIXIT
5.3.3.94		Range -1 to +1-2 ⁻¹⁵	IEC 60870-5-101, 7.2.6.6	PICS, 9.5
5.3.3.95	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.96		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.97		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.98		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.99		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.100		OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.110	M_ME_NB_1 ASDU 11 Measured value, scaled value	SVA with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.11	PICS, 9.5
5.3.3.111		SVA with SQ = 1, with only the IOA of the 1st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.11	PIXIT
5.3.3.112		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.11	PICS, 9.5
5.3.3.113	SVA	Value (translation considering the scaling factor)	IEC 60870-5-101, 7.2.6.7	PICS, 9.5 PIXIT
5.3.3.114		Range -2^{15} to $2^{15} - 1$	IEC 60870-5-101, 7.2.6.7	PICS, 9.5
5.3.3.115	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.116		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.117		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.118		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.119		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.120		OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.130	M_ME_NC_1 ASDU 13 Measured value, short floating point number	IEEE STD 754 with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.13	PICS, 9.5
5.3.3.131		IEEE STD 754 with SQ = 1, with only the IOA of the 1st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.13	PIXIT
5.3.3.132		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.13	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.133	IEEE STD 754	Fraction = 0... $1-2^{-23}$	IEC 60870-5-101, 7.2.6.8	PICS, 9.5
5.3.3.134		Exponent = 0...255	IEC 60870-5-4, 6.5	PICS, 9.5
5.3.3.135		Sign = 0,1	IEC 60870-5-101, 7.2.6.8 IEC 60870-5-4, 6.5	PICS, 9.5
5.3.3.136	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.137		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.138		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.139		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.140		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.141	M_IT_NA_1 ASDU 15 Integrated totals	OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.150		BCR with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.15	PICS, 9.5
5.3.3.151		BCR with SQ = 1, with only the IOA of the 1st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.15	PIXIT
5.3.3.152		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.15	PICS, 9.5
5.3.3.153		Value range -2^{31} to $+2^{31}-1$	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.154	BCR	Sequence Number SQ range 0 to 31	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.155		CY = 0,1	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.156		CA = 0,1	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.157		IV = 0,1	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.170		SCD with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.20	PICS, 9.5
5.3.3.171	M_PS_NA_1 ASDU 20 Packed single-point information with status change detection	SCD with SQ = 1, with only the IOA of the 1st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.20	PIXIT
5.3.3.172		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.20	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.173	SCD	STi = 0,1	IEC 60870-5-101, 7.2.6.40	PIXIT
5.3.3.174		CDi = 0,1	IEC 60870-5-101, 7.2.6.40	PIXIT
5.3.3.175	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.176		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.177		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.178		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.179		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.180		OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.190	M_ME_ND_1 ASDU 21 Measured value, normalised value without quality descriptor	NVA with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.21	PICS, 9.5
5.3.3.191		NVA with SQ = 1, with only the IOA of the 1st element and the following Information Elements are identified by numbers incrementing continuously by +1 from this offset (see IEC 60870-5-101, 7.2.2.1)	IEC 60870-5-101, 7.3.1.21	PIXIT
5.3.3.192	NVA	COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.21	PICS, 9.5
5.3.3.193		Value (translation considering the scaling factor)	IEC 60870-5-101, 7.2.6.6	PICS, 9.5 PIXIT
5.3.3.194		Range -1 to +1-2 ⁻¹⁵	IEC 60870-5-101, 7.2.6.6	PICS, 9.5
5.3.3.210		SIQ with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.22	PICS, 9.5
5.3.3.211	M_SP_TB_1 ASDU 30 Single-point information with time tag CP56Time2a	COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.22	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.212	SIQ	SPI = 0 (OFF), 1 (ON)	IEC 60870-5-101, 7.2.6.1	PICS, 9.5
5.3.3.213		RES = 0	IEC 60870-5-101, 7.2.6.1	PICS, 9.5
5.3.3.214		BL = 0, 1	IEC 60870-5-101, 7.2.6.1	PIXIT
5.3.3.215		SB = 0, 1	IEC 60870-5-101, 7.2.6.1	PIXIT
5.3.3.216		NT = 0, 1	IEC 60870-5-101, 7.2.6.1	PIXIT
5.3.3.217		IV = 0, 1	IEC 60870-5-101, 7.2.6.1	PICS, 9.5
5.3.3.218	CP56TIME2A	milliseconds = 0..59999	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.219		minutes = 0..59	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.220		hours = 0..23	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.221		Res1 = <0> genuine time, or <1> substituted time	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.222		res2, res3, res4 = 0	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.223		IV = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.224		SU = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.225		day of week = 0 or 1..7	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.226		day of month = 1..31	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.227		month = 1..12	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.228	M_DP_TB_1 ASDU 31 Double-point information with time-tag CP56Time2a	year = 0..99 (year 2000 = 00, year 1999 is 99)	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.230		DIQ with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.23	PICS, 9.5
5.3.3.231		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.23	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.232	DIQ	DIQ = 0 (indeterminate or intermediate state), 1 (OFF), 2 (ON), 3 (indeterminate state)	IEC 60870-5-101, 7.2.6.2	PICS, 9.5
5.3.3.233		RES = 0	IEC 60870-5-101, 7.2.6.2	PICS, 9.5
5.3.3.234		BL = 0,1	IEC 60870-5-101, 7.2.6.2	PIXIT
5.3.3.235		SB = 0,1	IEC 60870-5-101, 7.2.6.2	PIXIT
5.3.3.236		NT = 0,1	IEC 60870-5-101, 7.2.6.2	PIXIT
5.3.3.237		IV = 0,1	IEC 60870-5-101, 7.2.6.2	PICS, 9.5
5.3.3.238	CP56TIME2A	milliseconds = 0..59999	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.239		minutes = 0..59	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.240		hours = 0..23	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.241		Res1 = <0> genuine time, or <1> substituted time	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.242		res2, res3, res4 = 0	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.243		IV = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.244		SU = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.245		day of week = 0 or 1..7	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.246		day of month = 1..31	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.247		month = 1..12	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.248	M_ST_TB_1 ASDU 32 Step-position information with time-tag CP56Time2a	year = 0..99 (year 2000 = 00, year 1999 is 99)	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.250		VTI with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.24	PICS, 9.5
5.3.3.251		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.24	PICS, 9.5
5.3.3.252	VTI	Value valid range -64..+63	IEC 60870-5-101, 7.2.6.5	PICS, 9.5
5.3.3.253		Transient = 0,1	IEC 60870-5-101, 7.2.6.5	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.254	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.255		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.256		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.257		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.258		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.259		OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.260	CP56TIME2A	milliseconds = 0..59999	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.261		minutes = 0..59	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.262		hours = 0..23	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.263		Res1 = <0> genuine time, or <1> substituted time	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.264		res2, res3, res4 = 0	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.265		IV = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.266		SU = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.267		day of week = 0 or 1..7	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.268		day of month = 1..31	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.269		month = 1..12	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.270	M_BO_TB_1 ASDU 33 Bitstring of 32 bit with time-tag CP56Time2a	year = 0..99 (year 2000 = 00, year 1999 is 99)	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.280		BSI with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.25	PICS, 9.5
5.3.3.281		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.25	PICS, 9.5
5.3.3.282		BSI = 0,1	IEC 60870-5-101, 7.2.6.13	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.283	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.284		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.285		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.286		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.287		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.288		OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.289	CP56TIME2A	milliseconds = 0..59999	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.290		minutes = 0..59	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.291		hours = 0..23	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.292		Res1 = <0> genuine time, or <1> substituted time	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.293		res2, res3, res4 = 0	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.294		IV = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.295		SU = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.296		day of week = 0 or 1..7	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.297		day of month = 1..31	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.298		month = 1..12	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.299	M_ME_TD_1 ASDU 34 Measured value, normalised value with time-tag CP56Time2a	year = 0..99 (year 2000 = 00, year 1999 is 99)	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.310		NVA with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.26	PICS, 9.5
5.3.3.311		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.26	PICS, 9.5
5.3.3.312	NVA	Value (translation considering the scaling factor)	IEC 60870-5-101, 7.2.6.6	PICS, 9.5 PIXIT
5.3.3.313		Range -1 to +1-2 ⁻¹⁵	IEC 60870-5-101, 7.2.6.6	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.314	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.315		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.316		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.317		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.318		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.319		OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.320	CP56TIME2A	milliseconds = 0..59999	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.321		minutes = 0..59	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.322		hours = 0..23	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.323		Res1 = <0> genuine time, or <1> substituted time	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.324		res2, res3, res4 = 0	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.325		IV = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.326		SU = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.327		day of week = 0 or 1..7	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.328		day of month = 1..31	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.329		month = 1..12	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.330	M_ME_TE_1 ASDU 35 Measured value, scaled value with time-tag CP56Time2a	year = 0..99 (year 2000 = 00, year 1999 is 99)	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.340		SVA with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.27	PICS, 9.5
5.3.3.341		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.27	PICS, 9.5
5.3.3.342	SVA	Value (translation considering the scaling factor)	IEC 60870-5-101, 7.2.6.7	PICS, 9.5 PIXIT
5.3.3.343		Range -2^{15} to $2^{15} - 1$	IEC 60870-5-101, 7.2.6.7	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.344	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.345		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.346		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.347		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.348		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.349		OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.350	CP56TIME2A	milliseconds = 0..59999	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.351		minutes = 0..59	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.352		hours = 0..23	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.353		Res1 = <0> genuine time, or <1> substituted time	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.354		res2, res3, res4 = 0	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.355		IV = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.356		SU = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.357		day of week = 0 or 1..7	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.358		day of month = 1..31	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.359		month = 1..12	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.360	M_ME_TF_1 ASDU 36 Measured value, short floating point number with time-tag CP56Time2a	year = 0..99 (year 2000 = 00, year 1999 is 99)	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.370		IEEE STD 754 with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.28	PICS, 9.5
5.3.3.371		COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.28	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.372	IEEE STD 754	Fraction = 0..1-2 ⁻²³	IEC 60870-5-101, 7.2.6.8	PICS, 9.5
5.3.3.373		Exponent = 0..255	IEC 60870-5-4, 6.5	PICS, 9.5
5.3.3.374		Sign = 0,1	IEC 60870-5-101, 7.2.6.8 IEC 60870-5-4, 6.5	PICS, 9.5
5.3.3.375	QDS	RES = 0	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.376		BL = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.377		SB = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.378		NT = 0,1	IEC 60870-5-101, 7.2.6.3	PIXIT
5.3.3.379		IV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.380	CP56TIME2A	OV = 0,1	IEC 60870-5-101, 7.2.6.3	PICS, 9.5
5.3.3.381		milliseconds = 0..59999	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.382		minutes = 0..59	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.383		hours = 0..23	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.384		Res1 = <0> genuine time, or <1> substituted time	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.385		res2, res3, res4 = 0	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.386		IV = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.387		SU = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.388		day of week = 0 or 1..7	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.389		day of month = 1..31	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.390		month = 1..12	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.391		year = 0..99 (year 2000 = 00, year 1999 is 99)	IEC 60870-5-101, 7.2.6.18	PICS, 9.5

Table 3 (continued)

No.	Test	Description	Reference	Required
5.3.3.400	M_IT_TB_1	BCR with SQ = 0, each element with its own IOA	IEC 60870-5-101, 7.3.1.29	PICS, 9.5
5.3.3.401	ASDU 37 Integrated totals with time tag CP56Time2a	COT as defined in the attached PICS	IEC 60870-5-101, 7.3.1.29	PICS, 9.5
5.3.3.402	BCR	range = -2^{31} to $+2^{31}-1$	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.403		Sequence Number SQ range 0 to 31	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.404		CY = 0,1	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.405		CA = 0,1	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.406		IV = 0,1	IEC 60870-5-101, 7.2.6.9	PICS, 9.5
5.3.3.407	CP56TIME2A	milliseconds = 0..59999	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.408		minutes = 0..59	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.409		hours = 0..23	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.410		Res1 = <0> genuine time, or <1> substituted time	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.411		res2, res3, res4 = 0	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.412		IV = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.413		SU = 0..1	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.414		day of week = 0 or 1..7	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.415		day of month = 1..31	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.416		month = 1..12	IEC 60870-5-101, 7.2.6.18	PICS, 9.5
5.3.3.417		year = 0..99 (year 2000 = 00, year 1999 is 99)	IEC 60870-5-101, 7.2.6.18	PICS, 9.5