Recognized as an
American National Standard (ANSI)

IEEE Std 1313-1993
(Reaffirmation and redesignation of ANSI C92.1-1982)

IEEE Standard for Power Systems—Insulation Coordination

Sponsor

Technical Counsel
of the
IEEE Power Engineering Society

Approved March 18, 1993

IEEE Standards Board

Approved August 30, 1993

American National Standards Institute

Abstract: Equipment for three-phase alternating-current (ac) systems having a system voltage above 1 kV nominal is discussed. Except for some definitions, this standard includes only phase-to-ground insulation. The object of this standard is to guide the preparation of specifications for insulation of the various items of equipment in a given installation.
Keywords: alternating-current systems, insulation, system voltage, system voltage testing

---

The Institute of Electrical and Electronics Engineers, Inc.
345 East 47th Street, New York, NY 10017-2394, USA

Copyright © 1993 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 1993. Printed in the United States of America

ISBN 1-55937-405-5

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Documents
Document Sharing Hub

Authorized licensed use limited to: Tsinghua University. Downloaded on February 24,2026 at 14:12:07 UTC from IEEE Xplore. Restrictions apply.

Full document details: IEEE 1313-1993

IEEE Standards documents are developed within the Technical Committees of the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Board. Members of the committees serve voluntarily and without compensation. They are not necessarily members of the Institute. The standards developed within IEEE represent a consensus of the broad expertise on the subject within the Institute as well as those activities outside of IEEE that have expressed an interest in participating in the development of the standard.

Use of an IEEE Standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of all concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason IEEE and the members of its technical committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE Standards Board
445 Hoes Lane
P.O. Box 1331
Piscataway, NJ 08855-1331
USA

IEEE standards documents may involve the use of patented technology. Their approval by the Institute of Electrical and Electronics Engineers, Inc. does not mean that using such technology for the purpose of conforming to such standards is authorized by the patent owner. It is the obligation of the user of such technology to obtain all necessary permissions.

Documents
Document Sharing Hub

Authorized licensed use limited to: Tsinghua University. Downloaded on February 24,2026 at 14:12:07 UTC from IEEE Xplore. Restrictions apply.

Full document details: IEEE 1313-1993

Introduction

(This introduction is not a part of IEEE Std 1313-1993, IEEE Standard for Power Systems—Insulation Coordination.)

This standard is a major revision of the previous standard, ANSI C92.1-1971, and presents the process of insulation coordination. Two discrete areas are addressed: self-restoring and nonself-restoring insulation. The statistical procedure of insulation coordination is applicable only for self-restoring insulations.

The basic lightning impulse insulation levels (BIL) and the basic switching impulse insulation levels (BSL) for self-restoring insulations are statistically defined as the crest value of a lightning or switching impulse test voltage at which the insulation exhibits a 90% withstand probability (or a 10% flashover probability). The distribution of lightning or switching overvoltages is defined by a single value that is the crest value of an overvoltage having a 2% probability of being exceeded. The statistical or probabilistic method for insulation coordination allows for insulation failures to occur and attempts to quantify the probability of an insulation flashover. This method statistically compares the voltage stresses on the insulation with the strength of the insulation.

The conventional method for insulation coordination presently required for nonself-restoring insulations consists of comparing the conventional BIL or BSL with the maximum lightning or switching overvoltage. The probability of a flashover is not calculated using the conventional method.

For purposes of insulation coordination, maximum system voltages above 1 kV are divided into three voltage classes:

Medium Voltage. Greater than 1 kV and equal to or less than 72.5 kV.
High Voltage. Greater than 72.5 kV and equal to or less than 242 kV.
Extra-High and Ultra-High Voltage. Greater than 242 kV.

This standard, although applicable to the three voltage classes, places primary emphasis on voltages greater than 242 kV. For the purposes of insulation coordination, extra-high and ultra-high voltages are considered one class. Work on the medium- and high-voltage classes is now in progress in cooperation with the equipment committees and, upon completion, this standard will be revised.

This standard applies only to phase-to-ground insulation except for some definitions. Future revisions will treat phase-to-phase insulation and also the area of the lightning chopped wave insulation strength.

In the development of this standard, IEC Publication 71-1 (1976), Insulation coordination—Part 1: Terms, definitions, principles, and rules, was used as the primary guide. The major differences between this standard and the IEC standard are as follows:

a) Maximum system voltage of 550 kV and 800 kV are used instead of 525 kV and 765 kV.
b) Values of BILs and BSLs of 825 kV and 900 kV are used instead of 850 kV and 950 kV.
c) Values of BILs and BSLs above 1800 kV increase in increments of 125 kV, whereas in the IEC standard, increments of 150 kV are used.
d) The terms BIL and BSL are maintained in this standard, whereas the IEC standard uses the term rated lightning (or switching) impulse withstand voltage.
e) In this standard, the specific combination of values of BIL and BSL for an apparatus is not specified. In the IEC standard, a specific set of values of BIL are tied to each value of BSL.

Suggestions for improvement and revision of this standard will be welcome. They should be sent to the IEEE Standards Department, 445 Hoes Lane, Piscataway, NJ 08855-1331.

Documents
Document Sharing Hub

Authorized licensed use limited to: Tsinghua University. Downloaded on February 24,2026 at 14:12:07 UTC from IEEE Xplore. Restrictions apply.

Full document details: IEEE 1313-1993

The following persons were on the balloting committee:

J. D. Borst
John Boyle
J. S. Edmonds
C. W. Gellings
Jerry W. Hagge
M. L. Holm
J. H. Jones
Fred Kimsey
David G. Kumbera
Stephen R. Lambert
J. H. Mallory
Terry R. McComb
Gary L. Nissen
T. A. Pinkham
N. S. Porter
B. D. Russell
D. K. Sharma
D. R. Volzka
S. G. Whisenant
Charles A. White
J. A. Zulaski

The IEEE Standards Board reaffirmed this standard on March 18, 1993 with the following membership:

Wallace S. Read, *Chair* **Donald C. Loughry,** *Vice Chair*
Andrew G. Salem, *Secretary*

Gilles A. Baril
Clyde R. Camp
Donald C. Fleckenstein
Jay Forster*
David F. Franklin
Ramiro Garcia
Donald N. Heirman
Ben C. Johnson
Walter J. Karplus
Lorraine C. Kevra
E.G. "Al" Kiener
Ivor N. Knight
Joseph Koepfinger*
D.N. "Jim" Logothetis
Don T. Michael*
Marco W. Migliaro
L. John Rankine
Arthur K. Reilly
Ronald H. Reimer
Gary S. Robinson
Leonard L. Tripp
Donald W. Zipse

*Member Emeritus

Also included are the following nonvoting IEEE Standards Board liaisons:

Satish K. Aggarwal
James Beall
Richard B. Engelman
David E. Soffrin
Stanley Warshaw

Mary Lynne Nielsen
IEEE Standards Project Editor

Documents
Document Sharing Hub

Authorized licensed use limited to: Tsinghua University. Downloaded on February 24,2026 at 14:12:07 UTC from IEEE Xplore. Restrictions apply.

Full document details: IEEE 1313-1993

Contents

CLAUSE TITLE

1. Scope and purpose 1
2. Related standards 1
3. Definitions 2
4. Basic principles of insulation coordination 6
5. Preferred values of BIL for equipment in the medium-voltage and high-voltage classes 9
6. Standard BILs and BSLs for equipment in the extra-high and ultra-high voltage class 10
7. General test procedure 12

Documents
Document Sharing Hub

Authorized licensed use limited to: Tsinghua University. Downloaded on February 24,2026 at 14:12:07 UTC from IEEE Xplore. Restrictions apply.

Full document details: IEEE 1313-1993

THIS PAGE WAS
BLANK IN THE ORIGINAL

Documents
Document Sharing Hub

Authorized licensed use limited to: Tsinghua University. Downloaded on February 24,2026 at 14:12:07 UTC from IEEE Xplore. Restrictions apply.

Full document details: IEEE 1313-1993

IEEE Standard for Power Systems—Insulation Coordination

1. Scope and purpose

1.1 Scope

This standard applies to equipment for three-phrase alternating-current (ac) systems having a system voltage above 1 kV nominal and, except for some definitions, includes only phase-to-ground insulation.

1.2 Purpose

The object of this standard is to guide the preparation of specifications for insulation of the various items of equipment in a given installation. For the tests prescribed in this standard, the values of the basic lightning impulse insulation levels (BILs) and the basic switching impulse insulation levels (BSLs) shall be chosen from the preferred values of this standard. Each standards developer shall be responsible for specifying the BILs, BSLs, and test procedures suitable for its equipment, incorporating the content of this standard where practical.

2. Related standards

This standard is intended to be used in conjunction with the following publications. When the following standards are superseded by an approved revision, the revision shall apply.

IEEE Std C57.12.00-1987, IEEE Standard General Requirements for Liquid-Immersed Distribution, Power, and Regulating Transformers (ANSI).

IEEE Std C57.12.90-1987, IEEE Standard Test Code for Liquid-Immersed Distribution, Power, and Regulating Transformers, and Guide for Short-Circuit Testing of Distribution and Power Transformers (ANSI).

IEEE Std C62.1-1989, IEEE Standard for Gapped Silicon-Carbide Surge Arresters for AC Power Circuits (ANSI).

IEEE Std 4-1978, IEEE Standard Techniques for High Voltage Testing (ANSI).

IEEE Std 1312-1993, IEEE Standard Preferred Voltage Ratings for Alternating-Current Electrical Systems and Equipment Operating at Voltages Above 230 kV Nominal (ANSI).

Documents
Document Sharing Hub

Authorized licensed use limited to: Tsinghua University. Downloaded on February 24,2026 at 14:12:07 UTC from IEEE Xplore. Restrictions apply.

Full document details: IEEE 1313-1993