

IEEE Standard for Transient Overvoltage Protection of DC Electrification Systems by Application of DC Surge Arresters

IEEE Vehicular Technology Society

Developed by the
Rail Vehicle Transportation Standards Committee

IEEE
3 Park Avenue
New York, NY 10016-5997
USA

IEEE Std 1627™-2019

IEEE Standard for Transient Overvoltage Protection of DC Electrification Systems by Application of DC Surge Arresters

Developed by the

Rail Vehicle Transportation Standards Committee
of the
IEEE Vehicular Technology Society

Approved 21 May 2019

IEEE-SA Standards Board

Abstract: The design and application of dc surge arresters to protect dc electrification system from transient overvoltage caused by lightning and switching surges is the purpose of this standard. Lightning surges can cause high energy transient overvoltages by direct or indirect coupling with a dc electrification system. Transient overvoltage protection from lightning and switching surges of various dc transit electrification systems can be achieved by the application of metal-oxide varistor (MOV) gapless-surge arresters. The application of surge arresters to running rails in areas where lightning activity is severe requires special study of protection coordination with rail-ground shorting devices [also called voltage-limiting devices (VLDs)] and review of track circuits applied at the transit system. Such study and criteria of selecting VLDs is not included in this standard. However, a surge arrester applied to running rails in higher keraunic areas has been included and requires coordination with both the VLD devices and track circuits applied in the transit system. Many modern light- and heavy-rail transit projects use VLDs, although their application can be avoided by implementing other design measures, such as insulated platforms, or by simply coating the vehicle surface with some special insulation. The purpose of installing VLDs at dc transit projects is to enhance the safety of personnel from the touch potential (rail-ground voltage) on the train vehicle surface. No industry standard on VLDs exists today in North America. Only IEC EN 50526-2 covers VLD.

Keywords: IEEE 1627™, keraunic level, lightning arrester, lightning surges, maximum continuous operating voltage, metal-oxide varistor, MOV, OCS, overhead contact system, residual discharge voltage, SPD, surge arrester, surge-protective devices, switching surges, temporary overvoltage, transient overvoltage, voltage margin of protection, VSA

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2019 by The Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 29 July 2019. Printed in the United States of America.

IEEE and NESC are registered trademarks in the U.S. Patent & Trademark Office, owned by The Institute of Electrical and Electronics Engineers, Incorporated.

National Electrical Code, NEC, and NFPA 70 are registered trademarks in the U.S. Patent & Trademark Office, owned by the National Fire Protection Association.

PDF: ISBN 978-1-5044-5884-9 STD23718
Print: ISBN 978-1-5044-5885-6 STDPD23718

IEEE prohibits discrimination, harassment, and bullying.

For more information, visit <https://www.ieee.org/web/aboutus/whatis/policies/p9-26.html>.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Important Notices and Disclaimers Concerning IEEE Standards Documents

IEEE documents are made available for use subject to important notices and legal disclaimers. These notices and disclaimers, or a reference to this page, appear in all standards and may be found under the heading “Important Notices and Disclaimers Concerning IEEE Standards Documents.” They can also be obtained on request from IEEE or viewed at <https://standards.ieee.org/ipr/disclaimers.html>.

Notice and Disclaimer of Liability Concerning the Use of IEEE Standards Documents

IEEE Standards documents (standards, recommended practices, and guides), both full-use and trial-use, are developed within IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (“IEEE-SA”) Standards Board. IEEE (“the Institute”) develops its standards through a consensus development process, approved by the American National Standards Institute (“ANSI”), which brings together volunteers representing varied viewpoints and interests to achieve the final product. IEEE Standards are documents developed through scientific, academic, and industry-based technical working groups. Volunteers in IEEE working groups are not necessarily members of the Institute and participate without compensation from IEEE. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information or the soundness of any judgments contained in its standards.

IEEE Standards do not guarantee or ensure safety, security, health, or environmental protection, or ensure against interference with or from other devices or networks. Implementers and users of IEEE Standards documents are responsible for determining and complying with all appropriate safety, security, environmental, health, and interference protection practices and all applicable laws and regulations.

IEEE does not warrant or represent the accuracy or content of the material contained in its standards, and expressly disclaims all warranties (express, implied and statutory) not included in this or any other document relating to the standard, including, but not limited to, the warranties of: merchantability; fitness for a particular purpose; non-infringement; and quality, accuracy, effectiveness, currency, or completeness of material. In addition, IEEE disclaims any and all conditions relating to: results; and workmanlike effort. IEEE standards documents are supplied “AS IS” and “WITH ALL FAULTS.”

Use of an IEEE standard is wholly voluntary. The existence of an IEEE standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard.

In publishing and making its standards available, IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity nor is IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing any IEEE Standards document, should rely upon his or her own independent judgment in the exercise of reasonable care in any given circumstances or, as appropriate, seek the advice of a competent professional in determining the appropriateness of a given IEEE standard.

IN NO EVENT SHALL IEEE BE LIABLE FOR ANY DIRECT, INDIRECT, INCIDENTAL, SPECIAL, EXEMPLARY, OR CONSEQUENTIAL DAMAGES (INCLUDING, BUT NOT LIMITED TO: PROCUREMENT OF SUBSTITUTE GOODS OR SERVICES; LOSS OF USE, DATA, OR PROFITS; OR BUSINESS INTERRUPTION) HOWEVER CAUSED AND ON ANY THEORY OF LIABILITY, WHETHER IN CONTRACT, STRICT LIABILITY, OR TORT (INCLUDING NEGLIGENCE OR OTHERWISE) ARISING IN ANY WAY OUT OF THE PUBLICATION, USE OF, OR RELIANCE UPON ANY STANDARD, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE AND REGARDLESS OF WHETHER SUCH DAMAGE WAS FORESEEABLE.

Translations

The IEEE consensus development process involves the review of documents in English only. In the event that an IEEE standard is translated, only the English version published by IEEE should be considered the approved IEEE standard.

Official statements

A statement, written or oral, that is not processed in accordance with the IEEE-SA Standards Board Operations Manual shall not be considered or inferred to be the official position of IEEE or any of its committees and shall not be considered to be, or be relied upon as, a formal position of IEEE. At lectures, symposia, seminars, or educational courses, an individual presenting information on IEEE standards shall make it clear that his or her views should be considered the personal views of that individual rather than the formal position of IEEE.

Comments on standards

Comments for revision of IEEE Standards documents are welcome from any interested party, regardless of membership affiliation with IEEE. However, IEEE does not provide consulting information or advice pertaining to IEEE Standards documents. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Since IEEE standards represent a consensus of concerned interests, it is important that any responses to comments and questions also receive the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to comments or questions except in those cases where the matter has previously been addressed. For the same reason, IEEE does not respond to interpretation requests. Any person who would like to participate in revisions to an IEEE standard is welcome to join the relevant IEEE working group.

Comments on standards should be submitted to the following address:

Secretary, IEEE-SA Standards Board
445 Hoes Lane
Piscataway, NJ 08854 USA

Laws and regulations

Users of IEEE Standards documents should consult all applicable laws and regulations. Compliance with the provisions of any IEEE Standards document does not imply compliance to any applicable regulatory requirements. Implementers of the standard are responsible for observing or referring to the applicable regulatory requirements. IEEE does not, by the publication of its standards, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

IEEE draft and approved standards are copyrighted by IEEE under U.S. and international copyright laws. They are made available by IEEE and are adopted for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of engineering practices and methods. By making these documents available for use and adoption by public authorities and private users, IEEE does not waive any rights in copyright to the documents.

Photocopies

Subject to payment of the appropriate fee, IEEE will grant users a limited, non-exclusive license to photocopy portions of any individual standard for company or organizational internal use or individual, non-commercial use only. To arrange for payment of licensing fees, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Updating of IEEE Standards documents

Users of IEEE Standards documents should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of amendments, corrigenda, or errata. An official IEEE document at any point in time consists of the current edition of the document together with any amendments, corrigenda, or errata then in effect.

Every IEEE standard is subjected to review at least every ten years. When a document is more than ten years old and has not undergone a revision process, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE standard.

In order to determine whether a given document is the current edition and whether it has been amended through the issuance of amendments, corrigenda, or errata, visit IEEE Xplore at <http://ieeexplore.ieee.org> or contact IEEE at the address listed previously. For more information about the IEEE SA or IEEE's standards development process, visit the IEEE-SA Website at <http://standards.ieee.org>.

Errata

Errata, if any, for all IEEE standards can be accessed on the IEEE-SA Website at the following URL: <http://standards.ieee.org/findstds/errata/index.html>. Users are encouraged to check this URL for errata periodically.

Patents

Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken by the IEEE with respect to the existence or validity of any patent rights in connection therewith. If a patent holder or patent applicant has filed a statement of assurance via an Accepted Letter of Assurance, then the statement is listed on the IEEE-SA Website at <http://standards.ieee.org/about/sasb/patcom/patents.html>. Letters of Assurance may indicate whether the Submitter is willing or unwilling to grant licenses under patent rights without compensation or under reasonable rates, with reasonable terms and conditions that are demonstrably free of any unfair discrimination to applicants desiring to obtain such licenses.

Essential Patent Claims may exist for which a Letter of Assurance has not been received. The IEEE is not responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patents Claims, or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility. Further information may be obtained from the IEEE Standards Association.

Participants

At the time this IEEE standard was completed, the Power Supply Working Group had the following membership:

Dev Paul, *Chair*
Suresh Shrivale, *Vice Chair*
Zoltan Horvath, *Vice Chair*

Steve Adkins	Albert Hoe	Frank Pierson
Michael Adock	Ethan Kim	Edward Rowe
Jeff Boerma	Stuart Kuritzky	John Schlick
Matt Burke	Alan Latchford	Jeffrey N. Sisson
Butch Campbell	Gordon MacDonald	David Thurston
Ron Clark	Vish Mawley	Carl Wessel
Ramesh Dhingra	Steve Mitani	Paul White
Steve Gross	Stephen Norton	Joe Williams
Ian Hayes	Chris Pagni	Kelvin Zan

The following members of the individual balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Steven Adkins	Walter Keevil	Heather Riebeling
William Aycock	Peter Kelly	Ryandi Ryandi
Charles Barest	Sheldon Kennedy	Hugo Ricardo
Ronald Bennell	Yuri Khersonsky	Sanchez Reategui
Bill Brown	Ethan Kim	Nikunj Shah
Demetrio Bucaneg Jr.	Jim Kulchisky	Suresh Shrivale
William Bush	Saumen Kundu	Jeffrey N. Sisson
William Byrd	Thomas Kurihara	Jeremy Smith
Robert Eberly	Benjamin Lanz	Gary Smullin
John Fish	Yung-chiang Lee	Wayne Stec
Robert Fisher	Hugo Marroquin	Ralph Stell
Paul Forquer	Omar Mazzoni	Raymond Strittmatter
David Gilmer	Michael Newman	David Thurston
H. Glickenstein	Stephen Norton	Gary Touryan
John Grantham	Chris Pagni	David Turner
Randall Groves	Bansi Patel	John Vergis
Werner Hoelzl	Dev Paul	Paul White
Ronald Hotchkiss	Branimir Petosic	Robert Wilson
Peter Hrovat	David R. Phelps	Jian Yu
Andrew Jones	Iulian Profir	Matthew Zeedyk
	Moises Ramos	

When the IEEE-SA Standards Board approved this standard on 21 May 2019, it had the following membership:

Gary Hoffman, *Chair*
Ted Burse, *Vice Chair*
Jean-Philippe Faure, *Past Chair*
Konstantinos Karachalios, *Secretary*

Masayuki Ariyoshi
Stephen D. Dukes
J. Travis Griffith
Guido Hiertz
Christel Hunter
Thomas Koshy
Joseph L. Koepfinger*
Thomas Koshy

John D. Kulick
David J. Law
Joseph Levy
Howard Li
Xiaohui Liu
Kevin Lu
Daleep Mohla
Andrew Myles

Annette D. Reilly
Dorothy Stanley
Sha Wei
Phil Wennblom
Philip Winston
Howard Wolfman
Feng Wu
Jingyi Zhou

*Member Emeritus

Introduction

This introduction is not part of IEEE Std 1627-2019, IEEE Standard for Transient Overvoltage Protection of DC Electrification Systems by Application of DC Surge Arresters.

This standard applies to dc electrified transit systems that use different configurations to supply dc traction power from the dc traction power substations (TPSSs) to the vehicles. The probability of lightning surges striking a dc electrified transit system depends on its geometry; its height above the ground surface; the track lengths; the tracks' relative location with respect to the presence of tall buildings, trees, towers etc.; and the lightning flash-to-ground intensity of the general area of the rail transit system. If the expected frequency of direct lightning (ND) exceeds its tolerable frequency of lightning (NC) (established by National Electrical Code® (NEC®) (NFPA 70®) and IEC 62305) after the lightning probability risk assessment analysis, then the lightning-protection system (LPS) should be applied (refer to NFPA 780 and the IEC 62305 series to understand how to perform LPS risk analysis and apply it to protect systems from lightning surges).¹ LPSs shall be designed and installed to dc transit electrification systems based on the surge environment and the LPS analysis.

A LPS is not necessary if expected ND is below the expected NC and the dc transit electrification system is considered self-protected from lightning. However, surge arresters should still be applied to protect equipment insulation damage from inherent switching surges and surges induced by nearby lightning.

Arbitrary installation of direct-stroke diverters; such as lightning rods and ground wires above the transit system, such as overhead contact system (OCS) poles; change the geometry and may increase chances of more lightning exposure. Based on such reasoning, it appears that even in the area of higher lightning strokes, the application of ground wires and ground rods above the OCS should not be used as LPSs. The approach of this standard is to develop a transient overvoltage protection scheme that focuses on the basic approach of selection and application of dc surge arresters, their grounding configuration, and grounding of transit system support structures. To achieve such a protection scheme, a review of the following is necessary:

- a) Selection of appropriately rated dc surge arresters.
- b) Grounding of surge arresters by use of an insulated individual grounding conductor (as short as practical) connected to their individual ground electrodes.
- c) For a transit system consisting of an OCS, the grounding of surge arresters shall not be bonded to metallic OCS poles to keep lightning surge hazards away from the poles that can cause insulation breakdown of the insulators and that can cause damage to pole foundation. In addition, poles may become electrical shock hazards, and leakage current of the arrester may cause damage to pole rebar over time.

The selection of basic lightning impulse insulation levels (BILs) for dc electrification equipment is the scope of work for a future IEEE/APTA subcommittee standard, thus no further discussion is included in this standard. A discussion on BILs level of dc switchgear is included in [Table 6](#). BIL values of dc switchgear are also included in IEC 61992-1:2006.

DC transit electrification system components and associated structures cannot simply be compared to electric utility transmission lines as the physical configuration and location of conductive conductors supported on insulated structures of the two systems are quite different: An OCS structure is very close to ground and running rails where lightning spark to ground and OCS structure can occur simultaneously. Therefore, the concept of lightning protection by use of ground/shield wire does not apply to dc electrification systems. However, in the case of single-phase ac electrification OCSs (not included in this standard), an overhead ground wire that carries return traction ac current as well as shield wire above the ground wire are applied.

¹Information on references can be found in [Clause 2](#).

Prior to and during the development of this standard, there were reports of surge-arrester failures on several transit systems resulting in service interruption and equipment failures. Questions were raised regarding the grounding of OCS support poles and the pros and cons of using surge arresters in the OCS. Most importantly, there was no clear understanding of the proper selection and application location of dc surge arresters to OCSs and, in general, to dc electrification systems. This standard now provides technical understanding of surge-arrester application to dc transit projects.

To establish a lightning-protection design scheme for dc electrification systems, the derivation of lightning intensity and lightning stroke surge energy using lightning parameters is required. For such a derivation of lightning intensity, surge arrester selection is established based upon the typical available lightning data.

When considering lightning protection for dc transit electrification system components, especially for the OCS, numerous questions arise, such as:

- a) Will a dc surge arrester handle surge energy if a lightning flash (strike) directly hits the OCS wire near the arrester location?
- b) If a lightning flash directly hits the OCS wire between two TPSSs, what will be the energy discharged through the surge arresters at respective feeder poles?
- c) In higher keraunic areas, is there a need to apply dc surge arresters at the midpoint of two adjacent substations to enhance the lightning protection of the OCS?
- d) Do we need to apply surge arresters at the connection points of underground dc supplementary feeder cable to OCS contact wire located approximately every 122 m to 152.4 m (400 ft to 500 ft), where overhead messenger wire design is not possible in areas due to aesthetics and other restrictions of height of the messenger wires?
- e) Should there be a shield/ground wire above the messenger to enhance lightning protection?
- f) Should we apply surge arresters at dc disconnect sectionalizing switches?
- g) Should surge arresters be considered at the running rails, especially at elevated structures and bridges?

Responses to the above questions are discussed in this standard.

Origin and development IEEE Std 1627-2019

The Overhead Contact Systems Subcommittee was formed in 2001 with the purpose of developing standards governing the design, construction, and maintenance of the OCS and current collection system.

IEEE Std 1627-2019, IEEE Standard for Transient Overvoltage Protection of DC Electrification Systems by Application of DC Surge Arresters, was developed by Working Group 17 of the Overhead Contact Systems Subcommittee of the Rail Transit Vehicle Interface Standards Committee of the IEEE Vehicular Technology Society.

Working Group 17 was established to develop standards governing the transient overvoltage protection of dc transit systems. The primary concern of the working group was a lack of uniform practices and a lack of understanding of the proper application of dc surge arresters, and grounding configurations. Precise information of the transient environment, expected magnitude, duration, and frequency of transient surges is very unpredictable, and there has been no recorded data available to guide application engineers in the selection and application of appropriate dc surge arresters. However, it is clear that the unpredictable threat of transient overvoltage caused by power-system switching surges and lightning surges exists that can occur without warning, causing damage to the dc transit system equipment without proper application of surge-protective devices (SPDs).

It appears that the lack of knowledge of the transient environment and understanding the parameters and rating of dc surge arresters led to guesswork in the selection and application of such protective devices, causing failures at some installations. At some transit properties, failures of dc surge arresters and associated transit equipment damage have been reported. A lack of understanding of characteristics of transient overvoltage; dc surge arrester ratings; their proper selection, installation, and grounding configurations; and a lack of their clear test and application data from the manufacturers has been a major concern in the industry, which led to the development of this standard. Proper application of dc SPDs to practically divert surge energy away from the surge location at the dc transit system relates directly to their effect on equipment protection and personnel safety from surge hazards.

The previous PAR for IEEE P1627 expired in December 2015, just before the committee was finalizing the ballot review comments. Thus, a new PAR was submitted and approved by the IEEE Standards Association in June 2016. This standard is based on the new PAR.

Contents

1. Overview	12
1.1 Scope	12
1.2 Purpose	12
1.3 Contents	12
2. Normative references	13
3. Definitions, acronyms, and abbreviations	14
3.1 Definitions	14
3.2 Acronyms and abbreviations	16
4. Transient surges	16
4.1 Lightning and switching surges	17
4.2 Surge characteristics—Propagation	18
4.3 Magnetic stored energy of surge	19
5. Surge environment—DC transit electrification system	20
5.1 DC surge arrester test data and energy capability	23
5.2 DC surge arrester application	26
5.3 DC surge arrester MCOV rating for dc transit electrification systems	27
5.4 DC surge arrester voltage—Margin of protection	27
5.5 DC surge arrester energy discharge capability	28
5.6 DC surge arrester application analysis calculation	29
6. Lightning stroke terminology	30
6.1 Lightning stroke—OCS components flashover	31
6.2 Lightning stroke magnitude	32
6.3 Lightning stroke induced overvoltage	33
6.4 Lightning stroke surge energy	33
6.5 Arrester discharge energy	34
7. Lightning stroke to an OCS	34
7.1 Lightning strikes the OCS ahead of the supplementary cable connections	38
7.2 Lightning hits the OCS within the supplementary cable connections zone	39
7.3 Lightning surge propagation discussion for supplementary feeder cable	39
8. Grounding and bonding	40
9. DC surge arresters	41
9.1 Application criteria and other considerations	41
9.2 Surge arrester rating	44
10. DC surge arrester service requirements	45
11. DC surge arrester assembly and testing	45
11.1 Design tests	45
11.2 In service (field) tests	46
Annex A (informative) Bibliography	47

IEEE Standard for Transient Overvoltage Protection of DC Electrification Systems by Application of DC Surge Arresters

1. Overview

1.1 Scope

This standard covers the application of dc surge arresters for transient overvoltage protection of dc transit electrification systems. These dc transit electrification systems include light rail, heavy rail, streetcar, and trolley bus systems. This standard covers the selection and application of metal-oxide varistor (MOV) gapless-surge arresters to divert surge energy away from the transit system components. It does not cover low-voltage SPDs that are required within dc traction power system equipment, such as rectifier units, vehicle propulsion systems, or other sensitive components of the dc transit system.

1.2 Purpose

It is the purpose of this standard to provide uniform practices for lightning and switching transient overvoltage protection of dc transit electrification by proper selection of dc surge arresters based on the surge environment and site conditions of the transit system. This standard allows the use of SPDs in dc transit systems to avoid insulation failure due to transient overvoltage. Transient overvoltage protection is just as important as short-circuit protection. This standard will minimize equipment damage caused by transient overvoltages, increasing system reliability that will result in reduced maintenance.

1.3 Contents

First, the basic characteristics of transient surges, their origin, and energy and propagation behavior are described in [Clause 4](#) and [Clause 7](#). This is followed by a brief description of the surge environment expected at dc electrification system in [Clause 5](#) and [Clause 7](#). [Clause 5](#) also includes dc SPD requirements for comparison of transient overvoltage protection, dc surge arrester tested parameters by manufacturers, surge arrester application analysis calculation, and energy absorbing (handling) capability. [Clause 6](#) and [Clause 7](#) cover analysis of lightning strikes to the dc transit electrification system components. [Clause 8](#) covers surge arrester grounding and grounding of OCS poles. [Clause 9](#) includes dc surge arrester application locations and discussion of application parameters including various voltages assigned to a dc surge arrester to help in the selection of dc surge arresters. In addition, [Clause 9](#) includes insulation and BIL levels of dc switchgear. [Clause 10](#) covers dc surge arrester service requirements. [Clause 11](#) covers dc surge arrester assembly and testing and design and field tests, including an application example of dc surge arresters to OCSs.

The terms “surge arrester” and “earth” have been used in this standard in place of “lightning arrester” and “ground” (respectively) without affecting the technical contents of the standard.

2. Normative references

The following referenced documents are indispensable for the application of this document (i.e., they must be understood and used, so each referenced document is cited in text and its relationship to this document is explained). For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments or corrigenda) applies.

Accredited Standards Committee C2, National Electrical Safety Code® (NESC®).²

CENELEC CLC/TS 50544, Low voltage dc surge protective devices for traction systems—Selection and application rules for surge arresters.

CSA C22.1, Canadian Electrical Code.³

EN 50526-1:2012, Railway applications—Fixed installations—DC. Surge arresters and voltage limiting devices—Part 1: Surge arresters.⁴

EN 50526-2, Railway applications—Fixed installations—DC. Surge arresters and voltage limiting devices—Part 2: Voltage limiting devices.

EN 50526-3, Railway applications—Fixed installations—DC. Surge arresters and voltage limiting devices—Part 3: Application guide.

IEC 61992-1:2006, Railway applications—Fixed installations—DC switchgear—Part 1: General, 2006.⁵

IEC 62305, Protection against Lightning.

IEEE Std C37.14™-2015, IEEE Standard for DC (3200 V and below) Power Circuit Breakers Used in Enclosures.^{6,7}

IEEE Std C37.90.1™-2012, IEEE Standard for Surge Withstand Capability (SWC) Tests for Relays and Relay Systems Associated with Electric Power Apparatus.

NFPA 70®, National Electrical Code® (NEC®).⁸

NFPA 780, Standard for the Installation of Lightning Protection Systems.

²The NESC is available from The Institute of Electrical and Electronics Engineers, 445 Hoes Lane, Piscataway, NJ 08854, USA (<https://standards.ieee.org/>).

³CSA publications are available from the Canadian Standards Association (<http://www.csa.ca/>).

⁴EN publications are available from the European Committee for Standardization (CEN) (<https://www.cen.eu/>).

⁵IEC publications are available from the International Electrotechnical Commission (<https://www.iec.ch/>). IEC publications are also available in the United States from the American National Standards Institute (<http://www.ansi.org>).

⁶The IEEE standards or products referred to in this clause are trademarks of The Institute of Electrical and Electronics Engineers, Inc.

⁷IEEE publications are available from The Institute of Electrical and Electronics Engineers, 445 Hoes Lane, Piscataway, NJ 08854, USA (<https://standards.ieee.org/>).

⁸NFPA publications are available from Publications Sales, National Fire Protection Association (<https://www.nfpa.org/>).

3. Definitions, acronyms, and abbreviations

3.1 Definitions

For the purposes of this document, the following terms and definitions apply. The *IEEE Standards Dictionary Online* should be consulted for terms not defined in this clause.⁹ For additional definitions for understanding dc surge arresters' various parameters; which are dc rms voltages and peak voltages refer to standards, CENELEC CLC/TS 50544, BS EN 50163, EN 50526-1:2012, EN 50526-2: 2014, EN 50526-3: 2016, and IEC 61992-1:2006.

basic lightning impulse insulation level: Insulation levels designed to withstand surge voltages rather than only normal operating voltages. Since the insulation lines and equipment are protected by surge arresters draining the surges rapidly before the insulation is damaged, the arrester must operate below the minimum basic lightning impulse insulation level (BIL) and must withstand the surges.

clearance: The shortest distance in air between two conductive materials.

creepage distance: The shortest distance along the surface of the insulating material between two conductive materials.

electrical section: The part of an electrical circuit having its own voltage rating for insulation coordination.

flashover: Disruptive discharge over a solid surface.

grounded: An electrical section intentionally connected to earth that cannot be interrupted.

impulse: A unidirectional wave of voltage or current that without appreciable oscillations rises rapidly to a maximum value and falls—usually less rapidly—to zero with small, if any, excursions of opposite polarity.

insulated: All components isolated from the energized dc conductors by at least one level of insulation. An insulated section shall be under the influence of adjacent energized circuits. An insulated section shall be considered as an electrical section.

keraunic level: The number of thunderstorm days per year in an area.

lightning arrester: *See:* surge arrester.

lightning flash: A very bright light stream seen in the sky from cloud to ground, or from cloud to cloud, or from ground to cloud on a stormy day.

lightning intensity: The number of lightning strikes/per square meter/year in an area.

lightning strike: A cloud-to-ground lightning strike which is a short-duration stroke that (often but not always) appears as a single very bright flash and often has considerable branching. *Syn:* lightning stroke.

lightning stroke: *See:* lightning strike.

maximum continuous operating voltage (MCOV): The maximum designated rms continuous operating voltage in dc volts assigned to surge arrester where minimum current is conducted to ground through the arrester for any voltage less than this voltage.

⁹*IEEE Standards Dictionary Online* is available at: <http://dictionary.ieee.org>.