

**308™**

# **IEEE Standard Criteria for Class 1E Power Systems for Nuclear Power Generating Stations**

**IEEE Power Engineering Society**

Sponsored by the  
Nuclear Power Engineering Committee



Published by  
The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

1 March 2002

Print: SH94970  
PDF: SS94970

Recognized as an  
American National Standard (ANSI)

IEEE Std 308™-2001 (R2007)  
(Revision of IEEE Std 308-1991)

# IEEE Standard Criteria for Class 1E Power Systems for Nuclear Power Generating Stations

Sponsor

**Nuclear Power Engineering Committee**  
of the  
**IEEE Power Engineering Society**

Approved 1 August 2002

**American National Standards Institute**

Reaffirmed 21 March 2007

Approved 6 December 2001

**IEEE-SA Standards Board**

**Abstract:** Class 1E portions of alternating current and direct current power systems and instrumentation and control power systems in single-unit and multiunit nuclear power generating stations are covered. Not included are the preferred power supply; unit generator(s) and their buses; generator breaker; step-up, auxiliary, and start-up transformers; connections to the station switchyard; switchyard; transmission lines; and the transmission network. The intent is to provide criteria for the determination of Class 1E power system design features, criteria for sharing Class 1E power systems in multiunit stations, the requirements for their testing and surveillance, and the requirements for documentation of the Class 1E power system.

**Keywords:** Class 1E power systems, nuclear power station design, nuclear safety

The Institute of Electrical and Electronics Engineers, Inc.  
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2002 by the Institute of Electrical and Electronics Engineers, Inc.  
All rights reserved. Published 1 March 2002. Printed in the United States of America.

Print: ISBN 0-7381-3082-6 SH94970  
PDF: ISBN 0-7381-3083-4 SS94970

*No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.*

**IEEE Standards** documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE-SA) Standards Board. The IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of the Institute and serve without compensation. While the IEEE administers the process and establishes rules to promote fairness in the consensus development process, the IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards.

Use of an IEEE Standard is wholly voluntary. The IEEE disclaims liability for any personal injury, property or other damage, of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, or reliance upon this, or any other IEEE Standard document.

The IEEE does not warrant or represent the accuracy or content of the material contained herein, and expressly disclaims any express or implied warranty, including any implied warranty of merchantability or fitness for a specific purpose, or that the use of the material contained herein is free from patent infringement. IEEE Standards documents are supplied “**AS IS.**”

The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

In publishing and making this document available, the IEEE is not suggesting or rendering professional or other services for, or on behalf of, any person or entity. Nor is the IEEE undertaking to perform any duty owed by any other person or entity to another. Any person utilizing this, and any other IEEE Standards document, should rely upon the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

**Interpretations:** Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments. Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE-SA Standards Board  
445 Hoes Lane  
P.O. Box 1331  
Piscataway, NJ 08855-1331  
USA

Note: Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; +1 978 750 8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

# Introduction

(This introduction is not part of IEEE Std 308-2001, IEEE Standard Criteria for Class 1E Power Systems for Nuclear Power Generating Stations.)

This standard presents criteria and requirements for the electrical power systems of nuclear power generating stations specifically related to providing protection for the health and safety of the public. The Institute of Electrical and Electronics Engineers (IEEE) has developed these criteria to provide guidance in the determination of the design features and the surveillance requirements and testing related to the station electric power systems. Each applicant for a construction permit or an operating license for a nuclear power generating station in the United States is required to develop these items to comply with the Title 10, Code of Federal Regulations, Part 50. Adherence to these criteria may not suffice for assuring the public health and safety because it is the integrated performance of the structures, the fluid systems, the instrumentation, and the electric systems of the station that limits the consequences of accidents. Failure to meet these requirements may be an indication of system inadequacy. Each applicant has the responsibility to assure all applicable parties that this integrated performance is adequate.

## Background

IEEE Std 308-1970™ was prepared by Subcommittee 4, Auxiliary Power Systems of the Joint Committee on Nuclear Power Standards (JCNPS) of the IEEE Nuclear Science Group and the IEEE Power Engineering Society (PES). IEEE Std 308-1971 incorporated the experience of the first edition and added multiunit considerations. IEEE Std 308-1974 was completed by Working Group 4.1 of Subcommittee 4 of JCNPS, which had become the Nuclear Power Engineering Committee (NPEC) of the PES in 1973. IEEE Std 308-1978™ clarified the interface between the functional requirements of the Class 1E power system and the safety systems for elements of the safety system that are within the Class 1E power system. IEEE Std 308-1980™ implemented the recommendations of the Ad Hoc IEEE 308/603 Committee regarding the scope diagram for the IEEE Std 308 and IEEE Std 603™ interface. IEEE Std 308-1991 added criteria for interfacing the Class 1E power system with IEEE Std 765™-1983, IEEE Standard for the Preferred Power Supply for Nuclear Power Generating Stations, and IEEE Std 741™-1990, IEEE Standard Criteria for the Protection of Class 1E Power Systems and Equipment in Nuclear Power Generating Stations. The standard was also updated to reflect the latest requirements of IEEE Std 387™-1984, IEEE Standard Criteria for Diesel-Generator Units Applied as Standby Power Supplies for Nuclear Power Generating Stations; IEEE Std 946™-1985, IEEE Recommended Practice for the Design of Safety-Related DC Auxiliary Power Systems for Nuclear Power Generating Stations; and the recommendations of the NPEC Ad Hoc Committee on Shared Safety Systems. These recommendations resulted in a complete rewrite of the multiunit station considerations clause.

## Safety function concept

A safety system, by definition, shall encompass all of the elements required to achieve a protective or safety function. Figure 2 and Figure 3 illustrate the systems and equipment needed to perform a typical safety function, such as post-accident heat removal. As part of the safety system, the role of the Class 1E power system is clearly that of an auxiliary supporting feature, providing electric power to other safety systems (e.g., recirculation spray system, containment spray system, etc.). In this capacity, the portions of the Class 1E power system that contribute to performing a safety function must comply with the requirements of IEEE Std 603-1991. However, the components, equipment, and systems within the Class 1E power system that perform no direct safety function (e.g., overload devices, protective relaying, etc.) must meet the requirements in IEEE Std 603-1991 that assure that those components, equipment, and systems do not degrade the Class 1E power system below an acceptable level.

## Major role of Class 1E power system

The major role of the Class 1E power system is to provide electric power to the reactor trip system, engineered safety features, and auxiliary supporting features; therefore, the Class 1E power system is an auxiliary supporting feature.

The Class 1E power system is unique in that it extends throughout the plant, having far more complex interfaces than other auxiliary supporting features. Other auxiliary supporting features are usually limited to one area or a single process in the plant and are basically mechanical systems. Characteristic of the complex interfaces of the Class 1E power system is the fact that it is an auxiliary supporting feature; other auxiliary features are auxiliary supporting features for it, and the Class 1E power system may provide support for non-safety system equipment and provide the means for the execution of the safety system protective actions.

The sense and command features include equipment that produces signals (e.g., current transformer, voltage transformer, etc.), measures electric system parameters (e.g., voltage, current, watts, etc.), or functions to limit degradation effects (e.g., protective relaying, thermal overloads, undervoltage relays, etc.). The sense and command features of the Class 1E power system that directly perform a safety function shall comply with the requirements of IEEE Std 603-1991. Sense and command features of the Class 1E power system that do not have a direct safety function must be analyzed to show that their failure will have no unacceptable effects on the Class 1E power system.

In their execute features role, some Class 1E power system equipment, switchgear, circuit breakers, power cabling, and loads (primarily motors) are not only part of the Class 1E power system, but are also integral parts of the engineered safety features.

## Current revision

IEEE Std 308-2001 adds criteria for design and testing documentation of Class 1E power systems, including verification and validation. The standard adds to the criteria for power quality to include potential effects of harmonic distortion and degraded grid conditions. A general update to correct references and to address comments received since the standard was last revised has also been performed.

Working Group SC 4.1 members involved in the preparation of this standard were the following:

**J. E. Stoner, Jr., *Chair***

George Attarian  
Paul Gill

D. T. Goodney  
H. A. Robinson

G. D. Manasco  
William J. Mindick

The following members of the balloting committee voted on this standard. Balloters may have voted for approval, disapproval, or abstention.

Satish K. Aggarwal  
James W. Anderson  
George Attarian  
Vincent P. Bacanskas  
Farouk D. Baxter  
Mark D Bowman  
Daniel F. Brosnan  
Robert C. Carruth  
John P. Carter  
S.K. Chaudhuri  
Raymond J. Christensen  
Robert L. Copyak  
John J. Disosway

Surinder K. Dureja  
Julian Forster  
John Kenneth Greene  
Robert E. Hall  
Gregory K. Henry  
David A. Horvath  
Paul R. Johnson  
Gerald B. Lantz  
John D. MacDonald  
Alexander Marion  
John E. Merando Jr  
Richard B. Miller  
William J. Mindick  
Burt Nemroff

Roger D. Parker  
William G. Schwartz  
Thomas R. Sims  
Barry J. Skoras  
James E. Stoner  
John Tanaka  
John H. Taylor  
James E. Thomas  
Gary J. Toman  
John T. Ullo  
Raymond Weronick  
David J. Zaprazny  
Mark S. Zar

When the IEEE-SA Standards Board approved this standard on 6 December 2001, it had the following membership:

**Donald N. Heirman, *Chair***

**James T. Carlo, *Vice Chair***

**Judith Gorman, *Secretary***

Satish K. Aggarwal  
Mark D. Bowman  
Gary R. Engmann  
Harold E. Epstein  
H. Landis Floyd  
Jay Forster\*  
Howard M. Frazier  
Ruben D. Garzon

James H. Gurney  
Richard J. Holleman  
Lowell G. Johnson  
Robert J. Kennelly  
Joseph L. Koepfinger\*  
Peter H. Lips  
L. Bruce McClung  
Daleep C. Mohla

James W. Moore  
Robert F. Munzner  
Ronald C. Petersen  
Gerald H. Peterson  
John B. Posey  
Gary S. Robinson  
Akio Tojo  
Donald W. Zipse

\*Member Emeritus

Also included is the following nonvoting IEEE-SA Standards Board liaison:

Alan Cookson, *NIST Representative*

Donald R. Volzka, *TAB Representative*

Don Messina

IEEE Standards Project Editor

# Contents

|      |                                                                       |    |
|------|-----------------------------------------------------------------------|----|
| 1.   | Overview.....                                                         | 1  |
| 1.1  | Scope.....                                                            | 1  |
| 1.2  | Purpose.....                                                          | 2  |
| 2.   | References.....                                                       | 4  |
| 3.   | Definitions .....                                                     | 5  |
| 4.   | Principal design criteria .....                                       | 8  |
| 4.1  | General .....                                                         | 8  |
| 4.2  | Relationship between the safety system and Class 1E power system..... | 8  |
| 4.3  | Design basis event effects .....                                      | 8  |
| 4.4  | Design basis.....                                                     | 8  |
| 4.5  | Power quality.....                                                    | 11 |
| 4.6  | Location of indicators and control.....                               | 11 |
| 4.7  | Identification .....                                                  | 11 |
| 4.8  | Independence.....                                                     | 12 |
| 4.9  | Equipment qualification .....                                         | 12 |
| 4.10 | Single-failure criterion .....                                        | 12 |
| 4.11 | Connection of non-class 1E circuits.....                              | 12 |
| 4.12 | Control of access .....                                               | 13 |
| 4.13 | Circuits that penetrate containment.....                              | 13 |
| 4.14 | Protection.....                                                       | 13 |
| 5.   | Supplementary design criteria .....                                   | 13 |
| 5.1  | Class 1E power systems .....                                          | 13 |
| 5.2  | Alternating current power systems.....                                | 13 |
| 5.3  | Direct current power systems.....                                     | 16 |
| 5.4  | Instrumentation and control power systems.....                        | 18 |
| 5.5  | Execute features .....                                                | 20 |
| 5.6  | Sense and command features .....                                      | 21 |
| 6.   | Surveillance and test requirements .....                              | 21 |
| 6.1  | Surveillance methods .....                                            | 21 |
| 6.2  | Preoperational equipment tests and inspections.....                   | 23 |
| 6.3  | Preoperational system test.....                                       | 24 |
| 6.4  | Periodic tests.....                                                   | 24 |
| 7.   | Multiunit station considerations.....                                 | 23 |
| 7.1  | Criteria.....                                                         | 24 |
| 7.2  | Standby power supply capacity .....                                   | 25 |
| 7.3  | Battery supply.....                                                   | 25 |
| 8.   | Documentation.....                                                    | 25 |
| 8.1  | Design documentation records .....                                    | 25 |
| 8.2  | Verification and validation.....                                      | 25 |
| 8.3  | Test records .....                                                    | 26 |

TABLES

Table 1 Items included in systems covered by scope ..... 1

Table 2 Illustrative malfunctions, accidents, etc. .... 11

Table 3 Illustrative surveillance methods ..... 21

FIGURES

Figure 1 Example of a Class 1E power system for single unit with two 100% capacity divisions ..... 3

Figure 2 Typical safety function and the Class 1E power system..... 9

Figure 3 Simplified electrical one-line diagram illustrating one division of a Class 1E power system..... 10



# IEEE Standard Criteria for Class 1E Power Systems for Nuclear Power Generating Stations

## 1. Overview

### 1.1 Scope

This standard applies to the Class 1E portions of the following systems and equipment in single-unit and multiunit nuclear power generating stations:

- Alternating current power systems
- Direct current power systems
- Instrumentation and control (I&C) power systems

These systems include the items listed in Table 1.

**Table 1—Items included in systems covered by scope**

| General elements            | Illustrative examples |
|-----------------------------|-----------------------|
| <b>Power sources</b>        |                       |
| Sources                     | Standby generator     |
|                             | Batteries             |
| Components and distribution | Transformers          |
|                             | Buses                 |
| Equipment                   | Switchgear            |
|                             | Cable                 |
|                             | Battery chargers      |
|                             | Inverters             |

**Table 1—Items included in systems covered by scope (continued)**

| General elements                                                                                                 | Illustrative examples   |
|------------------------------------------------------------------------------------------------------------------|-------------------------|
| <b>Execute features</b>                                                                                          |                         |
| Actuation devices                                                                                                | Circuit breakers        |
|                                                                                                                  | Controllers             |
|                                                                                                                  | Control relays          |
|                                                                                                                  | Control switches        |
|                                                                                                                  | Pilot valves            |
| Actuated equipment                                                                                               | Motors                  |
|                                                                                                                  | Solenoids               |
|                                                                                                                  | Heaters                 |
| <b>Sense and command features</b>                                                                                |                         |
| Instrumentation, controls, and electrical protection (associated with power supplies and distribution equipment) | Surveillance indicators |
|                                                                                                                  | Switches                |
|                                                                                                                  | Current transformers    |
|                                                                                                                  | Voltage transformers    |
|                                                                                                                  | Transducers             |
|                                                                                                                  | Protective relays       |
|                                                                                                                  | Frequency relays        |
|                                                                                                                  | Microprocessors         |

This standard does not apply to the preferred power supply; the unit generators and their buses; generator breaker; step-up, auxiliary, and start-up transformers; connections to the station switchyard; switchyard; transmission lines; and the transmission network (see Figure 1).

## 1.2 Purpose

The purpose of this standard is to provide the following:

- The principal design criteria and the design features of the Class 1E power systems that enable the systems to meet their functional requirements under the conditions produced by the applicable design basis events.
- The requirements for tests and surveillance of the Class 1E power systems.
- The criteria for sharing Class 1E power systems in multiunit stations.
- The requirements for documentation of the Class 1E power systems.