

IEEE Standard Procedure for the Determination of the Ampacity Derating of Fire-Protected Cables

Sponsor

**Insulated Conductors Committee
of the
IEEE Power Engineering Society**

Reaffirmed 20 March 2003
Approved 5 August 1996
IEEE Standards Board

Abstract: A detailed test procedure is provided for determining the ampacity or derating factor in the following cable installation configurations: block-out or sleeve type cable penetration fire stops; conduits covered with a protective material; tray covered with a protective material; cable directly covered or coated with a fire-retardant material; and free-air drops enclosed with a protective material.

Keywords: ampacity derating factor, cable penetration fire stops, electrical separation wrap systems, fire-protected cable system, fire protected conduits

The Institute of Electrical and Electronics Engineers, Inc.
345 East 47th Street, New York, NY 10017-2394, USA

Copyright © 1996 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 1996. Printed in the United States of America.

ISBN 1-55937-780-1

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

IEEE Standards documents are developed within the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Board. Members of the committees serve voluntarily and without compensation. They are not necessarily members of the Institute. The standards developed within IEEE represent a consensus of the broad expertise on the subject within the Institute as well as those activities outside of IEEE that have expressed an interest in participating in the development of the standard.

Use of an IEEE Standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of all concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason, IEEE and the members of its societies and Standards Coordinating Committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE Standards Board
445 Hoes Lane
P.O. Box 1331
Piscataway, NJ 08855-1331
USA

Note: Attention is called to the possibility that implementation of this standard may require use of subject matter covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. The IEEE shall not be responsible for identifying all patents for which a license may be required by an IEEE standard or for conducting inquiries into the legal validity or scope of those patents that are brought to its attention.

Authorization to photocopy portions of any individual standard for internal or personal use is granted by the Institute of Electrical and Electronics Engineers, Inc., provided that the appropriate fee is paid to Copyright Clearance Center. To arrange for payment of licensing fee, please contact Copyright Clearance Center, Customer Service, 222 Rosewood Drive, Danvers, MA 01923 USA; (508) 750-8400. Permission to photocopy portions of any individual standard for educational classroom use can also be obtained through the Copyright Clearance Center.

Introduction

(This introduction is not part of IEEE Std 848-1996, IEEE Standard Procedure for the Determination of the Ampacity Derating of Fire-Protected Cables.)

Many cable installations in nuclear and fossil fuel generating stations require the installation of fire stop, fire protective materials, coating, and electrical separation wrap materials over the cables or the raceway for fire protection or electrical separation purposes. Appendix R of the Code of Federal Regulations for Nuclear Equipment may require some electrical circuits enclosed in a fire-protective material. IEEE Std 634-1976 specifies requirements for cable penetration fire stops at fire rated walls and floors. Compliance with IEEE Std 384-1992 may require installation of a wrap material over free air-drop cables or solid covers on cable trays.

Building codes for commercial and industrial facilities in some states require power cables, used in emergency power systems, to remain functional during a fire exposure. This may also necessitate the use of the fire protective material.

As discussed in IEEE Std 690-1984, utility generating stations use cable ampacities provided in IEEE 835-1994 for conduits, spaced cable tray installations, and duct bank installations. NEMA WC51-1991/ICEA P-54-440 is used for cable installation in random filled open-top trays. Commercial, industrial, and non-utility owned generating stations utilize cable ampacities published in NFPA 70-1996, National Electric Code® (NEC®). The NEC permits the use of IEEE Std 835-1994 and NEMA WC51-1991/ICEA P-54-440 under the direction of engineers.

Fire-protection related products may reduce the heat transfer characteristics associated with the ampacities provided in IEEE Std 835-1994 and NEMA WC51-1991/ICEA P-54-440. In future revisions, these ampacity standards may incorporate these new installation conditions on cable ampacity. Not all products, however, may be covered by changes in the ampacity standards due to their limited use to the generating station market. Hence, ampacity testing to determine ampacity derating of fire-protected cable systems is necessary.

Several analytical cable ampacity methods are listed in the bibliography to address fire stops, tray enclosure materials, and cable wrap material. The user may consider the applications of these analytical methods to avoid testing of minor differences in the installation of a given product.

This standard was prepared by the Task Group on Procedure for the Determination of the Ampacity Derating of Fire Protected Cables of the Subcommittee on Tests and Measurements of the Insulated Conductors Committee. The membership of the working group during the preparation of this draft was:

A. K. Gwal, Chair

J. L. White, Jr., Vice Chair

T. J. Al-Hussaini
P. Bhatia
K. Brown
E. A. Capouch
E. J. Coffey
E. J. D'Aquanno
J. Daly

P. A. Giaccaglia
A. Hiranandani
R. Jenkins
A. E. Kollar
R. Light
J. E. Merando
K. A. Petty
K. W. Prier

D. N. Priest
P. D. Skelly
M. Spurlock
W. Torok
J. R. Tuzinski
F. W. Van Nest
J. G. Waligorski

The following persons were on the balloting committee:

T. J. Al-Hussaini
R. W. Allen, Jr.
W. O. Anderson, Jr.
R. H. Arndt
T. P. Arnold
Hussein E. Badaly
T. A. Balaska
Anthony Barlow
Charles W. Blades
David T. Bogden
Vincent J. Boliver
R. R. Borowski
Ken E. Bow
John E. Bramfitt
M. D. Buckweitz
R. R. Burghardt
Paul S. Cardello
Paul L. Cinquemani
Wayne E. Cole
E. J. D'Aquanno
J. M. Daly
Russ Dantzler
Joseph A. Di Stanzo
C. Doench
J. P. Dupont
G. S. Eager, Jr.
R. M. Eichhorn
J. S. Englehardt
S. L. Fitzhugh
A. Fitzpatrick
E. O. Forster
Ronald F. Frank
R. D. Fulcomer
J. B. Gardner
R. B. Gear
Paul Giaccaglia
A. Godoshian
A. Gwal
V. Stan Harper
R. Hartlein
H. C. Hervig
S. V. Heyer
R. W. Higginbottom
L. J. Hiivala
Asit K. Hiranandi

John W. Hoffman
Darrel R. Jeter
C. Katz
L. J. Kelly
F. E. Kimsey
Joel Kitchens
H. T. Knox
Frederick B. Koch
Albert Kong
Donald E. Koonce
M. Kopchik, Jr.
Frank L. Kuchta
F. E. La Gase
Jeffrey J. La Marca
Carl Landinger
J. S. Lasky
Jack H. Lawson
Raoul H. Leuteritz
T. H. Ling
John V. Lipe
Mark E. Lowell
G. Ludasi
R. Luther
G. J. Luzzi
Jeffrey P. Mackevich
G. Allen MacPhail
M. A. Martin, Jr.
I. J. Marwick
M. S. Mashikian
S. G. Mastoras
F. M. McAvoy
A. R. McCulloch
E. J. McGowan
A. L. McKean
W. J. Mc
J. D. Medek
David J. Mintz
J. A. Moran, Jr.
D. J. Nichols
Harry E. Orton
J. J. Pachot
Cutter D. Palmer
Keith A. Petty
James J. Pickering
Jan S. Pirrong

Gary A. Polhill
Ronald J. Ponist
Paul F. Pugh
Peter Ralston
Greg P. Rampley
Robert A. Resuali
R. B. Robertson
Ralph W. Samm
George W. Seman
John F. Shimshock
Gilbert L. Smith
Joseph H. Snow
T. F. Stabosz
Joseph L. Steiner
Grover L. Stell, Jr.
Frank M. Stepniak
Orloff W. Styve
Mike D. Sweat
W. Keith Switzer
John Tanaka
James W. Tarpey
Frank A. Teti
H. D. Thomas
William A. Thue
Austin C. Tingley
William Torok
Duc B. Trinh
S. E. Turner
Jack R. Tuzinski
Donald A. Voltz
C. F. Von Hermann, Jr.
Richard L. Votoupal
Michael L. Walker
Steven P. Walldorf
Edward M. Walton
Daniel J. Ward
Roland H. W. Watkins
A. C. Westrom
Charles A. White
John L. White, Jr.
William D. Wilkens
Robert O. Wilkinson
J. A. Williams
William G. Wimmer
J. T. Zimnoch

The final conditions for approval of this standard were met on 5 August 1996. This standard was conditionally approved by the IEEE Standards Board on 20 June 1996, with the following membership:

Donald C. Loughry, *Chair*

Richard J. Holleman, *Vice Chair*

Andrew G. Salem, *Secretary*

Gilles A. Baril
Clyde R. Camp
Joseph A. Cannatelli
Stephen L. Diamond
Harold E. Epstein
Donald C. Fleckenstein
Jay Forster*
Donald N. Heirman
Ben C. Johnson

E. G. "Al" Kiener
Joseph L. Koepfinger*
Stephen R. Lambert
Lawrence V. McCall
L. Bruce McClung
Marco W. Migliaro
Mary Lou Padgett
John W. Pope

Jose R. Ramos
Arthur K. Reilly
Ronald H. Reimer
Gary S. Robinson
Ingo Risch
John S. Ryan
Chee Kiow Tan
Leonard L. Tripp
Howard L. Wolfman

*Member Emeritus

Also included are the following nonvoting IEEE Standards Board liaisons:

Satish K. Aggarwal
Alan H. Cookson
Chester C. Taylor

Lisa S. Young
IEEE Standards Project Editor

Contents

CLAUSE	PAGE
1. Overview	1
1.1 Scope	1
1.2 Purpose	1
2. References	2
3. Definitions	2
4. Test Description	3
4.1 General	3
4.2 Test specimens—protected cable systems	3
4.3 Test specimens—cable penetration fire stop	5
4.4 Test facility	6
4.5 Test procedure	11
5. Evaluation of test results	14
5.1 Normalizing test results	14
5.2 Ampacity derating factor	14
6. Documentation of testing	15
ANNEX	
Annex A (informative) Bibliography	16

IEEE Standard Procedure for the Determination of the Ampacity Derating of Fire-Protected Cables

1. Overview

1.1 Scope

This standard provides a detailed test procedure for determining the ampacity or derating factor in the following cable installation configurations:

- Block-out or sleeve type cable penetration fire stops
- Conduits covered with a protective material
- Tray covered with a protective material
- Cable directly covered or coated with a fire-retardant material
- Free-air drops enclosed with a protective material

The standard is applicable to cables installed and sized to IEEE Std 835-1994 for conduits and free-air drops, and NEMA WC51-1991/ICEA P-54-440 for cable tray.¹ IEEE Std 835-1994 does provide ampacities for cables in a tray with a fixed spacing and may be used for cable penetration fire stop configurations only.

This standard does not endorse the use of or provide application guidance for the installation of cable penetration fire stops and fire-protective materials. Cable designs are available that can withstand and remain functional during direct exposure to a fire. The user should refer to IEEE Std 634-1978 for the qualification requirements of cable penetration fire stops.

1.2 Purpose

The purpose of this standard is to provide a test procedure for use in establishing the ampacity or ampacity derating factor for cables installed in fire-protected conduits, trays, or free-air drops, cable penetration fire stops, or electrical separation wrap systems.

¹Information on references can be found in clause 2.