

IEEE C37.04h-1990

(Supplement to IEEE C37.04-1979 and
Revision to IEEE C37.04h-1986)

Supplement to IEEE Standard Rating Structure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis

Sponsor
**Switchgear Committee
of the
IEEE Power Engineering Society**

Approved December 6, 1990
IEEE Standards Board

Approved May 20, 1991
American National Standards Institute

The Institute of Electrical and Electronics Engineers, Inc. 345 East 47th Street, New York, NY 10017-2394, USA

© 1991 by the Institute of Electrical and Electronics Engineers, Inc.

All rights reserved. Published 1991. Printed in the United States of America

ISBN 1-55937-110-2

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Supplement to IEEE Standard Rating Structure for AC High-Voltage Circuit Breakers Rated on a Symmetrical Current Basis

In Supplement C37.04h-1986, change 6.2(4) to read as follows:

(4) For circuit breakers rated 800 kV: When the rated short-circuit current does not exceed 63 kA, the resultant of the forces imposed simultaneously shall be the same as (2)(a), (b), and (c) above except that the line pull loads in (b) shall be 300 lb and 450 lb, respectively.