

IEEE Std C37.100d-1991
(Supplement to C37.100-1981)
Draft 6, April 29, 1989

IEEE Standard Definitions for Power Switchgear

Sponsor

**Switchgear Committee of the
IEEE Power Engineering Society**

Approved February 11, 1991

IEEE Standards Board

© 199X by

**The Institute of Electrical and Electronics Engineers, Inc.
345 East 47th Street, New York, NY 10017-2394, USA**

*No part of this publication may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.*

The following definition will be added:

Initial Transient Recovery Voltage. The initial transient recovery voltage is a component of the transient recovery voltage which appears in the very short time immediately after current interruption. The initial transient recovery voltage is a result of traveling waves on the substation bus adjacent to the circuit-switching device.