

American National Standard

Pad-Mounted Equipment— Enclosure Integrity

Approved June 1, 1999

American National Standards Institute, Inc.

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2003 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Printed in the United States of America.

Print: ISBN 0-7381-3633-6 SH95113
PDF: ISBN 0-7381-3634-4 SS95113

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

American National Standard

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations shall be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken to reaffirm, revise, or withdraw this standard no later than five years from the date of approval. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

National Electrical Manufacturers Association
1300 N. 17th Street, Rosslyn, Virginia 22209

Copyright © 1999 National Electrical Manufacturers Association
All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without prior written permission of the publisher.

Printed in the United States of America

CONTENTS

	Page
Foreword	iii
1 Scope and purpose	1
1.1 Scope	1
1.2 Purpose	1
2 Referenced and related standards	1
2.1 Referenced standards	1
2.1.1 ASTM standards.....	1
2.1.2 Society of Automotive Engineers Standards.....	2
2.1.3 Related American National Standards (ANSI)	2
3 Definitions	2
3.1 Routine tests.....	2
3.2 Design tests.....	2
3.3 Conformance tests	3
3.4 Pad-mounted enclosure	3
3.5 Dry film thickness	3
3.6 Carbon steel	3
3.7 Padlock.....	3
3.8 Enclosure security	3
3.9 Axial force.....	3
3.10 Prying leverage.....	3
4 Enclosure security.....	3
4.1 Test requirements	3
4.1.1 Enclosure mounting.....	4
4.1.2 Water resistance	4
4.1.3 Sharp corners.....	4
4.1.4 Panel assembly	4
4.1.5 Door hardware.....	4
4.1.6 Handhole covers	4
4.1.7 Locking/latching devices	4
4.1.8 Enclosure access	4
4.1.9 Fire resistance.....	6
4.2 Test equipment.....	6
4.2.1 Pry bar.....	6
4.2.2 Pull tool.....	6
4.2.3 Push tool.....	6
4.2.4 Probe wire	6
4.3 Resistance to foreign objects	6
4.3.1 General.....	6
4.3.2 Pry tests.....	9
4.3.3 Pull tests.....	9
4.3.4 Wire probe tests	9
4.3.5 Deflection tests.....	9
4.3.6 Operation test.....	9
4.4 Test values	9
5 Enclosure design and coating system requirements	11
5.1 Enclosure design requirements objective	11
5.1.1 Accessibility	11
5.1.2 Contaminate accumulation.....	11
5.1.3 Welds—surface preparation	11

5.2	Coating system requirements.....	11
5.2.1	General.....	11
5.2.2	Specifications of coating characteristics	11
5.2.3	Coating touch-up prior to shipment	11
5.2.4	Enclosure color.....	11
5.3	Coating system test specimens.....	11
5.4	Coating system performance requirements	13
5.4.1	Salt spray test.....	13
5.4.2	Cross hatch adhesion test.....	13
5.4.3	Humidity test.....	13
5.4.4	Impact test.....	13
5.4.5	Insulating fluid resistance test (for liquid filled units only)	13
5.4.6	Ultraviolet accelerated weathering test	13
5.4.7	Ultraviolet accelerated weathering (QUV) and simulated corrosive atmospheric breaking (SCAB)	14
5.4.8	Abrasion resistance tabor abrader	14
5.4.9	Gravelometer test.....	14
6	Labels	16
6.1	Purpose	16
6.2	Application	16
7	General	16
7.1	Shipment	16
7.2	Coating repair procedure.....	16
Appendix 1		17

Figures

Figure 1	Captive and recessed pentahead bolts.....	5
Figure 2	Pry test bar	7
Figure 3	Pull hook.....	10
Figure 4	Pushing tool.....	10
Figure 5		12
Figure 6		12
Figure 7		12
Figure 8		15

Tables

Table 1	Test values	9
---------	-------------------	---

Foreword (This Foreword is not part of American National Standard C57.12.28-1999.)

The Accredited Standards Committee on Transformers, Regulators, and Reactors, C57, has for a number of years been developing and correlating standards on transformers and regulators. The data used in this work have been gathered from many sources, including the standards of the Institute of Electrical and Electronics Engineers and the National Electrical Manufacturers Association, reports of committees of the Edison Electric Institute, and others.

This standard and the related standards on three- and single-phase distribution transformers were prepared by the Joint C57/C37 Working Group on Enclosures.

Suggestions for improvement of this standard will be welcome. They should be sent to the National Electrical Manufacturers Association, 1300 N. 17th Street, Rosslyn, Virginia 22209.

This standard was processed and approved for submittal to ANSI by Accredited Standards Committee on Transformers, Regulators, and Reactors, C57, and Accredited Standards Committee, C37, Switchgear. Approval of the standard does not necessarily imply that all committee members voted for its approval.

At the time of approval, the Working Group members were as follows:

Joseph Martin, Chair

R. Olen	T. Diamantis	R. Stahara
K. Hanus	D. Elzey	T. Kaley
J. Malloy	R. Scheu	J. Carulli
A. Worland		

Accredited Standards Committee on Transformers, Regulators, and Rectors, C57:

John D. Borst, IEEE Delegation, Chairman
D. Rollings, NEMA Delegation, Vice Chairman
John A. Gauthier, NEMA, Secretary

<i>Organization</i>	<i>Committee Member</i>
U.S. Dept. of Energy, Western Area Power Admin.	K. C. Wolohon
Dept. of the Navy, Civil Engineer Corps.	C. M. Mandeville
Dept. of the Interior, Bureau of Reclamation	D. J. Mulligan
Department of Agriculture, R.E.A.	M. Eskandry
Tennessee Valley Authority	F. Lewis
Underwriters Laboratories, Inc.....	M. Schacker

Electric Light & Power Company (EL&P)..... P. E. Orehek, Chairman of Delegation
T. Diamantis
G. Anderson
G. Miller (Alternate)
K. S. Hanus
J. Sullivan
C. G. Nieman

Institute of Electrical and Electronics Engineers..... W. Binder, Chairman of Delegation
(IEEE) J. D. Borst
J. Matthews
B. Patel
H. Jin Sim (Alternate)
T. Prevost

National Electrical Manufacturers Association..... D. Rollings, Chairman of Delegation
(NEMA) G. D. Coulter
P. J. Hopkinson
R. Plaster
Harral Robin
H. Jin Sim (Alternate)

Accredited Standards Committee for Switchgear, C37:

E. Byron, Chairman

A. K. McCabe, Executive Vice-Chairman, HV Standards
J. C. Scott, Executive Vice-Chairman, LV Standards
D. L. Swindler, Executive Vice-Chairman, IEC Activities
M. Calwise, Secretary

<i>Organization</i>	<i>Committee Member</i>
---------------------	-------------------------

Association of Iron and Steel Engineers.....	Vacant
--	--------

Electric Light and Power Group	D. J. Borchart T. E. Bruck (Alternate) D. E. Galicia J. L. Koepfinger J. H. Provanzana
--------------------------------------	--

Institute of Electrical and Electronics Engineers.....	D. F. Peelo (Chairman) L. B. Beard P. W. Dwyer A. Monroe D. Sigmon S. C. Atkinson (Alternate) D. G. Kumbera (Alternate) L. V. McCall (Alternate)
--	---

National Electrical Manufacturers Association.....	R. Garzon (Chairman) W. Kracht H. L. Miller T. Olsen S. Stone E. Byron (Alternate) G. T. Jones (Alternate) G. Sakats (Alternate) D. L. Swindler (Alternate)
Testing Laboratory Group.....	L. Frier, MET Electrical Testing Association P. Notarian, Underwriters Laboratories, Inc.
Tennessee Valley Authority	D. N. Reynolds
U.S. Dept. of the Army—Office of the Chief of Engineers.....	J. A. Gilson
U.S. Dept. of the Navy—Naval Construction Battalion Center	R. R. Nicholas
Western Area Power Administration.....	G. D. Birney

