



IEEE Standard Requirements, Terminology, and Test Code for Bushings for DC Applications— Corrigendum 1

IEEE Power Engineering Society

Sponsored by the
Transformers Committee

IEEE
3 Park Avenue
New York, NY 10016-5997, USA

6 June 2006

IEEE Std C57.19.03™-2005
(Corrigendum to
IEEE Std C57.19.03-1996)

IEEE Standard Requirements, Terminology, and Test Code for Bushings for DC Applications— Corrigendum 1

Sponsor

**Transformers Committee
of the
IEEE Power Engineering Society**

Approved 7 December 2005

IEEE-SA Standards Board

Abstract: This corrigendum corrects IEEE Std C57.19.03-1996. The standard applies to outdoor and indoor power apparatus dc bushings of condenser type that have basic impulse insulation levels of 110 kV and above for use as components of oil-filled converter transformers and smoothing reactors, as well as air-to-air dc bushings. This standard defines the special terms used, service conditions, rating, general requirements, electrical insulation characteristics, and test procedure for the bushings for dc application.

Keywords: bushings, dc application

The Institute of Electrical and Electronics Engineers, Inc.
3 Park Avenue, New York, NY 10016-5997, USA

Copyright © 2006 by the Institute of Electrical and Electronics Engineers, Inc.
All rights reserved. Published 6 June 2006. Printed in the United States of America.

IEEE is a registered trademark in the U.S. Patent & Trademark Office, owned by the Institute of Electrical and Electronics Engineers, Incorporated.

Print: ISBN 0-7381-4884-9 SH95512
PDF: ISBN 0-7381-4885-7 SS95512

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.