

WITHDRAWN

Draft American National Standard

IEEE C57.19.101

(Issued July 1989
for trial use.)

IEEE Trial-Use Guide for Loading Power Apparatus Bushings

Circuits and Devices

Communications Technology

Computer

*Electromagnetics and
Radiation*

Energy and Power

Sponsored by the
Transformers Committee of the
IEEE Power Engineering Society

Industrial Applications

*Signals and
Applications*

*Standards
Coordinating
Committee*

IEEE C57.19.101



Published by the Institute of Electrical and Electronics Engineers, Inc., 345 East 47th Street, New York, NY 10017, USA.

July 17, 1989

SH12724

WITHDRAWN

IEEE C57.19.101
(Issued July 1989
for trial use.)

Draft American National Standard

IEEE Trial-Use Guide for Loading Power Apparatus Bushings

Sponsor

**Transformers Committee of the
IEEE Power Engineering Society**

Draft American National Standard

Publication of this draft standard for comment and criticism has been approved by the Institute of Electrical and Electronics Engineers. Distribution of this draft standard for comment shall not continue beyond 12 months from the date of publication. It is expected that following this 12 month period, this draft standard, revised as necessary, shall be submitted to the American National Standards Institute for approval as an American National Standard. Suggestions for revision should be directed to the Secretary, IEEE Standards Board, 345 East 47th Street, New York, NY 10017.

© Copyright 1989 by

**The Institute of Electrical and Electronics Engineers, Inc
345 East 47th Street, New York, NY 10017-2394, USA**

*No part of this publication may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.*

WITHDRAWN

IEEE Standards documents are developed within the Technical Committees of the IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Board. Members of the committees serve voluntarily and without compensation. They are not necessarily members of the Institute. The standards developed within IEEE represent a consensus of the broad expertise on the subject within the Institute as well as those activities outside of IEEE which have expressed an interest in participating in the development of the standard.

Use of an IEEE Standard is wholly voluntary. The existence of an IEEE Standard does not imply that there are no other ways to produce, test, measure, purchase, market, or provide other goods and services related to the scope of the IEEE Standard. Furthermore, the viewpoint expressed at the time a standard is approved and issued is subject to change brought about through developments in the state of the art and comments received from users of the standard. Every IEEE Standard is subjected to review at least every five years for revision or reaffirmation. When a document is more than five years old, and has not been reaffirmed, it is reasonable to conclude that its contents, although still of some value, do not wholly reflect the present state of the art. Users are cautioned to check to determine that they have the latest edition of any IEEE Standard.

Comments for revision of IEEE Standards are welcome from any interested party, regardless of membership affiliation with IEEE. Suggestions for changes in documents should be in the form of a proposed change of text, together with appropriate supporting comments.

Interpretations: Occasionally questions may arise regarding the meaning of portions of standards as they relate to specific applications. When the need for interpretations is brought to the attention of IEEE, the Institute will initiate action to prepare appropriate responses. Since IEEE Standards represent a consensus of all concerned interests, it is important to ensure that any interpretation has also received the concurrence of a balance of interests. For this reason IEEE and the members of its technical committees are not able to provide an instant response to interpretation requests except in those cases where the matter has previously received formal consideration.

Comments on standards and requests for interpretations should be addressed to:

Secretary, IEEE Standards Board
345 East 47th Street
New York, NY 10017
USA

IEEE Standards documents are adopted by the Institute of Electrical and Electronics Engineers without regard to whether their adoption may involve patents on articles, materials, or processes. Such adoption does not assume any liability to any patent owner, nor does it assume any obligation whatever to parties adopting the standards documents.

WITHDRAWN

Foreword

(This Foreword is not a part of IEEE C57.19.101, IEEE Trial-Use Guide for Loading Power Apparatus Bushings.)

Since ANSI/IEEE C57.92-1981, IEEE Guide for Loading Mineral-Oil-Immersed Power Transformers Up to and Including 100 MVA with 55 °C or 65 °C Average Winding Rise, excludes ancillary components such as bushings, the Transformers Committee has expressed concern that under some circumstances bushings could become a limiting item in the practice of loading power transformers beyond nameplate rating. In response to such concerns this trial-use guide was prepared by a working group of the Bushing Subcommittee of the Transformers Committee, of the IEEE Power Engineering Society.

At the time this trial-use guide was published it was under consideration for approval as an American National Standard. The American National Standards Committee C57 Transformers had the following members at the time this trial-use guide was sent to letter ballot.

K. Linsley, Chairman

J. A. Borst, Vice Chairman

C. H. White, Secretary

<i>Organization Represented</i>	<i>Name of Representative</i>
American National Standards Institute.....	C. Zegers
Electric Light and Power Group.....	Wayne Cole
	G. Gunnels
	P. Orehek
	D. Soffrin (<i>Alt</i>)
	J. Sullivan (<i>Alt</i>)
	A. Velazquez
Institute of Electrical and Electronics Engineers.....	L. Savio
	J. J. Bergerson
	J. Davis
	R. A. Veitch
National Electrical Manufacturers Association.....	C. D. Coulter
	P. Dewever (<i>Alt</i>)
	J. D. Douglass
	P. J. Hopkinson (<i>Alt</i>)
	W. C. Kendall
	L. S. McCormick
	J. R. Miller
	R. P. Miller, Sr
	J. J. Nay (<i>Alt</i>)
	Harold Robin
	Henry D. Smith (<i>Alt</i>)
Testing Laboratory Group.....	W. O'Grady
	R. Seelbach
Tennessee Valley Authority.....	L. R. Smith
US Department of the Navy	H. Stickley
US Department of Energy	D. Torgerson
US Department of the Interior	F. Cook, Sr
US Department of Agriculture, Rural Electrical Association.....	J. Arnold, Jr

At the time this trial-use guide was approved, the working group for Loading Power Apparatus Bushings, of the Transformers Committee, had the following membership:

J. K. Easley, Chairman

L. C. Aicher
J. H. Brunke
J. Corkran
D. O. Craghead
G. C. Evans
K. R. Highton

D. C. Johnson
J. W. Matthews
W. J. McNutt
N. J. Melton
H. E. Mills
T. R. Orrock

A. C. Parikh
J. L. Puri
F. R. Stockum
D. E. Truax
R. A. Veitch
L. B. Wagenaar



Documents
Document Sharing Hub

WITHDRAWN

The following persons were on the balloting committee that approved this document for submission to the IEEE Standards Board:

D. J. Allan
B. F. Allen
R. Allustiarti
S. J. Antalis
E. H. Arjeski
J. C. Arnold
J. Aubin
J. J. Bergeron
W. B. Binder
J. V. Bonucchi
J. D. Borst
G. H. Bowers
C. V. Brown
D. J. Cash
O. R. Compton
F. W. Cook, Sr
J. Corkran
D. W. Crofts
D. H. Douglas
J. C. Dutton
J. A. Ebert
R. L. Ensign
C. G. Evans
P. P. Falkowski
D. J. Fallon
H. G. Fischer
M. Frydman
H. E. Gabel, Jr
D. A. Gillies
R. L. Grubb
F. J. Gryszkiewicz
G. Gunnels, Jr
G. Hall
J. H. Harlow
F. W. Heinrichs

W. Henning
K. R. Highton
P. J. Hoefler
C. R. Hoesel
R. H. Hollister
C. C. Honey
F. Huber, Jr
C. Hurty
A. M. Iversen
R. G. Jacobsen
D. L. Johnson
A. J. Jonnatti
C. P. Kappeler
J. J. Kelly
W. N. Kennedy
A. D. Kline
E. Koenig
J. G. Lackey
R. E. Lee
H. F. Light
T. G. Lipscomb, II
L. A. Loudermilk
R. I. Lowe
M. L. Manning
T. Massouda
J. W. Matthews
J. W. McGill
C. J. McMillen
W. J. McNutt
S. P. Mehta
C. K. Miller
C. Millian
R. E. Minkwitz, Sr
M. I. Mitelman

H. R. Moore
W. E. Morehart
R. J. Musil
W. H. Mutschler, Jr
E. T. Norton
T. Orbeck
B. K. Patel
H. A. Pearce
D. Perco
J. M. Pollitt
C. A. Robbins
L. J. Savio
W. E. Saxton
V. Shenoy
W. W. Stein
L. R. Stensland
E. G. Strangas
D. W. Sundin
L. Swenson
A. L. Tanton
V. Thenappan
R. C. Thomas
J. A. Thompson
T. P. Traub
D. E. Truax
R. E. Uptengraff, Jr
G. Vaillancourt
R. A. Veitch
L. B. Wagenaar
R. J. Whearty
A. Wilks
W. E. Wrenn
A. C. Wurdack
D. A. Yannucci
E. J. Yasuda

When the IEEE Standards Board approved this guide on October 20, 1988, it had the following membership:

Donald C. Fleckenstein, *Chairman*

Marco Migliaro, *Vice Chairman*

Andrew G. Salem, *Secretary*

Arthur A. Blaisdell
Fletcher J. Buckley
James M. Daly
Stephen R. Dillon
Eugene P. Fogarty
Jay Forster*
Thomas L. Hannan
Kenneth D. Hendrix
Theodore W. Hissey, Jr

John W. Horch
Jack M. Kinn
Frank D. Kirschner
Frank C. Kitzantides
Joseph L. Koepfinger*
Irving Kolodny
Edward Lohse
John E. May, Jr
Lawrence V. McCall

L. Bruce McClung
Donald T. Michael*
Richard E. Mosher
L. John Rankine
Gary S. Robinson
Frank L. Rose
Helen M. Wood
Karl H. Zaininger
Donald W. Zipse

*Member Emeritus



Documents
Document Sharing Hub

WITHDRAWN

Contents

SECTION	PAGE
1. Scope and References.....	7
1.1 Scope.....	7
1.2 References	7
2. General	7
2.1 Basis of Rating and Rationalization of Thermal Requirements Rating	7
2.2 Overload Concerns.....	8
2.3 Limitations	9
3. Temperature Calculations for Short-Time Loads Above Bushing Rating.....	9
3.1 Steady State Hottest-Spot Temperature Calculations	9
3.2 Transient Hottest-Spot Temperature Calculations.....	10
4. Test Procedures for Derivation of Mathematical Model	12
4.1 Procedure for Performance Testing of Bottom-Connected Bushings that Comply with ANSI/IEEE Std 24-1984 [3], Tables 3 through 7	12
4.2 Tests on Draw Lead Bushings	15
4.3 Derivation of Model Constants.....	15
TABLE	
Table 1 Minimum Size of Nonmagnetic Metal Mounting Plate.....	12
FIGURES	
Fig 1 Bushing Hottest-Spot Transient Response	11
Fig 2 Representative Oil End Terminal Connector Arrangements.....	13
Fig 3 Representative Air End Terminal Connector Arrangements.....	14
APPENDIX	
Appendix Examples of Calculation Procedure	17