



شرکت ملی گاز ایران

مدیریت پژوهش و فناوری

امور تدوین استانداردها

IGS

Iranian Gas Standards

دستگاه نشانگر پیگ

Pig Signaler Specification



شرکت ملی گاز ایران

دفتر مدیرعامل

تاریخ: ۱۳۹۰/۱۰/۱۳

شماره: ۱۵۹۷۳-۴۳۷/۰ ک.ا.دب/۰

ابلاغ مصوبه هیأت مدیره

۱- اصل پرونده مصوبه

هیأت مدیره

۲- ضمیمه آگهی

لغو صورت اقدام لازم

مدیر محترم پژوهش و فناوری و رئیس شورای استاندارد

باسلام،

به استحضار می‌رساند در جلسه ۱۴۷۲ مورخ ۱۳۹۰/۸/۱ هیأت مدیره، نامه شماره ۹۹۲۲۶/۰۰۰/۹ ک مورخ ۹۰/۷/۲۰ آن مدیریت درمورد تصویب نهایی استاندارد تحت عنوان "دستگاه نشانگر عبور پیک" به شماره تقاضای IGS-E-PL-031(0) مطرح و مورد تصویب قرار گرفت.

این مصوبه در حکم مصوبه مجمع عمومی شرکتهای تابعه محسوب و برای کلیه شرکتهای تابعه لازم الاجراء می‌باشد.

ناصر آبگون

دبیر هیأت مدیره

۱۳۹۰/۱۰/۱۴

۱۵۹۷۳-۴۳۷

رونوشت: مدیرعامل محترم شرکت ملی گاز ایران و قائم مقام رئیس هیأت مدیره

: اعضای محترم هیأت مدیره

: مشاور محترم مدیرعامل

: مدیر محترم توسعه منابع انسانی

: رئیس محترم امور حسابرسی داخلی

: سرپرست محترم امور سازمان و بهبود روشها

: رئیس محترم امور حقوقی

: رئیس محترم امور مجامع

Documents

Document Sharing Hub

FOREWORD

This standard specification has been technically revised , and up dated , it intended to be mainly used by all divisions of N.I.G.C. and EPC contractors , and has been prepared on interpretation of recognized standards , technical documents , knowledge, backgrounds and experiences in gas industries at national and international levels.

Iranian Gas Standards (IGS) are prepared, reviewed and amended by technical standard committees within NIGC standardization division of research & technology management and submitted to "the standards council of NIGC" for approval.

Iranian Gas Standards (IGS) are subjected to revision, amendment or withdrawal, if required, thus the latest edition of IGS shall be checked / inquired by IGS users.

Any comments from concerned parties or individuals in IGS'S are welcomed.

Table of content

Element	Page no.
1. Scope.....	3
2. References.....	3
2.1.0. Normative references.	3
3. Pig signaler specification.....	3
3.1.Pig signaler shall consist of.....	4
3.2. Pig signaler characteristic.....	4
3.3. Functional requirements.....	5
4. Material.....	5
5.Inspection and testing.....	6
6. Surface preparation and final coating.....	6
7. Marking.	7
8. Documentation.....	7
9. Data sheet.....	8
10.Attachment 1(Details of topcoat).	
11.Attachment 2(list of certifying bodies approved by standard Council.	