

IGS-IN-301(1) : 1999

1999

64



National Iranian Gas Co.

مدیریت پژوهش و فناوری

Research and Technology Management

امور تدوین استانداردها

Standardization Division

IGS

Iranian Gas Standards

Specification for :

مشخصات فنی :

Safety Shut-off Valves

شیر ایمنی قطع کننده

APPROVED

FOREWORD

This standard is intended to be mainly used by **NIGC** and contractors and has been prepared on interpretation of recognized standards , technical documents , knowledge ,backgrounds and experiences in gas industries at national and international levels.

Iranian Gas Standards (**IGS**) are prepared , reviewed and ammended by technical standard committees within NIGC Standardization Div. and submitted to the **NIGC's "STANDARDS COUNCIL"** for approval .

IGS Standards are subject to revision , amendment or withdrawal , if required , thus the latest edition of **IGS** shall be checked/inquired by **NIGC** users .

This standard must not be modified or altered by the end users within **NIGC** and her contractors. Any deviation from normative references and/or well known manufacturers specifications must be reported to Standardization div.

Any comments from concerned parties on **NIGC** distributed **IGS** are welcome to technical standards committees and will receive serious attention and consideration should a revision to standards is recommended .

GENERAL DEFINITIONS :

Throughout this standard the following definitions , where applicable , should be followed :

1- "**STANDARDIZATION DIV.**" has been organized to deal with all aspects of industrial standards in NIGC . Therefore , all queries for clarification or amendments are requested to be directed to the mentioned div.

2- "**COMPANY**" : refers to national iranian gas company .

3- "**SUPLIER**" : refers to a firm who will supply the service , equipment or material to igs specification whether as the prime producer or manufacturer or a trading firm .

4- "**SHALL**" : is used where a provision is mandatory.

5- "**SHOULD**" : is used where a provision is advised only.

6- "**MAY**" : is used where a provision is completely discretionary.

Website : <http://igs.nigc.ir>

E-mail : nigcigs@nigc.org

پیشگفتار

- ۱- این استاندارد/دستورالعمل بمنظور استفاده اختصاصی در شرکت ملی گاز ایران و شرکتهای فرعی وابسته تهیه شده است.
- ۲- شرکت ملی گاز ایران در مورد نیازهای عمومی از استانداردهای وزارت نفت (IPS) و در مورد نیازهای اختصاصی از استانداردهای اختصاصی خود (IGS) استفاده می نماید.
- ۳- استانداردهای شرکت ملی گاز ایران (IGS) توسط کمیته های تخصصی استاندارد متشکل از کارشناسان بخش های مختلف و یا مشاور تهیه می شود و توسط شورای استاندارد (منتخب هیئت مدیره شرکت ملی گاز ایران) به تصویب میرسند.
- ۴- در تنظیم متن استانداردهای (IGS) از کلیه منابع شناخته شده استاندارد، اطلاعات فنی - تخصصی مربوط به صنایع گاز دنیا، مشخصات فنی تولیدات سازندگان معتبر جهانی و نیز از نتیجه تحقیقات و تجربیات کارشناسان و متخصصان داخلی بر حسب مورد استفاده می شود. همچنین بمنظور استفاده هر چه بیشتر از تولیدات داخلی قابلیت های سازندگان داخلی نیز مورد توجه قرار میگیرد.
- ۵- استانداردها از طریق پایگاه اینترنتی شرکت * ویا لوح فشرده (CD) در اختیار واحدها و کاربران قرار می گیرد .
- ۶- استانداردها بطور متوسط هر ۵ سال یکبار و یا در صورت ضرورت زودتر، مورد بازنگری و بروزرسانی قرار میگیرند. بنابراین کاربران باید همیشه آخرین نگارش را مورد استفاده قرار دهند.
- ۷- هرگونه نظر و یا پیشنهاد اصلاح در مورد استانداردها مورد استقبال و بررسی قرار خواهد گرفت و در صورت تأیید، استاندارد مربوطه نیز مورد تجدید نظر قرار خواهد گرفت .

تعاریف عمومی

در متن استانداردهای (IGS) از تعاریف و اصطلاحات زیر استفاده میشود.

- ۱- "شرکت" (COMPANY): منظور از شرکت "شرکت ملی گاز ایران" و یا شرکتهای فرعی وابسته میباشد.
- ۲- "فروشنده" (SUPPLIER/VENDOR): به فرد یا موسسه ای اطلاق میگردد که تعهدی را نسبت به شرکت تقبل نموده است.
- ۳- "خریدار" (PURCHASER): منظور از خریدار "شرکت ملی گاز ایران" و یا شرکتهای فرعی وابسته میباشد.
- ۴- "SHALL": در مواردی بکاربرده میشود که انجام خواسته مورد نظر اجباری است
- ۵- "SHOULD": در مواردی بکاربرده میشود که انجام خواسته مورد نظر ترجیحی و درعین حال اختیاری است
- ۶- "MAY": در مواردی بکاربرده میشود که انجام کار به شکل مورد بحث نیز قابل قبول میباشد

* آدرس پایگاه اینترنتی (<http://igs.nigc.ir>) ، آدرس الکترونیکی (nigcigs@nigc.ir)

IGS-MS-IN-301 (1) : 1996**Safety Shut-Off Valves****TABLE OF CONTENT**

	PAGE
1. SCOPE	2
2. GENERAL REQUIREMENTS	2
3. DESIGN AND SERVICE CONDITIONS	3
4. MATERIAL	5
5. INSPECTION	6
6. PREPARATION & PAINTING	9
7. MARKING	10
8. PACKING	10
9. GUARANTEE	10
10. APPENDIX "A" GAS ANALYSIS	12
11. APPENDIX "B" DATA SHEET	13 TO 15

N.I.G.C**IGS-MS-IN-301 : RFV.1.1996****1. SCOPE**

THIS SPECIFICATION COVERS THE MINIMUM DESIGN , MATERIAL , FABRICATION , TESTING , MARKING AND PACKING REQUIREMENTS FOR SAFETY SHUT OFF VALVE . THE SHUT OFF VALVE IS INTENDED TO BE INSTALLED AT THE UPSTREAM OF THE METERING AND PRESSURE REDUCING STATION WHERE THE PRESSURE IS CONTROLLED BY MEANS OF REGULATOR AND THE SHUT OFF VALVE SHALL OPERATE IN CASE OF REGULATOR FAILURE . FOR SPECIFIC REQUIREMENTS SEE THE ATTACHED DATA SHEET OF THIS SPECIFICATION AND FOR GAS ANALYSIS SEE APPENDIX "A " .

IN CASE OF ANY DEVIATION FROM THIS SPECIFICATION IT SHALL BE CLEARLY STATED ON THE TECHNICAL QUOTATION SUBMITTED BY MANUFACTURER .

2. GENERAL REQUIREMENTS

2.1- SUPPLIER IS REQUIRED TO FILL OUT THE ATTACHED DATA SHEET AND SIGN IT AND SUBMIT 3 COPIES OF THE FOLLOWING DOCUMENTATION IN ENGLISH ALONG WITH TECHNICAL QUOTATIONS :

2.1.1- ALL TECHNICAL INFORMATION AND ORIGINAL PRINTED CATALOGUE (S) .

2.1.2- COMPLETE PARTS LIST CATALOGUE (S) AND RECOMMENDED SPARE PARTS LIST FOR COMMISSIONING AND TWO YEARS OPERATION . (WITH PRICE FOR FINANCIAL QUOTATION AND WITHOUT PRICE FOR TECHNICAL QUOTATION) .

2.1.3- GENERAL DRAWING (S) SHOWING OUTLINE DIMENSIONS AND THE DESCRIPTIVE SKETCH OF CONTROL UNIT .

2.1.4- FULL DESCRIPTION OF CONTROL SYSTEM OPERATION .