

STANDARD

ISA-12.01.01-2009

**Definitions and Information
Pertaining to Electrical Equipment in
Hazardous (Classified) Locations**

Approved 22 January 2009

ISA-12.01.01-2009, Definitions and Information Pertaining to Electrical Equipment
in Hazardous (Classified) Locations

ISBN: 978-1-934394-96-0

Copyright © 2009 by ISA. All rights reserved. Not for resale. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means (electronic mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709

Preface

This preface, as well as all footnotes and annexes, is included for information purposes and is not part of ISA-12.01.01-2009.

This document has been prepared as part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Secretary, Standards and Practices Board; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; E-mail: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavor to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. *Standard for Use of the International System of Units (SI): The Modern Metric System*, published by the American Society for Testing & Materials as IEEE/ASTM SI 10-97, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports. Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards, recommended practices, and technical reports that ISA develops.

CAUTION — ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.

PURSUANT TO ISA'S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.

OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.

ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following members of ISA subcommittee ISA12.01 contributed to the development of this document:

NAME	COMPANY
J. Cospolich, Chair	Waldemar S Nelson & Company Inc.
M. Coppler, Managing Director	Ametek Inc.
D. Ankele*	Underwriters Laboratories Inc.
E. Briesch*	Underwriters Laboratories Inc.
A. Ballard	Cooper Crouse-Hinds
D. Bishop	David N Bishop Consultant
C. Bombria	Consultant
U. Dugar	Mobil Chemical Company
W. Fiske	Intertek
W. Lawrence	FM Approvals LLC
R. Masek	CSA International
W. Mostia	SIS-Tech Solutions
C. Oudar	ExLoc Corporation
W. Seaforth	Woltech Company Inc.
R. Seitz	Artech Engineering
D. Wechsler	The Dow Chemical Company

* One vote per company

The following members of ISA committee ISA12 contributed to the development of this document:

NAME	COMPANY
T. Schnaare, Chair	Rosemount Inc.
W. Lawrence, Vice Chair	FM Approvals LLC
M. Coppler, Managing Director	Ametek Inc.
D. Ankele	Underwriters Laboratories Inc.
A. Ballard	Cooper Crouse-Hinds
K. Boegli	Phoenix Contact Inc.
D. Burns	Shell Exploration & Production Co.
C. Casso	Nabors Industries
S. Czaniecki	Intrinsic Safety Concepts Inc.

J. Dolphin
M. Dona
T. Dubaniewicz
A. Engler
W. Fiske
G. Garcha
C. Huntley
D. Jagger
F. Kent
P. Kovscek
J. Kuczka
N. Ludlam
R. Masek
E. Massey
J. Miller
A. Mobley
A. Page
R. Seitz
M. Spencer
D. Wechsler
R. Wigg

PSC Solutions
Santos Ltd.
NIOSH
Det Norske Veritas DNV
Intertek
GE Energy
MSHA A&CC
Bifold-Fluid Power
Honeywell Inc.
Industrial Scientific Corp.
Killark
FM Approvals Ltd.
CSA International
Baldor Electric Co.
Detector Electronics Corp.
3M Co.
Consultant
Artech Engineering
Columbia Gas Transmission
Dow Chemical Co.
E-x Solutions International Pty. Ltd.

This standard was approved for publication by the ISA Standards and Practices Board on 22 January 2009.

NAME

COMPANY

J. Tatera
P. Brett
M. Coppler
E. Cosman
B. Dumortier
D. Dunn
R. Dunn
J. Gilsinn
E. Icahan
J. Jamison
D. Kaufman
K. P. Lindner
V. Maggioli
T. McAviney
G. McFarland
R. Reimer
N. Sands
H. Sasajima
T. Schnaare
I. Verhappen
R. Webb
W. Weidman
J. Weiss
M. Widmeyer
M. Zielinski

Tatera & Associates Inc.
Honeywell Inc.
Ametek Inc.
The Dow Chemical Company
Schneider Electric
Aramco Services Co.
DuPont Engineering
NIST/MEL
ACES Inc.
Husky Energy Inc.
Honeywell
Endress + Hauser Process Solutions AG
Feltronics Corp.
Jacobs Engineering Group
Emerson Process Mgmt. Power & Water Sol.
Rockwell Automation
DuPont
Yamatake Corp.
Rosemount Inc.
MTL Instrument Group
ICS Secure LLC
Worley Parsons
Applied Control Solutions LLC
Consultant
Emerson Process Management

This page intentionally left blank.

Contents

1	Purpose	9
2	Scope	9
3	Definitions	10
4	Area (location) classification	26
4.1	North American methods	27
4.2	Additional background information	29
5	Protection techniques for electrical equipment in hazardous (classified) locations	33
5.1	Explosion confinement and flame quenching	33
5.2	Isolation from flammable atmospheres	34
5.3	Energy release limitation	36
5.4	Other methods of protection	37
5.5	Summary of Types of Protection (Gas)	37
5.6	Summary of Types of Protection (Dust)	38
6	Wiring methods	39
6.1	Conduit system	44
6.2	Cable systems	44
6.3	Conduit and cable seals	45
6.4	Comparison of the installation systems	49
6.5	Comparisons of wiring methods (see Tables 4a and 4b)	54
6.6	Flexible cords	54
7	Grounding and bonding practices	56
8	Maintenance practices	57
	Annex A (informative — per IEC TC31) Introduction of an alternative risk assessment method encompassing “equipment protection levels” for Ex equipment	59
	Annex B — Acronyms	65
	Annex C — References	69
	Annex D — Listing of worldwide codes, guides, and standards	81
	Annex E — Listing of worldwide installation requirements	89

This page intentionally left blank.

1 Purpose

This document provides definitions and information pertaining to protection techniques, terminology, and the installation of electrical equipment in hazardous (classified) locations and provides an introduction and basic background to the ISA12, Electrical Safety, series of publications and committee activities. It replaces ANSI/ISA-12.01.01, *Definitions and Information Pertaining to Electrical Instruments in Hazardous (Classified) Locations*, published in 1999.

This document provides a general review of applicable codes and standards, and it should not be used in lieu of those codes and standards for equipment design, manufacture, installation, maintenance and test criteria.

2 Scope

2.1 This document provides general guidance for safe design, installation, and maintenance of electrical equipment in hazardous (classified) locations using appropriate means to prevent ignition of flammable gases and vapors, flammable liquids, combustible dusts, or ignitable fibers or flyings.

2.2 This document covers only locations made hazardous, or potentially hazardous, due to the presence of flammable gases or vapors, flammable liquids, combustible dusts, or ignitable fibers or flyings. The document is not necessarily relevant to the hazards posed by pyrophoric materials such as explosives or propellants containing their own oxidizers.

2.3 This document is concerned only with design, manufacture, installation, maintenance, and test criteria related to arcs, sparks, or hot surfaces produced by electrical and non-electrical* equipment that may cause ignition of flammable gas or vapor-in-air mixtures, clouds or blankets of combustible dust, or easily ignitable fibers or flyings. Equipment should also comply with the applicable ordinary location requirements (e.g., ANSI/ISA-61010-1).

* Under development (Mechanical and ESD, for example). Some equipment may produce static electricity or cause high temperatures or sparks due to mechanical failure. The materials of construction of parts in such equipment will be an important consideration for application in hazardous locations.

2.4 This document does not cover mechanisms of ignition from external sources, such as static electricity or lightning. Some equipment may produce static electricity. The materials of construction of parts in such equipment will be an important consideration for application in hazardous locations. The extra precautions necessary for this are beyond the scope of this document.

2.5 This document does not consider the effects of installation in corrosive atmospheres and the resulting deleterious conditions to the original design integrity of the equipment. The additional precautions necessary for these conditions are outside the scope of this document.

2.6 This document is not an instruction manual for untrained persons. However, it is intended to provide introductory guidance to those involved with the design, manufacture, installation, and maintenance of equipment used in hazardous (classified) locations. It is also intended to promote uniformity of practice among those skilled in the art. Nothing contained in this document is to be construed as a fixed rule without regard to sound engineering judgment.

2.7 For hazardous location equipment, atmospheric conditions are generally considered to be

- a) an ambient temperature range of -20 °C (-4 °F) to 60 °C (140 °F) for zones and to -25 °C (-13 °F) to +40 °C (104 °F) for divisions;

- b) air with normal oxygen content, typically 21 percent by volume; and
- c) a pressure of 80 kPa (11.6 psia) to 110 kPa (16 psia).

NOTE Equipment specified for atmospheric conditions beyond the above is generally permitted but may be subjected to additional requirements.

2.8 Specialized industries such as, but not limited to, mining and shipping may be regulated by the specific authority having jurisdiction. This document does not include specific requirements or the rules and regulations unique to any specific industry.

2.9 Various organizations have developed codes, guides, and standards that have substantial acceptance by industry and governmental bodies. Codes, guides, and standards useful in the design and installation of electrical instruments in hazardous (classified) locations are listed in Annex C. These are not considered to be a part of this document except for those specific sections of documents referenced elsewhere in this document.

2.10 Due to the purpose of this document, an attempt was made to avoid originality in principles whenever possible, but rather to utilize definitions, explanations, etc., from accepted publications. As a result, much of the material, except for minor changes, is directly as published by others. While specific credit is not given for each reference, all references are included in Annex B.

3 Definitions

The following are terms and definitions commonly used for hazardous (classified) locations.

NOTE: The list is not intended to be all inclusive. Throughout this document, reference is made to areas, spaces, locations, and zones. These terms should be considered interchangeable terms designating a three-dimensional space. Additional definitions may be found in IEC 60050-426, the International Electrotechnical Vocabulary (IEV 426-04-07).

3.1

accessible surface

a surface to which a flammable or combustible mixture has access.

3.2

adequately ventilated area

an adequately ventilated area is an area that has a ventilation system (natural or artificial) that, as a minimum, prevents the accumulation of gases or vapors to an explosive level. Most standards and recommended practices recommend preventing levels in excess of 25 percent of the Lower Flammable Limit, LFL.

NOTE Adequate ventilation of an area alone is not an effective means for the prevention of dust explosions.

3.3

AEx

required marking prefix for equipment meeting one or more types of protection in ANSI/ISA-60079-0 or ANSI/ISA-61241-0.

3.4

approved

acceptable to the authority having jurisdiction.

NOTE 1 See AUTHORITY HAVING JURISDICTION.

NOTE 2 In determining the acceptability of installations or procedures, equipment, or material, the AUTHORITY HAVING JURISDICTION may base acceptance on compliance with appropriate standards. In the absence of such standards, said authority may require evidence of proper installation, procedure, or use. The AUTHORITY HAVING JURISDICTION may also

refer to the listing or labeling practices of product-testing organizations. These organizations are in a position to determine compliance with appropriate standards for the current production of listed or labeled items.

3.5

arcing device

an electrical make/break component, that is generally interpreted as capable of producing an arc with energy sufficient to cause ignition of a specific ignitable mixture.

3.6

associated apparatus

apparatus in which the circuits are not intrinsically safe themselves but affect the energy in the intrinsically safe circuits and are relied upon to maintain intrinsic safety. Associated electrical apparatus may be either

- a) electrical apparatus that has an alternative type of protection for use in the appropriate hazardous (classified) location, or
- b) electrical apparatus not so protected that shall not be used within a hazardous (classified) location.

See also INTRINSIC SAFETY.

3.7

ATEX, ATEX Directive

European Directive 94/9/EC (also referred to as ATEX 95 or 100a Directive) for electrical and mechanical equipment used in hazardous locations. A parallel directive for use, 1999/92/EC (also referred to as ATEX 137 Directive), requires zoning and risk assessment in the workplace.

3.8

authority having jurisdiction

the organization, office, or individual that has the responsibility and authority for approving equipment, installations, or procedures.

NOTE The term AUTHORITY HAVING JURISDICTION is used in a broad manner since jurisdiction and approval agencies vary, as do their responsibilities. Where public safety is primary, the authority having jurisdiction may be a federal, state/provincial, local, other regional department, or an individual such as an inspector from a labor or health department, electrical inspector, or others having statutory authority. An insurance inspection agency, rating bureau, or other insurance company representative may be the authority having jurisdiction. An owner or his designated agent may also assume the role. At government-owned installations, the commanding officer, departmental official, or designated agent may be the authority having jurisdiction.

3.9

automatic

self-acting, operating by its own mechanism when actuated by some impersonal influence, as for example, a change in current strength, pressure, temperature, or mechanical configuration.

3.10

bonding

the permanent joining of metallic parts to form an electrically conductive path that will ensure electrical continuity and the capacity to conduct safely any current likely to be imposed.

3.11

cable gland

a device permitting the introduction of an electric cable into electrical equipment.

3.12**certified**

generic term referring to equipment that has been evaluated by a recognized testing agency and confirmed to be in compliance with the applicable standard(s).

NOTE Some agencies use the terms *approved*, *listed*, or *labeled equipment* to indicate compliance with the applicable standard.

3.13**Class I location**

a location in which flammable gases or vapors are or may be present in the air in quantities sufficient to produce explosive or ignitable mixtures. See 3.117, 3.119, & 3.121 for definitions of Class I, Zones 0, 1, & 2.

3.14**Class I, Division 1 location**

a location (1) in which ignitable concentrations of flammable gases or vapors can exist under normal operating conditions; (2) in which ignitable concentrations of such gases or vapors may exist frequently because of repair or maintenance operations or because of leakage; or (3) in which breakdown or faulty operation of equipment or processes might release ignitable concentrations of flammable gases or vapors and might also cause simultaneous failure of electrical equipment that could act as a source of ignition.

3.15**Class I, Division 2 location**

a location (1) in which volatile flammable liquids or flammable gases are handled, processed, or used, but in which the liquids, vapors, or gases will normally be confined within closed containers or closed systems from which they can escape only in case of accidental rupture or breakdown of such containers or systems, or in case of abnormal operation of equipment; or (2) in which ignitable concentrations of gases or vapors are normally prevented by positive mechanical ventilation and might become hazardous through failure or abnormal operation of the ventilating equipment; or (3) that is adjacent to a Class I, Division 1 location and to which ignitable concentrations of gases or vapors might occasionally be communicated unless such communication is prevented by adequate positive-pressure ventilation from a source of clean air and effective safeguards against ventilation failure are provided.

3.16**Class II location**

a location that is hazardous because of the presence of combustible dust.

3.17**Class II, Division 1 location**

a location (1) in which combustible dust is in the air under normal operating conditions in quantities sufficient to produce explosive or ignitable mixtures; or (2) in which mechanical failure or abnormal operation of machinery or equipment might cause such explosive or ignitable mixtures to be produced and might also provide a source of ignition through simultaneous failure of electrical equipment, operation of protection devices, or from other causes; or (3) in which combustible dusts of an electrically conductive nature may be present in hazardous quantities.

3.18**Class II, Division 2 location**

a location in which combustible dust is not normally in the air in quantities sufficient to produce explosive or ignitable mixtures and dust accumulations are normally insufficient to interfere with the normal operation of electrical equipment or other equipment, but combustible dust may be in suspension in the air as a result of infrequent malfunctioning of handling or processing

equipment and where combustible dust accumulations on, in, or in the vicinity of the electrical equipment may be sufficient to interfere with the safe dissipation of heat from electrical equipment or may be ignitable by abnormal operation or failure of electrical equipment.

3.19

Class III location

a location that is hazardous because of the presence of easily ignitable fibers or flyings but in which such fibers or flyings are not likely to be in suspension in the air in quantities sufficient to produce ignitable mixtures.

3.20

Class III, Division 1 location

a location in which easily ignitable fibers or materials producing combustible flyings are handled, manufactured, or used.

3.21

Class III, Division 2 location

a location in which easily ignitable fibers are stored or handled (except in the process of manufacture).

3.22

code of practice

a term referring to a document that describes basic safety features and methods of protection and recommends, e.g., the selection, installation, inspection, and maintenance procedures that should be followed to ensure the safe use of electrical equipment.

3.23

continuous dilution

the technique of supplying a protective gas flow continuously to an enclosure containing an internal potential source of flammable gas or vapor for the purpose of diluting any flammable gas or vapor that could be present to a level below its LFL. Refer to 5.2.2.

3.24

control drawing

a drawing or other document provided by the manufacturer of the intrinsically safe or associated apparatus that details the allowed interconnections between the intrinsically safe and associated apparatus.

3.25

degree of protection (IP)

a system of rating standard levels of protection provided by equipment for the protection of persons against contact with live or moving parts inside the equipment, as well as the protection provided by equipment against ingress of solids and/or liquids. This type of protection classification is in addition to (and not an alternative to) the types of protection necessary to ensure protection against ignition in hazardous (classified) locations. Definitions are found in IEC Publication 60529.

NOTE See also ENCLOSURE TYPE.

3.26

dust, combustible

any finely divided solid material 420 microns or less in diameter (i.e., material passing a U.S. No. 40 sieve) that presents a fire or explosion hazard when dispersed.

3.27**dust-ignitionproof**

a term used to describe an enclosure that will exclude dust and that, when installed in accordance with the original design intent, will not permit arcs, sparks, or heat otherwise generated or liberated inside the enclosure to cause ignition of exterior accumulations or atmosphere suspensions of a specified dust in the vicinity of the enclosure.

3.28**dust layer, combustible**

any surface accumulation of combustible dust that is thick enough to propagate flame or will degrade and ignite.

3.29**dust-protected enclosure**

a term describing an enclosure in which the ingress of dust is not totally prevented, but dust does not enter in sufficient quantity to interfere with the safe operation of the equipment or accumulate in a position within the enclosure where it is possible to cause an ignition hazard.

3.30**Dust-tight enclosure**

an enclosure so constructed that dust will not enter the enclosing case under specified test conditions.

3.31**EEx**

designation of explosion-protected electrical equipment complying with EN 50014.

NOTE When EN 50014 was replaced by EN 60079-0, the marking was replaced with just Ex.

3.32**electrical equipment**

items applied as a whole or in part for the utilization of electrical energy. These include, among others, equipment for the generation, transmission, distribution, storage, measurement, regulation, conversion, and consumption of electrical energy and items for telecommunication.

3.33**enclosure type**

a North American system of rating standard levels of protection provided to electrical equipment by enclosures for 1) the protection of persons against contact with live or moving parts inside the enclosure, 2) the protection provided by the enclosure against ingress of solids and/or liquids, 3) the protection provided by the enclosure against the deleterious effects of corrosion, and 4) the protection provided by the enclosure against damage due to the formation of external ice. This enclosure type is in addition to (and not an alternative to) the types of protection necessary to ensure protection against ignition in hazardous (classified) locations. Definitions are found in UL 50 or NEMA 250.

NOTE See also DEGREE OF PROTECTION.

3.34**encapsulation**

a type of protection in which the parts that could ignite an explosive atmosphere by either sparking or heating are enclosed in an encapsulant in such a way that this explosive atmosphere cannot be ignited. This type of protection is referred to as "m."

3.35

energized

electrically connected to a source of potential difference.

3.36

entity concept

a concept that allows interconnection of intrinsically safe equipment to associated apparatus not specifically examined in such a combination. The criteria for interconnection is that the voltage (V_{max}) and current (I_{max}) which intrinsically safe equipment can receive and remain intrinsically safe, considering faults, must be equal to or greater than the voltage (V_{oc} or V_t) and current (I_{sc} or I_t) levels which can be delivered by the associated apparatus, considering faults and applicable factors. In addition, the maximum unprotected capacitance (C_i) and inductance (L_i) of the intrinsically safe equipment, including interconnecting wiring, must be equal to or less than the capacitance (C_a) and inductance (L_a) that can safely be connected to the associated apparatus. If these criteria are met, then the combination may be connected without compromising intrinsic safety. For additional information refer to ANSI/ISA-RP12.06.01.

3.37

entry, direct

a method of connection of an electrical equipment to the external circuits by means of the connecting facilities inside the main enclosure or in a terminal compartment having a free opening to the main enclosure. (IEV 426-04-07)

3.38

entry, indirect

a method of connection of an electrical equipment to the electrical circuits by means of a terminal box or a plug and socket connection which is external to the main enclosure. (IEV 426-04-08)

3.39

equipment protection level EPL

level of protection assigned to equipment based on its likelihood of becoming a source of ignition and distinguishing the differences between explosive gas atmospheres, explosive dust atmospheres, and the explosive atmospheres in mines susceptible to firedamp (Annex A).

NOTE Although the marking identifying the equipment protection level (EPL) may appear on equipment, the 2008 NEC does not recognize the concept of employing the equipment protection level in a complete risk assessment of an installation.

3.40

Ex

designation of explosion-protected electrical equipment

3.41

Ex component

part of electrical equipment for explosive atmospheres which is not to be used alone in such atmospheres and which requires additional evaluation of any electrical equipment with which it is used.

3.41

IEC Ex Scheme

an international system of certification for explosion-protected electrical equipment administered by the IECEx Management Committee and described by IECEx 01. The goal of this scheme is that a manufacturer of hazardous location electrical equipment would be able to obtain a single 'IEC Ex' Certificate of Conformity from one Certification Laboratory and provide that product in

any participating country without legal or technical obstacle and without the need to get it recertified locally. More information can be found at www.iecex.com.

3.42 explosionproof

a term used to describe an enclosure that is capable of withstanding an explosion of a specified gas or vapor that may occur within it and of preventing the ignition of a specified gas or vapor surrounding the enclosure by sparks, flashes, or explosion of the gas or vapor within, and that operates at such an external temperature that a surrounding flammable atmosphere will not be ignited thereby. (NEC)

NOTE See also FLAMEPROOF ENCLOSURE.

3.43 explosive atmosphere

a mixture with air, under atmospheric conditions, of flammable substances in the form of gas, vapor, mist, or dust in which, after ignition, combustion spreads throughout the unconsumed mixture.

NOTE See also HAZARDOUS (CLASSIFIED) LOCATION.

3.44 fault (as applicable to intrinsically safe systems)

a defect or electrical breakdown of any component, spacing, or insulation that alone or in combination with other defects or breakdowns may adversely affect the electrical or thermal characteristics of the intrinsically safe system. If a defect or breakdown leads to defects or breakdowns in other components, the primary and subsequent defects and breakdowns are considered to be a single fault. Certain components may be considered not subject to fault when analyses or tests for intrinsic safety are made. See also PROTECTIVE COMPONENT.

3.45 fibers and flyings

these are materials not normally in suspension in air; and are of larger particle size than dusts. Fibers and flyings include materials such as cotton linters, sawdust, textile fibers, and other large particles that are usually more a fire hazard than an explosion hazard.

3.46 flameproof

a type of protection of electrical equipment in which an enclosure will withstand an internal explosion of a flammable mixture which has penetrated into the interior, without suffering damage and without causing ignition, through any joints or structural openings in the enclosure, of an external explosive atmosphere consisting of one or more of the gases or vapors for which it is designed. This type of protection is referred to as "d."

NOTE See also EXPLOSIONPROOF EQUIPMENT.

3.47 flammable limits

the flammable limits of a gas or vapor are the lower (LFL) and upper (UFL) flammable limit, stated in percent by volume of gas in a gas-air mixture, between which a flammable mixture is formed.

NOTE 1 For additional information refer to NFPA Fire Protection Handbook and IEC 60079-20.

NOTE 2 In the past, flammable and explosive have been used interchangeably in many texts, but the trend is to avoid the confusion that this causes. The term flammable relates to the properties of the material that determine its ability to produce self-sustaining flame propagation in any direction (upwards, sideways or downwards). The term explosive relates to flame propagation that is accompanied by pressure rise and noise (usually higher-speed propagation) and is

significantly affected by (non-material related) test-chamber conditions (geometry, degree of confinement...). LFL concentrations are typically lower than LEL concentrations for the same material and UFL concentrations are typically higher than UEL concentrations for the same material.

3.48

flammable liquid

any liquid having a flash point below 37.8 °C (100 °F) and having a vapor pressure not exceeding 275 kPa (40 psia) at 37.8 °C (100 °F).

NOTE For additional information, refer to NFPA Fire Protection Handbook.

3.49

flammable gas or vapor

a gas or vapor which, when mixed with air in certain proportions, will form a flammable gas atmosphere.

3.50

flash point

the minimum temperature at which a liquid gives off vapor in sufficient concentration to form an ignitable mixture with air near the surface of the liquid, as specified by test.

NOTE For additional information, refer to NFPA Fire Protection Handbook.

3.51

ground

a conducting connection, whether intentional or accidental, between an electrical circuit or equipment and the earth, or to some conducting body that serves in place of the earth.

3.52

grounded (earthed)

connected to earth or to some conducting body that serves in place of earth.

3.53

group

a classification of combustible materials.

NOTE Refer to Clause 4 for additional information.

3.54

hazardous (classified) location

a location in which fire or explosion hazards may exist due to an explosive atmosphere of flammable gases or vapors, flammable liquids, combustible dust, or easily ignitable fibers or flyings.

NOTE See also EXPLOSIVE ATMOSPHERE.

3.55

hermetically sealed device

a device that is sealed against the entrance of an external atmosphere and in which the seal is made by fusion, e.g., soldering, brazing, welding or the fusion of glass to metal.

3.56

high temperature equipment

as specified by NEC, Articles 501.5 and 505.16, the term "*high temperatures*" is to be interpreted as those where the maximum operating temperature (including ambient temperature effect) exceeds 80 percent of the autoignition temperature in degrees Celsius (°C) of the gas or vapor involved.

3.57**identified (as applied to equipment)**

recognizable as suitable for the specific purpose, function, use, environment, application, etc., where described in a particular requirement, e.g. NEC.

NOTE Suitability of equipment for a specific purpose, environment, or application may be determined by a qualified testing laboratory, inspection agency, or other organization concerned with product evaluation. Such identification may include labeling or listing. For additional information see *labeled* and *listed*.

3.58**ignition (autoignition) temperature (AIT)**

the minimum temperature required to initiate or cause self-sustained combustion of a solid, liquid, or gas independently of the heating or heating elements.

NOTE 1 For additional information refer to NFPA Fire Protection Handbook.

NOTE 2 A distinction is made between ignition temperature and flash point. See FLASH POINT.

3.59**ignition capable**

equipment or wiring that under normal conditions, or under specified abnormal conditions, can release sufficient electrical or thermal energy (including electrostatic, frictional sparking or hot surfaces) to cause ignition of a specific explosive atmosphere.

3.60**increased safety**

a type of protection applied to electrical equipment that does not produce arcs or sparks in normal service and under specified abnormal conditions, in which additional measures are applied so as to give increased security against the possibility of excessive temperatures and of the occurrence of arcs and sparks. This type of protection is referred to as "e."

3.61**internal wiring**

wiring and electrical connections that are made within equipment by the manufacturer. Within racks or panels, interconnections between separate pieces of equipment made in accordance with detailed instructions from the equipment manufacturer are also considered to be internal wiring.

3.62**intrinsic safety**

a type of protection in which a portion of the electrical system contains only intrinsically safe equipment, circuits, and wiring that is incapable of causing ignition in the surrounding atmosphere. No single device or wiring is intrinsically safe by itself (except for battery-operated, self-contained equipment such as portable pagers, transceivers, gas detectors, etc., which are specifically designed as intrinsically safe self-contained devices) but is intrinsically safe only when employed in a properly designed intrinsically safe system. This type of protection is referred to as "i."

NOTE See also ASSOCIATED APPARATUS.

3.63**intrinsic safety barrier**

a component containing a network designed to limit the energy (voltage and current) available to the protected circuit in the hazardous (classified) location under specified fault conditions.

3.64

intrinsically safe circuit

a circuit in which any spark or thermal effect, produced either normally or in specified fault conditions, is incapable, in the specified test conditions, of causing ignition of a given explosive atmosphere.

3.65

intrinsically safe electrical equipment

electrical equipment in which all the circuits are intrinsically safe circuits.

3.66

intrinsic safety ground bus

a grounding system that has a dedicated conductor separate from the power system so that ground currents will not normally flow and that is reliably connected to a ground electrode.

NOTE For further information, refer to Article 504 of NEC, or Section 10 of CSA C22.1, or ANSI/ISA-RP12.06.01.

3.67

intrinsically safe system

an assembly of interconnected intrinsically safe equipment, associated apparatus, other equipment, and interconnecting cables in which those parts of the system that may be used in hazardous (classified) locations are intrinsically safe circuits.

3.68

labeled

equipment or materials with a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation that maintains periodic inspection of production of labeled equipment or materials and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

NOTE Some agencies use the term *approved*, *listed*, or *certified* to indicate compliance with the applicable standard.

3.69

liquid, combustible

a liquid having a flash point at or above 37.8 °C (100 °F). Combustible liquids are subdivided as follows:

- a) Class II liquids include those having flash points at or above 37.8 °C (100 °F) and below 60 °C (140 °F).
- b) Class IIIA liquids include those having flash points at or above 60 °C (140 °F) and below 93 °C (200 °F).
- c) Class IIIB liquids include those having flash points at or above 93 °C (200 °F).

NOTE For additional information, refer to NFPA 30. It should also be noted that these classes have no relation to the hazardous location classes.

3.70

listed

equipment or materials included in a list published by an organization acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of listed equipment or materials, and whose listing states either that the equipment or material meets appropriate designated standards or has been tested and found suitable for use in a specified manner.

NOTE The means for identifying listed equipment may vary for each organization concerned with product evaluation, some of which do not recognize equipment as listed unless it is also labeled. The authority having jurisdiction should utilize the system employed by the listing organization to identify a listed product.

3.71**lower explosive limit (LEL)**

refer to FLAMMABLE LIMITS.

3.72**lower flammable limit (LFL)**

refer to FLAMMABLE LIMITS.

3.73**maintenance, corrective**

any maintenance activity that is not normal in the operation of equipment and requires access to the equipment's interior. Such activities are expected to be performed by a qualified person. Such activities typically include locating causes of faulty performance, replacement of defective components, adjustment of internal controls, and the like.

3.74**maintenance, operational**

any maintenance activity, excluding corrective maintenance, intended to be performed by the operator and required in order for the equipment to serve its intended purpose. Such activities typically include the correcting of zero on a panel instrument, changing charts, record keeping, adding ink, and the like.

3.75**make/break component**

components having contacts that can interrupt a circuit (even if the interruption is transient in nature). Examples of make/break components are relays, circuit breakers, servo potentiometers, adjustable resistors, switches, connectors, and motor brushes.

3.76**maximum surface temperature**

the highest temperature attained by a surface accessible to flammable gases, vapors, or combustible dusts under conditions of operation within the ratings of the equipment (including specified abnormal conditions).

3.77**minimum cloud ignition temperature**

the minimum temperature at which a combustible dust atmosphere will autoignite and propagate an explosion.

3.78**minimum dust layer ignition temperature**

the minimum temperature of a surface that will ignite a dust on it after a long time (theoretically, until infinity). In most dusts, free moisture has been vaporized before ignition.

3.79**minimum explosive (dust) concentration**

the minimum concentration of a dust cloud that, when ignited, will propagate a flame away from the source of ignition.

3.80

minimum ignition energy (MIE)

the smallest amount of energy that can ignite the most easily ignitable mixture of a specific gas or vapor-in-air mixture or dust-in-air mixture.

3.81

maximum experimental safe gap (MESG)

the maximum clearance between two parallel metal surfaces that has been found, under specified test conditions, to prevent an explosion in a test chamber from being propagated to a secondary chamber containing the same gas or vapor at the same concentration.

3.82

minimum igniting current ratio (MIC Ratio)

the ratio derived by dividing the minimum current required from an inductive spark discharge to ignite the most easily ignitable mixture of a gas or vapor by the minimum current required from an inductive spark discharge to ignite methane under the same test conditions.

NOTE For additional information, refer to IEC 60079-3.

3.83

nonautomatic

non-self-acting — requiring personal intervention for control. As applied to an electric controller, nonautomatic control does not necessarily imply a manual controller, but only that personal intervention is necessary.

3.84

nonhazardous (unclassified) location

a location in which fire or explosion hazards are not expected to exist specifically due to the presence of flammable gases or vapors, flammable liquids, combustible dusts, or ignitable fibers or flyings. Such a location may also be referred to as a safe area.

3.85

nonincendive circuit

a circuit, other than field wiring, in which any arc or thermal effect produced, under intended operating conditions of the equipment, is not capable, under specified test conditions, of igniting the flammable gas-, vapor-, or dust-air mixture. See also NONINCENDIVE FIELD WIRING.

3.86

nonincendive component

a component having contacts for making or breaking an ignition-capable circuit and in which the contacting mechanism is constructed so that the component is incapable of igniting the specified explosive atmosphere. The housing of a nonincendive component is not intended to (1) exclude the flammable atmosphere or (2) contain an explosion. This type of protection is referred to as "nC."

3.87

nonincendive equipment

equipment having electrical/electronic circuitry and components that are incapable, under normal conditions, of causing ignition of the flammable gas-, vapor-, or dust-air mixture due to arcing or thermal effect. This type of protection is referred to as "nA," "nC," or "nR."

3.88**nonincendive field wiring**

wiring that enters or leaves an equipment enclosure and, under normal operating conditions of the equipment, is not capable, due to arcing or thermal effects, of igniting the flammable gas-, vapor-, or dust-air mixture. Normal operation includes opening, shorting, or grounding the field wiring. See also NONINCENDIVE CIRCUIT.

3.89**normal conditions**

equipment is generally considered to be under normal conditions when it conforms electrically and mechanically with its design specifications and is used within the limits specified by the manufacturer.

3.90**oil-immersion**

type of protection in which the electrical equipment or parts of the electrical equipment are immersed in a protective liquid in such a way that an explosive atmosphere which may be above the liquid or outside the enclosure cannot be ignited. This type of protection is referred to as "o."

3.91**powder filling**

a type of protection in which the parts capable of igniting an explosive atmosphere are fixed in position and completely surrounded by filling material to prevent the ignition of an external explosive atmosphere. This type of protection is referred to as "q."

NOTE This type of protection may not prevent the surrounding explosive atmosphere from penetrating into the equipment and Ex components and being ignited by the circuits. However, due to the small free volumes in the filling material and due to the quenching of a flame that may propagate through the paths in the filling material, an external explosion is prevented.

3.92**pressurization**

the technique of guarding against the ingress of the external atmosphere into an enclosure by maintaining a PROTECTIVE GAS therein at a pressure above that of the external atmosphere. This type of protection is referred to as "p."

3.93**pressurization, Type X**

a method of reducing the classification within an enclosure from Division 1/Zone 1 to nonhazardous (unclassified). See 5.2.1.

3.94**pressurization, Type Y**

a method of reducing the classification within an enclosure from Division 1/Zone 1 to Division 2/Zone 2. See 5.2.1.

3.95**pressurization, Type Z**

a method of reducing the classification within an enclosure from Division 2/Zone 2 to nonhazardous (unclassified). See 5.2.1.

3.96**protection, type of**

the specific measures applied to electrical equipment to avoid ignition of a surrounding explosive atmosphere. Examples are "e" and "n."

3.97

protective component (as applied to intrinsic safety)

a component that is so unlikely to become defective in a manner that will lower the intrinsic safety of the circuit that it may be considered not subject to fault when analyses or tests for intrinsic safety are made.

3.98

protective gas

the gas used for pressurization or for the dilution of flammable gases to a level well below their lower explosive limit, usually below 25 percent LFL/LEL. The *protective gas* may be air, nitrogen, other nonflammable gas, or a mixture of such gases.

3.99

purging

in a pressurized enclosure, the operation of passing a quantity of PROTECTIVE GAS through the enclosure and ducts, so that the concentration of the explosive gas atmosphere is brought to a safe level.

3.100

qualified person

one familiar with the construction and operation of the equipment and the hazards involved.

3.101

restricted breathing

a protection technique in which the tightness of an enclosure is assured so that short-term presence of a flammable gas or vapor cloud around the enclosure will not cause the concentration inside the enclosure to reach the LFL/LEL because of breathing or diffusion. This type of protection is referred to as "nR."

3.102

safe area

refer to NONHAZARDOUS (UNCLASSIFIED) LOCATION.

3.103

seal, cable, explosionproof

a cable termination fitting filled with compound and designed to contain an explosion in the enclosure to which it is attached or to minimize passage of flammable gases or vapors from one location to another. A conduit seal in combination with a cable termination fitting may also be used as a cable seal.

3.104

seal, conduit, explosionproof

a sealing fitting, filled with a poured potting compound, designed to contain an explosion in the enclosure to which it is attached and to minimize passage of flammable gases or vapors from one location to another.

3.105

seal, factory

a construction where components capable of initiating an internal explosion due to arcing, sparking, or thermal effects under normal conditions are isolated from the wiring system by means of factory installed flameproof seal or joint for the purpose of eliminating the need for an external, field-installed conduit seal and, in some cases, a field-installed cable seal.

3.106**sealed device**

a device so constructed that it cannot be opened during normal operational conditions or operational maintenance; it has a free internal volume less than 100 cubic centimeters (6.1 cubic inches) and is sealed to restrict entry of an external atmosphere. This type of protection is referred to as "nC."

3.107**simple apparatus (as applied to intrinsic safety)**

a device that will not generate or store more than 1.2 V, 0.1 A, or 25 mW. Examples are: switches, thermocouples, light-emitting diodes, and resistance temperature detectors (RTDs).

3.108**source of release**

a point from which flammable gases or vapors, flammable liquid, combustible dusts, or ignitable fibers or flyings may be released into the atmosphere.

3.109**special protection**

a protection technique other than those that have been standardized.

3.110**temperature, ambient**

the temperature of air or other media where electrical equipment is to be used.

3.111**temperature Class**

a system of classification by which one of 14 temperature classes (for zones, six temperature classes) is allocated to equipment. The temperature class represents the maximum surface temperature of any part of the equipment that may come in contact with the flammable gas or vapor mixture. See Table 1.

3.112**type of protection**

refer to PROTECTION, TYPE OF.

3.113**upper explosive limit (UEL)**

refer to FLAMMABLE LIMITS.

3.114**upper flammable limit (UFL)**

refer to FLAMMABLE LIMITS.

3.115**Zone**

a method of specifying the probability that a location is made hazardous by the presence, or potential presence, of flammable concentrations of gases and vapors, or combustible mixtures of dusts.

3.116

Zone 0 (IEC)

an area in which an explosive gas atmosphere is present continuously or for long periods. (IEV 426-03-03, modified)

3.117

Zone 0, Class I (NEC)

a Class I, Zone 0 location is a location (1) in which ignitable concentrations of flammable gases or vapors are present continuously; or (2) in which ignitable concentrations of flammable gases or vapors are present for long periods of time. (NEC Section 505.5 (B)(1))

3.118

Zone 1 (IEC)

an area in which an explosive gas atmosphere is likely to occur in normal operation. (IEV 426-03-04)

3.119

Zone 1, Class I (NEC)

a Class I, Zone 1 location is a location (1) in which ignitable concentrations of flammable gases or vapors are likely to exist under normal operating conditions; or (2) in which ignitable concentrations of flammable gases or vapors may exist frequently because of repair or maintenance operations or because of leakage; or (3) in which equipment is operated or processes are carried on, of such a nature that equipment breakdown or faulty operations could result in the release of ignitable concentrations of flammable gases or vapors and also cause simultaneous failure of electrical equipment in a mode to cause the electrical equipment to become a source of ignition; or (4) that is adjacent to a Class I, Zone 0 location from which ignitable concentrations of vapors could be communicated, unless communication is prevented by adequate positive-pressure ventilation from a source of clean air and effective safeguards against ventilation failure are provided. (NEC Article 505.5 (B)(2))

3.120

Zone 2 (IEC)

an area in which an explosive gas atmosphere is not likely to occur in normal operation and, if it does occur, is likely to do so only infrequently and will exist for a short period only. (IEV 426-03-05, modified)

3.121

Zone 2, Class I (NEC)

a Class I, Zone 2 location is a location (1) in which ignitable concentrations of flammable gases or vapors are not likely to occur in normal operation, and if they do occur, will exist only for a short period; or (2) in which volatile flammable liquids, flammable gases, or flammable vapors are handled, processed, or used, but in which the liquids, gases, or vapors normally are confined within closed containers or closed systems from which they can escape only as a result of accidental rupture or breakdown of the containers or system, or as the result of the abnormal operation of the equipment with which the liquids or gases are handled, processed, or used; or (3) in which ignitable concentrations of flammable gases or vapors normally are prevented by positive mechanical ventilation, but which may become hazardous as the result of failure or abnormal operation of the ventilation equipment; or (4) that is adjacent to a Class I, Zone 1 location from which ignitable concentrations of flammable gases or vapors could be communicated, unless such communication is prevented by adequate positive-pressure ventilation from a source of clean air, and effective safeguards against ventilation failure are provided. (NEC Section 505.5 (B)(3))

3.122 Zone 20**3.122.1 (IEC)**

an area in which combustible dust, as a cloud, is present continuously or frequently, during normal operation, in sufficient quantity to be capable of producing an explosible concentration of combustible dust in mixture with air and/or where layers of dust of uncontrollable and excessive thickness can be formed. This can be the case inside dust containment where dust can form explosible mixtures frequently or for long periods of time. This occurs typically inside equipment. (IEC 61241-10 (soon to become IEC 60079-10-2) - 2.11).

3.122.2 (NEC)

An area where combustible dust or ignitable fibers and flyings are present continuously or for long periods of time in quantities sufficient to be hazardous.

3.123 Zone 21**3.123.1 (IEC)**

an area not classified as Zone 20 in which combustible dust, as a cloud, is likely to occur during normal operation, in sufficient quantity to be capable of producing an explosible concentration of combustible dust in mixture with air. This Zone can include, among others, areas in the immediate vicinity of powder filling or emptying points and areas where dust layers occur and are likely in normal operation to give rise to an explosible concentration of combustible dust in mixture with air. (IEC 61241-10 (soon to become IEC 60079-10-2) - 2.12).

3.123.2 (NEC)

An area where combustible dust or ignitable fibers and flyings are likely to exist occasionally under normal operation in quantities sufficient to be hazardous

3.124 Zone 22**3.124.1 (IEC)**

an area not classified as Zone 21 in which combustible dust, as a cloud, can occur infrequently, and persist only for a short period, or in which accumulations or layers of combustible dust can give rise to an explosive concentration of combustible dust in mixture with air. This Zone can include, among others, areas in the vicinity of equipment containing dust, and in which dust can escape from leaks and form deposits (e.g. milling rooms in which dust can escape from the mills and then settle). (IEC 61241-10 (soon to become IEC 60079-10-2) - 2.13)

3.124.2 (NEC)

An area where combustible dust or ignitable fibers and flyings are not likely to occur under normal operation in quantities sufficient to be hazardous.

4 Area (location) classification

Area classification schemes should specify the kind of flammable material that may be present and the probability that it will be present in ignitable concentrations. Area classification schemes and systems of material classification have been developed to provide a succinct description of the hazard so that appropriate safeguards may be selected. The type of protection technique selected and the level of protection it must provide depend upon the potential hazard caused by using electrical equipment in a location in which a combustible, flammable, or ignitable substance may be present.

4.1 North American methods

In the United States, the area classification definitions are stated in Articles 500, 505 and 506 of the National Electrical Code, (NEC) NFPA 70. In Canada, similar definitions are given in the Canadian Electrical Code (CEC), Part 1, Section 18 and Annex J18 (CSA C22.1).

Various organizations have developed numerous guides and standards that have substantial acceptance by industry and governmental bodies for area classification. Refer to Annex C.

Area classification definitions used in the United States and Canada include the following:

- a) CLASS — the generic form of the flammable materials in the atmosphere, which may include gas or vapor, dusts, or easily ignitable fibers or flyings (see Clause 3 for detailed definitions);
- b) DIVISION (or ZONE) —an indication of the probability of the presence of the flammable material in ignitable concentration (see Clause 3 for detailed definitions); and
- c) GROUP — the exact nature of the flammable material (see 4.1.1 & 4.1.2).

4.1.1 Groups (NEC Article 500 / CEC Annex J18)

The United States and Canadian Electrical Codes recognize seven groups: Groups A, B, C, D, E, F, and G. Groups A, B, C, and D apply to Class I locations; Groups E, F, and G apply to Class II Locations. In NEC these groups are defined as:

Group A - Acetylene

Group B - Flammable gas, flammable liquid-produced vapor, or combustible liquid-produced vapor mixed with air that may burn or explode, having either a MAXIMUM EXPERIMENTAL SAFE GAP (MESG) less than or equal to 0.45 mm or a MINIMUM IGNITING CURRENT RATIO (MIC RATIO) less than 0.4.

NOTE A typical Class I, Group B material is hydrogen.

Group C - Flammable gas, flammable liquid-produced vapor, or combustible liquid-produced vapor mixed with air that may burn or explode, having either a MAXIMUM EXPERIMENTAL SAFE GAP (MESG) values greater than 0.45 mm and less than or equal to 0.75 mm or a MINIMUM IGNITING CURRENT RATIO (MIC RATIO) greater than or equal to 0.4 and less than or equal to 0.80.

NOTE A typical Class I, Group C material is ethylene.

Group D - Flammable gas, flammable liquid-produced vapor, or combustible liquid-produced vapor mixed with air that may burn or explode, having a MAXIMUM EXPERIMENTAL SAFE GAP (MESG) greater than 0.75 mm or a MINIMUM IGNITING CURRENT RATIO (MIC RATIO) greater than 0.80, or gases or vapors of equivalent hazard.

NOTE A typical Class I, Group D material is propane.

Additional information on group classification can be found in NFPA 497, Classification of Flammable Liquids, Gases or Vapors and of Hazardous (Classified) Locations for Electrical Installations in Chemical Process Areas.

Group E - Atmospheres containing combustible metal dusts, including aluminum, magnesium, and their commercial alloys, or other combustible dusts whose particle size, abrasiveness, and conductivity present similar hazards in the use of electrical equipment.

Group F - Atmospheres containing combustible carbonaceous dusts that have more than 8 percent total entrapped volatiles (see ASTM D3175-89 for coal and coke dusts) or that have been sensitized by other materials so that they present an explosion hazard. Coal, carbon black, charcoal, and coke dusts are examples of carbonaceous dusts.

Group G - Atmospheres containing other combustible dusts, including flour, grain, wood flour, plastic, and chemicals.

Additional information on Group Classification can be found in NFPA 499 Classification of Combustible Dusts and of Hazardous (Classified) Locations for Electrical Installations in Chemical Process Areas.

4.1.2 Groups (NEC Article 505/CSA C22.1 Section 18/IEC 60079-20-1)

These groups are defined as:

Group IIC - Flammable gas, flammable liquid-produced vapor, or combustible liquid-produced vapor mixed with air that may burn or explode, having either MAXIMUM EXPERIMENTAL SAFE GAP (MESG) less than or equal to 0.5 mm or MINIMUM IGNITING CURRENT RATIO (MIC RATIO) less than 0.45, or gases or vapors of equivalent hazard.

NOTE 1 This group is similar to a combination of Groups A & B as described in 4.1.1, although the MESG and MIC RATIO numbers are slightly different.

NOTE 2 Typical gases include acetylene, carbon disulfide, hydrogen, and gases or vapors of equivalent hazard.

Group IIB - Flammable gas, flammable liquid-produced vapor, or combustible liquid-produced vapor mixed with air that may burn or explode, having either MAXIMUM EXPERIMENTAL SAFE GAP (MESG) values greater than 0.5 mm and less than or equal to 0.9 mm or MINIMUM IGNITING CURRENT RATIO (MIC RATIO) greater than or equal to 0.45 and less than or equal to 0.80, or gases or vapors of equivalent hazard.

NOTE 1 This group is similar to Group C as described in 4.1.1, although the MESG and MIC RATIO numbers are slightly different.

NOTE 2 Typical gases include ethylene and gases or vapors of equivalent hazard.

Group IIA - Flammable gas, flammable liquid-produced vapor, or combustible liquid-produced vapor mixed with air that may burn or explode, having MAXIMUM EXPERIMENTAL SAFE GAP (MESG) greater than 0.9 mm or MINIMUM IGNITING CURRENT RATIO (MIC RATIO) greater than 0.80, or gases or vapors of equivalent hazard.

NOTE 1 This group is similar to Group D as described in 4.1.1, although the MESG number is slightly different.

NOTE 2 Typical gases include propane and gases or vapors of equivalent hazard.

Additional information on group classification can be found in IEC 60079-20-1.

4.1.3 Dust Groups

4.1.3.1 Groups (NEC Article 506)

There are currently no dust groups defined in NEC article 506.

4.1.3.2 Groups (IEC 60079-0)

Electrical equipment of Group III is intended for use in places with an explosive dust atmosphere other than mines susceptible to firedamp. Electrical equipment of Group III is subdivided according to the nature of the explosive dust atmosphere for which it is intended.

Group III subdivisions:

- IIIA, Combustible flyings - solid particles, including fibres, greater than 500 μm in nominal size which may be suspended in air and could settle out of the atmosphere under their own weight
- IIIB, Non-conductive dust - combustible dust with electrical resistivity greater than $10^3 \Omega\cdot\text{m}$
- IIIC, Conductive dust - combustible dust with electrical resistivity equal to or less than $10^3 \Omega\cdot\text{m}$

NOTE IEC 61241-2-2 contains the test method for determining the electrical resistivity of dusts.

4.2 Additional background information

4.2.1 History

Historically, the topic of Hazardous (Classified) Locations first appeared in the National Electrical Code (NEC) in 1923, when a new article entitled "Extra-Hazardous Locations" was accepted. This article addressed rooms or compartments in which highly flammable gases, liquids, mixtures or other substances were manufactured, used, or stored. In 1931, "Classifications" consisting of Class I, Class II, etc., for the hazardous locations were defined. However it was not until 1935 that Groups were introduced into the NEC.

NOTE Divisions were introduced into the NEC in 1947.

The four gas Groups, A, B, C, and D, complemented the design of electrical equipment used in hazardous (classified) locations and were defined based on the level of hazard associated with explosion pressures of specific atmospheres and the likelihood that the effects of that explosion could be transmitted outside the enclosure. Group A was defined as atmospheres containing acetylene. Group B was defined as atmospheres containing hydrogen or gas or vapors of equivalent hazard. Group C was defined as atmospheres containing ethyl ether vapor; and Group D was defined as atmospheres containing gasoline, petroleum, naphtha, alcohols, acetone, lacquers solvent vapors, and natural gas.

Despite the fact that the introduction of these Groups was done without standardized testing and without the advantage of today's technological advances or equipment, these definitions have changed little since that time. The first major testing, in fact, was only conducted in the late 1950s, when engineers at Underwriters Laboratories developed a test apparatus that provided a means to determine how various materials behaved with respect to explosion pressures and transmission, when the specific combustible material was ignited in the test vessel. This apparatus, called the Westerberg Explosion Test Vessel, provided standardized documentation of a factor called the Maximum Experimental Safe Gap (MESG) and permitted other materials to be "classified by test" into one of the four gas groups. The results of these tests are contained in Underwriter Laboratories (UL) Bulletin Nos. 58 and 58A (reissued in July, 1993, as UL Technical Report No. 58). In 1971, the International Electrotechnical Commission (IEC) published IEC 79-1A defining a different type of apparatus for obtaining MESG results. While the two MESG test apparatus are physically different in both size and shape, the results are statistically comparative, although in some cases differences have been observed. A sample of values is shown in the following table: