

RECOMMENDED PRACTICE

ISA–RP92.02.02, Part II–1998 (R2013)

**Installation, Operation, and
Maintenance of Carbon Monoxide
Detection Instruments
(50-1000 ppm Full Scale)**

Reaffirmed 16 January 2013

ISA–RP92.02.02, Part II–1998 (R2013), Installation, Operation, and Maintenance of Carbon Monoxide Detection Instruments (50-1000 ppm Full Scale)

ISBN: 978-1-937560-92-8

Copyright © 2013 by the International Society of Automation. All rights reserved. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709

Preface

This preface, all footnotes, and annexes are included for informational purposes and are not a part of ISA-RP92.02.02, Part II-1998 (R2013).

This recommended practice has been prepared as a part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Standards and Practices Board Secretary; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; Internet: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavour to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. IEEE/ASTM SI 10, *American National Standard for Metric Practice*, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports.

Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards that ISA develops.

CAUTION — ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.

PURSUANT TO ISA'S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.

OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.

ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following members of ISA92 approved ISA-RP92.02.02, Part II-1998:

NAME	COMPANY
J. Thomason, Chairman	Omni Industrial Systems, Inc.
D. Bishop, Managing Director	Chevron Production Technology Company
W. Alexander	Mine Safety Appliances Company
D. Alpha	Detcom, Inc.
K. Burden	Sensidyne, Inc.
J. Chang	Motorola SPA
M. Coppler	Ametek Inc.
T. Donkin	Enmet Corporation
C. Groppetti	Detector Electronics Corporation
B. Holcom	Gas Tech, Inc.
K. Johnson	KWJ Engineering, Inc.
D. Li	Canadian Standards Association
A. Maynard	Gas Measurement Instruments Ltd.
R. Mease	City of St. Johns
*F. McGowan	Factory Mutual Research Corporation
R. Menot	Factory Mutual Research Corporation
D. Mohla	Union Carbide Chemicals & Plastics
G. Naujoks	Keithley Instruments
B. Northam	Munro Electronics
R. Novack	Ametek Inc.
M. Schaeffer	Control Instruments Corporation
W. Shao	Canadian Standards Association
A. Spataru	The Adept Group, Inc.
M. Stryker	NCASI
P. Stupay	Keithley Instruments
D. Wagner	Industrial Scientific Corporation
R. Warburton	Industrial Scientific Corporation

*One vote per company

The following members of ISA92.02 approved ISA-RP92.02.02, Part II-1998:

NAME	COMPANY
J. Thomason, Acting Chairman	Omni Industrial Systems, Inc.
D. Bishop, Managing Director	Chevron Production Technology Co.
W. Alexander	Mine Safety Appliances Company
D. Alpha	Detcon, Inc.

J. Chilton
M. Coppler
S. Day
T. Donkin
C. Groppetti
B. Holcom
K. Johnson
D. Li
B. Matheson
A. Maynard
R. Menot
J. Miller
C. Nakata
B. Northam
R. Novack
M. Schaeffer
W. Shao
P. Stupay
R. Warburton
J. Zabrenski

NIOSH PRC
Ametek Inc.
Foxboro Company
Enmet Corporation
Detector Electronic Corporation
Gas Tech, Inc.
KWJ Engineering, Inc.
Canadian Standards Association
Sensidyne, Inc.
Gas Measurement Instruments, Ltd.
Factory Mutual Research Corporation
Detector Electronics Corporation
Motorola, Inc.
Munro Electronics
Ametek Inc.
Control Instruments Corporation
Canadian Standards Association
Keithley Instruments
Industrial Scientific Corporation
Air Products & Chemicals, Inc.

This recommended practice was approved for publication by the ISA Standards and Practices Board on October 15, 1997.

NAME

COMPANY

R. Webb, Vice President
H. Baumann
D. Bishop
P. Brett
W. Calder III
M. Cohen
H. Dammeyer
R. Dieck
W. Holland
H. Hopkins
A. Iverson
K. Lindner
V. Maggioli
T. McAviney
A. McCauley, Jr.
G. McFarland
J. Mock
E. Montgomery
D. Rapley
R. Reimer
J. Rennie
W. Weidman
J. Weiss
J. Whetstone
M. Widmeyer
R. Wiegler
C. Williams
G. Wood
M. Zielinski

Pacific Gas & Electric Company
H. D. Baumann & Associates, Ltd.
Chevron Production Technology Co.
Honeywell, Inc.
Calder Enterprises
Flexonics, Inc.
Ohio State University
Pratt & Whitney
Southern Co. Services, Inc.
Utility Products of Arizona
Ivy Optiks
Endress + Hauser GmbH + Company
Feltronics Corporation
Instrumentation & Control Engineering, LLC
Chagrin Valley Controls, Inc.
Honeywell, Inc.
Consultant
Fluor Daniel, Inc.
Rapley Engineering Services, Inc.
Allen-Bradley Company
Factory Mutual Research Corporation
Consultant
Electric Power Research Institute
National Institute of Standards & Technology
Carnegie Mellon University
Canus Corporation
Eastman Kodak Company
Graeme Wood Consulting
Fisher-Rosemount Systems, Inc.

The following members of ISA92 reaffirmed this document.

NAME	COMPANY
J. Miller, Chairman	Detector Electronics Corporation
R. Seitz, Vice Chairman	Artech Engineering
M. Coppler, Managing Director	Det Norske Veritas Certification Inc.
S. Baliga	General Monitors
W. Bennett	Mine Safety Appliances Co.
T. Crawford	Intertek Testing Services
G. Garcha	GE Energy
R. Goins	Lyondell Basell
K. Hedrick	MSHA Approval & Certification Center
S. Henney	FM Approvals
C. Lucarino	Sensient
R. Masi	Detcon Inc.
D. Mills	Underwriters Laboratories Inc.
L. Owen	Dooley Tackaberry Inc.
A. Skinner	GMI Gas Measurement Instruments LLC
J. Stratman	Honeywell Analytics Inc.
J. Thomason	Omni Industrial Systems Inc.
A. Vial	Shell Exploration & Production Co.
D. Wechsler	American Chemistry Council

This recommended practice was approved by the Standards and Practices Board on 16 January 2013.

NAME	COMPANY
E. Cosman, Vice President	The Dow Chemical Company
D. Bartusiak	ExxonMobil Chemical Co.
P. Brett	Honeywell Inc.
J. Campbell	Consultant
M. Coppler	Det Norske Veritas Certification Inc
B. Dumortier	Schneider Electric
D. Dunn	Aramco Services Co.
J. Federlein	Federlein & Assoc. Inc.
J. Gilsinn	NIST/EL
E. Icaan	ACES Inc.
J. Jamison	EnCana Corporation Ltd.
K. P. Lindner	Endress + Hauser Process Solutions AG
V. Maggioli	Feltronics Corp.
V. Mezzano	Fluor Corporation
T. McAviney	Instrumentation and Control Engineering, LLC
C. Monchinski	Automated Control Concepts Inc.,
R. Reimer	Rockwell Automation
S. Russell	Valero Energy Corp.
N. Sands	DuPont
H. Sasajima	Azbil Corp.
T. Schnaare	Rosemount Inc.
J. Tatera	Tatera & Associates Inc.
I. Verhappen	Yokogawa Canada Inc.
W. Weidman	WCW Consulting
J. Weiss	Applied Control Solutions LLC
M. Wilkins	Yokogawa IA Global Marketing (USMK)
D. Zetterberg	Chevron Energy Technology Co.

Contents

1 Scope	9
2 Purpose.....	9
3 General requirements.....	9
4 Unpacking.....	10
5 Storage.....	10
6 User record keeping	10
7 Maintenance	11
8 Preparing instruments for use.....	11
9 Installation of stationary instruments.....	11
9.1 Installation in hazardous (classified) locations.....	12
9.2 Detector head locations	12
10 Equipment checkout procedures	13
10.1 Portable instruments	13
10.2 Stationary instruments	14
11 General considerations	15
11.1 General	15
11.2 Atypical mixtures	16
11.3 Desensitizing agents	16
11.4 Entering atmospheres potentially containing carbon monoxide.....	16
11.5 Use of appropriate accessories.....	17
11.6 Electromagnetic interference (EMI).....	17
11.7 Maintenance schedule	17
12 Operational checks.....	18
13 Maintenance procedures.....	19
13.1 General	19
13.2 Preliminary checkout.....	19
13.3 Detector head	20
13.4 Flow system.....	20
13.5 Readout devices	21
13.6 Alarms.....	21
13.7 Calibration test.....	21
14 External power supply systems	22
14.1 General	22
14.2 AC supplies.....	23
14.3 DC supplies	23

Annex A— Environmental and application checklist for carbon monoxide



Documents

Document Sharing Hub

detectors (typical)	25
Annex B— Instrument maintenance record for carbon monoxide detectors (typical)	27
Annex C: Reference publications.....	29

1 Scope

1.1 This recommended practice applies to all carbon monoxide gas detection instruments that satisfy the performance requirements in ISA-S92.02.01, Part I.

1.2 Reference Clause 3 of ISA-S92.02.01, Part I, for definitions of terms as used herein.

1.3 References useful in the installation, operation, and maintenance of carbon monoxide gas detection instruments are listed in Annex C. These references are not considered to be part of this document, except for those specific sections of documents referenced elsewhere in this recommended practice.

2 Purpose

ISA-RP92.02.02, Part II establishes user criteria for the installation, operation, and maintenance of carbon monoxide gas detection instruments.

Its companion standard, ISA-S92.02.01, Part I, "Performance Requirements for Carbon Monoxide Detection Instruments," has been prepared to provide minimum requirements for the performance of carbon monoxide gas detection instruments.

3 General requirements

3.1 To assure that the instrument is suitable for the application and is compatible with its operating environment:

- a) the user should provide the potential supplier with detailed information on the conditions that exist in the area(s) in which the instrument is to be used;
- b) the instrument must meet the requirements of the applicable regulating agency having jurisdiction; and
- c) the instrument must be compatible with the environmental conditions; e.g., relative humidity, temperature, atmospheric contaminants, etc., in which the instrument is to operate. A typical "Environmental and Application Checklist" is included as Annex A and is intended to aid users in properly specifying requirements for their specific applications.

4 Unpacking

4.1 Unpack the shipping carton(s) and determine whether the order is complete "as received." Check for main assembly, accessories, spare parts, and instruction manual. Understanding the manufacturer's instruction manual is of vital importance to the future operation and maintenance of the carbon monoxide gas detection instrument.

4.2 In the event of shipment damage, or for purposes of future correspondence, record the following:

- a) user's purchase order number and manufacturer's order number, and their respective dates;
- b) carrier waybill number and date received in case of transit claim; and
- c) instrument serial number and user identification (ID) number, if assigned.

5 Storage

5.1 When storing carbon monoxide gas detection instruments, leave them in their original containers or provide suitable protective covers.

5.2 Select a location that is in accordance with the manufacturer's recommendations. Store carbon monoxide gas detection instruments where environmental conditions (temperature, humidity, etc.) are within the manufacturer's storage specifications.

5.3 Before storage, inspect the instruments and remove any internal batteries that could cause corrosion. If the instruments have rechargeable or "permanent" batteries, consult the manufacturer's instructions for battery maintenance during this period.

5.4 Prepare gas detection instruments for long-term storage per manufacturer's Instruction Manual.

6 User record keeping

It is recommended that the user:

- a) assign an equipment identification (control) number to each instrument; and

- b) maintain complete records including periodic performance, calibration, and maintenance checks (see Annex B).

7 Maintenance

7.1 To maintain the reliability of carbon monoxide gas detection instruments, it is recommended that the user assign responsibility for their initial inspection and subsequent use, including maintenance, to a specific qualified individual or group.

7.2 It is important that the Checkout Procedures (see Clause 10) be performed by qualified personnel trained in the operation, maintenance, and repair of carbon monoxide gas detection instruments, and that the group responsible for maintenance be defined clearly.

7.3 The user should establish responsibility for obtaining the gas mixture recommended by the instrument manufacturer for calibrating and testing.

7.4 It is recommended that when instruments are first put into use, the calibration be checked on a routine basis as prescribed by the manufacturer, but at least monthly. If experience shows minimal calibration deviation, then the period between calibration checks may be extended. Likewise, if routine checks indicate an increasing need for calibration, the period should be shortened and the cause should be investigated and the manufacturer consulted.

8 Preparing instruments for use

Read and understand the manufacturer-provided instruction manual. Particular attention should be paid to the locations and functions of all controls and readout devices.

A calibration test of the type described in 13.7 is recommended before the initial use of any carbon monoxide gas detection instrument.

9 Installation of stationary instruments

It is extremely important that the equipment manufacturer-provided instruction manual be read thoroughly and followed completely.