RECOMMENDED PRACTICE

ISA–RP92.04.02, Part II–1996 (R2013)

Installation, Operation, and Maintenance of Instruments Used to Detect Oxygen-Deficient/ Oxygen-Enriched Atmospheres

Reaffirmed 16 January 2013

Documents
Document Sharing Hub

Copyright International Society of Automation

Full document details: ISA RP92.04.02 Part 2-1996 (2013)

ISA–RP92.04.02, Part II–1996 (R2013), Installation, Operation, and Maintenance of Instruments Used To Detect Oxygen-Deficient/Oxygen-Enriched Atmospheres

ISBN: 978-1-937560-94-2

Copyright © 2013 by the International Society of Automation. All rights reserved. Printed in the United States of America. No part of this publication may be reproduced, stored in a retrieval system, or transmitted, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the prior written permission of the Publisher.

ISA
67 Alexander Drive
P.O. Box 12277
Research Triangle Park, North Carolina 27709

Documents
Document Sharing Hub

Copyright International Society of Automation

Full document details: ISA RP92.04.02 Part 2-1996 (2013)

Preface

This preface, all footnotes, and annexes are included for informational purposes and are not a part of ISA-RP92.04.02, Part II-1996 (R2013).

This recommended practice has been prepared as a part of the service of ISA toward a goal of uniformity in the field of instrumentation. To be of real value, this document should not be static but should be subject to periodic review. Toward this end, the Society welcomes all comments and criticisms and asks that they be addressed to the Standards and Practices Board Secretary; ISA; 67 Alexander Drive; P. O. Box 12277; Research Triangle Park, NC 27709; Telephone (919) 549-8411; Fax (919) 549-8288; Internet: standards@isa.org.

The ISA Standards and Practices Department is aware of the growing need for attention to the metric system of units in general, and the International System of Units (SI) in particular, in the preparation of instrumentation standards. The Department is further aware of the benefits to USA users of ISA standards of incorporating suitable references to the SI (and the metric system) in their business and professional dealings with other countries. Toward this end, this Department will endeavour to introduce SI-acceptable metric units in all new and revised standards, recommended practices, and technical reports to the greatest extent possible. IEEE/ASTM SI 10, *American National Standard for Metric Practice*, and future revisions, will be the reference guide for definitions, symbols, abbreviations, and conversion factors.

It is the policy of ISA to encourage and welcome the participation of all concerned individuals and interests in the development of ISA standards, recommended practices, and technical reports.

Participation in the ISA standards-making process by an individual in no way constitutes endorsement by the employer of that individual, of ISA, or of any of the standards that ISA develops.

CAUTION — ISA DOES NOT TAKE ANY POSITION WITH RESPECT TO THE EXISTENCE OR VALIDITY OF ANY PATENT RIGHTS ASSERTED IN CONNECTION WITH THIS DOCUMENT, AND ISA DISCLAIMS LIABILITY FOR THE INFRINGEMENT OF ANY PATENT RESULTING FROM THE USE OF THIS DOCUMENT. USERS ARE ADVISED THAT DETERMINATION OF THE VALIDITY OF ANY PATENT RIGHTS, AND THE RISK OF INFRINGEMENT OF SUCH RIGHTS, IS ENTIRELY THEIR OWN RESPONSIBILITY.

PURSUANT TO ISA'S PATENT POLICY, ONE OR MORE PATENT HOLDERS OR PATENT APPLICANTS MAY HAVE DISCLOSED PATENTS THAT COULD BE INFRINGED BY USE OF THIS DOCUMENT AND EXECUTED A LETTER OF ASSURANCE COMMITTING TO THE GRANTING OF A LICENSE ON A WORLDWIDE, NON-DISCRIMINATORY BASIS, WITH A FAIR AND REASONABLE ROYALTY RATE AND FAIR AND REASONABLE TERMS AND CONDITIONS. FOR MORE INFORMATION ON SUCH DISCLOSURES AND LETTERS OF ASSURANCE, CONTACT ISA OR VISIT WWW.ISA.ORG/STANDARDSPATENTS.

OTHER PATENTS OR PATENT CLAIMS MAY EXIST FOR WHICH A DISCLOSURE OR LETTER OF ASSURANCE HAS NOT BEEN RECEIVED. ISA IS NOT RESPONSIBLE FOR IDENTIFYING PATENTS OR PATENT APPLICATIONS FOR WHICH A LICENSE MAY BE REQUIRED, FOR CONDUCTING INQUIRIES INTO THE LEGAL VALIDITY OR SCOPE OF PATENTS, OR DETERMINING WHETHER ANY LICENSING TERMS OR CONDITIONS PROVIDED IN CONNECTION WITH SUBMISSION OF A LETTER OF ASSURANCE, IF ANY, OR IN ANY LICENSING AGREEMENTS ARE REASONABLE OR NON-DISCRIMINATORY.

ISA REQUESTS THAT ANYONE REVIEWING THIS DOCUMENT WHO IS AWARE OF ANY PATENTS THAT MAY IMPACT IMPLEMENTATION OF THE DOCUMENT NOTIFY THE ISA STANDARDS AND PRACTICES DEPARTMENT OF THE PATENT AND ITS OWNER.

Documents
Document Sharing Hub
Copyright International Society of Automation
Full document details: ISA RP92.04.02 Part 2-1996 (2013)

ADDITIONALLY, THE USE OF THIS DOCUMENT MAY INVOLVE HAZARDOUS MATERIALS, OPERATIONS OR EQUIPMENT. THE DOCUMENT CANNOT ANTICIPATE ALL POSSIBLE APPLICATIONS OR ADDRESS ALL POSSIBLE SAFETY ISSUES ASSOCIATED WITH USE IN HAZARDOUS CONDITIONS. THE USER OF THIS DOCUMENT MUST EXERCISE SOUND PROFESSIONAL JUDGMENT CONCERNING ITS USE AND APPLICABILITY UNDER THE USER'S PARTICULAR CIRCUMSTANCES. THE USER MUST ALSO CONSIDER THE APPLICABILITY OF ANY GOVERNMENTAL REGULATORY LIMITATIONS AND ESTABLISHED SAFETY AND HEALTH PRACTICES BEFORE IMPLEMENTING THIS DOCUMENT.

THE USER OF THIS DOCUMENT SHOULD BE AWARE THAT THIS DOCUMENT MAY BE IMPACTED BY ELECTRONIC SECURITY ISSUES. THE COMMITTEE HAS NOT YET ADDRESSED THE POTENTIAL ISSUES IN THIS VERSION.

The following members of ISA Subcommittee SP92.04 developed this Recommended Practice:

NAME	COMPANY
R. Novack, Chairperson	AMETEK
D. Bishop, Managing Director	Chevron USA Production Company
*W. Alexander	Mine Safety Appliances Company
S. Bruce	Delphian Corporation
J. Chang	Motorola SPS
J. Chilton	U.S. Bureau of Mines
M. Coppler	Bacharach, Inc.
T. Donkin	Enmet Corporation
A. Gimbrone	Gantech Association
A. Gottlieb	Random Technologies
A. Guerrera	Control Systematolotists, Inc.
S. Hildebrand	Exxon Company USA
B. Holcom	Gas Tech, Inc.
K. Johnson	KWJ Engineering, Inc.
D. Li	Canadian Standards Association
*R. Loeffelholz	National Draeger, Inc.
*S. Long	Mine Safety Appliances Company
T. Loomis	Consultant
B. Matheson	Sensidyne, Inc.
*J. McCann	International Sensor Technology
*J. McGowan	International Sensor Technology
A. McNiel	Consultant
B. Northam	Munro Electronics
*H. Oetjen	National Draeger, Inc.
R. Ring Mine	Safety Appliances Company
M. Schaeffer	Control Instruments Corporation
*K. Shaffer	National Draeger, Inc.
R. Smith	Illinois Instruments, Inc.
J. Thomason	Omni Industrial Systems, Inc.
R. Warburton	National Draeger, Inc.
D. Wolsk	Wolsk Alarms, Ltd.
J. Zabrenski	Air Products & Chemicals, Inc.

*One vote per company

Documents
Document Sharing Hub
Copyright International Society of Automation
Full document details: ISA RP92.04.02 Part 2-1996 (2013)

The following members of ISA Committee SP92 developed this Recommended Practice:

NAME	COMPANY
J. Thomason, Chairperson	Omni Industrial Systems, Incl
D. Bishop, Managing Director	Chevron USA Production Company
*W. Alexander	Mine Safety Appliances Company
J. Chang	Motorola SPS
M. Coppler	Bacharach, Inc.
S. Hildebrand	Exxon Company USA
B. Holcom	Gas Tech, Inc.
K. Johnson	KWJ Engineering, Inc.
D. Li	Canadian Standards Association
F. McGowan	Factory Mutual Research Corporation
B. Northam	Munro Electronics
R. Novack	AMETEK
*R. Ring	Mine Safety Appliances Company
M. Schaeffer	Control Instruments Corporation
M. Stryker	NCASI
R. Warburton	National Draeger, Inc.

*One vote per company

This Recommended Practice was approved for publication by the ISA Standards and Practices Board on May 15, 1996.

NAME	COMPANY
M. Widmeyer, Vice President	Washington Public Power Supply System
H. Baumann	H. D. Baumann & Associates, Ltd.
D. Bishop	Chevron USA Production Company
P. Brett	Honeywell, Inc.
W. Calder III	Factory Mutual Research Corporation
H. Dammeyer	Phoenix Industries, Inc.
R. Dieck	Pratt & Whitney
W. Holland	Southern Company Services, Inc.
H. Hopkins	Utility Products of Arizona
A. Iverson	Lyondell Petrochemical Company
K. Lindner	Endress + Hauser GmbH + Company
T. McAvinew	Metro Wastewater Reclamation District
A. McCauley, Jr.	Chagrin Valley Controls, Inc.
G. McFarland	Honeywell Industrial Automation & Controls
J. Mock	Consultant
E. Montgomery	Fluor Daniel, Inc.
D. Rapley	Rapley Engineering Services
R. Reimer	Rockwell Automation A-B
J. Rennie	Factory Mutual Research Corporation
R. Webb	Pacific Gas & Electric Company
W. Weidman	Consultant
J. Weiss	Electric Power Research Institute
J. Whetstone	National Institute of Standards &Technology
H. Wiegle	Canus Corporation
C. Williams	Eastman Kodak Company
G. Wood	Graeme Wood Consulting
M. Zielinski	Fisher-Rosemount

Documents
Document Sharing Hub
Copyright International Society of Automation
Full document details: ISA RP92.04.02 Part 2-1996 (2013)

The following members of ISA92 reaffirmed this document.

NAME	COMPANY
J. Miller, Chairman	Detector Electronics Corporation
R. Seitz, Vice Chairman	Artech Engineering
M. Coppler, Managing Director	Det Norske Veritas Certification Inc.
S. Baliga	General Monitors
W. Bennett	Mine Safety Appliances Co.
T. Crawford	Intertek Testing Services
G. Garcha	GE Energy
R. Goins	Lyondell Basell
K. Hedrick	MSHA Approval & Certification Center
S. Henney	FM Approvals
C. Lucarino	Sensient
R. Masi	Detcon Inc.
D. Mills	Underwriters Laboratories Inc.
L. Owen	Dooley Tackaberry Inc.
A. Skinner	GMI Gas Measurement Instruments LLC
J. Stratman	Honeywell Analytics Inc.
J. Thomason	Omni Industrial Systems Inc.
A. Vial	Shell Exploration & Production Co.
D. Wechsler	American Chemistry Council

This recommended practice was approved by the Standards and Practices Board on 16 January 2013.

NAME	COMPANY
E. Cosman, Vice President	The Dow Chemical Company
D. Bartusiak	ExxonMobil Chemical Co.
P. Brett	Honeywell Inc.
J. Campbell	Consultant
M. Coppler	Det Norske Veritas Certification Inc.
B. Dumortier	Schneider Electric
D. Dunn	Aramco Services Co.
J. Federlein	Federlein & Assoc. Inc.
J. Gilsinn	NIST/EL
E. Icayan	ACES Inc.
J. Jamison	EnCana Corporation Ltd.
K. P. Lindner	Endress + Hauser Process Solutions AG
V. Maggioli	Feltronics Corp.
V. Mezzano	Fluor Corporation
T. McAvinew	Instrumentation and Control Engineering, LLC
C. Monchinski	Automated Control Concepts Inc.
R. Reimer	Rockwell Automation
S. Russell	Valero Energy Corp.
N. Sands	DuPont
H. Sasajima	Azbil Corp.
T. Schnaare	Rosemount Inc.
J. Tatera	Tatera & Associates Inc.
I. Verhappen	Yokogawa Canada Inc.
W. Weidman	WCW Consulting
J. Weiss	Applied Control Solutions LLC
M. Wilkins	Yokogawa IA Global Marketing (USMK)
D. Zetterberg	Chevron Energy Technology Co.

AVA Documents Document Sharing Hub
Copyright International Society of Automation
Full document details: ISA RP92.04.02 Part 2-1996 (2013)

Contents

1 Scope 9

2 Purpose 9

3 General requirements 9

4 Unpacking 10

5 Storage 10

6 User record keeping 10

7 Maintenance 11

8 Preparing instruments for use 11

9 Installation of stationary instruments 11

9.1 Installation in hazardous (classified) locations 11

9.2 Detector locations 12

10 Equipment checkout procedures 13

10.1 Portable instruments 13

10.2 Stationary instruments 14

11 General considerations 15

11.1 Precautions 15

11.2 Desensitizing agents 16

11.3 Entering atmospheres of potentially depleted/enriched oxygen 16

11.4 Use of appropriate accessories 16

11.5 Electromagnetic interference (EMI) 17

11.6 Maintenance schedule 17

12 Operational check 17

13 Maintenance procedures 18

13.1 General 18

13.2 Preliminary checkout 19

13.3 Detector head 20

13.4 Flow system 20

13.5 Readout devices 20

13.6 Alarms 21

13.7 Shop calibration test 21

14 External power supply systems 22

14.1 General 22

14.2 AC supplies 22

14.3 DC supplies 22

Documents
Document Sharing Hub

Copyright International Society of Automation

Full document details: ISA RP92.04.02 Part 2-1996 (2013)

Annex A — Environmental and application checklist for oxygen-deficient/ oxygen-enriched (typical) 25

Annex B — Instrument maintenance record for oxygen-deficient/ oxygen-enriched detectors (typical) 27

Annex C — References 29

Documents
Document Sharing Hub

Copyright International Society of Automation

Full document details: ISA RP92.04.02 Part 2-1996 (2013)

1 Scope

1.1 ISA-RP92.04.02, Part II, applies to all oxygen detection instruments that satisfy the performance requirements in ANSI/ISA-S92.04.01, Part I, *Performance Requirement for Instruments Used to Detect Oxygen-Deficient/Oxygen-Enriched Atmospheres*.

1.2 Definitions of terms, as used herein, are referenced in Clause 3 of ANSI/ISA-S92.04.01, Part I.

1.3 References useful in the installation, operation, and maintenance of oxygen detection instruments are listed in Annex C. These references are not considered to be part of this document, except for those specific clauses of documents referenced elsewhere in this Recommended Practice.

2 Purpose

This Recommended Practice establishes user criteria for the installation, operation, and maintenance of instruments used to detect oxygen-deficient/oxygen-enriched atmospheres.

Its companion Standard, ANSI/ISA-S92.04.01, Part I, provides minimum requirements for the performance of instruments used to detect oxygen-deficient/oxygen-enriched atmospheres.

3 General requirements

3.1 The following general requirements are intended to ensure that the instrument is suitable for the intended application and is compatible with its operating environment:

a) The user should provide the potential supplier with detailed information on the conditions that exist in the area(s) in which the instrument is to be used;

b) The instrument must meet the requirements of the applicable authority having jurisdiction; and

c) The instrument must be compatible with the environmental conditions; e.g., relative humidity, temperature, altitude, and atmospheric contaminants, etc. in which the instrument is to operate. A typical "Environmental and Application Checklist," included as Annex A, is intended to aid users in properly specifying requirements for their specific applications.

Copyright International Society of Automation

Documents
Document Sharing Hub

Full document details: ISA RP92.04.02 Part 2-1996 (2013)

4 Unpacking

4.1 Unpack the shipping carton(s) and determine whether the order is complete "as received." Check for main assembly, accessories, spare parts, and instruction manual.

4.2 In the event of shipment damage or for purposes of future correspondence, record the following:

a) User's purchase order number and manufacturer's order number and their respective dates

b) Carrier waybill number and date received in case of transit claim

c) Instrument serial number and user identification (ID) number, if assigned

5 Storage

5.1 When storing oxygen detection instruments, leave the instruments in their original containers or provide suitable protective covers.

5.2 Select a storage location that is in accordance with the manufacturer's recommendations. The environmental conditions (temperature, humidity, etc.) should comply with the manufacturer's storage specifications.

5.3 Before storage, inspect the instruments and remove any internal batteries and sensors that could cause corrosion, as directed by the manufacturer's instructions. If the instruments have rechargeable or "permanent" batteries, consult the manufacturer's instructions for battery maintenance during this period.

6 User record keeping

6.1 It is recommended that users

a) assign an equipment identification (control) number to each instrument; and

b) maintain complete records including periodic performance, calibration, and maintenance checks. (See Annex B.)

Documents
Document Sharing Hub

Copyright International Society of Automation

Full document details: ISA RP92.04.02 Part 2-1996 (2013)

7 Maintenance

7.1 To maintain the reliability of oxygen detection instruments, it is recommended that users assign responsibility for their initial inspection and subsequent use, including maintenance, to a specific qualified individual or group.

7.2 It is important that the checkout procedures (see Clause 10) be performed by qualified personnel who are trained in the operation, maintenance, and repair of instruments, and that the group responsible for maintenance be defined clearly.

7.3 It is recommended that users establish responsibility for obtaining the gas mixture recommended for calibration and testing by the instrument manufacturer.

7.4 It is recommended that when instruments are first put into use, the calibration be checked on a routine basis, as prescribed by the manufacturer. If experience shows minimal calibration deviation, then the period between calibration checks may be extended. Likewise, if routine checks indicate an increasing need for calibration, the period should be shortened and the cause should be investigated.

8 Preparing instruments for use

Read and understand the manufacturer-provided instruction manual. Pay particular attention to the location and functions of all controls and readout devices.

It is recommended that a shop calibration test of the type described in 13.7 be performed before the initial use of any oxygen-detecting instrument.

9 Installation of stationary instruments

It is extremely important that the equipment manufacturer-provided instruction manual be read thoroughly and followed completely.

9.1 Installation in hazardous (classified) locations

If instruments or ancillary components are installed in a hazardous (classified) location, they must be suitable for the area in which they are installed and so marked. Hazardous (classified) locations in the United States are defined by the *National Electrical Code®*, NFPA 70-1993, Articles 500-504. Markings required by ANSI/ISA-S92.04.01, Part I, should be visible to the operator. Installation of intrinsically safe systems shall be in accordance with ANSI/ISA-RP12.6, *Installation of Intrinsically Safe Systems for Hazardous (Classified) Environments*.

NOTE — Oxygen enrichment presents increased ignition risk, especially in a hazardous

AVA Documents
Document Sharing Hub

Copyright International Society of Automation
Full document details: ISA RP92.04.02 Part 2-1996 (2013)