



**International
Standard**

ISO 22484

**Displacement and dynamic
compressors — Performance
test code for electric driven low-
pressure air compressor packages**

*Compresseurs volumétriques et turbocompresseurs — Code
d'essai de performance des ensembles de compresseurs à air
basse pression à entraînement électrique*

**First edition
2024-11**

Reference number
ISO 22484:2024(en)

Full document details: [ISO 22484-2024](#)

© ISO 2024  **Documents**
Document Sharing Hub



COPYRIGHT PROTECTED DOCUMENT

© ISO 2024

All rights reserved. Unless otherwise specified, or required in the context of its implementation, no part of this publication may be reproduced or utilized otherwise in any form or by any means, electronic or mechanical, including photocopying, or posting on the internet or an intranet, without prior written permission. Permission can be requested from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
CP 401 • Ch. de Blandonnet 8
CH-1214 Vernier, Geneva
Phone: +41 22 749 01 11
Email: copyright@iso.org
Website: www.iso.org

Published in Switzerland

Contents

Page

Foreword	v
Introduction	vi
1 Scope	1
2 Normative references	1
3 Terms and definitions	1
4 Units	6
5 Guarantee and measurement	8
5.1 Packaged compressor	8
5.2 Preconditions of the guarantee	8
5.3 Object of the guarantee	9
5.4 Low-pressure compressor to be tested	9
5.5 Low-pressure compressor specifications to be provided prior to testing	10
6 Measuring equipment, methods and accuracy	10
6.1 General	10
6.2 Measurement of pressure	10
6.2.1 General	10
6.2.2 Atmospheric pressure	11
6.2.3 Pressure measurement for ambient inlet	11
6.2.4 Pressure measurement for piped inlet	11
6.2.5 Pressure measurement for piped discharge	11
6.3 Measurement of temperature	11
6.3.1 General	11
6.3.2 Temperature measurement for ambient inlet	12
6.3.3 Temperature measurement for piped inlet	12
6.3.4 Temperature measurement for piped discharge	12
6.4 Measurement of humidity	12
6.5 Measurement of rotational frequency	12
6.6 Measurement of flow rate	12
6.7 Measurement of external coolant flow rate	12
6.8 Measurement of power and energy	12
6.8.1 General	12
6.9 Calibration of instruments	13
7 Test	13
7.1 General test process	13
7.2 Allowed deviation of rotational speed between test and guarantee	14
7.3 Allowed deviation of ambient conditions	15
7.3.1 Testing against general performance data	15
7.3.2 Testing against customer specified data sheets	15
7.4 Allowed deviation of preconditions	15
7.5 Allowed deviation of machine Mach number	15
7.6 Selection of test flow	16
7.6.1 Selection of flow setting	16
7.7 Selection of test pressure	16
7.7.1 Note: The following terms are required for R_{te} and K_{te} with formulae and source.	16
7.7.2 For positive displacement low-pressure compressors with or without internal compression	16
7.7.3 For dynamic low-pressure compressors	17
7.8 Allowed deviation of flow and work coefficient	17
7.8.1 Allowed deviations to be checked for test validity	17
7.9 Fluctuations on the specific test readings/results during test at steady state	17
7.10 Two-speed test	18
7.10.1 General	18

7.10.2	First test.....	18
7.10.3	Second test.....	18
8	Correction of test results	19
8.1	General.....	19
8.2	Correction of measured flow (variable speed packaged compressors, only)	19
8.3	Correction of measured pressure.....	19
8.3.1	For dynamic low-pressure packaged compressors.....	19
8.3.2	For positive displacement low-pressure packaged compressors.....	20
8.3.3	For positive displacement and dynamic low-pressure packaged compressors.....	20
8.4	Correction of specific energy demand.....	20
8.5	Corrected packaged compressor power consumption.....	21
8.6	Power correction of the two-speed test.....	21
8.7	Calculated package isentropic efficiency.....	21
8.8	Comparison of corrected values with guaranteed values	22
8.9	Examples of calculations	22
9	Test report.....	23
9.1	Test report content	23
9.2	Test results summary.....	23
Annex A (normative) Equipment checklist.....		24
Annex B (informative) Test result summary		25
Annex C (informative) Examples of acceptance test reports/calculations		26
Annex D (informative) Background of thermodynamics.....		50
Bibliography.....		57

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO document should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

ISO draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). ISO takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, ISO had not received notice of (a) patent(s) which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at www.iso.org/patents. ISO shall not be held responsible for identifying any or all such patent rights.

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 118, *Compressors and pneumatic tools, machines and equipment*, Subcommittee SC 6 *Air compressors and compressed air systems*.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

This document was developed in response to a recognized need to provide a methodology to correct performance of a low-pressure air compressor to guarantee conditions for positive displacement and dynamic compression types.

In dynamic compression, air is drawn between the blades on a rapid rotating compression impeller¹⁾ and accelerates to high velocity. The gas is then discharged through a diffuser, where the kinetic energy is transformed into static pressure. Dynamic low-pressure compressors are of a radial flow design, with the following typical examples:

- single-stage centrifugal (aka high speed “turbo”) compressors;
- multi-stage centrifugal compressors without intercooling.

Positive displacement low-pressure compressors work on the principle of trapping a volume of air and reducing its volume, internally or externally. Two basic types are typical, as follows:

- Rotary screw positive displacement compressor where air is drawn into a compression chamber formed by intermeshing rotors¹. As the rotors turn, the cavity between the rotors becomes smaller, reducing the volume of the trapped air and increasing its pressure;
- Rotary lobe positive displacement compressor where air is drawn into the case and is trapped between the rotor and the case wall. These air pockets are progressively moved to the discharge port. At the discharge port, a back flow of air into the pocket from the higher-pressure discharge line produces a constant volume pressure rise.

Existing standards (e.g. ISO 1217, ISO 5389, ISO 18740) for positive displacement compressors and dynamic compressors, do not provide clear and concise means of comparing different technologies.

This document provides simplified wire to air performance test methods that measure true performance of low-pressure air compressor packages.

1) In this document the terms “rotor” and “impeller” are used to describe the rotating element(s) which cause(s) compression, and can be considered to be interchangeable.

Displacement and dynamic compressors — Performance test code for electric driven low-pressure air compressor packages

1 Scope

This document specifies the performance test method of electrically driven low-pressure air compressor packages, where the compression is performed by positive displacement or dynamic compression; utilising atmospheric air as the compression gas. Low-pressure air compressor packages are often referred to as “blowers”.

NOTE Throughout this document, the term ‘low-pressure compressor’ is used to describe a low-pressure air compressor (“blower”) package

Low-pressure compressors with and without means of controlling flow (control may be electrical (e.g. with a variable frequency drive) or mechanical or both) are covered.

This document applies to low-pressure compressors meeting all the following limits:

- Atmospheric inlet air pressure between 0,5 bar and 1,1 bar.
- Discharge vs inlet pressure differential between 0,1 bar and 2,5 bar.
- Discharge vs inlet pressure ratio between 1,1 and 3,5.

This document is not applicable to:

- positive displacement low-pressure compressors with a liquid in the compression element (such as liquid ring pumps and liquid injected low-pressure compressor of screw type)
- multi-stage low-pressure compressors other than multistage centrifugal compressors comprised of multiple, identical or very similar uncooled sections along a single shaft (repeating stages).
- single shaft, multistage centrifugal compressors are treated from the point of measurement and calculation as a single stage

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements*

ISO 9300, *Measurement of gas flow by means of critical flow nozzles*

ISO 17089-1, *Measurement of fluid flow in closed conduits — Ultrasonic meters for gas — Part 1: Meters for custody transfer and allocation measurement*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1

acceptance test

performance test carried out in accordance with this document

Note 1 to entry: See [Annex C](#) for an example of acceptance test report.

3.2

displacement compressor

packaged compressor where a static pressure rise is obtained by allowing successive volumes of gas to be aspirated into and exhausted out of a closed space by means of the displacement of a moving member

[SOURCE: ISO 5390:1977, 3.1]

3.3

dynamic compressor

packaged compressor in which the fluid pressure increase is obtained by transformation of kinetic energy into potential energy with continuous flow from intake point to discharge point

[SOURCE: ISO 5390:1977, 3.2]

3.4

external coolant

medium externally supplied to the compressor to which the generated heat is finally rejected

Note 1 to entry: This is usually ambient air or cooling water

[SOURCE: ISO 1217:2009, 3.1.7]

3.5

packaged compressor

compressor with prime mover, transmission, fully piped and wired internally, including ancillary and auxiliary items of equipment where these are within the scope of supply

[SOURCE: ISO 1217:2009, 3.1.13]

3.6

isentropic compression

idealized (i.e. reversible) adiabatic thermodynamic compression process that occurs without transfer of heat into or out of a system

3.7

rotational speed

number of revolutions of the compressor drive shaft per unit of time

[SOURCE: ISO 1217:2009, 3.1.18]

3.8

process air inlet point

point upstream of any technically required component

Note 1 to entry: In the case in which a technically required component is not physically present during the test the impact of the component on performance shall be accounted for

3.9

process air discharge point

point downstream of any technically required component

Note 1 to entry: In the case in which a technically required component is not physically present during the test the impact of the component on performance shall be accounted for

3.10

guarantee conditions

site conditions for which the equipment is expected to perform. Typically, this will include atmospheric pressure and ambient temperature

3.11

absolute pressure

pressure with reference to absolute zero, i.e. with reference to an absolute vacuum

Note 1 to entry: It equals the algebraic sum of atmospheric pressure and gauge pressure (static pressure or total pressure).

[SOURCE: ISO 3857-1:1977, 1.3, modified — The second sentence was moved as a note.]

3.12

ambient pressure

absolute pressure ([3.11](#)) of the atmospheric air measured in the vicinity of the compressor

[SOURCE: ISO 1217:2009, 3.2.2]

3.13

atmospheric pressure

absolute pressure ([3.11](#)) of the atmospheric air measured at the test place

[SOURCE: ISO 1217:2009, 3.2.3]

3.14

discharge pressure

total mean *absolute pressure* ([3.11](#)) at the *process air discharge point* ([3.9](#))

3.15

inlet pressure

total mean *absolute pressure* ([3.11](#)) at the standard *process air inlet point* ([3.8](#))

3.16

total pressure

pressure measured at the stagnation point when a gas stream is brought to rest and its kinetic energy is converted by an *isentropic compression* ([3.6](#)) from the flow condition to the stagnation condition

[SOURCE: ISO 1217:2009, 3.2.9]

3.17

ambient temperature

total temperature ([3.20](#)) of the atmospheric air in the vicinity of the compressor, but unaffected by it

[SOURCE: ISO 1217:2009, 3.3.1]

3.18

discharge temperature

total temperature ([3.20](#)) at the *process air discharge point* ([3.9](#))

3.19

inlet temperature

total temperature ([3.21](#)) at the standard *process air inlet point* ([3.8](#))

3.20**total temperature**

temperature that would be measured at the stagnation point if a gas stream were brought to rest and its kinetic energy converted by an *isentropic compression* (3.6) from the flow condition to the stagnation condition

[SOURCE: ISO 1217:2009, 3.3.4]

3.21**relative humidity**

ratio, in humid air, expressed as a percentage, of the water vapour actual pressure to the saturated vapour pressure at the same dry bulb temperature

$$\varphi = \frac{p}{p_{\text{sat}}}$$

where p is partial pressure (ISO 80000-4:2019, item 4-14.1) of vapour and p_{sat} is its partial pressure at saturation (at the same temperature)

[SOURCE: ISO 80000-5:2019, 5-33]

3.22**isentropic exponent**

ratio of the specific heat at constant pressure to the specific heat at constant volume

3.23**actual volume flow rate**

volume flow rate of air, compressed and delivered at the standard discharge point, referred to conditions of *total temperature* (3.20), total pressure and composition prevailing at the standard inlet point

3.24**isentropic power**

power that is theoretically required to compress an ideal gas under constant entropy, from given inlet conditions to a given *discharge pressure* (3.14)

Note 1 to entry: The term “ideal gas” is used to indicate any gas in a condition or state so that it follows closely the ideal gas law

[SOURCE: ISO 1217:2009/Amd.1:2016, 3.5.1]

3.25**isentropic efficiency**

ratio of the required *isentropic power* (3.24) to measured power for the same specified boundaries with the same gas and the same inlet conditions and *discharge pressure* (3.14)

$$\eta_{\text{isen}} = \frac{P_{\text{isen}}}{P_{\text{real}}}$$

[SOURCE: ISO 1217:2009/Amd.1:2016, 3.6.1]

3.26**power input**

sum of the electrical power inputs to the prime mover and any ancillaries and auxiliaries driven from the compressor shaft or by a separate prime mover at rated supply conditions, including the effect of all equipment included in the *packaged compressor* (3.5)

Note 1 to entry: Auxiliaries include oil pump, cooling fan and integral compressed air dryer

Note 2 to entry: Rated supply conditions refer to phase, voltage, frequency and ampere capability

[SOURCE: ISO 1217:2009, 3.5.3]

3.27

specific energy requirement

<of a packaged compressor> *power input* (3.26) per unit of compressor actual volume flow rate

[SOURCE: ISO 1217:2009, 3.7.2]

3.28

specific isentropic compression work

work expressed as energy per unit mass of air during *isentropic compression* (3.6)

3.29

specific isochoric compression work

work expressed as energy per unit mass of air during isochoric compression

3.30

specific combined compression work

sum of the *specific isentropic compression work* (3.28) and *specific isochoric compression work* (3.29), weighted by the internal volume ratio

3.31

internal volume ratio

ratio of the enclosed volume at moment of closure of the inlet port to the enclosed volume at the moment of opening of the discharge port for a positive *displacement compressor* (3.2)

3.32

rotor tip speed

peripheral speed at the largest rotor/impeller tip diameter

3.33

machine Mach number

ratio of the rotor tip speed to the speed of sound of the fluid inlet state at inlet conditions

3.34

accounted for value

means (measured/estimated/calculated/corrected) – a simulated or calculated substitute characteristic of components not available for the test, for example; the pressure drop of a remote air filter

3.35

idle power consumption

total consumed power when the *packaged compressor* (3.5) is not producing flow to the discharge but is rotating at significant speed. i.e. for *packaged compressor* (3.5) equipped with idling functionality

3.36

standby power consumption

power required to keep the *packaged compressor* (3.5) ready for immediate start from non-rotating state

3.37

flow coefficient

flow velocity formed from the inlet volume flow and an impeller cross-section area and rendered dimensionless by the tip speed of the impeller

3.38

work coefficient

specific compression work of the reference process rendered dimensionless by the kinetic energy of tip speed

3.39

reduced speed

alternate test speed used to achieve ratio of Mach number for contract to test equal to one

3.40**two speed test**

combination of one test to determine the thermodynamic performance and one test to determine the electromechanical performance

3.41**package motor**

item(s) that is a part of the *packaged compressor* (3.5) including any additional drive train components

3.42**test motor**

item(s) that replaces the *package motor* (3.41) for testing

3.43**shaft power**

mechanical input power at the rotor/impeller

3.44**electromechanical**

part of the total losses, total power consumption or total efficiency, that is not the result of the compression work on the gas

Note 1 to entry: This shall include the impact on said values from motor(s), control(s), gear(s), bearing(s), seal(s) and all auxiliaries (e.g. fans and pumps), whether said components are mounted on or related to the driver(s), compression element(s) or part of the package.

4 Units

General use of SI units (see ISO 80000-1) as given throughout this document is recommended, see [Table 1](#) and [Table 2](#). However, in agreement with accepted practice in the pneumatic industry sector, some non-preferred SI units, accepted by ISO, are also used, see

Table 1 — List of symbols

Symbol	Term	SI unit
c	sonic velocity	m/s
c_p	specific heat capacity	J/(kg·K)
D	the largest rotor/impeller tip diameter	m
e	specific energy	J/m ³
h	specific enthalpy	J/kg
Ma	machine Mach number	—
M	molar mass	kg/mol
m	mass	kg
q_m	mass flow	kg/s
n	rotational speed	1/s
P	power	W
p	pressure	Pa
R	specific gas constant	J/(kg·K)
Re	Reynolds number	—
s	specific entropy	J/(kg·K)
T	thermodynamic temperature	K
t	Celsius temperature	°C
U	supply voltage	V
u	tip speed	m/s

Table 1 (continued)

Symbol	Term	SI unit
v	specific volume	m ³ /kg
v_i	internal volume ratio	—
V	volume	m ³
q_V	volume flow	m ³ /s
X_n	ratio of reduced speeds of rotation	—
x	mass ratio of water vapour to dry gas	kg/kg
y	specific compression work	J/kg
Δ	difference	—
η	efficiency	—
ϑ	ratio of (RZ1 T1) values	—
κ	ratio of specific heat capacities (isentropic exponent)	—
π	pressure ratio	—
ρ	density	kg/m ³
ϕ	ratio of volume flow rate ratios	—
φ	flow coefficient	—
φ_{rel}	relative humidity	—
ψ	work coefficient	—
σ	standard deviation	—

Table 2 — List of subscripts used in this document

Subscript	Term
0	ambient
1	inlet (suction side)
2	discharge (discharge side)
air	dry air
abs	absolute (pressure)
amb	ambient (air, temperature)
co	corrected to guarantee conditions
cog	corrected to the pressure ratio and inlet volume flow of the guarantee point
comb	combined
cool	coolant
d	dynamic
em	electromechanical
dry	dry
g	guarantee conditions or performance data at guarantee conditions
i	internal or intermediate
isoc	isochoric
ideal	according to an ideal thermodynamic process
out	output
pack	Packaged compressor boundary
Pr	reference or standard process
red	reduced speed
ref	reference value
rel	relative

Table 2 (continued)

Subscript	Term
s	isentropic
sat	saturated
st	static
target	target
te	test result
te1	first test in 2-speed testing
te2	second test in 2-speed testing
tol	permissible deviation
tot	total
u	tip or peripheral
vap	vapour, vapor, steam
wet	moist
idle	idle
standby	standby

5 Guarantee and measurement

5.1 Packaged compressor

The packaged compressor shall comprise all components that are necessary for the long-term functioning of the low-pressure compressor under guarantee conditions and are needed to fulfil the object of the guarantee and the preconditions of the guarantee:

- low-pressure compressor with drive system;
- variable frequency drive (as applicable);
- cooling/lubrication system;
- inlet filter;
- inlet valve/guide vanes (as applicable);
- bearing power supply (as applicable);
- fully piped and wired internally;
- including ancillary and auxiliary items of equipment and all power devices that affect power consumption.

5.2 Preconditions of the guarantee

If no preconditions are defined in the contract, the preconditions of the guarantee shall be applied in accordance with [Table 3](#) below.

For testing to be possible, at least the following shall be specified as the preconditions of the guarantee:

- air inlet pressure;
- air inlet temperature;
- air inlet humidity;
- coolant inlet temperature;

- coolant flow;
- supply voltage;
- supply frequency.

NOTE Air inlet pressure, air inlet temperature, air inlet humidity and coolant inlet temperature can be taken from the default conditions in [Table 3](#).

Table 3 — Reference conditions

Default inlet condition	Value
Inlet air pressure	100 kPa ^a
Inlet air temperature	20 °C
Inlet relative humidity	0 %
Temperature of the coolants at package inlet	20 °C
^a 1 bar.	

Additional limits can be specified, such as:

- electromagnetic compatibility standard to be fulfilled;
- specified maximum noise level outside the packaged compressor;
- total harmonics distortion on the electrical supply;
- input current supply;
- minimum permissible starts/hour;
- minimum permissible unload cycles/hour;
- allowable pulsation level at the discharge of the packaged compressor;
- filtration grade of the air inlet filter.

5.3 Object of the guarantee

The object of the guarantee is the set of values to be guaranteed within the defined preconditions:

- inlet volume flow rate;
- discharge pressure at the discharge of the packaged compressor;
- specific energy of the packaged compressor for the delivered flow at the guaranteed discharge pressure;
- isentropic efficiency of the packaged compressor for the delivered flow at the guaranteed discharge pressure;
- idle power consumption;
- standby power consumption.

5.4 Low-pressure compressor to be tested

The low-pressure compressor configuration to be tested shall include all components required to fulfil all the preconditions.

As a general rule, the configuration of the unit under test shall be identical to the configuration of the unit to be delivered.

A packaged compressor checklist, such as given in [Annex A](#), shall be completed by the manufacturer and shall be part of each low-pressure compressor test report. The checklist shall be used to ensure that the tested packaged compressor matches that specified.

The checklist shall indicate which components and their performance related characteristics are included, excluded, accounted for value, or not applicable for normal functioning at guarantee conditions.

If any required components are not installed in the test configuration, the correction calculations for these components shall be shown in conjunction with the checklist.

Ancillaries required for the sustainable operation of the low-pressure packaged compressor, excluding stand-by ancillaries, are to be in operation.

5.5 Low-pressure compressor specifications to be provided prior to testing

The low-pressure compressor is tested against a specified discharge pressure (at the discharge of the packaged compressor).

In addition to the preconditions, the reference inlet conditions (or the guarantee inlet conditions) and the checklist, certain data needs to be provided by the manufacturer before the test event, typically with a tender to provide the equipment:

- rotational speed at guarantee conditions when the machine is fulfilling the object of the guarantee (for variable speed machines or if the motor in testing a fixed speed machine can differ from the one to be used at the site of assembly);
- internal volume ratio for positive displacement low-pressure compressor;
- variable geometry settings (if applicable) for the low-pressure compressor.

6 Measuring equipment, methods and accuracy

6.1 General

The equipment and methods given in this document are not intended to restrict the use of other equipment and methods with the same or better accuracy. Where an international standard relating to a particular measurement or type of instrument exists, any measurements carried out or instruments used shall be in accordance with such an international standard.

All inspection, measuring, test equipment and devices that can affect the test shall be calibrated and adjusted at prescribed intervals, or prior to use, against certified equipment having a known valid relationship to nationally recognized standards. The use of data acquisition systems shall be allowed and the test logs may be print outs resulting from the system.

No measurement uncertainty tolerances are to be taken into account in corrections or acceptance. For guarantee acceptance, as tested results are treated as measured in comparison to [Table 5](#) without additional uncertainty tolerances applied.

6.2 Measurement of pressure

6.2.1 General

Pressure taps in the pipe or receiver shall be normal to, and flush with, the inside wall. A minimum of two static or total pressure-measuring instruments shall be utilized for each measurement location spaced at 180° intervals around the pipe circumference, and 90° to temperature instrumentation

NOTE For low pressures or high flow velocities, minor irregularities such as burrs can lead to serious error.

Connecting piping shall be leak-free, as short as possible, of sufficient diameter and arranged to avoid blockage by dirt or condensed liquid. For measurement of liquid pressure or pressure of liquid-gas mixtures,

the instrument shall be mounted at the same height as the measuring point and the connecting piping shall be arranged so that the height of liquid columns in the piping exerts no influence. Otherwise, account shall be taken of the difference in height.

Instruments shall be mounted so that they are not susceptible to disturbing vibrations.

The measuring instrument (analogue or digital) shall have an accuracy of $\pm 1\%$ at the measured value.

The pressure measurement shall be a total measurement, or static measurement corrected to total conditions.

For definitions of static, dynamic and total measurements refer to ISO 5389:2005, 5.2 and 5.3.

6.2.2 Atmospheric pressure

The absolute atmospheric pressure shall be measured with a barometer having an accuracy better than $\pm 0,15\%$.

6.2.3 Pressure measurement for ambient inlet

The compressor package inlet pressure, p_1 , is the atmospheric pressure measured by a barometer near the compressor package where the velocity is zero.

6.2.4 Pressure measurement for piped inlet

The pressure is the total pressure, p_1 , measured at the process air inlet point. The pressure shall be measured at a location at least one pipe diameter upstream of the inlet.

6.2.5 Pressure measurement for piped discharge

The pressure is the total pressure, p_2 , measured at the process air discharge point. The pressure shall be measured at a location at least two pipe diameters downstream of the discharge.

6.3 Measurement of temperature

6.3.1 General

Temperature shall be measured by certified or calibrated instruments such as thermometers, thermo-electrical instruments, resistance thermometers or thermistors having an accuracy of $\pm 0,5\text{ K}$ inserted into the pipe or into pockets.

A minimum of two temperature-measuring instruments shall be used for each measurement location. For measurements made on piping these shall be spaced at 180° intervals around the pipe circumference.

Thermometer pockets shall be as thin, and their diameters as small, as is practical, with their outside surface substantially free from corrosion or oxide. The pocket shall be partially filled with a suitable liquid.

The thermometers or the pockets shall extend into the pipe to a distance of 100 mm, or one third the diameter of the pipe, whichever is less.

When taking readings, the thermometer shall not be lifted out of the medium being measured nor out of the pocket when one is used.

Precautions shall be taken to ensure that the:

- immediate vicinity of the insertion point and the projecting parts of the connection are well insulated so that the pocket is virtually at the same temperature as the medium being observed;
- sensor of any temperature measuring device or thermometer pocket is well swept by the medium (the sensor or thermometer pocket shall point against the gas stream; in extreme cases a position perpendicular to the gas stream may be used);

- thermometer pocket does not disturb the normal flow.

6.3.2 Temperature measurement for ambient inlet

The packaged compressor ambient temperature is the atmospheric temperature measured at the packaged compressor in the plane of the intake system.

6.3.3 Temperature measurement for piped inlet

The inlet temperature is the total temperature, T_1 , measured at the process air inlet point. The temperature instrumentation shall be located at half of one pipe diameter upstream of the inlet.

6.3.4 Temperature measurement for piped discharge

The discharge temperature is the total temperature, T_2 , measured at the process air discharge point. The temperature instrumentation shall be located one pipe diameter downstream of the discharge and 90° relatively rotated to the pressure measurement.

6.4 Measurement of humidity

If the gas contains moisture, the humidity shall be checked during the test. The humidity shall be measured at the process air inlet point with an instrument having an accuracy of $\pm 3\%$ or better.

6.5 Measurement of rotational frequency

Rotational speed shall be determined by using methods that have an accuracy of $\pm 0,2\%$ or better.

6.6 Measurement of flow rate

The actual volume flow rate is the net mass flow rate through the process connection of the packaged compressor discharge. All seal losses and side streams not delivered to the process piping connection of the packaged compressor shall be excluded from the delivered mass flow rate evaluation.

The actual volume flow rate of the compressor shall be measured by performing a test as indicated in either ISO 5167-1, ISO 9300 or ISO 17089-1 as appropriate:

- ISO 5167-1 – Pressure differential devices;
- ISO 9300 – Critical flow venturi nozzle devices;
- ISO 17089-1 – Ultrasonic devices.

Overall uncertainty of measured value shall be $\pm 1,5\%$ or better.

6.7 Measurement of external coolant flow rate

The mass flow of liquid external coolant shall be determined by using a measuring method with an accuracy of $\pm 5\%$ of the measured value or better.

6.8 Measurement of power and energy

6.8.1 General

Electric power of the packaged compressor shall be referred to the electrical input terminals. Factors influencing the measurement, such as voltage drop in supply cables or measurement systems, shall be taken into account.

The two-wattmeter method or some other method with similar accuracy shall be used.

Current and voltage transformers shall be chosen to operate as near to their rated load as possible so that their ratio error will be minimized.

Electrical measurement equipment shall be capable of measuring true root mean square (RMS) current, true RMS voltage, and real power up to the 40th harmonic of fundamental supply source frequency.

Overall uncertainty of the measured value shall be $\pm 0,75$ % or better.

The power supply shall

- maintain the voltage greater than or equal to 95 % and less than or equal to 110 % of the rated value of the motor, and
- maintain the voltage unbalance of the power supply within ± 3 % of the rated values of the motor.

For inverter applications, the wire power-measuring instrument shall be capable of handling the distorted voltage and current waveforms and phase relationship of the power factor caused by the harmonics and Electro Magnetic Interference (EMI) as a result of an inverter's high-speed switching mode.

6.9 Calibration of instruments

Calibration records of the instruments shall be available prior to the test.

Recalibration after the test shall be carried out for those instruments of primary importance that are liable to variation in their calibration because of use during the test.

Any change in the instrument calibrations, which will create a variation exceeding the class of accuracy of the instrument, may be cause for rejecting the test.

7 Test

7.1 General test process

In order to compare the performance data of low-pressure compressors with different technologies, it is necessary to test these low-pressure compressors under the same conditions and with the same methods by applying the same principles and process steps. If a performance metric (i.e., isentropic efficiency) is based on a reference process, it shall be the same for both positive displacement and dynamic low-pressure compressors. For the derivation of correction formulae, the most appropriate ideal reference process shall be used, which in this methodology is different for different types of low-pressure compressors. For positive displacement low-pressure compressors with or without internal compression the combined isentropic and isochoric process and for dynamic low-pressure compressors of any kind the isentropic process is used.

The test shall be carried out at an appropriate test field under prevailing conditions. No changes to geometry are allowed between test and specified conditions. For the set-up, the low-pressure compressor is connected to the test equipment. Correct cooling conditions shall be established. The low-pressure compressor shall run for warm-up against test discharge pressure until steady state conditions are reached and the temperature remains constant at the inlet and discharge of the flow measuring device. The low-pressure compressor package shall operate at the steady state condition for the duration of data collection for each test point.

In [Figure 1](#), the general process of testing is shown in a schematic.




Figure 1 — Overview of test process

For variable flow low-pressure compressor this method can be repeated at several flow rates to establish the performance over the operating range of the compressor at the specified discharge pressure. For the purpose of general data sheets, or in case there is no specific agreement with the client on how to test variable flow compressors, 5 flow rates shall be tested. The minimum and maximum flow rates that can be achieved continuously under guarantee conditions shall be specified and tested by the manufacturer. Furthermore, three additional flow rates evenly spread within the total flow rate range of the low-pressure compressor shall be specified and tested. For each test point, the adequate test loads shall be determined in the same way as for a single working point.

7.2 Allowed deviation of rotational speed between test and guarantee

The manufacturer shall identify the expected rotational speed for the specified point while operating at guarantee conditions prior to conducting the test.

When allowed, the deviation for rotational speed between test and guarantee is ($\pm 5\%$).

- Fixed speed compressors:
 - displacement:
 - package motor: no speed correction allowed;
 - test motor: speed correction allowed;
 - dynamic:
 - package motor: no speed correction allowed;
 - test motor: speed correction allowed;
- variable speed compressors:
 - displacement:
 - package motor: no speed correction allowed;