
International Standard



5219

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION • МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ • ORGANISATION INTERNATIONALE DE NORMALISATION

Air distribution and air diffusion — Laboratory aerodynamic testing and rating of air terminal devices

Distribution et diffusion d'air — Essai en laboratoire et présentation des caractéristiques aérauliques des bouches d'air

First edition — 1984-06-15

UDC 697.922 : 533.6.08

Ref. No. ISO 5219-1984 (E)

Descriptors : air flow, aerodynamics, air distribution, air diffusion, air terminal devices, tests, laboratory tests, flow measurement, flow rate, pressure measurement, velocity measurement, definitions.



Documents

Document Sharing Hub

Price based on 28 pages

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of developing International Standards is carried out through ISO technical committees. Every member body interested in a subject for which a technical committee has been authorized has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council.

International Standard ISO 5219 was developed by Technical Committee ISO/TC 144, *Air distribution and air diffusion*, and was circulated to the member bodies in April 1981.

It has been approved by the member bodies of the following countries :

Australia	Germany, F.R.	South Africa, Rep. of
Austria	Italy	Sweden
Belgium	Korea, Rep. of	Switzerland
Czechoslovakia	Poland	United Kingdom
Egypt, Arab Rep. of	Romania	USA

The member body of the following country expressed disapproval of the document on technical grounds :

France

Air distribution and air diffusion — Laboratory aerodynamic testing and rating of air terminal devices

1 General

1.1 Scope and field of application

This International Standard is intended to standardize laboratory aerodynamic testing and rating of air terminal devices, including the specification of suitable test facilities and measurement techniques.

This International Standard gives only tests for the assessment of characteristics of the air terminal devices under isothermal conditions. Annex D¹⁾ gives specifications for a supplementary but not mandatory test method under non-isothermal conditions.

1.2 Definitions

All definitions are in accordance with ISO 3258 and the following.

1.2.1 Functional characteristics of air terminal devices

1.2.1.1 nominal size of an air terminal device: The nominal value of dimensions of the prepared opening into which the air terminal device is to be fitted.

NOTE — For an air diffuser, the nominal size is generally known as neck size.

1.2.1.2 Core and specific areas

1.2.1.2.1 core of an air terminal device: That part of an air terminal device located within a convex shut surface of minimum area inside of which are all the openings of the air terminal device through which the air can pass.

1.2.1.2.2 effective area (of an air terminal device): Smallest net area of an air terminal device utilized by the airstream in passing through the air terminal device.

1.2.1.2.3 free area (of air terminal device): Sum of the smallest areas of the cross-section of all openings of the air terminal device.

1.2.1.2.4 core of a grille: That part of a grille located inside a convex shut plane curve of minimum length of contour, inside which are all the openings of the grille.

1.2.1.2.5 core area (of a grille): Area limited by the plane curve defined above.

1.2.1.2.6 free area (of a grille): Sum of the minimum measured areas of each opening through which the air can pass.

1.2.1.2.7 free area ratio (of a grille): The ratio of the free area to the core area.

1.2.1.2.8 A_k value (of an air terminal device): The quotient resultant from measured air flow rate and measured air velocity as determined in a specified manner with a specified instrument.

1.2.1.3 Aspect and vane ratios

1.2.1.3.1 aspect ratio (of a rectangular air terminal device): The ratio of the larger side to the smaller side of the rectangular core.

1.2.1.3.2 vane ratio (of a grille): The ratio of the chord length to the vane pitch.

1.2.1.4 Special terms relating to air

1.2.1.4.1 standard air: Atmospheric air having a density of 1,2 kg/m³ at 20 °C, 101 325 Pa (1 013,25 mbar) and 65% relative humidity.

1.2.1.4.2 supply air: Air entering a supply air terminal device from an upstream duct.

1.2.1.4.3 induced air: Air flow from the treated space induced by the supply air from a supply air terminal device.

1.2.1.4.4 exhaust air: Air leaving an exhaust air terminal device into a downstream duct.

1) Annexe D is being developed by ISO/TC 144/SC 1 and will be added when approved.

1.2.1.5 Specific terms relating to air diffusion rating

1.2.1.5.1 supply temperature differential: Algebraic difference between the supply air temperature and the mean measured air temperature of the occupied zone.

1.2.1.5.2 exhaust temperature differential: Algebraic difference between the exhaust air temperature and the mean measured air temperature of the occupied zone.

1.2.1.5.3 mean measured air temperature of the occupied zone: Arithmetical average of the measured values of air temperature within the occupied zone.

1.2.1.5.4 temperature differential within the occupied zone: Largest value of the difference between measured air temperature within the occupied zone.

1.2.1.5.5 primary air flow rate: Volume of air entering a supply air terminal device in unit time.

1.2.1.5.6 exhaust air flow rate: Volume of air leaving an exhaust air terminal device in unit time.

1.2.1.5.7 local air velocity: Magnitude of the time-averaged vector of velocity at a point of an air stream.

The velocity vector (and therefore its three mutually perpendicular components u , v , w) in any point of a turbulent stream is submitted to fluctuations with respect to time. The time-averaged vector of velocity is a vector for which each component is averaged with respect to time. The components being:

$$\bar{u} = \frac{1}{T} \int_0^T u \, dt; \quad \bar{v} = \frac{1}{T} \int_0^T v \, dt;$$

$$\bar{w} = \frac{1}{T} \int_0^T w \, dt;$$

the local air velocity is therefore:

$$\sqrt{\bar{u}^2 + \bar{v}^2 + \bar{w}^2}$$

1.2.1.5.8 local measured air velocity: Measured value of local air velocity.

1.2.1.5.9 envelope: Geometrical surface in a treated space where the local measured air velocity has the same value and is the reference velocity associated with this envelope.

1.2.1.5.10 room air velocity: Value of velocity conventionally derived from the various local measured air velocities within the occupied zone.

1.2.1.5.11 free area velocity: Primary air flow rate divided by the free area of a supply air terminal device.

Exhaust air flow divided by the free area of an exhaust air terminal device.

1.2.1.5.12 throw (for a supply air terminal device): Maximum distance between the centre of the core and a plane which is tangent to a specified envelope, such as 0,25 m/s, 0,5 m/s etc., and perpendicular to the intended direction of flow.

1.2.1.5.13 drop (for a supply air terminal device): Vertical distance between the lowest horizontal plane tangent to a specified envelope, such as 0,25 m/s, 0,5 m/s, etc., and the centre of the core.

1.2.1.5.14 rise (for a supply air terminal device): Vertical distance between the highest horizontal plane tangent to a specified envelope, such as 0,25 m/s, 0,5 m/s, etc., and the centre of the core.

1.2.1.5.15 spread (for a supply air terminal device): Maximum distance between two vertical planes tangent to a specified envelope, such as 0,25 m/s, 0,5 m/s, etc., and perpendicular to a plane through the centre of the core.

There may be two different spreads, not always equal: One for the left side, the other for the right side (considered when looking at the treated space from the supply air terminal device).

1.3 Symbols

The following nomenclature is used throughout this International Standard:

Symbol	Quantity	Corresponding SI unit	Dimensions
A	Area	m^2	L^2
A_d	Area corresponding to the nominal size of the duct to which the device is fitted	m^2	L^2
A_k	k factor area $A_k = \left(\frac{q_V}{v_k} \right)$	m^2	L^2
b_R	Width of test room or installation	m	L
D_e	Equivalent diameter $\left(\sqrt{\frac{4 \times A_d}{\pi}} \right)$	m	L
D_h	Hydraulic diameter $\left(\frac{4 \times A_d}{\text{perimeter}} \right)$	m	L
d	Diameter	m	L
h_D	Face height of linear grille or diffuser	m	L
h_R	Height of test room or installation	m	L
l_R	Length of test room or installation	m	L
p	Absolute static pressure	Pa	$\text{ML}^{-1}\text{T}^{-2}$
p_a	Atmospheric pressure	Pa	$\text{ML}^{-1}\text{T}^{-2}$
p_s	Static gauge pressure $(p - p_a)$	Pa	$\text{ML}^{-1}\text{T}^{-2}$
p_t	Stagnation (or absolute total) pressure	Pa	$\text{ML}^{-1}\text{T}^{-2}$
p_t	Total pressure $(p_t - p_a)$	Pa	$\text{ML}^{-1}\text{T}^{-2}$
p_d	Velocity pressure $\left(\rho \frac{v^2}{2} \right)$	Pa	$\text{ML}^{-1}\text{T}^{-2}$
Δp	Pressure difference (for a pressure difference device)	Pa	$\text{ML}^{-1}\text{T}^{-2}$
q_V	Volume rate of flow	m^3/s	L^3T^{-1}
v	Velocity	m/s	LT^{-1}
v_m	Mean flow velocity	m/s	LT^{-1}
v_k	k factor velocity $\left(\frac{q_V}{A_k} \right)$	m/s	LT^{-1}
v_x	Maximum velocity at distance x from centre of supply air terminal device	m/s	LT^{-1}
X	Throw	m	L
Y	Spread	m	L
Z	Drop	m	L
ζ	Loss coefficient	—	Dimensionless number
Θ	Thermodynamic temperature	K	Θ
ρ	Density	kg/m^3	ML^{-3}

2 Instrumentation

2.1 Air flow rate measurement

2.1.1 Air flow meters shall have the following ranges and accuracies:

Range	Accuracy of measurement
More than 0,07 m ³ /s	2,5 %
From 0,007 to 0,07 m ³ /s	5 %
Below 0,007 m ³ /s	0,0009 m ³ /s

All methods meeting the requirements of ISO 5221¹⁾ will meet the accuracies given above and do not require calibration.

Alternatively flow meters may be calibrated *in situ* by means of the pitot static tube traverse techniques described in ISO 3966²⁾.

2.1.2 Flow meters shall be checked at intervals as appropriate but not exceeding 24 months. This check may take the form of one of the following:

- a dimensional check for all flow meters not requiring calibration;
- a check calibration over their full range using the original method employed for the initial calibration of meters calibrated *in situ*.
- a check against a flow meter which meets ISO flow meter standards.

2.2 Pressure measurement

2.2.1 Pressure in the duct shall be measured with a liquid-filled, calibrated manometer.

2.2.1.1 The maximum scale interval shall not be greater than the characteristics listed for the accompanying range of manometer.

Range Pa	Maximum scale interval Pa
From 1,25 to 25	1,25
From 25 to 250	2,5
From 250 to 500	5,0
Above 500	25

2.2.1.2 For air flow rate measurements, the minimum pressure differential shall be:

- 25 Pa with an inclined tube manometer or micro-manometer;
- 500 Pa with a vertical tube manometer.

2.2.1.3 Calibration standards shall be:

- for instruments with the range 1,25 to 25 Pa, a micro-manometer accurate to $\pm 0,25$ Pa;
- for instruments with the range 25 to 500 Pa, a manometer accurate to $\pm 2,5$ Pa (hook gauge or micro-manometer);
- for instruments with the range 500 Pa and upwards, a manometer accurate to ± 25 Pa (vertical manometer).

2.3 Temperature measurement

Measurement of temperature shall be by means of mercury-in-glass thermometers, resistance thermometers or thermocouples. Instruments shall be graduated or give readings in intervals not greater than 0,5 K and calibrated to an accuracy of 0,25 K.

2.4 Velocity measurement

2.4.1 The measurement of low velocities within treated spaces, to determine air terminal device performance characteristics shall be made with a measuring device in accordance with annex A.

2.4.2 The measurement of air terminal device velocities to determine ATD³⁾ v_k velocity characteristics shall be made with a measuring device in accordance with annex B.

3 Testing of pressure requirement

3.1 Measurement of pressure requirement for a supply air terminal device

The pressure requirement of an ATD is for a given value of flow rate dependent on the type and size of the device and on the velocity profile upstream of the device. A standard test duct immediately upstream of the ATD shall be employed. If an inlet duct arrangement or flow equalizing and/or damping device is an integral part of an ATD, then the standard test duct shall be employed immediately upstream of the integral inlet duct or accessory.

3.1.1 The test system shall comprise at least a fan, a means for controlling the air flow rate, a flow rate measuring device and a standard test duct for the ATD. Tests shall be carried out under isothermal conditions.

3.1.2 Pressure tests on the ATD alone or ATD in combination with flow equalizing and/or damping device shall be conducted to establish a pressure for a given air flow rate. The air terminal device shall be mounted in one of the two test installations

1) ISO 5221, *Air distribution and air diffusion — Rules to methods of measuring air flow rate in an air handling duct*.

2) ISO 3966, *Measurement of fluid flow in closed conduits — Velocity area method using Pitot static tubes*.

3) Abbreviation signifying "air terminal device".

described in 3.1.3 (see figure 1) or 3.1.5 (see figure 2). To determine minimum pressure, measurements shall be made with flow equalizing and/or damping devices in the normally open position. Pressure tests on the ATD shall be clearly referenced to any position of adjustment.

Two methods may be used for determining pressure requirements on test installation A: one by measuring static pressure (see 3.1.3), the other by directly measuring total pressure (see 3.1.4).

3.1.3 Measurement of static pressure with the first test installation A

The air terminal device shall be mounted in a test duct with cross-sectional dimensions equal to the nominal size of the device or to the duct dimensions normally recommended by the manufacturer. This duct shall be straight and shall include an efficient flow straightener located at a position at least three equivalent diameters (D_e) from any part of the ATD. It is recommended that straightener cells have an axial length at least equal to six times the hydraulic diameter of their cross-section.

3.1.3.1 The test installation shall be generally constructed as shown in figure 1. The plane of measurement shall be at 1,5 equivalent diameters upstream of the ATD. A static pressure traverse shall be taken on two orthogonal diameters in order to obtain the maximum and minimum values. The measured pressure at the selected point of test in the plane of measurement shall not differ by more than 10 % from both the maximum and the minimum value within the pressure measurement plane.

3.1.3.2 Record the results for a minimum of four air flow rates regularly distributed over the upper half of the working range for each ATD tested.

3.1.3.3 The total pressure in the plane of measurement shall be considered to be that equal to the sum of the measured static gauge pressure and the velocity pressure calculated from the velocity obtained by dividing the test air flow rate by the duct cross-sectional area. The pressures so obtained may also be corrected to a standard air density of 1,2 kg/m³.

3.1.4 Direct measurement of total pressure with the first test installation A

The test installation and the plane of measurement shall be the same as described in figure 1 and in 3.1.3. A pitot tube shall be used for successively measuring the total pressure at five points in this plane. These five points are distributed as shown in figure 2. One point is on the duct axis — the other four points are located on two orthogonal diameters at a distance from the duct axis equal to 0,4 times the diameter of the cross-section. The total pressure shall be considered as the mean arithmetic value of the five total pressure recorded measurements. The pressures so obtained may also be corrected to a standard air density of 1,2 kg/m³. For rectangular cross-section, measurements shall be made on diagonals with their length used as the referenced dimensions to locate the four supplementary points as shown on figure 6.

3.1.4.1 Record the results for a minimum of four air flow rates regularly distributed over the upper half of the working range for each ATD tested. The pressure may be corrected to standard density.

3.1.5 Measurement of static pressure with the first test installation B

The test installation shall be constructed as shown in figure 3, such that the following equation is satisfied:

$$\frac{q_V}{A} < \sqrt{\frac{p_s}{5 \varrho}}$$

where

q_V is the volume flow rate;

A is the area of the internal cross-section of the chamber;

p_s is the required pressure;

ϱ is the density of the air.

NOTE — As the normal density of the air $\varrho = 1,2 \text{ kg/m}^3$, the formula becomes

$$\frac{q_V}{A} < \sqrt{\frac{p_s}{6}}$$

The ATD to be tested shall be mounted in a short test duct equal to the nominal size of the ATD and having a length equal to D_e or 0,15 m, whichever is greater. It is recommended that the test duct should have a conical entrance.

The required pressure shall be measured with at least a single wall static tapping located within 0,05 m of the inside surface of the ATD mounting plate.

Equalizing sections shall be provided within the chamber to guarantee that a relatively uniform flow, free from swirl, exists in the test chamber with the ATD mounting plate removed.

3.1.5.1 Record the results for a minimum of four air flow rates regularly distributed over the upper half of the working range for each ATD tested.

3.1.5.2 The measured pressure, p_s , shall be considered to be the total pressure, p_t , and this pressure may also be corrected to a standard air density of 1,2 kg/m³.

3.1.6 Presentation of data

3.1.6.1 The data shall be corrected to standard air conditions and the pressure requirements of the ATD determined from a graph of the total pressure versus the air flow rate.

3.1.6.2 The loss coefficient ζ shall be calculated from the following appropriate relationships, based upon the pressures measured under 3.1.3, 3.1.4 and 3.1.5:

$$\zeta = \frac{p_s}{p_d} + 1 \text{ (see 3.1.3)}$$

$$\zeta = \frac{p_t}{p_d} \text{ (see 3.1.4 and 3.1.5)}$$

where p_s or p_t is the measured quantity and p_d is calculated as $\frac{\rho}{2} \left(\frac{q_v}{A_d} \right)^2$

(where both ρ and q_v are also at the same test conditions).

The single loss coefficient ζ may be substituted for the graph of total pressure versus air volume flow rate.

3.2 Measurement of pressure requirement for an exhaust air terminal device

The pressure requirement of an exhaust ATD is for a given value of flow rate dependent on the type and size of the device and on the velocity profile upstream and downstream of the device. A standard test duct immediately downstream of the ATD shall be employed. If a connecting duct arrangement, flow equalizing and/or damping device is an integral part of an ATD, then the standard test duct shall be employed immediately downstream of the integral connecting duct or accessory.

3.2.1 The test system shall comprise at least a fan, a means for controlling the air flow rate, a flow rate measuring device and a standard test duct for the ATD. Tests shall be carried out under isothermal conditions.

3.2.1.1 The device under test shall be mounted in a simulated wall or ceiling surface using the method of fixing recommended by the manufacturer. For circular and square ATD's this surface shall extend on all sides of the ATD to at least $2 D_e$ from the boundaries of the ATD.

For slots or similar ATD's, the surface shall extend by at least twice the width of the slot on each side of the device.

For special exhaust ATD's (for example, heat removal luminaires), where in the plane of the ceiling surface the velocity does not exceed 1 m/s, no extended surface is necessary.

3.2.2 Pressure tests on the exhaust ATD alone or in combination with connecting ducts, flow equalizing and/or damping devices shall be conducted to establish a pressure for a given air flow rate. The air terminal device shall be mounted in one of the test installations described in 3.2.3 (see figure 4) or 3.2.5 (see figure 5).

To determine the minimum pressure, measurements shall be made with the damping device in the normally open position. Pressure tests on the exhaust ATD shall be clearly referenced to any position of adjustment.

Two methods may be used for determining pressure requirements on test installation C: one by measuring static pressure (see 3.2.3), the other by directly measuring total pressure (see 3.2.4).

3.2.3 Measurement of static pressure with the first test installation C for exhaust ATD (excluding air transfer devices)

The air terminal device shall be mounted in a test duct with a cross-sectional dimension equal to the nominal size of the

device or to the duct dimensions normally recommended by the manufacturers. This duct shall be straight and shall include an efficient flow straightener located at a position at least 7,5 equivalent diameters from any part of the exhaust ATD. It is recommended that straightener cells have an axial length at least equal to six times the hydraulic diameter of their cross-section.

3.2.3.1 The test installation shall be generally constructed as shown in figure 4. To establish the plane of measurement in the straight, constant area duct section, static pressure measurements shall be made at increments of not less than $1 D_e$ downstream of the device until the rate of change between the measurements is substantially zero. A pressure traverse shall be taken on two orthogonal diameters in order to obtain the maximum and minimum values. The measured pressure at the selected point of test in the plane of measurement shall not differ more than 10 % from both the maximum and the minimum value within the pressure measurement plane.

3.2.3.2 Record the results for a minimum of four air flow rates regularly distributed over the upper half of the working range for each ATD tested.

3.2.3.3 The static pressure requirement of the device shall be obtained by correcting for the static pressure change along the duct length from the equation:

$$p_{sD} = p_s - (0,02 L/D_h) p_d$$

where

p_s is the static pressure (negative) measured on the axis of the duct in the section where it begins not to vary noticeably;

L is the distance between the ATD to the measuring section of p_s ;

D_h is the hydraulic diameter of the duct;

p_d is the dynamic pressure corresponding to the mean velocity in the test duct.

3.2.3.4 The total pressure in the plane of measurement shall be considered equal to the sum of the measured static pressure and the velocity pressure calculated from the velocity obtained by dividing the test air flow rate duct cross-sectional area. The pressures so obtained may also be corrected to a standard density of 1,2 kg/m³.

3.2.4 Direct measurement of total pressure with the first test installation C, for exhaust ATD

The test installation shall be the same as described in figure 4 and in 3.2.3.

3.2.4.1 The plane of measurement through which a pitot-static tube shall be used shall be the same as described in 3.2.3.1. Measurements of total and static pressure shall be

made at the same five points in the plane as defined in 3.1.4 and for successive planes as defined in 3.2.3.1. If the maximum discrepancy in the static pressure value for these five measured points does not exceed two tenths of the mean static pressure measured in the duct, the value of the mean total pressure p_{tm} used to calculate the total pressure loss shall be the mean arithmetical value of the total pressure data obtained for each of the five points.

3.2.4.2 Record the results for a minimum of four air flow rates regularly distributed over the upper half of the working range for each ATD tested.

3.2.4.3 The total pressure requirement of the device shall be obtained by correcting for the total pressure change along the duct length from the equation:

$$p_{td} = p_t - (0,02 L/D_h) p_d$$

The pressure so obtained may also be corrected to a standard density of 1,2 kg/m³.

3.2.5 Measurement of static pressure with the first installation D for exhaust ATD

The test installation shall be constructed as shown in figure 5 such that the following equation is satisfied:

$$\frac{q_V}{A} < \sqrt{\frac{p_s}{\rho}}$$

where

q_V is the volume flow rate;

A is the area of the internal cross-section of the chamber;

p_s is the required pressure;

ρ is the density of the air.

NOTE — As the normal density of the air $\rho = 1,2 \text{ kg/m}^3$, the formula becomes

$$\frac{q_V}{A} < \sqrt{\frac{p_s}{6}}$$

The ATD to be tested shall be mounted in a short test duct equal to the nominal size of the ATD and having a length equal to D_e or 0,15 m, whichever is greater.

The required pressure shall be measured with at least a single wall static tapping located within 0,05 m of the inside surface of the ATD mounting plate.

Equalizing sections shall be provided within the chamber to guarantee that a relatively uniform flow, free from swirl, exists in the test chamber with the ATD mounting plate removed.

3.2.5.1 Record the results for a minimum of four air flow rates regularly distributed over the upper half of the working range for each ATD tested.

3.2.5.2 The measured pressure, p_s , shall be considered to be the total pressure, p_t , and this pressure may also be corrected to a standard air density of 1,2 kg/m³.

3.2.6 Presentation of data

3.2.6.1 The data shall be corrected to standard air conditions and the pressure requirements of the ATD determined from a graph of the total pressure versus the air flow rate.

3.2.6.2 The loss coefficient ζ shall be calculated from the following appropriate relationship based upon the pressures measured under 3.2.3, 3.2.4 and 3.2.5:

$$\zeta = \frac{p_s}{p_d} - (1 + 0,02 \frac{L}{D_h}) \text{ (see 3.2.3)}$$

$$\zeta = \frac{p_t}{p_d} - 0,02 \frac{L}{D_h} \text{ (see 3.2.4)}$$

$$\zeta = \frac{p_t}{p_d} \text{ (see 3.2.5)}$$

where p_s or p_t is the measured quantity and p_d is calculated as $\frac{\rho}{2} \left(\frac{q_V}{A_d} \right)^2$

(where both ρ and q_V are also at the same test conditions).

The single loss coefficient ζ may be substituted for the graph of total pressure versus air volume flow rate.

3.3 Determination of air velocity v_k and the corresponding area value A_k for the air terminal device

3.3.1 The same test installation used to measure pressure shall be used to measure v_k and to calculate A_k , see figures 1, 3, 4 and 5.

3.3.2 The v_k velocity shall be measured with an air velocity meter selected in accordance with specifications in 2.4.2.

3.3.2.1 Specifications for the positions and locations of the air velocity measuring points at the air terminal device shall be stated with the corresponding v_k values.

3.3.2.2 The v_k values shall be referenced to the specific adjustment position of the air terminal device.

3.3.2.3 For each of the test air flow rates, the arithmetic mean of the velocities measured to establish v_k shall be determined from measurements taken at the number and position of points on the ATD as specified by the manufacturer.

3.3.2.4 The A_k values shall be calculated by dividing the measured air flow rate by the mean v_k .

3.3.3 A test shall be carried out for a minimum of four air flow rate values distributed within the range of the air terminal device nominal capacity.