



INTERNATIONAL TELECOMMUNICATION UNION

ITU-T

TELECOMMUNICATION
STANDARDIZATION SECTOR
OF ITU

L.32

(10/98)

SERIES L: CONSTRUCTION, INSTALLATION AND
PROTECTION OF CABLES AND OTHER ELEMENTS OF
OUTSIDE PLANT

**Protection devices for through-cable
penetrations of fire-sector partitions**

ITU-T Recommendation L.32

(Previously CCITT Recommendation)

ITU-T L-SERIES RECOMMENDATIONS
CONSTRUCTION, INSTALLATION AND PROTECTION OF CABLES AND OTHER ELEMENTS OF
OUTSIDE PLANT

For further details, please refer to ITU-T List of Recommendations.

ITU-T RECOMMENDATION L.32

PROTECTION DEVICES FOR THROUGH-CABLE PENETRATIONS OF FIRE-SECTOR PARTITIONS

Summary

This Recommendation describes the protection of cables by means of incombustible materials and provides information on the classification and characteristics of the sealing materials. Appendix I contains examples of methods used to apply such systems in fire-sector barriers.

Source

ITU-T Recommendation L.32 was prepared by ITU-T Study Group 6 (1997-2000) and was approved under the WTSC Resolution No. 1 procedure on the 9th of October 1998.

FOREWORD

ITU (International Telecommunication Union) is the United Nations Specialized Agency in the field of telecommunications. The ITU Telecommunication Standardization Sector (ITU-T) is a permanent organ of the ITU. The ITU-T is responsible for studying technical, operating and tariff questions and issuing Recommendations on them with a view to standardizing telecommunications on a worldwide basis.

The World Telecommunication Standardization Conference (WTSC), which meets every four years, establishes the topics for study by the ITU-T Study Groups which, in their turn, produce Recommendations on these topics.

The approval of Recommendations by the Members of the ITU-T is covered by the procedure laid down in WTSC Resolution No. 1.

In some areas of information technology which fall within ITU-T's purview, the necessary standards are prepared on a collaborative basis with ISO and IEC.

NOTE

In this Recommendation, the expression "Administration" is used for conciseness to indicate both a telecommunication administration and a recognized operating agency.

INTELLECTUAL PROPERTY RIGHTS

The ITU draws attention to the possibility that the practice or implementation of this Recommendation may involve the use of a claimed Intellectual Property Right. The ITU takes no position concerning the evidence, validity or applicability of claimed Intellectual Property Rights, whether asserted by ITU members or others outside of the Recommendation development process.

As of the date of approval of this Recommendation, the ITU had not received notice of intellectual property, protected by patents, which may be required to implement this Recommendation. However, implementors are cautioned that this may not represent the latest information and are therefore strongly urged to consult the TSB patent database.

© ITU 1999

All rights reserved. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the ITU.

CONTENTS

	Page
1 Introduction	1
2 It is recommended:	1
Appendix I – Examples of the use of fire-stopping materials and cable management systems for through-cable penetration of fire-sector barriers	2
I.1 Cable penetration through floor openings or grooves	2
I.1.1 Example 1 (see Figure I.1)	3
I.1.2 Example 2 (see Figure I.2)	3
I.2 Cable-tray penetration position	4
I.2.1 Example 1 (see Figure I.3)	4
I.2.2 Example 2 (see Figure I.4)	4
I.3 Penetration of tubing/cables through a fire-sector partition	5
I.3.1 Example 1 – For metal or PVC tubing up to 25 mm in diameter (see Figure I.5)	5
I.3.2 Example 2 – For metal or PVC tubing of more than 25 mm in diameter (see Figure I.6)	5
I.3.3 Example 3 (see Figure I.7)	5
I.4 Penetration of a fire-sector partition in a cable tunnel.....	6