

JAPANESE
INDUSTRIAL
STANDARD

Translated and Published by
Japanese Standards Association

JIS T 9241-3 : 2008

**Hoists for the transfer of persons with
disabilities — Part 3: Stationary hoists**

ICS 11.180.10

Reference number : JIS T 9241-3 : 2008 (E)

PROTECTED BY COPYRIGHT

Date of Establishment: 2008-06-20

Date of Public Notice in Official Gazette: 2008-06-20

Investigated by: Japanese Industrial Standards Committee
Standards Board
Technical Committee on Support for Aged and
Handicapped Persons

JIS T 9241-3 : 2008, First English edition published in 2009-01

Translated and published by: Japanese Standards Association
4-1-24, Akasaka, Minato-ku, Tokyo, 107-8440 JAPAN

In the event of any doubts arising as to the contents,
the original JIS is to be the final authority.

© JSA 2009

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

Printed in Japan

PROTECTED BY COPYRIGHT

Contents

	Page
Introduction	1
1 Scope	1
2 Normative references.....	1
3 Terms and definitions	2
4 Classification and division.....	5
4.1 Classification	5
4.2 Division (symbol for division) according to maximum load	5
5 Design, appearance and construction	5
5.1 Design	5
5.2 Appearance	5
5.3 Construction	6
6 Performance.....	7
6.1 General requirements.....	7
6.2 Rate (velocity) of lifting and lowering.....	7
6.3 Operating forces.....	7
6.4 Durability	8
6.5 Static strength	8
6.6 Sound level	8
7 Test methods.....	8
7.1 General	8
7.2 Test methods for performance	9
8 Inspection	12
9 Marking and instruction for use.....	12
9.1 Marking	12
9.2 Instruction for use	13
Annex A (normative) Hydraulic and pneumatic components—Requirements	14
Annex B (informative) Periodic inspection	16
Annex C (informative) Applications of hoists	17
Annex JA (informative) Comparison table between JIS and corresponding International Standard.....	18

Foreword

This translation has been made based on the original Japanese Industrial Standard established by the Minister of Economy, Trade and Industry, through deliberations at the Japanese Industrial Standards Committee in accordance with the Industrial Standardization Law.

This JIS document is protected by the Copyright Law.

Attention is drawn to the possibility that some parts of this Standard may conflict with a patent right, application for a patent after opening to the public, utility model right or application for registration of utility model after opening to the public which have technical properties. The relevant Minister and the Japanese Industrial Standards Committee are not responsible for identifying the patent right, application for a patent after opening to the public, utility model right or application for registration of utility model after opening to the public which have the said technical properties.

JIS T 9241 consists of the following 5 parts under the general title “*Hoists for the transfer of persons with disabilities*”:

Part 1 : Classification and general requirement

Part 2 : Mobile hoist

Part 3 : Stationary hoists

Part 4 : Rail guide hoists

Part 5 : Sling Sheets

Hoists for the transfer of persons with disabilities—

Part 3 : Stationary hoists

Introduction

This Japanese Industrial Standard has been prepared based on the first edition of ISO 10535 published in 1998 dividing into parts by classification of products and with some modifications of the technical contents to reflect domestic situation.

The portions given continuous sidelines or dotted underlines are the matters not stated in the original International Standard. A list of modifications with the explanation is given in Annex JA.

1 Scope

This Standard specifies the required performance, test methods and marking for stationary hoists which are a type of hoist used for the persons unable to easily transfer or move on their own (hereafter referred to as “hoists”).

NOTE : The International Standard corresponding to this Standard is as follows.

ISO 10535:1998 *Hoists for the transfer of disabled persons—Requirements and test methods* (MOD)

In addition, symbols, which denote the degree of correspondence in the contents between the relevant International Standard and JIS, are IDT (identical), MOD (modified), and NEQ (not equivalent) according to ISO/IEC Guide 21.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this Standard. The most recent editions of the standards (including amendments) indicated below shall be applied.

JIS B 8360	<i>Wire reinforced rubber hose assemblies for hydraulic use</i>
JIS B 8361	<i>Hydraulic fluid power—General rules relating to systems</i>
JIS B 8364	<i>Textile reinforced rubber hose assemblies for hydraulic use</i>
JIS B 8370	<i>Pneumatic fluid power—General rules relating to systems</i>
JIS C 1509-1	<i>Electroacoustics—Sound level meters—Part 1: Specifications</i>
JIS C 9730-1	<i>Automatic electrical controls for household and similar use—Part 1: General requirements</i>
JIS T 9241-1	<i>Hoists for the transfer of persons with disabilities—Part 1: Classification and general requirement</i>
JIS Z 8703	<i>Standard atmospheric conditions for testing</i>

3 Terms and definitions

For the purposes of this Standard, the terms and definitions given in JIS T 9241-1 and the following terms and definitions apply:

3.1 stationary hoist

a hoist with which a lifted person is lifted, transferred or moved within a pre-defined area and which is fixed to a wall, ceiling, floor, bathtub, bed, etc. (see figure 1)

3.2 attendant

the person who operates the hoist to transfer or move the lifted person

3.3 body-support unit

the part of the hoist that supports the person being lifted, moved or transferred (e.g. sling, seat, stretcher, etc) along with the associated attachment construction

3.4 central suspension point (CSP)

a reference point on the hoist to be used for measurements (this point may be a connecting point)

3.5 connecting point

the part to which the body-support unit attaches

3.6 control devices

the part or parts of the hoist which operates the lifting and lowering mechanism of the CSP as well as other functions

3.7 end limiting device

a device that stops any movement at a predetermined end position

3.8 flexible device

a component of the lifting device which connects the spreader bar with the component that functions as a lifting device (e.g. chain, tape, rope)

3.9 free wheeling

the mechanism to transmit only a force in one way direction and to spin free in the reverse rotation, like a rear wheel of bicycles

3.10 functional test

the test to confirm that the corresponding mechanism and construction meet the requirements specified in clause 5, by means of operating, etc.

3.11 hoisting range

the vertical distance between the maximum and minimum heights of the CSP

3.12 hoisting reach

the unimpeded horizontal distance between the post and a vertical line passing through the CSP at a given height within the hoisting range (see figure 1)

3.13 hold to run control device

control device which initiates and maintains the operation of the hoist element only as long as the manual control is actuated

The manual control automatically returns to the “stop” or “off” position when released.

3.14 lifted person

the person who is transferred by the hoist

3.15 lifting cycle

the raising and lowering of the lifting machinery for the same distance in both directions

3.16 lifting device

means of lifting and lowering the body-support unit

3.17 lifting machinery

device that performs the lifting function

3.18 maximum load

the greatest permissible load, including the lifted person, the body-support unit, etc, that can be applied to the hoist

3.19 multi-purpose hoist

a hoist that can be assembled, possibly with the use of different parts, to provide a variety of operations

3.20 sling

the body-support unit manufactured from such soft cloth that fits the body and to be attached to the lifting device of the hoist

3.21 rigid body-support unit

a preformed seat or recumbent device, manufactured from rigid materials (if necessary padded), or flexible materials encased by a frame, with associated connecting means for attaching to the lifting device of the hoist

3.22 single fault condition

condition in which a single means for protection against a safety hazard in equipment is defective or a single external abnormal condition ¹⁾ is present

Note ¹⁾ For example, electric power failure is supposed.

3.23 sitting part

part of the body-support unit that is available for sitting on

3.24 adverse condition

the condition in which failure is most likely to occur

3.25 spreader bar

a rigid construction with more than one connection point, onto which the body-support unit is attached





Figure 1 Example of stationary hoist (Hoisting range/reach)



e) Example of stationary hoist on equipment

Figure 1 (concluded)

4 Classification and division

4.1 Classification

The classification of stationary hoists shall be as given in 4.1.1 of JIS T 9241-1.

4.2 Division (symbol for division) according to maximum load

The division (symbol for division) according to the maximum load shall be as given in 4.2 of JIS T 9241-1.

5 Design, appearance and construction

5.1 Design

5.1.1 Risk analysis

The risk analysis shall be as given in 5.2.1 of JIS T 9241-1.

5.1.2 Ergonomics factors

The ergonomics factors shall be as given in 5.2.2 of JIS T 9241-1.

5.2 Appearance

The appearance shall be as follows.