Specification

T0054 Luminaire – Down Lighting

Issue no.:	A1		Issue date:	June 2015
			Review date:	June 2018

Contents

1 Purpose 2

2 Scope 2

3 Requirements 2

3.1 General 2
3.2 Standards 2
3.3 Physical Construction of Luminaire 4
3.4 Operation and Maintenance 5
3.5 Electrical 6
3.6 Drivers and Controls 7
3.7 Photometry 7
3.8 Performance 8
3.9 Environmental Conditions 8
3.10 Reliability 9
3.11 Safety 9
3.12 Materials Compliance 10
3.13 Labelling 10
3.14 Testing 10

4 Person accountable for this document 11

5 Document History 11

6 Lighting Product Specification Criteria 12

7 List of Abbreviations 15

8 Definitions 16

MAYOR OF LONDON
Transport for London
Documents
UNDERGROUND
Copyright London Underground Library
Provided by IHS
No reproduction or networking permitted without license from IHS
Full document details: LUL T0054 2015
Licensee=Weston Williamson/5989497001, User=sam, albett
Not for Resale, 03/28/2016 05:17:39 MDT

1 Purpose

The purpose of this document is to outline the minimum performance specification for square ceiling luminaires for use on the London Underground.

For simplicity, this document makes reference to Light Emitting Diode (LED) technology, however other lighting technologies will also be considered.

2 Scope

This Specification applies to Transport for London (TfL)

TfL is in the process of establishing Supplier framework contracts with lighting manufactures to procure products that will demonstrate the most superior whole life costs and performance for its given use.

3 Requirements

3.1 General

3.1.1 The Supplier shall comply with all requirements contained within this document.

3.1.2 The luminaire and all components such as control gear or lamps shall be Conformité Européenne (CE) marked.

3.1.3 The Supplier shall demonstrate full compliance with the CE Declaration of Conformity in the form of a certificate.

3.1.4 The CE Declaration of Conformity shall be backed up with test results demonstrating full compliance to all standards and criteria. These test results shall form part of the Suppliers submission.

3.1.5 The Supplier shall complete the Lighting Product Specification Criteria for each submission.

3.2 Standards

The luminaire shall comply with all relevant London Underground, British and International standards. These include but are not limited to those listed in the following.

3.2.1 London Underground standards

S1066	Lighting of London Underground Assets
S1069	Low voltage electrical installations
S1085	Fire safety performance of materials
S1123	Requirements for matching electrical loads to supplies when making changes to low voltage infrastructure
S1212	Production of a Reliability Case
S1222	Electromagnetic Compatibility

MAYOR OF LONDON
Transport for London
Documents
UNDERGROUND
Copyright London Underground Library
Provided by IHS
No reproduction or networking permitted without license from IHS
Full document details: LUL T0054 2015
Licensee=Weston Williamson/5989497001, User=sam, albett
Not for Resale, 03/28/2016 05:17:39 MDT

3.2.2 British and European standards and guidance

BS 6853	Code of practice for fire precautions in the design and construction of passenger carrying trains
BS EN 12600:2002	Glass in building. Pendulum test. Impact test method and classification for flat glass
BS EN 13032	Light and lighting
BS EN 50126	Railway applications (RAMS)
BS EN 55011	Industrial, scientific and medical equipment. Radio-frequency disturbance characteristics. Limits and methods of measurement
BS EN 55015:2013	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment
BS EN 60529:2013	Degrees of protection provided by enclosures (IP code)
BS EN 60598	Luminaires
BS EN 61000	Electromagnetic compatibility
BS EN 61347-2-13:2006	Lamp control gear. Particular requirements for dc. or ac supplied electronic control gear for LED modules
BS EN 61547:2009	Equipment for general lighting purposes. EMC immunity requirements
BS EN 62031:2015	LED modules for general lighting – Safety specifications
BS EN 62262:2002	Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)
BS EN 62384:2006	DC or AC supplied electronic control gear for LED modules. Performance requirements
BS EN 62471:2008	Photobiological safety of lamp & lamp systems
BS EN 62504:2014	General lighting / Light emitting diode (LED) products and related equipment. Terms and definitions
BS EN 62612:2013	Self-ballasted LED lamps for general lighting services with supply voltages > 50 V – Performance requirements
BS EN ISO 4589	Plastics. Determination of burning behaviour by oxygen index
Directive 2004/108/EC	Electromagnetic compatibility (EMC)

MAYOR OF LONDON
Transport for London
Documents
UNDERGROUND
Copyright London Underground Library
Provided by IHS
No reproduction or networking permitted without license from IHS
Full document details: LUL T0054 2015
Licensee=Weston Williamson/5989497001, User=sam, albett
Not for Resale, 03/28/2016 05:17:39 MDT

HSG 38 – 1997	Lighting at Work
PD IEC/TR 62696:2011	Luminaires. Application of the IK code IEC 62262

3.2.3 International standards and guidance

ASSIST Publication Volume 1, Issue 1 May 2012	Flicker Parameters for Reducing Stroboscopic Effects from Solid-state Lighting Systems
IEC/PAS 62717	LED modules for general lighting – Performance requirements
IEC/PAS 62722	Luminaire Performance
IES-LM-79-08	Approved Method: Electrical and Photometric Measurements of Solid-State Lighting Products
IES-LM-80-08	Approved Method: Measuring Lumen Maintenance of LED Light Sources
ISO 16933:2007	Glass in building - Explosion-resistant security glazing - Test and classification for arena air-blast loading

3.3 Physical Construction of Luminaire

3.3.1 Access to individual luminaires in public areas shall require the use of a tool.

3.3.2 Luminaires shall have a modular design so that components are replaceable upon failure, become life expired or redundant. For example:

- Drivers.
- LED panel/module.
- Battery and inverter.
- Diffuser.
- Reflectors / Refractors.
- Surge Protection.

MAYOR OF LONDON
Transport for London
Documents
Copyright London Underground Library
Provided by IHS
No reproduction or networking permitted without license from IHS
Full document details: LUL T0054 2015
Licensee=Weston Williamson/5989497001, User=sam, albett
Not for Resale, 03/28/2016 05:17:39 MDT

3.3.3 Luminaires shall be designed to maintain their International Protection (IP) rating throughout its lifecycle and not degrade due to maintenance and periodic testing.

3.3.4 The cable connection to the luminaire shall not compromise its IP rating.

3.3.5 The Supplier shall provide glands to maintain the IP rating of the fitting during installation. This shall include glands for both single and multicore cables.

3.3.6 The IP rating shall be determined when the luminaire is free standing and not mounted during testing.

3.3.7 Diffusers and lids shall have captive fixings.

3.3.8 The luminaire body shall be available in different colours upon request.

3.3.9 Where lids are removable, the luminaire shall have provision for additional fixings through the use of chains or lanyards. Down lights below 10 inches in diameter are excluded from this requirement.

3.3.10 The luminaire shall be rated at IP65.

3.3.11 Diffusers shall have the option to be coated with polymeric resin or equivalent technology to reduce the accumulation of dirt and grime.

3.4 Operation and Maintenance

3.4.1 The Supplier shall submit a manufactures installation instruction specifying how the luminaire should be installed.

3.4.2 The manufactures installation instruction shall specify the correct installation method for cable glands, through the provision of photographs.

3.4.3 The Supplier shall submit an Operation and Maintenance (O&M) manual specifying how the luminaire should be maintained.

3.4.4 The O&M manual shall include wiring diagrams for the luminaire.

3.4.5 The Supplier shall demonstrate how the following maintenance activities can be executed through the provision of photographs

- Cleaning.
- Relamping.
- Replacement of luminaires and their individual components.
- Access for inspection.

3.4.6 The Supplier shall demonstrate how to maintain the IP rating throughout the life of the luminaire and shall provide details of the methodology in the O&M Manual.

3.4.7 Maintenance of the IP rating must take into account the environmental conditions of London Underground.

3.4.8 The O&M manual shall contain a complete list of spare parts along with their rated life.

3.4.9 The O&M manual shall specify the limits of the maintenance tasks that can be undertaken without voiding the warranty.

MAYOR OF LONDON
Transport for London
Documents
UNDERGROUND
Copyright London Underground Library
Provided by IHS
No reproduction or networking permitted without license from IHS
Full document details: LUL T0054 2015
Licensee=Weston Williamson/5989497001, User=sam, albett
Not for Resale, 03/28/2016 05:17:39 MDT