

NFPA®

1

Fire Code

Code | 2024



Documents

Document Sharing Hub

Copyright © NFPA. For exclusive use on NFPA Free Access platform. Not for distribution, downloading, or printing.

For inquiries contact custserv@nfpa.org. To report unauthorized use, contact legal@nfpa.org.

Full document details: NFPA 1 2024

NFPA® 1

Fire Code

2024 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02269-9101
An International Codes and Standards Organization

Documents
Document Sharing Hub

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A **Δ** before a section number indicates that words within that section were deleted and a **Δ** to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the **Δ** symbol. Where one or more sections were deleted, a **•** is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an **N**.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at www.nfpa.org/docinfo. Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.



ALERT: THIS STANDARD HAS BEEN MODIFIED BY A TIA OR ERRATA

NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) may be superseded at any time by the issuance of a new edition, be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. This updating considers the then-current and available information on incidents, materials, technologies, innovations, and methods that develop over time. Therefore, any previous edition may no longer represent the current NFPA Standard on the subject matter. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata]. An official NFPA Standard at any point in time consists of the current edition of the document, with any issued TIAs and Errata. Visit the “Codes & Standards” section at www.nfpa.org for more information.

ADDITIONAL IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at www.nfpa.org.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

Copyright © 2023 National Fire Protection Association®. All Rights Reserved.

NFPA® 1

Fire Code

2024 Edition

This edition of NFPA 1, *Fire Code*, was prepared by the Technical Committees on Building Systems and Special Occupancies; Fundamentals of the Fire Code; and Special Equipment, Processes and Hazardous Materials. It was released by the Correlating Committee on Fire Code. It was issued by the Standards Council on August 25, 2023, with an effective date of September 14, 2023, and supersedes all previous editions.

This document has been amended by one or more Tentative Interim Amendments (TIAs) and/or Errata. See “Codes & Standards” at www.nfpa.org for more information.

This edition of NFPA 1 was approved as an American National Standard on September 14, 2023.

Origin and Development of NFPA 1

This *Code* was originally developed as a result of the requests of many members of the National Fire Protection Association for a document covering all aspects of fire protection and prevention that used the other developed NFPA codes and standards. NFPA staff initiated this work in 1971 upon a directive from the NFPA Board of Directors. The original code was written around a format that served as a guide for the development of a local fire prevention code. Prerogatives of local officials were excluded from the main text of the document but were included within appendices as guidance for exercising desired prerogatives.

In the late 1980s, the Fire Marshals Association of North America (now the International Fire Marshals Association [IFMA]) undertook the task of developing a code that was more self-contained, adding administrative sections and extracting heavily from other NFPA codes and standards. The draft was submitted to the Fire Prevention Code Committee. The committee examined changes in the built environment as it is affected by fire and incorporated significant portions of the *Life Safety Code*®. A special task group on hazardous materials examined technological changes in the handling, storage, and use of flammable and combustible materials. Chapters extracting hazardous material requirements placed a greater emphasis on protection of life and property from chemical products made and used in the environment. A major rewrite resulted in the 1992 edition of the *Fire Prevention Code*.

The 1997 edition updated the text extracted from other NFPA codes and standards and added compliance with additional NFPA codes and standards as part of the requirements of NFPA 1.

The 2000 edition of NFPA 1 was a complete revision that updated the text extracted from other NFPA codes and standards. Additional direct references from NFPA codes and standards that are essential to a code official's use of the document were added. The committee also added a new section on performance-based design as a tool for code officials and design professionals. NFPA 1 was restructured to be more functional with respect to administration, code enforcement, and regulatory adoption processes.

The 2003 edition of NFPA 1, *Uniform Fire Code*™, was a complete revision. It incorporated provisions from the Western Fire Chiefs, *Uniform Fire Code*™, under a partnership between NFPA and Western Fire Chiefs, while it updated and expanded the provisions extracted from other key NFPA codes and standards. To emphasize the partnership, the document was renamed NFPA 1, *Uniform Fire Code*™. The *Uniform Fire Code* is a trademark of the Western Fire Chiefs Association. NFPA 1, *Uniform Fire Code*™, was restructured into parts to be more compatible with the regulatory adoption procedures, including administration and code enforcement, occupancies, processes, equipment, and hazardous materials provisions. The Committee included a newly expanded chapter on performance-based design as an enhanced tool for code officials and design professionals. Additional extracts and references from NFPA codes and standards that are essential to a code official's use of the document were added, bringing the number of referenced NFPA codes and

standards to over 125. Additional chapters on hazardous materials were included that incorporate the provisions covered in the *Uniform Fire Code*[™].

The 2006 edition of NFPA 1, *Uniform Fire Code*, was a complete revision of the code that incorporated the provisions from NFPA 230, *Standard for the Fire Protection of Storage*. The Technical Committee on Uniform Fire Code had been given responsibility for NFPA 230 by the NFPA Standards Council, so they incorporated the requirements into NFPA 1 rather than maintain a separate standard.

The 2006 edition of NFPA 1 also included new chapters on classification of occupancy, motion picture studios, outdoor tire storage, and general storage, along with other extracted provisions updated and expanded the from other key NFPA codes and standards that were essential to a code official's use of the document. The number of NFPA codes and standards referenced in this edition was 117.

With the 2009 edition of NFPA 1, the title of the document was changed from *Uniform Fire Code* to *Fire Code*. The revision updated all the extracted provisions from the 117 codes and standards that were included as mandatory reference publications in the 2006 edition. The revisions also included an expansion of Section 12.5 on interior finish to contain extracted provisions from NFPA 101; an expansion of Section 12.6 on furnishings, contents, decorations, and treated fabrics to contain extracted provisions from NFPA 101; a new Section 18.4, which moved fire flow requirements for buildings from Annex H; a new Section 32.5 for regulating locations for motion picture and television production studios, soundstages, and approved production facilities with extracted provisions from NFPA 140; and new Sections 40.3 through 40.7 on combustible dust explosion protection and fire prevention with extracted provisions from NFPA 654. Additional information on hazardous materials classifications was added to Annex B. This revision also added three annexes to the 2009 edition, including Annex O, In-Building Public Safety Radio Enhancement Systems; Annex P, Fire Department Service Delivery Concurrency Evaluation; and Annex Q, Fire Fighter Safety Building Marking System. The number of NFPA codes and standards referenced in this edition was 119.

Six annexes published in the 2006 edition were deleted from the 2009 edition, including Annex E, Model Citation Program; Annex F, Model Fees and Charges Program; Annex H, Fire Flow Requirements for Buildings; Annex J, Protection of Outdoor Storage; Annex M, Recommendations for Fighting Rubber Tire Fires in Sprinklered Buildings; and Annex N, AHJ Minimum Qualifications and Job Descriptions for Code Enforcement Personnel.

The 2012 edition of NFPA 1 included revisions to requirements for the fire code board of appeals (Section 1.10); certificates of fitness (Section 1.13); application limits of referenced standards (Section 2.1); emergency plan provisions (Section 10.9); prohibited storage of grills on balconies (10.11.6.2); new requirements for standardized elevator keys (11.3.6); new requirements for determination of fire department communication capabilities in buildings and two-way radio communication enhancement systems and deleted former Annex O (Section 11.10); medical gas and vacuum systems (Section 11.11); photovoltaic systems (Section 11.12); quality assurance of fire barrier penetrations and joints (12.3.2); and automatic sprinkler system requirement for new buildings three or more stories in height above grade (13.3.2.4). The 2012 edition also relocated former Annex P to the new Chapter 15, Fire Department Service Delivery Concurrency Evaluation; expanded Chapter 17, Wildland Urban Interface; added a new Chapter 36, Telecommunication Facilities and Information Technology Equipment; added a new Chapter 37, Fixed Guideway Transit and Passenger Rail Systems; added requirements for carbon monoxide detection in residential occupancies; relocated former Annex G to the new Chapter 54, Ozone Gas-Generating Equipment; extensively revised Chapter 60, Hazardous Materials, to extract from NFPA 400, *Hazardous Materials Code*; updated Chapter 66, Flammable and Combustible Liquids, per the current edition of NFPA 30, *Flammable and Combustible Liquids Code*; revised Chapter 67, Flammable Solids, to reference NFPA 400; revised Chapter 68, Highly Toxic and Toxic Solids and Liquids, to reference NFPA 400; completely revised Chapter 70, Oxidizer Solids and Liquids; revised Chapter 71, Pyrophoric Solids and Liquids, to reference NFPA 400; revised Chapter 72, Unstable (Reactive) Solids and Liquids, to reference NFPA 400; added a new Chapter 74, Ammonium Nitrate; added a new Chapter 75, Organic Peroxide Solids and Liquids; deleted Annex K, Explanation of Rack Storage Test Data and Procedures; deleted Annex L, Protection of Baled Cotton: History of Guidelines; and updated all extracts through the Annual 2011 revision cycle.

Key revisions for the 2015 edition of NFPA 1 included the prohibition of the use of sky lanterns (10.10.9.3); expanded application of photovoltaic system requirements to existing installations (Section 11.12); AHJ authorization to permit the removal of nonrequired, existing occupant-use hose (13.2.2.6); mandatory automatic sprinkler requirement for all new hotels without exception (13.3.2.15); enhanced attic protection for residential board and care occupancies with residential sprinkler systems (13.3.2.21.2.7); expanded occupancy-based fire alarm system provisions to correlate with NFPA 101 (Section 13.7); new occupant load factor for concentrated business use (14.8.1.2); completely revised fire hydrant location and distribution requirements and deleted former Annex E (Section 18.5); revisions to NFPA 654 extracts for dust explosion prevention (Chapter 40); new hot work permit limits from NFPA 51B (41.3.4.4); expanded existing commercial cooking equipment extinguishing system requirements from NFPA 96 (50.4.4.3.2); expanded ammonia refrigeration system maintenance and testing requirements (Section 53.3); updated hazardous materials maximum allowable quantities from NFPA 400 (60.4.2); new provisions for alcohol-based hand rub dispensers from NFPA 101 (60.5.2); revisions to aerosol product classifications from NFPA 30B (61.1.3); new requirements for cleaning and purging gas piping systems from NFPA 55 (63.3.1.19); new provisions for cooking oil storage tank systems in commercial kitchens from NFPA 30 (66.19.7); and updates of all extracts through the Annual 2014 revision cycle.

The 2018 edition of NFPA 1 included revisions to requirements for the application of referenced publications (1.4.1.1 and 2.1.1); references for the professional qualifications for fire inspectors, plan examiners, and fire marshals (1.7.2); new minimum fire prevention inspection frequencies for existing occupancies (10.2.7); updates to premises identification (10.11.1); new and updated marking and access criteria for photovoltaic systems (Section 11.12); new provisions for rubberized asphalt melters (Section 16.7); listing requirements for electric gates used on fire department access roads (18.2.4.2.6); new provisions on the outside storage of biomass feedstock (31.3.10); new requirements for the outdoor storage of wood and wood composite pallets or listed pallets equivalent to wood (34.10.3); a new chapter on marijuana growing, processing, or extraction facilities (Chapter 38); a revision of Chapter 40 to replace extracts from NFPA 654 with extracted provisions from NFPA 652 (Chapter 40); complete reorganization of aircraft fuel servicing provisions in accordance with NFPA 407 (Section 42.10); a new section on mobile and temporary cooking operations (Section 50.7); extensive revisions of Chapter 52 on energy storage systems (Chapter 52); a new Chapter 55 on cleaning and purging of flammable gas piping systems with reference to NFPA 56 (Chapter 55); new provisions for insulated liquid carbon dioxide systems extracted from NFPA 55 (Section 63.9); a new annex on fire-fighter breathing-air replenishment systems (Annex E); and updates of all extracts through the Annual 2017 revision cycle.

Key revisions for the 2021 edition included updates to in-building emergency responder communication enhancement system requirements for better alignment with NFPA 1221 (Section 11.10); new signage requirements for nonsprinklered high-rise buildings (13.3.2.25.2.4); new provisions for carbon dioxide enrichment equipment, indoor horticultural grow structures, and listing requirements for extraction equipment as they relate to cannabis facilities (Chapter 38); a new chapter on wastewater treatment and collection facilities (Chapter 39); a new chapter on additive manufacturing (3D printing, Chapter 46); energy storage system requirements extracted from NFPA 855 (Chapter 52); and updates of all extracts through the Annual 2020 revision cycle.

The 2024 edition of NFPA 1 includes revisions to the requirements for permits (1.13.8); new requirements for inspections during declared disasters (1.7.7.6); new requirements for pre-incident planning (Section 1.10); revisions to requirements for document retention for AHJs (1.12.1.1); new requirements for the outdoor use of electrically powered cooking appliances in residential occupancies (10.10.6); new requirements for charging of micromobility devices (Section 10.21); revisions to requirements for listing of relocatable power taps (11.1.4); revisions to requirements for in-building emergency responder communication enhancement systems, including new references to NFPA 1225 (Section 11.10); new requirements for timeframes for correcting impairments in water-based fire protection systems (13.1.9); new requirements for inspection and testing of private fire service mains (13.5.4); removal of all extracts from NFPA 241 and replacement with reference to NFPA 241 (Chapter 16); new requirements for handling and storage of batteries for automobile wrecking yards (22.9.6); revised classifications for mechanical refrigeration (Chapter 53); and updates to all extracts through the Annual 2023 revision cycle.

NFPA 1 reflects the technical knowledge of the committees responsible for the codes and standards referenced in, and from which text is extracted and incorporated into, the technical provisions of NFPA 1. This *Code* is intended to provide state, county, and local jurisdictions with an effective fire code.

Correlating Committee on Fire Code

Kenneth E. Bush, *Chair*

Maryland State Fire Marshals Office, MD [E]

Carl F. Baldassarra, Wiss, Janney, Elstner Associates, Inc., IL [SE]

Scott M. Bryant, Fire & Risk Alliance LLC, MD [U]
Rep. Edison Electric Institute

Chris L. Butts, Sompo International, NC [I]

Shane M. Clary, Bay Alarm Company, CA [M]
Rep. Automatic Fire Alarm Association, Inc.

Robert J. Davidson, Davidson Code Concepts, LLC, SC [SE]

John August Denhardt, American Fire Sprinkler Association (AFSA), TX [IM]

Ernest J. Gallo, Telcordia Technologies (Ericsson), NJ [U]
Rep. Alliance for Telecommunications Industry Solutions

Marvin Dwayne Garriss, Synergy Consortium Group, LLC, GA [M]
Rep. Fire Equipment Manufacturers' Association

Edward M. Hawthorne, DFW Dynamics, TX [U]
Rep. American Petroleum Institute

Rick Heffernan, SDi, NJ [M]
Rep. National Electrical Manufacturers Association

David W. Hollinger, Drexel University, PA [U]

Jeffrey M. Hugo, National Fire Sprinkler Association, Inc., MI [M]

James Kendzel, American Supply Association, IL [M]

William E. Koffel, Koffel Associates, Inc., MD [SE]

Kelly T. Nicoletto, UL LLC, TX [RT]

Michael O'Brian, Code Savvy Consultants, MI [SE]

Raymond C. O'Brocki, American Wood Council, DE [M]
Rep. American Wood Council

Wade Palazini, JENSEN HUGHES, RI [SE]

Leonard J. Ramo, Telgian Corporation, GA [SE]

Steven F. Sawyer, Retired, CT [E]
Rep. International Fire Marshals Association

Catherine L. Stashak, Office of the Illinois State Fire Marshal, IL [E]

Kenneth Earl Tyree, Jr., West Virginia State Fire Marshals Office, WV [E]

Peter J. Willse, Portland Fire Marshal's Office, CT [E]

Alternates

Roland A. Asp, National Fire Sprinkler Association, Inc., MD [M]
(Alt. to Jeffrey M. Hugo)

Kevin Ryan Hall, American Fire Sprinkler Association (AFSA), MD [IM]
(Alt. to John August Denhardt)

Roy C. Kimball, Brooks Equipment Company, LLC, NC [M]
(Alt. to Marvin Dwayne Garriss)

Richard G. Kluge, Ericsson, NJ [U]
(Alt. to Ernest J. Gallo)

Brian L. Olsen, Phillips 66, OK [U]
(Alt. to Edward M. Hawthorne)

Rodger Reiswig, Johnson Controls, VA [M]
(Alt. to Shane M. Clary)

David P. Tyree, American Wood Council, CO [M]
(Alt. to Raymond C. O'Brocki)

Nonvoting

Bruce E. Johnson, UL LLC, NY [RT]
Rep. TC on Building Systems and Special Occupancies

James S. Peterkin, TLC Engineering, FL [U]
Rep. TC on Fundamentals

Jen Sisco, NFPA Staff Liaison

Michael D. Snyder, Dekra Insight, MI [RT]
Rep. TC on Special Equipment, Processes and Hazardous Materials

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This committee shall have primary responsibility for documents on a Fire Prevention Code that includes appropriate administrative provisions, to be used with the National Fire Codes for the installation, operation, and maintenance of buildings, structures, and premises for the purpose of providing safety to life and property from fire and explosion. This includes development of requirements for, and maintenance of, systems and equipment for fire control and extinguishment. Safety to life of occupants of buildings and structures is under the primary jurisdiction of the Committee on Safety to Life.

Technical Committee on Building Systems and Special Occupancies

Bruce E. Johnson, *Chair*
UL LLC, NY [RT]

Musfiqul Azad, Prokausholee Bangladesh, Bangladesh [SE]
Laura Bennett-Hourigan, Walt Disney World Parks & Resorts, FL [U]
Justin B. Biller, Emerson Graham + Associates, VA [SE]
Ralph E. Bless, Jr., Telgian Corporation, GA [SE]
Kenneth E. Bush, Maryland State Fire Marshals Office, MD [E]
Chris L. Butts, Sompo International, NC [I]
Michael Connolly, Jacobs Engineering, MD [SE]
Timothy R. Costello, Wiss, Janney, Elstner Associates, Inc., NJ [SE]
Andrew Fukuda, Honolulu Fire Department, HI [L]
Marvin Dwayne Garriss, Synergy Consortium Group, LLC, GA [M]
 Rep. Fire Equipment Manufacturers' Association
Kevin Ryan Hall, American Fire Sprinkler Association (AFSA), MD [IM]
Sarina L. Hart, Koffel Associates, Inc., MD [SE]
Edward M. Hawthorne, DFW Dynamics, TX [U]
 Rep. American Petroleum Institute
Terin Hopkins, National Fire Sprinkler Association (NFSA), MD [M]
Jaewook Kwon, Loring Consulting Engineers, Inc., NY [SE]
Maria B. Marks, Siemens Industry, Inc., MD [M]
 Rep. Automatic Fire Alarm Association, Inc.
Balakrishnan V. Nair, TUV-SUD, Singapore [SE]
Sam Newman, Flame King, CA [M]

Raymond C. O'Brocki, American Wood Council, DE [M]
 Rep. American Wood Council
James S. Peterkin, TLC Engineering, PA [U]
 Rep. NFPA Health Care Section
Richard Jay Roberts, Honeywell Fire Safety, IL [M]
Bruce L. Rottner, H2M Architects & Engineers, NJ [SE]
Mohammed A. Saeeefan, Saudi Aramco, Saudi Arabia [U]
Michael L. Savage, Sr., Marion County Building Safety, FL [E]
Steven F. Sawyer, Retired, CT [E]
 Rep. New England Association of Fire Marshals
Kenneth R. Schneider, UA-ITF, MO [L]
Michael Sheehan, SLS Consulting, Inc., FL [SE]
 Rep. Property Markets Group (PMG)
Alex Spataru, The Adept Group, Inc., CA [SE]
Catherine L. Stashak, Office of the Illinois State Fire Marshal, IL [E]
Michael J. Thomas, California State University, Los Angeles, CA [RT]
Kenneth Earl Tyree, Jr., West Virginia State Fire Marshals Office, WV [E]
Carl F. Weaver, Greater Orlando Aviation Authority, FL [U]
Peter J. Willse, Portland Fire Marshal's Office, CT [E]
Jeremy Zeedyk, National Energy Management Institute Committee (NEMIC), CT [IM]

Alternates

Daniel Buuck, National Association of Home Builders (NAHB), DC [U]
 (Voting Alt.)
Shane M. Clary, Bay Alarm Company, CA [M]
 (Alt. to Maria B. Marks)
Ty Darby, International Association of Fire Fighters (IAFF), OR [L]
 (Alt. to Andrew Fukuda)
John August Denhardt, American Fire Sprinkler Association (AFSA), TX [IM]
 (Alt. to Kevin Ryan Hall)
Matthew Michael DonMoyer, NBC Universal Parks and Resorts, FL [U]
 (Alt. to Laura Bennett-Hourigan)
Tracy L. Vecchiarelli, NFPA Staff Liaison

Chris Hill, Edwards/CARRIER/UTC/Kidde Safety, FL [M]
 (Alt. to Richard Jay Roberts)
Roy C. Kimball, Brooks Equipment Company, LLC., NC [M]
 (Alt. to Marvin Dwayne Garriss)
Kelly T. Nicoletto, UL LLC, TX [RT]
 (Alt. to Bruce E. Johnson)
Brian L. Olsen, Phillips 66, OK [U]
 (Alt. to Edward M. Hawthorne)
Vincent Powers, National Fire Sprinkler Association (NFSA), MD [M]
 (Alt. to Terin Hopkins)

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This committee shall have primary responsibility for documents on building fire protection and life safety systems, construction operations, occupancy fire safety and definitions for the purpose of providing safety to life and property from fire and explosion.

Technical Committee on Fundamentals of the Fire Code

James S. Peterkin, *Chair*
TLC Engineering, PA [U]
Rep. NFPA Health Care Section

Mohammed Abdulah Alkhalidi, Saudi Aramco Refinery, Saudi Arabia [U]

Anthony C. Apfelbeck, Altamonte Springs Building/Fire Safety Division, FL [E]

Tracey D. Bellamy, Telgian Corporation, GA [SE]

H. Butch Browning, Jr., Louisiana Office of State Fire Marshal, LA [E]

Rep. International Association of Fire Chiefs

Kenneth E. Bush, Maryland State Fire Marshals Office, MD [E]

Chris L. Butts, Sompo International, NC [I]

Daniel Buuck, National Association of Home Builders (NAHB), DC [U]

Rep. National Association of Home Builders (NAHB)

Ramjee Pradeep Chand, Ezone Rest Assured, India [M]

Shane M. Clary, Bay Alarm Company, CA [M]
Rep. Automatic Fire Alarm Association, Inc.

Michael Scott Custer, Fort Detrick Fire Department, MD [E]

Andrew Fukuda, Honolulu Fire Department, HI [L]

Marvin Dwayne Garriss, Synergy Consortium Group, LLC, GA [M]
Rep. Fire Equipment Manufacturers' Association

Kevin Ryan Hall, American Fire Sprinkler Association (AFSA), MD [IM]

Sarina L. Hart, Koffel Associates, Inc., MD [SE]

Terin Hopkins, National Fire Sprinkler Association (NFSA), MD [M]

Michael A. Jackson, Philadelphia Fire Department, PA [E]

James Kendzel, American Supply Association, IL [M]
Rep. American Supply Association

Scott T. Laramee, AON Property Risk, CA [I]

Brian Mosberian, Phoenix Fire Department, AZ [E]

Kelly T. Nicoletto, UL LLC, TX [RT]

Michael O'Brian, Code Savvy Consultants, MI [SE]

Raymond C. O'Brocki, American Wood Council, DE [M]
Rep. American Wood Council

Brian L. Olsen, Phillips 66, OK [U]

Rep. American Petroleum Institute

Wade Palazini, JENSEN HUGHES, RI [SE]

Gary S. Santoro, Self Employed, FL [SE]

Steven F. Sawyer, Retired, CT [E]
Rep. New England Association of Fire Marshals

Randy H. Schubert, Ericsson, NJ [U]

Rep. Alliance for Telecommunications Industry Solutions

Robert E. Solomon, SLS Consulting, Inc., MA [SE]

Catherine L. Stashak, Office of the Illinois State Fire Marshal, IL [E]

Kenneth Earl Tyree, Jr., West Virginia State Fire Marshals Office, WV [E]

Christopher Weniger, Hillsborough Township Fire Commission, NJ [E]

Alternates

Ty Darby, International Association of Fire Fighters (IAFF), OR [L]
(Alt. to Andrew Fukuda)

John August Denhardt, American Fire Sprinkler Association (AFSA), TX [IM]
(Alt. to Kevin Ryan Hall)

Ernest J. Gallo, Telcordia Technologies (Ericsson), NJ [U]
(Alt. to Randy H. Schubert)

Edward M. Hawthorne, DFW Dynamics, TX [U]
(Alt. to Brian L. Olsen)

Jeffrey M. Hugo, National Fire Sprinkler Association, Inc., MI [M]
(Alt. to Terin Hopkins)

Bruce E. Johnson, UL LLC, NY [RT]
(Alt. to Kelly T. Nicoletto)

Roy C. Kimball, Brooks Equipment Company, LLC., NC [M]
(Alt. to Marvin Dwayne Garriss)

Rodger Reiswig, Johnson Controls, VA [M]
(Alt. to Shane M. Clary)

Annie Renee Therrien, SLS Consulting, Inc., NC [SE]
(Alt. to Robert E. Solomon)

Janet A. Washburn, Bonita Springs Fire Control District, FL [E]
(Alt. to H. Butch Browning, Jr.)

Jen Sisco, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This committee shall have primary responsibility for documents on the basic goals, objectives, performance requirements, classification of occupancy, general safety requirements, building services, fire department access, and definitions for the purpose of providing safety to life and property from fire and explosion.

Technical Committee on Special Equipment, Processes and Hazardous Materials

Michael D. Snyder, *Chair*
Dekra Insight, MI [RT]

Chris L. Butts, Sompo International, NC [I]
John Caliri, SLS Consulting, Inc., GA [SE]
Kathryn M. Cifa, Bechtel National, Inc., VA [SE]
Benjamin Craig, Insight Risk/D.B.A. REM Risk Consultants, TX [SE]
Robert J. Davidson, Davidson Code Concepts, LLC, SC [SE]
Jeffery Charles Dunkel, National Fire Sprinkler Association (NFSA), KS [M]
Andrew Fukuda, Honolulu Fire Department, HI [L]
Michael Anthony Galfano, UA-ITF, IL [L]
Marvin Dwayne Garriss, Synergy Consortium Group, LLC, GA [M]
 Rep. Fire Equipment Manufacturers' Association
Joseph Henry Griner, Griner Engineering, FL [SE]
Kevin Ryan Hall, American Fire Sprinkler Association (AFSA), MD [IM]
James Herrmann, Williams County Emergency Management, ND [U]

David W. Hollinger, Drexel University, PA [U]
Kevin J. Kelly, Victaulic, PA [M]
Richard G. Kluge, Ericsson, NJ [U]
 Rep. Alliance for Telecommunications Industry Solutions
William E. Koffel, Koffel Associates, Inc., MD [SE]
Kelly T. Nicolello, UL LLC, TX [RT]
Brian L. Olsen, Phillips 66, OK [U]
 Rep. American Petroleum Institute
Nicholas Ozog, Wiss, Janney, Elstner Associates, Inc., IL [SE]
Geoffrey A. Raifsnider, Global Finishing Solutions, WI [M]
Leonard J. Ramo, Telgian Corporation, GA [SE]
Ryan Sandler, ADT Commercial LLC./Red Hawk Fire Security, CA [M]
 Rep. Automatic Fire Alarm Association, Inc.
Catherine L. Stashak, Office of the Illinois State Fire Marshal, IL [E]
Peter J. Willse, Portland Fire Marshal's Office, CT [E]

Alternates

Ty Darby, International Association of Fire Fighters (IAFF), OR [L]
 (Alt. to Andrew Fukuda)
Edward M. Hawthorne, DFW Dynamics, TX [U]
 (Alt. to Brian L. Olsen)
Bruce E. Johnson, UL LLC, NY [RT]
 (Alt. to Kelly T. Nicolello)
Roy C. Kimball, Brooks Equipment Company, LLC., NC [M]
 (Alt. to Marvin Dwayne Garriss)
Joshua P. McDonald, American Fire Sprinkler Association (AFSA), TX [IM]
 (Alt. to Kevin Ryan Hall)
Alex Ing, NFPA Staff Liaison

Chad Putney, Portsmouth Fire Department (NH), NH [M]
 (Alt. to Ryan Sandler)
Ronald W. Ritchey, National Fire Sprinkler Association (NFSA), IN [M]
 (Alt. to Jeffery Charles Dunkel)
Randy H. Schubert, Ericsson, NJ [U]
 (Alt. to Richard G. Kluge)

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This committee shall have primary responsibility for documents on special equipment and processes in buildings, the storage, use and handling of hazardous materials indoors and outdoors, and definitions for the purpose of providing safety to life and property from fire and explosion.

Contents

Chapter 1 Administration	1- 13	10.10 Open Flames, Candles, Open Fires, and Incinerators.	1- 72
1.1 Scope.	1- 13	10.11 Fire Protection Markings.	1- 73
1.2 Purpose.	1- 13	10.12 Seasonal and Vacant Buildings and Premises.	1- 74
1.3 Application.	1- 13	10.13 Combustible Vegetation.	1- 74
1.4 Equivalencies, Alternatives, and Modifications.	1- 14	10.14 Special Outdoor Events, Carnivals, and Fairs.	1- 74
1.5 Units.	1- 14	10.15 Portable and Vehicle-Mounted Generators.	1- 77
1.6 Enforcement.	1- 15	10.16 Outside Storage.	1- 78
1.7 Authority.	1- 15	10.17 Parade Floats.	1- 78
1.8 Duties and Powers of the Incident Commander. ..	1- 16	10.18 Powered Industrial Trucks.	1- 78
1.9 Liability.	1- 17	10.19 Storage of Combustible Materials.	1- 78
1.10 Pre-incident Planning.	1- 17	10.20 Indoor Play Structures.	1- 79
1.11 Fire Code Board of Appeals.	1- 17	10.21 Powered Micromobility Devices.	1- 79
1.12 Records and Reports.	1- 18	10.22 Alcohol-Based Hand-Rub (ABHR) Dispensers.	1- 80
1.13 Permits and Approvals.	1- 18	Chapter 11 Building Services	1- 81
1.14 Certificates of Fitness.	1- 24	11.1 Electrical Fire Safety.	1- 81
1.15 Plan Review.	1- 25	11.2 Heating, Ventilation, and Air-Conditioning.	1- 82
1.16 Technical Assistance.	1- 26	11.3 Elevators, Escalators, and Conveyors.	1- 82
1.17 Notice of Violations and Penalties.	1- 26	11.4 Utilities.	1- 83
1.18 Fees.	1- 26	11.5 Heating Appliances.	1- 83
Chapter 2 Referenced Publications	1- 27	11.6 Waste Chutes, Incinerators, and Laundry Chutes.	1- 84
2.1 General.	1- 27	11.7 Stationary Generators and Standby Power Systems.	1- 84
2.2 NFPA Publications.	1- 27	11.8 Smoke Control.	1- 85
2.3 Other Publications.	1- 29	11.9 Emergency Command Center.	1- 85
2.4 References for Extracts in Mandatory Sections. ...	1- 34	11.10 In-Building Emergency Responder Communication Enhancement Systems.	1- 85
Chapter 3 Definitions	1- 35	11.11 Medical Gas and Vacuum Systems.	1- 85
3.1 General.	1- 35	11.12 Photovoltaic Systems.	1- 85
3.2 NFPA Official Definitions.	1- 35	Chapter 12 Features of Fire Protection	1- 88
3.3 General Definitions.	1- 35	12.1 General.	1- 88
3.4 Special Performance-Based Definitions.	1- 56	12.2 Construction.	1- 88
Chapter 4 General Requirements	1- 57	12.3 Fire-Resistive Materials and Construction.	1- 88
4.1 Goals and Objectives.	1- 57	12.4 Fire Doors and Other Opening Protectives.	1- 89
4.2 Assumptions.	1- 58	12.5 Interior Finish.	1- 92
4.3 Compliance Options.	1- 58	12.6 Contents and Furnishings.	1- 95
4.4 Fundamental Requirements.	1- 58	12.7 Fire Barriers.	1- 97
4.5 General Requirements.	1- 59	12.8 Smoke Partitions.	1- 102
Chapter 5 Performance-Based Option	1- 61	12.9 Smoke Barriers.	1- 103
5.1 General.	1- 61	Chapter 13 Fire Protection Systems	1- 105
5.2 Performance Criteria.	1- 62	13.1 General.	1- 105
5.3 Retained Prescriptive Requirements.	1- 62	13.2 Standpipe Systems.	1- 106
5.4 Design Scenarios.	1- 63	13.3 Sprinkler Systems.	1- 107
5.5 Evaluation of Proposed Designs.	1- 64	13.4 Fire Pumps.	1- 120
5.6 Safety Factors.	1- 64	13.5 Water Supply.	1- 121
5.7 Documentation Requirements.	1- 64	13.6 Portable Fire Extinguishers.	1- 121
Chapter 6 Classification of Occupancy	1- 65	13.7 Detection, Alarm, and Communications Systems.	1- 130
6.1 Classification of Occupancy.	1- 65	13.8 Other Fire Protection Systems.	1- 161
Chapter 7 Reserved	1- 70	13.9 Non-Listed Fire Protection or Suppression Devices and Equipment.	1- 161
Chapter 8 Reserved	1- 70	Chapter 14 Means of Egress	1- 162
Chapter 9 Reserved	1- 70	14.1 Application.	1- 162
Chapter 10 General Safety Requirements	1- 70	14.2 Exit Access Corridors.	1- 162
10.1 Fundamental Requirements.	1- 70	14.3 Exits.	1- 162
10.2 Owner/Operator/Tenant Responsibilities.	1- 70	14.4 Means of Egress Reliability.	1- 163
10.3 Occupancy.	1- 70	14.5 Door Openings.	1- 163
10.4 Emergency Action Plans.	1- 71	14.6 Enclosure and Protection of Stairs.	1- 172
10.5 Building Evacuation.	1- 71	14.7 Exit Passageways.	1- 172
10.6 Fire Drills.	1- 71	14.8 Capacity of Means of Egress.	1- 172
10.7 Reporting of Fires and Other Emergencies.	1- 71	14.9 Number of Means of Egress.	1- 175
10.8 Tampering with Fire Safety Equipment.	1- 71	14.10 Arrangement of Means of Egress.	1- 176
10.9 Smoking.	1- 72		

14.11	Discharge from Exits.	1- 178	22.2	Permits.	1- 223
14.12	Illumination of Means of Egress.	1- 179	22.3	Fire Apparatus Access Roads.	1- 223
14.13	Emergency Lighting.	1- 179	22.4	Welding and Cutting.	1- 223
14.14	Marking of Means of Egress.	1- 180	22.5	Housekeeping.	1- 223
14.15	Secondary Means of Escape.	1- 182	22.6	Fire Extinguishers.	1- 223
Chapter 15	Fire Department Service Delivery		22.7	Tire Storage.	1- 223
	Concurrency Evaluation	1- 182	22.8	Burning Operations.	1- 223
15.1	Application.	1- 182	22.9	Motor Vehicle Fluids and Hazardous Materials. ...	1- 223
15.2	Level of Service Objectives.	1- 182	Chapter 23	Cleanrooms	1- 223
15.3	Evaluator Qualifications.	1- 183	23.1	General.	1- 223
15.4	Fire Department Service Delivery Concurrency		23.2	Applicability.	1- 223
	Evaluation Documentation.	1- 183	23.3	Permits.	1- 223
15.5	Independent Review.	1- 183	Chapter 24	Drycleaning	1- 223
15.6	Approval.	1- 183	24.1	General.	1- 223
Chapter 16	Safeguarding Construction, Alteration, and		24.2	Permits.	1- 223
	Demolition Operations	1- 183	Chapter 25	Grandstands and Bleachers, Folding and	
16.1	General Requirements.	1- 183		Telescopic Seating, Tents, and Membrane	
16.2	Alteration of Buildings.	1- 183		Structures	1- 223
16.3	Fire Safety During Demolition.	1- 183	25.1	General.	1- 223
16.4	Torch-Applied Roofing Systems.	1- 183	25.2	Tents.	1- 225
16.5	Tar Kettles and Rubberized Asphalt Melters.	1- 183	25.3	Grandstands.	1- 226
16.6	Asbestos Removal.	1- 186	25.4	Folding and Telescopic Seating.	1- 227
16.7	Lead Removal.	1- 186	25.5	Permanent Membrane Structures.	1- 228
Chapter 17	Wildland Urban Interface	1- 186	25.6	Temporary Membrane Structures.	1- 229
17.1	General.	1- 186	Chapter 26	Laboratories Using Chemicals	1- 230
17.2	Plans.	1- 188	26.1	General.	1- 230
17.3	Wildland Fire-Prone Areas.	1- 188	26.2	Permits.	1- 230
Chapter 18	Fire Department Access and Water Supply ...	1- 190	Chapter 27	Manufactured Home and Recreational	
18.1	General.	1- 190		Vehicle Sites	1- 231
18.2	Fire Department Access.	1- 190	27.1	General.	1- 231
18.3	Water Supplies.	1- 192	27.2	Manufactured Home Sites.	1- 231
18.4	Fire Flow Requirements for Buildings.	1- 192	27.3	Recreational Vehicle Parks and Campgrounds.	1- 231
18.5	Fire Hydrants.	1- 193	Chapter 28	Marinas, Boatyards, Marine Terminals,	
Chapter 19	Combustible Waste and Refuse	1- 196		Piers, and Wharves	1- 231
19.1	General.	1- 196	28.1	Marinas, Boatyards, and Other Recreational	
19.2	Combustible Waste and Refuse.	1- 196		Marine Facilities.	1- 231
Chapter 20	Occupancy Fire Safety	1- 197	28.2	Marine Terminals, Piers, and Wharves.	1- 234
20.1	Assembly Occupancies.	1- 197	28.3	Construction, Conversion, Repair, and Lay-Up of	
20.2	Educational Occupancies.	1- 203		Vessels.	1- 235
20.3	Day-Care Occupancies.	1- 204	Chapter 29	Parking Garages	1- 235
20.4	Health Care Occupancies.	1- 206	29.1	General.	1- 235
20.5	Residential Board and Care Occupancies.	1- 209	Chapter 30	Motor Fuel Dispensing Facilities and Repair	
20.6	Ambulatory Health Care Centers.	1- 211		Garages	1- 235
20.7	Detention and Correctional Occupancies.	1- 212	30.1	Motor Fuel Dispensing Facilities.	1- 235
20.8	Hotels and Dormitories.	1- 214	30.2	Repair Garages for Vehicles Powered by	
20.9	Apartment Buildings.	1- 215		Flammable and Combustible Liquids.	1- 236
20.10	Lodging or Rooming Houses.	1- 215	30.3	Repair Garages for Vehicles Powered by Alternate	
20.11	One- and Two-Family Dwellings and			Fuels.	1- 237
	Manufactured Housing.	1- 216	30.4	Operational Requirements.	1- 243
20.12	Mercantile Occupancies.	1- 216	Chapter 31	Forest Products and Biomass Feedstocks	1- 243
20.13	Business Occupancies.	1- 216	31.1	General.	1- 243
20.14	Industrial Occupancies.	1- 217	31.2	Permits.	1- 243
20.15	Storage Occupancies.	1- 217	31.3	Protection of Storage of Forest Products.	1- 243
20.16	Special Structures and High-Rise Buildings.	1- 218	Chapter 32	Motion Picture and Television Production	
20.17	Historic Buildings and Cultural Resources.	1- 218		Studio Soundstages and Approved	
Chapter 21	Airports and Heliports	1- 218		Production Facilities	1- 247
21.1	Hangars.	1- 218	32.1	General.	1- 247
21.2	Terminals.	1- 219	32.2	Permits.	1- 247
21.3	Rooftop Heliport Construction and Protection. ...	1- 220	32.3	Fire Watch.	1- 247
Chapter 22	Automobile Wrecking Yards	1- 223	32.4	Decorative Materials.	1- 248
22.1	General.	1- 223			

32.5	Smoking.	1- 248	40.13	Emergency Planning and Response.	1- 268
32.6	Pyrotechnic Special Effects and Open Flames.	1- 248	40.14	Incident Investigation.	1- 268
32.7	Fire Department Access.	1- 248	40.15	Management of Change.	1- 268
32.8	Housekeeping.	1- 248	40.16	Documentation Retention.	1- 268
32.9	Soundstages and Approved Production Facilities.	1- 248	40.17	Management Systems Review.	1- 268
32.10	Production Locations.	1- 249	40.18	Employee Participation.	1- 268
Chapter 33	Outside Storage of Tires	1- 250	Chapter 41	Welding, Cutting, and Other Hot Work	1- 269
33.1	General.	1- 250	41.1	General.	1- 269
33.2	Individual Piles.	1- 250	41.2	Responsibility for Hot Work.	1- 269
33.3	Emergency Response Plan.	1- 251	41.3	Fire Prevention Precautions.	1- 270
33.4	Fire Control Measures.	1- 251	41.4	Sole Proprietors and Individual Operators.	1- 272
33.5	Site Access.	1- 251	41.5	Public Exhibitions and Demonstrations.	1- 272
33.6	Signs and Security.	1- 251	41.6	Arc Welding Equipment.	1- 272
33.7	Outdoor Storage of Altered Tire Material.	1- 251	Chapter 42	Refueling	1- 272
Chapter 34	General Storage	1- 251	42.1	General.	1- 272
34.1	General.	1- 251	42.2	Automotive Fuel Servicing.	1- 272
34.2	Classification of Commodities.	1- 252	42.3	Storage of Liquids.	1- 273
34.3	Commodity Classes.	1- 252	42.4	Piping for Liquids.	1- 276
34.4	Building Construction.	1- 255	42.5	Fuel Dispensing Systems.	1- 278
34.5	Storage Arrangement.	1- 255	42.6	Building Construction Requirements.	1- 280
34.6	General Fire Protection.	1- 255	42.7	Operational Requirements.	1- 280
34.7	Building Equipment, Maintenance, and Operations.	1- 256	42.8	Additional Requirements for CNG, LNG, Hydrogen, and LP-Gas.	1- 285
34.8	Protection of Rack Storage.	1- 257	42.9	Marine Fueling.	1- 285
34.9	Protection of Rubber Tires.	1- 257	42.10	Aircraft Fuel Servicing.	1- 289
34.10	Protection of Roll Paper.	1- 258	42.11	Alternate Fuels.	1- 305
34.11	Storage of Idle Pallets.	1- 258	42.12	On-Demand Mobile Fueling.	1- 305
Chapter 35	Animal Housing Facilities	1- 259	Chapter 43	Spraying, Dipping, and Coating Using Flammable or Combustible Materials	1- 308
35.1	General.	1- 259	43.1	Application.	1- 308
35.2	Permits.	1- 259	43.2	Automated Electrostatic Spray Equipment.	1- 322
Chapter 36	Telecommunication Facilities and Information Technology Equipment	1- 259	43.3	Handheld Electrostatic Spray Equipment.	1- 322
36.1	General.	1- 259	43.4	Drying, Curing, and Fusion Processes.	1- 322
Chapter 37	Fixed Guideway Transit and Passenger Rail Systems	1- 259	43.5	Miscellaneous Spray Operations.	1- 322
37.1	General.	1- 259	43.6	Powder Coating.	1- 324
Chapter 38	Cannabis Growing, Processing, or Extraction Facilities	1- 260	43.7	Organic Peroxides and Plural Component Coatings.	1- 324
38.1	Application.	1- 260	43.8	Containers. [33:17.7.2]	1- 324
38.2	Permits.	1- 260	43.9	Styrene Cross-Linked Composites Manufacturing (Glass Fiber-Reinforced Plastics).	1- 324
38.3	Fire Protection Systems.	1- 260	43.10	Dipping, Coating, and Printing Processes.	1- 325
38.4	Means of Egress.	1- 260	43.11	Training.	1- 326
38.5	Growing or Production of Cannabis.	1- 260	Chapter 44	Solvent Extraction	1- 326
38.6	Processing or Extraction.	1- 261	44.1	General.	1- 326
38.7	Transfilling.	1- 264	44.2	Application.	1- 326
Chapter 39	Wastewater Treatment and Collection Facilities	1- 264	44.3	Permits.	1- 326
39.1	General.	1- 264	44.4	Special Requirements.	1- 326
Chapter 40	Dust Explosion and Fire Prevention	1- 264	Chapter 45	Combustible Fibers	1- 326
40.1	Application.	1- 264	45.1	General.	1- 326
40.2	Permits.	1- 264	45.2	Electrical Wiring.	1- 326
40.3	Retroactivity.	1- 264	45.3	No Smoking.	1- 326
40.4	General.	1- 264	45.4	Vehicles and Material Handling Equipment.	1- 326
40.5	Dust Hazards Analysis (DHA).	1- 264	45.5	Loose Storage of Combustible Fibers.	1- 326
40.6	Operating Procedures and Practices.	1- 265	45.6	Baled Storage.	1- 327
40.7	Housekeeping.	1- 265	45.7	Storage of Hay, Straw, and Other Similar Agricultural Products.	1- 327
40.8	Hot Work.	1- 267	45.8	Hazardous Materials.	1- 327
40.9	Personal Protective Equipment.	1- 267	Chapter 46	Additive Manufacturing (3D Printing)	1- 328
40.10	Inspection, Testing, and Maintenance.	1- 267	46.1	Application.	1- 328
40.11	Training and Hazard Awareness.	1- 267	46.2	Nonindustrial Additive Manufacturing.	1- 328
40.12	Contractors.	1- 268	46.3	Industrial Additive Manufacturing.	1- 328
			Chapter 47	Reserved	1- 328

Chapter 48	Reserved	1– 328	60.6	Emergency Action Planning, Fire Risk Control, and Chemical Hazard Requirements for Industrial Processes.	1– 360
Chapter 49	Reserved	1– 328	60.7	Performance Alternative.	1– 360
Chapter 50	Commercial Cooking	1– 329	Chapter 61	Aerosol Products	1– 361
50.1	Application.	1– 329	61.1	General Provisions.	1– 361
50.2	General Requirements for Cooking Operations in Buildings and Mobile and Temporary Cooking Operations.	1– 329	61.2	Basic Requirements.	1– 362
50.3	Protection of Coverings and Enclosure Materials.	1– 329	61.3	Storage in Warehouses and Storage Areas.	1– 364
50.4	Fire-Extinguishing Equipment for Cooking Operations in Buildings.	1– 330	61.4	Mercantile Occupancies.	1– 365
50.5	Fire-Extinguishing Equipment for Mobile and Temporary Cooking Operations.	1– 332	61.5	Operations and Maintenance.	1– 366
50.6	Procedures for the Use, Inspection, Testing, and Maintenance of Equipment.	1– 333	Chapter 62	Reserved	1– 367
50.7	Minimum Safety Requirements for Cooking Equipment.	1– 335	Chapter 63	Compressed Gases and Cryogenic Fluids	1– 367
50.8	Mobile and Temporary Cooking Operations.	1– 336	63.1	General Provisions.	1– 367
Chapter 51	Industrial Ovens and Furnaces	1– 339	63.2	Building-Related Controls.	1– 369
51.1	General.	1– 339	63.3	Compressed Gases.	1– 374
51.2	Location.	1– 339	63.4	Cryogenic Fluids.	1– 389
51.3	Safety Controls.	1– 339	63.5	Bulk Oxygen Systems.	1– 396
Chapter 52	Energy Storage Systems	1– 339	63.6	Gas Hydrogen Systems.	1– 396
52.1	General.	1– 339	63.7	Bulk Liquefied Hydrogen Systems.	1– 396
52.2	Remediation Measures.	1– 341	63.8	Gas Generation Systems.	1– 396
52.3	System Interconnection.	1– 341	63.9	Insulated Liquid Carbon Dioxide Systems.	1– 396
52.4	Operation and Maintenance.	1– 341	63.10	Storage, Handling, and Use of Ethylene Oxide for Sterilization and Fumigation.	1– 399
52.5	Electrochemical Energy Storage Systems.	1– 341	63.11	Carbon Dioxide Beverage Systems.	1– 399
52.6	Capacitor Energy Storage Systems.	1– 341	63.12	Liquid Oxygen in Home Care.	1– 400
52.7	Fuel Cell Energy Storage Systems.	1– 341	Chapter 64	Corrosive Solids and Liquids	1– 401
52.8	Storage of Used or Off-Specification Batteries.	1– 341	64.1	General.	1– 401
Chapter 53	Mechanical Refrigeration	1– 341	Chapter 65	Explosives, Fireworks, and Model Rocketry	1– 401
53.1	General.	1– 341	65.1	General.	1– 401
53.2	Safety Features.	1– 342	65.2	Display Fireworks.	1– 401
53.3	Operations, Maintenance, Testing, and Decommissioning.	1– 344	65.3	Pyrotechnics Before a Proximate Audience.	1– 401
Chapter 54	Ozone Gas-Generating Equipment	1– 344	65.4	Flame Effects Before an Audience.	1– 401
54.1	Scope.	1– 344	65.5	Fireworks Manufacturing.	1– 401
54.2	Location.	1– 344	65.6	Model Rocketry.	1– 401
54.3	Piping, Valves, and Fittings.	1– 345	65.7	Rocketry Manufacturing.	1– 401
54.4	Automatic Shutdown.	1– 345	65.8	High Power Rocketry.	1– 401
54.5	Manual Shutdown.	1– 345	65.9	Explosives.	1– 401
Chapter 55	Cleaning and Purging of Flammable Gas Piping Systems	1– 345	Chapter 66	Flammable and Combustible Liquids	1– 402
55.1	Application.	1– 345	66.1	General.	1– 402
55.2	Permits.	1– 345	66.2	Reserved.	1– 402
Chapter 56	Reserved	1– 345	66.3	Definitions.	1– 402
Chapter 57	Reserved	1– 345	66.4	Classification of Liquids.	1– 403
Chapter 58	Reserved	1– 345	66.5	Reserved.	1– 404
Chapter 59	Reserved	1– 345	66.6	Fire and Explosion Prevention and Risk Control.	1– 404
Chapter 60	Hazardous Materials	1– 345	66.7	Electrical Systems.	1– 408
60.1	General Requirements.	1– 345	66.8	Application of Area Classification.	1– 408
60.2	Special Definitions.	1– 346	66.9	Storage of Ignitable (Flammable or Combustible) Liquids in Containers — General Requirements.	1– 408
60.3	Classification of Materials, Wastes, and Hazard of Contents.	1– 347	66.10	Reserved.	1– 417
60.4	Permissible Storage and Use Locations.	1– 347	66.11	Reserved.	1– 417
60.5	Fundamental Requirements.	1– 353	66.12	Reserved.	1– 417
			66.13	Reserved.	1– 417
			66.14	Hazardous Materials Storage Lockers.	1– 417
			66.15	Outdoor Storage.	1– 418
			66.16	Automatic Fire Protection for Inside Liquid Storage Areas.	1– 420
			66.17	Processing Facilities.	1– 452
			66.18	Dispensing, Handling, Transfer, and Use of Ignitable (Flammable or Combustible) Liquids.	1– 459
			66.19	Specific Operations.	1– 461
			66.20	Reserved.	1– 465

66.21	Storage of Ignitable (Flammable or Combustible) Liquids in Tanks — Requirements for All Storage Tanks.	1– 465	Chapter 71	Pyrophoric Solids and Liquids	1– 516
66.22	Storage of Ignitable (Flammable or Combustible) Liquids in Tanks — Aboveground Storage Tanks.	1– 471	71.1	General.	1– 516
66.23	Storage of Ignitable (Flammable or Combustible) Liquids in Tanks — Underground Tanks.	1– 480	Chapter 72	Unstable (Reactive) Solids and Liquids	1– 516
66.24	Storage Tank Buildings.	1– 480	72.1	General.	1– 516
66.25	Storage Tank Vaults.	1– 484	Chapter 73	Water-Reactive Solids and Liquids	1– 516
66.26	Reserved.	1– 485	73.1	General.	1– 516
66.27	Piping Systems.	1– 485	Chapter 74	Ammonium Nitrate	1– 517
66.28	Bulk Loading and Unloading Facilities for Tank Cars and Tank Vehicles.	1– 489	74.1	General.	1– 517
66.29	Wharves.	1– 491	Chapter 75	Organic Peroxide Solids and Liquids	1– 517
Chapter 67	Flammable Solids	1– 494	75.1	General.	1– 517
67.1	General.	1– 494	Annex A	Explanatory Material	1– 518
Chapter 68	Highly Toxic and Toxic Solids and Liquids ..	1– 494	Annex B	Sample Ordinance Adopting the NFPA 1, Fire Code	1– 719
68.1	General.	1– 494	Annex C	Fire Fighter Safety Building Marking System	1– 720
Chapter 69	Liquefied Petroleum Gases and Liquefied Natural Gases	1– 494	Annex D	Firefighter Breathing-Air Replenishment Systems	1– 721
69.1	General Provisions.	1– 494	Annex E	Fire Sprinkler Disclosure Statement for One- and Two-Family Dwellings	1– 721
69.2	LP-Gas Equipment and Appliances.	1– 494	Annex F	Informational References	1– 722
69.3	Installation of LP-Gas Systems.	1– 496	Index		1– 730
69.4	LP-Gas Liquid Transfer.	1– 509			
69.5	Storage of Cylinders Awaiting Use, Resale, or Exchange.	1– 512			
69.6	Vehicular Transportation of LP-Gas.	1– 514			
69.7	LP-Gases at Utility Plants.	1– 516			
69.8	Liquefied Natural Gas (LNG) Facilities.	1– 516			
Chapter 70	Oxidizer Solids and Liquids	1– 516			
70.1	General.	1– 516			

NFPA 1

Fire Code

2024 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Standards.” They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the “List of NFPA Codes & Standards” at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced and extracted publications can be found in Chapter 2 and Annex F.

Chapter 1 Administration

1.1 Scope.

1.1.1* The scope includes, but is not limited to, the following:

- (1) Inspection of permanent and temporary buildings, processes, equipment, systems, and other fire and related life safety situations
- (2) Investigation of fires, explosions, hazardous materials incidents, and other related emergency incidents
- (3) Review of construction plans, drawings, and specifications for life safety systems, fire protection systems, access, water supplies, processes, hazardous materials, and other fire and life safety issues
- (4) Fire and life safety education of fire brigades, employees, responsible parties, and the general public
- (5) Existing occupancies and conditions, the design and construction of new buildings, remodeling of existing buildings, and additions to existing buildings
- (6) Design, installation, alteration, modification, construction, maintenance, repairs, servicing, and testing of fire protection systems and equipment
- (7) Installation, use, storage, and handling of medical gas systems

- (8) Access requirements for fire department operations
- (9) Hazards from outside fires in vegetation, trash, building debris, and other materials
- (10) Regulation and control of special events including, but not limited to, assemblage of people, exhibits, trade shows, amusement parks, haunted houses, outdoor events, and other similar special temporary and permanent occupancies
- (11) Interior finish, decorations, furnishings, and other combustibles that contribute to fire spread, fire load, and smoke production
- (12) Storage, use, processing, handling, and on-site transportation of flammable and combustible gases, liquids, and solids
- (13) Storage, use, processing, handling, and on-site transportation of hazardous materials
- (14) Control of emergency operations and scenes
- (15) Conditions affecting fire fighter safety
- (16) Arrangement, design, construction, and alteration of new and existing means of egress

1.1.2 Title. The title of this Code shall be NFPA 1, *Fire Code*, of the National Fire Protection Association (NFPA).

1.2* Purpose. The purpose of this Code is to prescribe minimum requirements necessary to establish a reasonable level of fire and life safety and property protection from the hazards created by fire, explosion, and dangerous conditions.

1.3 Application.

1.3.1 This Code shall apply to both new and existing conditions.

1.3.2* Referenced Standards.

1.3.2.1 Details regarding processes, methods, specifications, equipment testing and maintenance, design standards, performance, installation, or other pertinent criteria contained in those codes and standards listed in Chapter 2 of this Code shall be considered a part of this Code.

1.3.2.2* Where no applicable codes, standards, or requirements are set forth in this Code or contained within other laws, codes, regulations, ordinances, or bylaws adopted by the authority having jurisdiction (AHJ), compliance with applicable codes and standards of NFPA or other nationally recognized standards, as are approved, or approved performance-based options in accordance with Chapter 5, shall be deemed as prima facie evidence of compliance with the intent of this Code.

1.3.2.3 Nothing herein shall diminish the authority of the AHJ to determine compliance with codes or standards for those activities or installations within the AHJ's responsibility.

1.3.2.4 Retroactivity of Referenced Standards to Existing Conditions. Unless otherwise specified by 1.3.2.4.1 through 1.3.2.4.3, the current provisions of the referenced standards shall not apply to facilities, equipment, structures, or installations that existed or were approved for construction or installation prior to the effective date of this Code.

1.3.2.4.1 Where specified by a reference standard for existing occupancies, conditions, or systems, the provisions of the referenced standards shall be retroactive.

1.3.2.4.2 Facilities, equipment, structures, and installations, installed in accordance with a reference standard, shall be

maintained in accordance with the edition of the standard in effect at the time of installation.

1.3.2.4.3 In those cases where the AHJ determines that the existing situation constitutes an imminent danger, the AHJ shall be permitted to apply retroactively any portions of the current referenced standards deemed appropriate.

1.3.3 Conflicts.

1.3.3.1 When a requirement differs between this *Code* and a referenced document, the requirement of this *Code* shall apply.

1.3.3.2 When a conflict between a general requirement and a specific requirement occurs, the specific requirement shall apply.

1.3.4 Multiple Occupancies. Where two or more classes of occupancy occur in the same building or structure and are so intermingled that separate safeguards are impractical, means of egress facilities, construction, protection, and other safeguards shall comply with the most restrictive fire safety requirements of the occupancies involved.

1.3.5 Vehicles and Vessels. Vehicles, vessels, or other similar conveyances, when in fixed locations and occupied as buildings, as described by Section 11.6 of NFPA 101 shall be treated as buildings and comply with this *Code*.

1.3.6 Buildings.

1.3.6.1 Buildings permitted for construction after the adoption of this *Code* shall comply with the provisions stated herein for new buildings.

1.3.6.2* Buildings in existence or permitted for construction prior to the adoption of this *Code* shall comply with the provisions stated herein or referenced for existing buildings (*see 10.3.2*).

1.3.6.3 Repairs, renovations, alterations, reconstruction, change of occupancy, and additions to buildings shall conform to this *Code*, NFPA 101, and the building code.

1.3.6.4 Newly introduced equipment, materials, and operations regulated by this *Code* shall comply with the requirements for new construction or processes.

1.3.7 Severability. If any provision of this *Code* or the application thereof to any person or circumstance is held invalid, the remainder of the *Code* and the application of such provision to other persons or circumstances shall not be affected thereby.

1.4 Equivalencies, Alternatives, and Modifications.

1.4.1 Equivalencies. Nothing in this *Code* is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety to those prescribed by this *Code*, provided technical documentation is submitted to the AHJ to demonstrate equivalency and the system, method, or device is approved for the intended purpose.

1.4.1.1* Compliance with Subsequent Editions of Referenced Publications. The AHJ shall be authorized to accept subsequent editions of publications referenced in this *Code* as evidence of compliance with the specified edition. When the AHJ accepts compliance with a subsequent edition of a referenced publication, compliance with subsequent edition shall be considered evidence of compliance with this *Code's* specified edition.

1.4.1.1.1* Compliance with subsequent editions of reference publications shall be achieved by complying with the entire subsequent edition of the referenced publication.

1.4.1.1.2* Compliance with individual specific sections contained in subsequent editions of referenced publications, and not the entire reference publication, shall only be approved by the AHJ through technical documentation submitted in compliance with 1.4.1 or 1.4.2.

1.4.2 Alternatives. The specific requirements of this *Code* shall be permitted to be altered by the AHJ to allow alternative methods that will secure equivalent fire safety, but in no case shall the alternative afford less fire safety than, in the judgment of the AHJ, that which would be provided by compliance with the provisions contained in this *Code*.

1.4.3* Modifications. The AHJ is authorized to modify any of the provisions of this *Code* upon application in writing by the owner, a lessee, or a duly authorized representative where there are practical difficulties in the way of carrying out the provisions of the *Code*, provided that, in the judgment of the AHJ, the intent of the *Code* shall be complied with, public safety secured, and substantial justice done.

1.4.4 Buildings with equivalency, alternatives, or modifications approved by the AHJ shall be considered as conforming with this *Code*.

1.4.5 Each application for an equivalent, alternative, or modified fire protection feature shall be filed with the AHJ and shall be accompanied by such evidence, letters, statements, results of tests, or other supporting information as required to justify the request. The AHJ shall keep a record of actions on such applications, and a signed copy of the AHJ's decision shall be provided for the applicant.

1.4.6 Approval. The AHJ shall approve such equivalent, alternative, or modified construction systems, materials, or methods of design when it is substantiated that the standards of this *Code* are at least equaled. If, in the opinion of the AHJ, the standards of this *Code* are not equaled by the alternative requested, approval for permanent work shall be refused. Consideration shall be given to test or prototype installations.

1.4.7 Tests.

1.4.7.1 Whenever evidence of compliance with the requirements of this *Code* is insufficient or evidence that any material or method of construction does not conform to the requirements of this *Code*, or to substantiate claims for alternative construction systems, materials, or methods of construction, the AHJ shall be permitted to require tests for proof of compliance to be made by an approved agency at the expense of the owner or his/her agent.

1.4.7.2 Test methods shall be as specified by this *Code* for the material in question. If appropriate test methods are not specified in this *Code*, the AHJ is authorized to accept an applicable test procedure from another recognized source.

1.4.7.3 Copies of the results of all such tests shall be retained in accordance with Section 1.12.

1.5 Units.

1.5.1 International System of Units. Metric units of measurement in this *Code* are in accordance with the modernized metric system known as the International System of Units (SI).

1.5.2 Primary and Equivalent Values. If a value for a measurement as given in this *Code* is followed by an equivalent value in other units, the first stated value shall be regarded as the requirement. A given equivalent value could be approximate.

1.6 Enforcement. This *Code* shall be administered and enforced by the AHJ designated by the governing authority. (See *Annex B* for sample wording for enabling legislation.)

1.7 Authority.

1.7.1 Administration. The provisions of this *Code* shall apply without restriction, unless specifically exempted.

1.7.2* Minimum Qualifications to Enforce This Code. The AHJ shall establish minimum qualifications for all persons assigned the responsibility of enforcing this *Code*.

1.7.2.1 Fire inspectors and plans examiners shall meet the minimum professional qualifications established in NFPA 1030.

1.7.2.2 The AHJ shall be authorized to approve alternative qualifications for personnel conducting fire inspections and plan examination under 1.7.2.1 if the AHJ determines the individual possesses the knowledge, skills, and abilities to perform the job performance requirements of the position.

1.7.2.3 Fire marshals shall meet the minimum professional qualifications established in NFPA 1030.

1.7.2.4 The AHJ shall be authorized to approve alternative qualifications for personnel performing the position of fire marshal under 1.7.2.3 if the AHJ determines the individual possesses the knowledge, skills, and abilities to perform the job performance requirements of the position.

1.7.3 Interpretations, Rules, and Regulations.

1.7.3.1 The AHJ is authorized to render interpretations of this *Code* and to make and enforce rules and supplemental regulations in order to carry out the application and intent of its provisions.

1.7.3.2 Such interpretations, rules, and regulations shall be in conformance with the intent and purpose of this *Code* and shall be available to the public during normal business hours.

1.7.4 Enforcement Assistance. Police and other enforcement agencies shall have authority to render necessary assistance in the enforcement of this *Code* when requested to do so by the AHJ.

1.7.5 Delegation of Authority. The AHJ shall be permitted to delegate to other qualified individuals such powers as necessary for the administration and enforcement of this *Code*.

1.7.6 Reliance on Other Enforcement Officials.

1.7.6.1* The AHJ shall be authorized to rely on plan reviews, inspections, opinions, and approvals rendered by other enforcement officials in determining compliance with this *Code*.

1.7.6.2 When the AHJ relies on inspections, plan reviews, opinions, and approvals rendered by other enforcement officials in determining compliance with this *Code*, the other enforcement officials shall be deemed to be acting as agents under their own authority and not as agents of the AHJ enforcing this *Code*.

1.7.7 Inspection.

1.7.7.1* The AHJ shall be authorized to inspect, at all reasonable times, any building or premises for dangerous or hazardous conditions or materials as set forth in this *Code*.

1.7.7.2 To the full extent permitted by law, any AHJ engaged in fire prevention and inspection work shall be authorized at all reasonable times to enter and examine any building, structure, marine vessel, vehicle, or premises for the purpose of making fire safety inspections.

1.7.7.3 Before entering, the AHJ shall obtain the consent of the occupant thereof or obtain a court warrant authorizing entry for the purpose of inspection except in those instances where an emergency exists.

1.7.7.4 As used in 1.7.7.3, emergency shall mean circumstances that the AHJ knows, or has reason to believe, exist and that can constitute imminent danger.

1.7.7.5 Persons authorized to enter and inspect buildings, structures, marine vessels, vehicles, and premises as herein set forth shall be identified by credentials issued by the governing authority.

1.7.7.6* Building, fire and life safety, fire protection systems and equipment, and other AHJ code-related inspections shall be permitted to be modified or delayed as permitted by the AHJ due to national, regional, or locally declared disasters.

1.7.8 Authority to Order Corrections and Abate.

1.7.8.1 The AHJ shall have authority to order any person(s) to remove or remedy such dangerous or hazardous condition or material. Any person(s) failing to comply with such order shall be in violation of this *Code*.

1.7.8.2 Where conditions exist and are deemed hazardous to life or property by the AHJ, the AHJ shall have the authority to summarily abate such hazardous conditions that are in violation of this *Code*.

1.7.8.3* Where such hazardous conditions exist, abatement actions by the AHJ shall include the authority to order the immediate disconnection or reconnection of utilities to a structure or property.

1.7.9 Interference with Enforcement. Persons shall not interfere or cause conditions that would interfere with an AHJ carrying out any duties or functions prescribed by this *Code*.

1.7.10 Impersonation. Persons shall not use a badge, uniform, or other credentials to impersonate the AHJ.

1.7.11 Investigation.

1.7.11.1 Authority. The AHJ shall have the authority to investigate the cause, origin, and circumstances of any fire, explosion, release of hazardous materials, or other hazardous condition.

1.7.11.2 Evidence. The AHJ shall have the authority to take custody of all physical evidence relating to the origin and cause of a fire, explosion, release of hazardous materials, or other hazardous condition.

1.7.11.3 Limiting Access. The AHJ shall have the authority to limit access to emergencies or other similar situations.

1.7.12 Plans and Specifications.

1.7.12.1 The AHJ shall have the authority to require plans and specifications to ensure compliance with applicable codes and standards.

1.7.12.2 Plans shall be submitted to the AHJ prior to construction unless otherwise permitted by 1.7.12.4.

1.7.12.3 The construction documents for each phase shall be complete in themselves, so that review and inspection can properly be made. Preliminary plans of the total building shall be submitted with the construction documents, and with sufficient detail, so that proper evaluation can be made. Areas and items not included in the phase to be permitted shall be shown as not included. [5000:1.7.6.3.3.3]

1.7.12.4 The AHJ is authorized to exempt detached one- and two-family dwellings and accessory structures from the submission of plans and permit requirements in 1.7.12.8.

1.7.12.5 Plans shall be submitted to the AHJ prior to the change of occupancy of any existing building.

1.7.12.6 Plans shall be submitted to the AHJ prior to the alteration of the means of egress or fire protection systems of any existing building.

1.7.12.7 Plans shall be submitted to the AHJ for other conditions as deemed necessary by the AHJ to determine compliance with the applicable codes and standards.

1.7.12.8 The AHJ shall be authorized to require permits for conditions listed in 1.7.12.2, 1.7.12.5, and 1.7.12.6, unless otherwise permitted by 1.7.12.4.

1.7.12.9 No construction work shall proceed until the AHJ has reviewed the plans for compliance with the applicable codes and standards and the applicable permits have been issued.

1.7.13 Inspection of Construction and Installation.

1.7.13.1 The AHJ shall be notified by the person performing the work when the installation is ready for a required inspection.

1.7.13.2 Whenever any installation subject to inspection prior to use is covered or concealed without having first been inspected, the AHJ shall have the authority to require that such work be exposed for inspection.

1.7.13.3 When any construction or installation work is being performed in violation of the plans and specifications as approved by the AHJ, a written notice shall be issued to the responsible party to stop work on that portion of the work that is in violation.

1.7.13.4 The notice shall state the nature of the violation, and no work shall be continued on that portion until the violation has been corrected.

1.7.14 Certificate of Occupancy. When the building code requires a certificate of occupancy, the certificate of occupancy shall not be issued until approved by the AHJ for fire code enforcement.

1.7.15 Stop Work Order. The AHJ shall have the authority to order an operation, construction, or use stopped when any of the following conditions exists:

- (1) Work is being done contrary to provision of this *Code*.

- (2) Work is occurring without a permit required by Section 1.13.
- (3) An imminent danger has been created.

1.7.16 Imminent Dangers and Evacuation.

1.7.16.1 When, in the opinion of the AHJ, an imminent danger exists, the AHJ shall be authorized to order the occupants to vacate, or temporarily close for use or occupancy, a building, the right-of-way, sidewalks, streets, or adjacent buildings or nearby areas.

1.7.16.2 Where, in the opinion of the AHJ, an imminent danger exists, the AHJ shall be authorized to order the immediate disconnection or reconnection of utilities to a structure or property.

1.7.16.3 The AHJ shall be authorized to employ the necessary resources to perform the required work in order to mitigate the imminent danger.

1.7.16.4 Costs incurred by the AHJ in the performance of emergency work shall be the responsibility of the property owner or other responsible party creating such imminent danger.

1.7.17 Standby and Fire Watch Personnel.

1.7.17.1 The AHJ shall have the authority to require standby fire personnel, emergency medical services personnel, or an approved fire watch when potentially hazardous conditions or a reduction in a life safety feature exist due to the type of performance, display, exhibit, occupancy, contest, or activity; an impairment to a fire protection feature; or the number of persons present.

1.7.17.2 The owner, agent, or lessee shall employ one or more qualified persons, as required and approved, to be on duty.

1.7.17.2.1 The cost of standby fire personnel or emergency medical services personnel shall be at no cost to the AHJ.

1.7.17.3* Such standby fire personnel, emergency medical services personnel, or fire watch personnel shall be subject to the AHJ's orders at all times and shall be identifiable and remain on duty during the times such places are open to the public, when such activity is being conducted, or as required by the AHJ.

1.7.18 Public Fire Education.

1.7.18.1 The AHJ shall have the authority to develop and implement a public fire safety education program as deemed necessary for the general welfare with respect to the potential fire hazards within the jurisdiction.

1.7.18.2 The AHJ shall have the authority to ensure duly authorized public fire safety education programs or public fire safety messages are disseminated to the general public.

1.8 Duties and Powers of the Incident Commander.

1.8.1 Authority. The incident commander conducting operations in connection with the extinguishment and control of any fire, explosion, hazardous materials incident, natural disaster, rescue, and/or other emergency shall have authority to direct all operations of fire extinguishment, mitigation of a hazardous materials incident, natural disaster, rescue, and/or control and to take necessary precautions to save life, protect property, and prevent further injury or damage.

1.8.2 Controlling Scene. During any emergency described in 1.8.1, including the investigation of the cause of such emergency, the incident commander or authorized representative shall be permitted to control or prohibit the approach to the scene of such emergency by any vehicle, vessel, or person.

1.8.3 Obstruction of Operations. Persons shall not obstruct the operations of the fire department or disobey any command of the incident commander or authorized representative or any part thereof, or any order of a police officer assisting the fire department.

1.8.4 Scene Barrier. The incident commander or authorized representative in charge of an emergency scene shall have the authority to establish barriers to control access in the vicinity of such emergency and to place, or cause to be placed, ropes, guards, barricades, or other obstructions across any street or alley to delineate such emergency scene barrier.

1.8.5 Persons, except as authorized by the incident commander in charge of the emergency, shall not be permitted to cross barriers established in accordance with 1.8.4.

1.9 Liability.

1.9.1 The AHJ, and other individuals charged by the AHJ, or the incident commander of emergency operations, charged with the enforcement of this *Code* or any other official duties, acting in good faith and without malice in the discharge of their duties, shall not thereby be rendered personally liable for any damage that could accrue to persons or property as a result of any act or by reason of any act or omission in the discharge of their duties.

1.9.2 The fire department and AHJ, acting in good faith and without malice in the discharge of the organizations' public duty, shall not thereby be rendered liable for any damage that could accrue to persons or property as a result of any act or by reason of any act or omission in the discharge of such duties.

1.9.3 Any suit brought against the AHJ, the incident commander, or such individuals because of such act or omission performed in the enforcement of any provision of such codes or other pertinent laws or ordinances implemented through the enforcement of this *Code* or enforced by the code enforcement agency shall be defended by this jurisdiction until final termination of such proceedings, and any judgment resulting therefrom shall be assumed by this jurisdiction.

1.9.4 This *Code* shall not be construed to relieve from or lessen the responsibility of any person owning, operating, or controlling any building or structure for any damages to persons or property caused by defects, nor shall the code enforcement agency or its parent jurisdiction be held as assuming any such liability by reason of the inspections authorized by this *Code* or any permits or certificates issued under this *Code*.

1.10 Pre-incident Planning. The fire department and the AHJ shall be authorized to conduct pre-incident planning activities in accordance with NFPA 1660.

1.11 Fire Code Board of Appeals.

1.11.1 Establishment of Fire Code Board of Appeals. A Board of Appeals shall be established to rule on matters relating to the fire code and its enforcement.

1.11.1.1 Membership.

1.11.1.1.1 The members of the Board of Appeals shall be appointed by the governing body of the jurisdiction.

1.11.1.1.2 The Board of Appeals shall consist of five or seven principal members and one ex officio member representative of the AHJ. Each principal member shall be permitted to have an alternate with similar experience to serve in his or her stead when necessary.

1.11.1.1.2.1 The jurisdiction governing body shall have the authority to appoint alternates who shall serve when a principal member is unable to fulfill their obligations. Alternates shall have the full authority and responsibility of principal members when serving in place of a principal member.

1.11.1.1.3 Members and alternate members shall be appointed based on their education, experience, and knowledge.

1.11.1.1.4 Members and alternates shall be appointed to a 3-year term.

1.11.1.1.5 Members and alternates shall be composed of individuals experienced in the following fields or professions:

- (1) Engineering or architectural design
- (2) General contracting
- (3) Fire protection contracting
- (4) Fire department operations or fire code enforcement
- (5) Building code enforcement
- (6) Legal
- (7) General public

1.11.1.1.5.1 Members and alternates shall not be employees, agents, or officers of the jurisdiction.

1.11.1.1.5.2 Members and alternates shall be residents of the jurisdiction.

1.11.1.1.5.3 No more than one member shall represent the same field or provision listed in 1.11.1.1.5.

1.11.1.1.6 The representative of the AHJ shall be an ex officio member and shall be entitled to participate in all discussions. The ex officio member shall not be entitled to a vote.

1.11.1.1.7 No member of the Board of Appeals shall sit in judgment on any case in which the member holds a direct or indirect property or financial interest in the case.

1.11.1.1.8 The board shall select one of its members to serve as chair and one member to serve as vice chair.

1.11.2 Rules and Procedures of the Board of Appeals. The Board of Appeals shall have the authority to establish rules and regulations for conducting its business that are consistent with the provisions of this *Code*.

1.11.3 Authority of the Board of Appeals.

1.11.3.1 The Board of Appeals shall provide for the reasonable interpretation of the provisions of this *Code* and issue rulings on appeals of the decisions of the AHJ.

1.11.3.2 The ruling of the Board of Appeals shall be consistent with the letter of the *Code* or when involving issues of clarity, ensuring that the intent of the *Code* is met with due consideration for public safety and fire fighter safety.

1.11.3.3 The Board of Appeals shall have the authority to grant alternatives or modifications through procedures outlined in Section 1.4 of the *Code*.

1.11.3.4 The Board of Appeals shall not have the authority to waive the requirements of the *Code*.

1.11.3.5 The Board of Appeals decisions shall not be precedent setting.

1.11.4 Means of Appeals.

1.11.4.1 Any person with standing shall be permitted to appeal a decision of the AHJ to the Board of Appeals when it is claimed that any one or more of the following conditions exist:

- (1) The true intent of the *Code* has been incorrectly interpreted.
- (2) The provisions of the *Code* do not fully apply.
- (3) A decision is unreasonable or arbitrary as it applies to alternatives or new materials.

1.11.4.2 An appeal shall be submitted to the AHJ in writing within 30 calendar days of notification of violation. The appeal shall outline all of the following:

- (1) The *Code* provision(s) from which relief is sought
- (2) A statement indicating which provisions of 1.11.4.1 apply
- (3) Justification as to the applicability of the provision(s) cited in 1.11.4.1
- (4) A requested remedy
- (5) Justification for the requested remedy stating specifically how the *Code* is complied with, public safety is secured, and fire fighter safety is secured

1.11.4.3* Documentation supporting an appeal shall be submitted to the AHJ at least 7 calendar days prior to the Board of Appeals hearing.

1.11.5 Meetings and Records.

1.11.5.1 Meetings of the Board of Appeals shall be held at the call of the chair, at such other times as the board determines, and within 30 calendar days of the filing of a notice of appeal.

1.11.5.2 All hearings before the Board of Appeals shall be open to the public.

1.11.5.3 The Board of Appeals shall keep minutes of its proceedings showing the vote of each member on every question or, if the member is absent or fails to vote, these actions shall be recorded.

1.11.5.4 The Board of Appeals shall keep records of its examinations and other official actions.

1.11.5.5 Minutes and records of the Board of Appeals shall be public record.

1.11.5.6 A quorum shall consist of not less than a simple majority of appointed members or alternates.

1.11.5.7 In varying the application of any provision of this *Code*, or in modifying an order of the AHJ, a two-thirds vote of the quorum shall be required.

1.11.6 Decisions.

1.11.6.1 Every decision of the Board of Appeals shall be entered in the minutes of the board meeting.

1.11.6.2 A decision of the Board of Appeals to modify an order of the AHJ shall be in writing and shall specify the

manner in which such modification is made, the conditions upon which it is made, the reasons therefore, and justification linked to specific code sections.

1.11.6.3 Every decision shall be promptly filed in the office of the AHJ and shall be open for public inspection.

1.11.6.4 A certified copy shall be sent by mail or delivered in person to the appellant, and a copy shall be publicly posted in the office of the AHJ for 2 weeks after filing.

1.11.6.5 The decision of the Board of Appeals shall be final, subject to such remedy as any aggrieved party might have through legal, equity, or other avenues of appeal or petition.

1.11.6.6 If a decision of the Board of Appeals reverses or modifies a refusal, order, or disallowance of the AHJ, or varies the application of any provision of this *Code*, the AHJ shall take action immediately in accordance with such decision.

1.12 Records and Reports.

1.12.1 A record of examinations, approvals, equivalencies, and alternates shall be maintained by the AHJ and shall be available for public inspection during business hours in accordance with applicable laws.

Δ 1.12.1.1 Documents requested from a property owner shall be maintained by the AHJ.

1.12.2 The AHJ shall keep a record of all fire prevention inspections, including the date of such inspections and a summary of any violations found to exist, the date of the services of notices, and a record of the final disposition of all violations.

1.12.3 The AHJ shall keep a record of all permits and plans reviewed, including the dates of such reviews and a summary of any comments, denials, or approvals.

1.12.4 Emergency Response Records.

1.12.4.1 The fire department shall keep a record of fire and other emergency responses occurring within its jurisdiction and of facts concerning the same, including statistics as to the extent and damage caused by such fires or emergencies.

Δ 1.12.4.2 The fire department shall report its incident record data, collected in accordance with 1.12.4, to the recognized agency responsible for collecting such data.

1.12.5 All records required to be kept shall be maintained until their usefulness has been served or as required by law.

1.13 Permits and Approvals.

1.13.1 The AHJ shall be authorized to establish and issue permits, certificates, and approvals pertaining to conditions, operations, or materials hazardous to life or property pursuant to Section 1.13.

1.13.2 Applications for permits shall be made to the AHJ on forms provided by the jurisdiction and shall include the applicant's answers in full to inquiries set forth on such forms.

1.13.2.1 Applications for permits shall be accompanied by such data as required by the AHJ and fees as required by the jurisdiction.

1.13.2.2 The AHJ shall review all applications submitted and issue permits as required.

1.13.2.3 If an application for a permit is rejected by the AHJ, the applicant shall be advised of the reasons for such rejection.

1.13.2.4 Permits for activities requiring evidence of financial responsibility by the jurisdiction shall not be issued unless proof of required financial responsibility is furnished.

1.13.3 Conditions of Approval.

1.13.3.1 Any conditions of the initial approval by the AHJ of a use, occupancy, permit, or construction shall remain with the use, occupancy, permit, or construction unless modified by the AHJ.

1.13.3.2 The AHJ shall be permitted to require conditions of approval be memorialized via recording in the public records, as part of the plat, permit, or other method as approved by the AHJ.

1.13.4 Approvals by Other AHJs.

1.13.4.1 The AHJ shall have the authority to require evidence to show that other regulatory agencies having jurisdiction over the design, construction, alteration, repair, equipment, maintenance, process, and relocation of structures have issued appropriate approvals.

1.13.4.2 The AHJ shall not be held responsible for enforcement of the regulations of such other regulatory agencies unless specifically mandated to enforce those agencies' regulations.

1.13.5 Misrepresentation.

1.13.5.1 Any attempt to misrepresent or otherwise deliberately or knowingly design; install; service; maintain; operate; sell; represent for sale; falsify records, reports, or applications; or other related activity in violation of the requirements prescribed by this *Code* shall be a violation of this *Code*.

1.13.5.2 Such violations shall be cause for immediate suspension or revocation of any related approvals, certificates, or permits issued by this jurisdiction.

1.13.5.3 Such violations shall be subject to any other criminal or civil penalties as available by the laws of this jurisdiction.

1.13.6 Permits.

1.13.6.1 A permit shall be predicated upon compliance with the requirements of this *Code* and shall constitute written authority issued by the AHJ to maintain, store, use, or handle materials; to conduct processes that could produce conditions hazardous to life or property; or to install equipment used in connection with such activities.

1.13.6.2 Any permit issued under this *Code* shall not take the place of any other approval, certificate, license, or permit required by other regulations or laws of this jurisdiction.

1.13.6.3 Where additional permits, approvals, certificates, or licenses are required by other agencies, approval shall be obtained from those other agencies.

1.13.6.4 The AHJ shall have the authority to require an inspection prior to the issuance of a permit.

1.13.6.5 A permit issued under this *Code* shall continue until revoked or for the period of time designated on the permit.

1.13.6.6 The permit shall be issued to one person or business only and for the location or purpose described in the permit.

1.13.6.7 Any change that affects any of the conditions of the permit shall require a new or amended permit.

1.13.6.8 The AHJ shall have the authority to grant an extension of the permit time period upon presentation by the permittee of a satisfactory reason for failure to start or complete the work or activity authorized by the permit.

1.13.6.9 A copy of the permit shall be posted or otherwise readily accessible at each place of operation and shall be subject to inspection as specified by the AHJ.

1.13.6.10 Any activity authorized by any permit issued under this *Code* shall be conducted by the permittee or the permittee's agents or employees in compliance with all requirements of this *Code* applicable thereto and in accordance with the approved plans and specifications.

1.13.6.11 No permit issued under this *Code* shall be interpreted to justify a violation of any provision of this *Code* or any other applicable law or regulation.

1.13.6.12 Any addition or alteration of approved plans or specifications shall be approved in advance by the AHJ, as evidenced by the issuance of a new or amended permit.

1.13.6.13* Permits shall be issued by the AHJ and shall indicate the following:

- (1) Operation, activities, or construction for which the permit is issued
- (2) Address or location where the operation, activity, or construction is to be conducted
- (3) Name, address, and phone number of the permittee
- (4) Permit number
- (5) Period of validity of the permit
- (6) Inspection requirements
- (7) Name of the agency authorizing the permit (AHJ)
- (8) Date of issuance
- (9) Permit conditions as determined by the AHJ

1.13.6.14 Any application for, or acceptance of, any permit requested or issued pursuant to this *Code* shall constitute agreement and consent by the person making the application or accepting the permit to allow the AHJ to enter the premises at any reasonable time to conduct such inspections as required by this *Code*.

1.13.7 Revocation or Suspension of Permits.

1.13.7.1 The AHJ shall be permitted to revoke or suspend a permit or approval issued if any violation of this *Code* is found upon inspection or in case any false statements or misrepresentations have been submitted in the application or plans on which the permit or approval was based.

1.13.7.2 Revocation or suspension shall be constituted when the permittee is duly notified by the AHJ.

1.13.7.3 Any person who engages in any business, operation, or occupation, or uses any premises, after the permit issued therefore has been suspended or revoked pursuant to the provisions of this *Code*, and before such suspended permit has been reinstated or a new permit issued, shall be in violation of this *Code*.

1.13.8 Permits shall be required in accordance with Table 1.13.8(a) through Table 1.13.8(d).

Table 1.13.8(a) Permit Requirements

Operations and Materials	Permit Required	Cross Reference Section Number
Additive manufacturing	To conduct industrial additive manufacturing operations	46.1.2
Aerosol products	To store or handle an aggregate quantity of Level 2 or Level 3 aerosol products in excess of 500 lb (226.8 kg)	61.1.2
Aircraft fuel servicing	To provide aircraft fuel servicing	42.1.2
Aircraft hangars	For servicing or repairing aircraft	21.1.1
Aircraft refueling vehicles	To operate aircraft refueling vehicles	42.1.2
Airport terminal buildings	For construction and alteration	21.2.2.1
Ammonium nitrate	For storage	74.1.3
Amusement parks	For construction, alteration, or operation of amusement park fire protection safety features	10.14.1
Animal housing facilities	For operation	35.2
Asbestos removal	For the removal of asbestos	16.6.2
Automatic fire suppression systems	For installation, modification, or removal from service of any automatic fire suppression system*	13.1.1.1; 50.4.2; 1.7.12.6
Automobile wrecking yards	To operate automobile wrecking yards	22.2
Automotive fuel servicing	To provide automotive fuel servicing	42.1.2
Biomass feed stock storage	To store more than 250,000 ft ³ (7080 m ³)	31.2
Candles, open flames, and portable cooking	To use in connection with assembly areas, dining areas of restaurants, or drinking establishments	17.3.2; 20.1.1.1
Cannabis growing, processing, or extraction facilities	For the construction, alteration, or operation of a cannabis growing, processing, or extraction facility	38.2
Carnivals and fairs	To conduct a carnival or fair	10.14.1
Cellulose nitrate film	To store, handle, use, or display	20.15.7.2
Cellulose nitrate plastic	To store or handle more than 25 lb (11.3 kg)	43.1.1.7
Change of occupancy	For the change of occupancy classification of an existing building	1.7.12.5
Cleaning and purging of flammable gas piping systems	Cleaning and purging	55.2
Cleanrooms	For construction, alteration, or operation	23.3
Combustible fibers	For storage or handling of combustible fibers greater than 100 ft ³ (2.8 m ³)	45.1.4
Combustible material storage	To store more than 2500 ft ³ (70.8 m ³) gross volume	10.19.2; 19.1.1; 31.2
Commercial cooking	Placement, operation, or construction	50.1.2
Commercial rubbish-handling operation	To operate	19.1.1
Compressed gases	1. To store, use, or handle compressed gases in excess of the amounts listed in Table 1.13.8(b) 2. When the compressed gases in use or storage exceed the amounts listed in Table 1.13.8(b), a permit is required to install, repair damage to, abandon, remove, place temporarily out of service, close, or substantially modify a compressed gas system 3. For additional permit requirements for compressed gases facility closures, see 63.1.2 4. Insulated liquid carbon dioxide (CO ₂) systems in accordance with 63.9.2	63.1.2; 63.9.2
Construction	For the construction of a building or structure	1.7.12.2
Covered mall buildings	Annual requirement for facilities that utilize mall area for exhibits or displays with four conditions	20.1.5.5.1

(continues)

Table 1.13.8(a) Continued

Operations and Materials	Permit Required	Cross Reference Section Number
Crop maze	To operate a crop maze	10.14.12.1
Cryogens	To produce, store, or handle cryogens in excess of amounts listed in Table 1.13.8(c) <i>Exception: Where federal or state regulations apply or for fuel systems of a vehicle.</i>	63.1.2
Cutting and welding operation	For operations within a jurisdiction	31.3.2.1.12; 41.1.5; 41.3.5
Display fireworks (1.3G)	For possession, transportation, storage, manufacture, sale, handling, and discharge of display fireworks within the jurisdiction	65.2.3; 65.5.2
Drycleaning plants	To engage in business of drycleaning or to change to a more hazardous cleaning solvent	24.2
Dust-producing operations	To operate a grain elevator, flour mill, starch mill, feed mill, or plant pulverizing aluminum, coal, cocoa, magnesium, spices, sugar, or other similar combustible material	40.2
Energy storage systems	To install and operate energy storage systems having an aggregate capacity exceeding the threshold quantities in Table 1.3 of NFPA 855	52.1.3
Exhibit and trade shows	For operation of all exhibits and trade shows held within a jurisdiction	20.1.5.5.1
Explosives	1. Manufacture, sell, dispose, purchase, storage, use, possess, or transport of explosives within the jurisdiction 2. For additional permit requirements for blasting operations, see 65.9.2	65.9.2
Fire alarm and detection systems and related equipment	For installation, modification, or removal from service of any fire alarm and detection systems and related equipment*	13.1.1.1; 1.7.12.6
Fire apparatus access roads	For the construction of a fire apparatus access road	18.1.2
Fire hydrants and water-control valves	To use a fire hydrant or operate a water-control valve intended for fire suppression purposes	13.1.1.1
Fire pumps and related equipment	For installation of, modification to, or removal from service of any fire pumps, jockey pumps, controllers, and generators*	13.1.1.1; 1.7.12.6
Flame effects	Use of flame effects before an audience	65.4.2
Flammable and combustible liquids	1. To use or operate, repair, or modify a pipeline for the on-site transportation of flammable or combustible liquids 2. To store, handle, or use Class I liquids in excess of 5 gal (18.9 L) in a building or in excess of 10 gal (37.9 L) outside of a building <i>Exception to item (2): A permit is not required for the following:</i> <i>(a) The storage or use of Class I liquids in the fuel tank of a motor vehicle, aircraft, motorboat, mobile power plant, or mobile heating plant unless such storage in the opinion of the chief would cause an unsafe condition</i> <i>(b) The storage or use of paints, oils, varnishes, or similar flammable mixtures when such liquids are stored for maintenance, painting, or similar purposes for a period of not more than 30 days</i> 3. To store, handle, or use Class II or Class III-A liquids in excess of 25 gal (94.6 L) in a building or in excess of 60 gal (227.1 L) outside a building <i>Exception to item (3): Fuel oil used in connection with oil-burning equipment</i> 4. To remove Class I or Class II liquids from an underground storage tank used for fueling motor vehicles by any means other than the approved, stationary on-site pumps normally used for dispensing purposes 5. To install, construct, alter, or operate tank vehicles, equipment, tanks, plants, terminals, wells, fuel-dispensing stations, refineries, distilleries, and similar facilities where flammable and combustible liquids are produced, processed, transported, stored, dispensed, or used 6. To install, alter, clean, repair, line with a protective coating, remove, abandon, place temporarily out of service, or otherwise dispose of a flammable or combustible liquid tank	66.1.6

(continues)

Shaded text = Revisions.  = Text deletions and figure/table revisions. • = Section deletions.  = New material



Table 1.13.8(a) *Continued*

Operations and Materials	Permit Required	Cross Reference Section Number
	7. To change the type of contents stored in a flammable or combustible liquid tank to a material other than those for which the tank was designed and constructed	
Fruit ripening	To operate a fruit-ripening process	63.1.2
General storage	To store materials indoors or outdoors, representing a broad range of combustibles, including plastics, rubber tires, and roll paper	34.1.2
Grandstands, bleachers, and folding and telescopic seating	For construction, location, erection, or placement of grandstands, bleachers, and folding and telescopic seating	25.1.2
Hazardous materials	1. To store, transport on site, dispense, use, or handle hazardous materials in excess of the amounts listed in Table 1.13.8(d) 2. To install, repair, abandon, remove, place temporarily out of service, close, or substantially modify a storage facility or other area regulated by Chapter 60 when the hazardous materials in use or storage exceed the amounts listed in Table 1.13.8(d)	60.1.3
High-piled combustible storage	To use any building or portion thereof as a high-piled storage area exceeding 500 ft ² (46.45 m ²)	20.15.8.2
High-powered rocketry	For the manufacture, sale, and use of high-powered rocketry	65.8.2; 65.7.2
Hot work operations	To conduct hot work	17.3.2; 41.1.5; 41.3.5
In-building emergency responder communications enhancement systems	To install and operate an in-building emergency responder communication enhancement system	11.10.1
Industrial ovens and furnaces	For operation of industrial ovens and furnaces covered by Chapter 51	51.1.2
Laboratories using chemicals	For construction, alteration, or operation	26.2
Lead removal	For lead removal operations	16.7.2
Liquefied petroleum gases	1. To store, use, handle, or dispense LP-Gas of 125 gal (0.5 m ³) (water capacity) aggregate capacity or greater 2. To install or modify LP-Gas systems	42.1.2 69.1.2
Liquid- or gas-fueled vehicles	To display, compete, or demonstrate liquid- or gas-fueled vehicles or equipment in assembly buildings	20.1.5.5.1
Lumberyards and woodworking plants	For storage of lumber exceeding 100,000 board ft	31.2
Manufactured home and recreational vehicle sites	Installation, construction, and location	27.1.4
Marinas, boatyards, marine terminals, piers, and wharves	To operate, locate, or construct	28.1.1.5
Marine craft fuel servicing	To provide marine craft fuel servicing	41.1.5
Means of egress	For the modification of a means of egress system in an existing building	1.7.12.6
Membrane structures, tents, and canopies — permanent	For construction, location, erection, or placement	25.1.2
Membrane structures, tents, and canopies — temporary	To erect or operate an air-supported temporary membrane structure or tent having an area in excess of 200 ft ² (18.6 m ²) or a canopy in excess of 400 ft ² (37.2 m ²) <i>Exception: Temporary membrane structures, tents, or canopy structures used exclusively for camping.</i>	25.1.2
Mobile cooking operations	Placement, operation, or construction	50.1.2
Motion picture and television production studio soundstages and approved production facilities	1. To design, construct, operate, and maintain soundstages and approved production facilities used in motion picture and television industry productions 2. Electrical power connections 3. For additional permit requirements for operations, see 32.2.2	32.2; 32.10.1.1

(continues)

Table 1.13.8(a) *Continued*

Operations and Materials	Permit Required	Cross Reference Section Number
Oil- and gas-fueled heating appliances	To install oil- and gas-fired heating appliances	11.5.1.8
On-demand mobile fueling	To conduct on-demand mobile fueling operations	42.1.2; 42.12
Open fires	1. For kindling or maintaining an open fire 2. For additional permit requirements for open fires, see 10.10.4†	10.10.4; 10.10.1
Open flame devices	The use of tar pots, decorative torches, and other devices, machines, or processes liable to start or cause an unwanted fire.	10.10.9.1
Organic coatings	For operation and maintenance of a facility that manufactures organic coatings	43.1.1.7
Organic peroxide formulations	To store, transport on site, use, or handle materials in excess of amounts listed in Table 1.13.8(c) and Table 1.13.8(d)	75.1.3
Outside storage of tires	To store more than 500 tires outside	33.1.2
Oxidizers	To store, transport on site, use, or handle materials in excess of amounts listed in Table 1.13.8(c) and (d)	70.1.4
Ozone gas-generating equipment	Location and operation	54.1.3
Parade floats	To use a parade float for public performance, presentation, spectacle, entertainment, or parade	10.17.1
Photovoltaic systems	Installation and placement	11.12.1.2
Places of assembly	To operate a place of assembly	10.14.1; 20.1.1.1
Pyrotechnic articles	For the manufacture, storage, sale, or use of pyrotechnic articles within the jurisdiction	65.2.3; 65.3.3; 65.5.2
Pyrotechnics before a proximate audience	For the display and use of pyrotechnic materials before a proximate audience	65.3.3
Pyroxylin plastics	For storage, handling, assembly, or manufacture of pyroxylin plastics	43.1.1.7
Private fire hydrants	For installation, modification, or removal from service of any private fire hydrants	13.1.1.1
Refrigeration equipment	To install or operate a mechanical refrigeration unit or system regulated by this Code	53.1.2
Repair garages	For operation of repair garages	30.1.1.3; 30.2.1.1
Rocketry manufacturing	For the manufacture of model rocket motors	65.7.2
Rooftop heliports	For construction, modification, or operation of a rooftop heliport	21.3.2.1
Rubberized asphalt melters	For operation	16.5.3.2
Solvent extraction	For storage, use, and handling	44.3
Spraying or dipping of flammable finish	For installation or modification of any spray room, spray booth, or preparation workstation, or to conduct a spraying or dipping operation utilizing flammable or combustible liquids or powder coating	43.1.1.7
Standpipe systems	For installation, modification, or removal from service of any standpipe system*	13.1.1.1; 1.7.12.6
Special amusement buildings	Operation	20.1.4.1.3
Special outdoor events	For the location and operation of special outdoor events	10.14.1
Tar kettles	To place a tar kettle, a permit must be obtained prior to the placement of a tar kettle	16.5.1.2; 17.3.2
Temporary cooking	Placement, operation, or construction	50.1.2
Tire storage	To use an open area or portion thereof to store tires in excess of 500 tires	33.1.2; 34.1.2
Torch-applied roofing operation	For the use of a torch for application of roofing materials	16.4.1

(continues)

Shaded text = Revisions. ▴ = Text deletions and figure/table revisions. • = Section deletions. N = New material



Table 1.13.8(a) *Continued*

Operations and Materials	Permit Required	Cross Reference Section Number
Wastewater treatment and collection facilities	For the operation or construction	39.1.2
Water supply system for fire flow	For the construction of a water supply system for fire flow	18.1.2
Wildland-fire-prone areas	For use of hazardous areas within fire-prone areas	17.3.2
Wood products	To store wood chips, hogged material, wood by-products, lumber, or plywood in excess of 200 ft ³ (5.7 m ³)	31.2

*Maintenance performed in accordance with this *Code* is not considered a modification and does not require a permit.

†Cooking and recreational fires are exempt and do not require a permit.

Table 1.13.8(b) Permit Amounts for Compressed Gases

Type of Gas	Amount*	
	ft ³	m ³
Corrosive	200	0.57
Flammable	200	0.57
Highly toxic	Any amount	
Inert and simple asphyxiant	6000	169.9
Oxidizing (including oxygen)	504	14.3
Pyrophoric	Any amount	
Toxic	Any amount	
Unstable (reactive)	Any amount	

Note: See Chapters 41, 42, 60, 63, and 69 for additional requirements and exceptions.

*Cubic feet measured at normal temperature and pressure.

Table 1.13.8(c) Permit Amounts for Cryogenics

Type of Cryogen	Inside Building (gal)	Outside Building (gal)
Corrosive	Over 1	Over 1
Flammable	Over 1	60
Toxic/highly toxic	Over 1	Over 1
Nonflammable	60	500
Oxidizer (includes oxygen)	10	50

Note: See Chapter 63.

1.14 Certificates of Fitness.

1.14.1 Authorization. The AHJ shall have the authority to require certificates of fitness and collect fees for individuals or companies performing any of the following activities:

- (1) Inspection, servicing, or recharging of portable fire extinguishers
- (2) Installation, servicing, modification, or recharging of fixed fire extinguishing systems
- (3) Installation, servicing, or modification of fire alarm or fire communication systems
- (4) Installation, modification, or servicing of gas- or oil-burning heating systems
- (5) Chimney sweep operations

- (6) Installation, inspection, servicing, or modification of range-hood systems
- (7) Installation or servicing of private fire service mains and their appurtenances
- (8) Crowd management services required by the *Code*
- (9) Utilization of pyrotechnics before a proximate audience
- (10) Installation, modification, or maintenance of liquefied petroleum gas or liquefied natural gas tanks or systems
- (11) Installation or modification of medical gas systems where a permit is required by Table 1.13.8(a)
- (12) Installation, modification, or maintenance of standpipe systems
- (13) Installation, modification, or maintenance of automatic sprinkler systems
- (14) Installation, modification, or maintenance of fire pumps
- (15) Installation, modification, or maintenance of tanks, wells, or drafting points used for fire protection water supplies

1.14.2 Mandatory. The AHJ shall require certificates of fitness and collect fees for individuals or companies performing any of the following activities:

- (1) Use of explosive materials
- (2) Fireworks displays involving display fireworks, 1.3G

1.14.3 The AHJ shall be responsible for the issuance of certificates of fitness required by the AHJ.

1.14.4 All applications for a certificate of fitness shall be filed with the AHJ on forms provided by the AHJ.

1.14.5 Certification of Applicant.

1.14.5.1 Every individual or company applying for a certificate of fitness shall furnish to the AHJ evidence of a familiarity with applicable codes, regulations, standards, listings, guidelines, and construction and safety practices for the activity for which the certificate of fitness is issued.

1.14.5.2* The AHJ shall also utilize certification programs provided by national organizations acceptable to the AHJ, where available, to determine evidence of compliance with 1.14.5.1.

1.14.5.3 The AHJ shall investigate every application for a certificate of fitness.

1.14.5.4* The investigation shall include an examination of the applicant's experience and training in the field of the certificate of fitness for which application has been made.

Table 1.13.8(d) Permit Amounts for Hazardous Materials

Type of Material	Amount	
	US Unit	Metric Unit
Cellulose nitrate	25 lb	11.3 kg
Combustible fiber	100 ft ³	2.8 m ³
Combustible liquids	See Table 1.13.8(a)	
Corrosive gases	See Table 1.13.8(b)	
Corrosive liquids	55 gal	208 L
Corrosive solids	500 lb	227 kg
Cryogenics	See Table 1.13.8(c)	
Display fireworks (1.3G)	Any amount	
Explosives	Any amount	
Flammable gases	See Table 1.13.8(b)	
Flammable liquids	See Table 1.13.8(a)	
Flammable solids	100 lb	45.4 kg
Highly toxic gases	See Table 1.13.8(b)	
Highly toxic liquids	Any amount	
Highly toxic solids	Any amount	
LP-Gas	See Table 1.13.8(b)	
Nitrate film (cellulose)	Any amount	
Organic peroxides:	See Table 1.13.8(a)	
Class I	Any amount	
Class II	Any amount	
Class III	10 lb	4.5 kg
Class IV	20 lb	9 kg
Class V	Not required	
Unclassified detonable	Any amount	
Oxidizing gases	See Table 1.13.8(b)	
Oxidizing liquids:	See Table 1.13.8(a)	
Class 4	Any amount	
Class 3	1 gal	3.8 L
Class 2	10 gal	38 L
Class 1	55 gal	208 L
Oxidizing solids:	See Table 1.13.8(a)	
Class 4	Any amount	
Class 3	10 lb	4.5 kg
Class 2	100 lb	45 kg
Class 1	500 lb	227 kg
Pyrophoric gases	See Table 1.13.8(b)	
Pyrophoric liquids	Any amount	
Pyrophoric solids	Any amount	
Toxic gases	See Table 1.13.8(b)	
Toxic liquids	10 gal	38 L
Toxic solids	100 lb	45 kg
Unstable (reactive) gases	See Table 1.13.8(b)	
Unstable (reactive) liquids:	Any amount	
Class 4	Any amount	
Class 3	Any amount	
Class 2	5 gal	19 L
Class 1	10 gal	38 L
Unstable (reactive) solids:	Any amount	
Class 4	Any amount	
Class 3	Any amount	
Class 2	50 lb	22.7 kg
Class 1	100 lb	45 kg
Water reactive liquids:	Any amount	
Class 3	Any amount	
Class 2	5 gal	19 L
Class 1	10 gal	38 L
Water reactive solids:	Any amount	
Class 3	Any amount	
Class 2	50 lb	22.7 kg
Class 1	100 lb	45 kg

Note: See Chapter 60 for additional requirements and exceptions.

1.14.5.5 When the AHJ determines that an applicant is not fit to receive the certificate of fitness because of the applicant's inability to comply with the provisions of this *Code*, the AHJ shall refuse to issue the certificate of fitness.

1.14.5.6 If the refusal is based on the applicant's inability to pass an examination given to determine competency, the applicant shall not be permitted to apply again for the certificate of fitness within a 10-day period following the examination.

1.14.6 Certificates of fitness shall not be transferable.

1.14.7 Certificates of fitness shall be issued for the period of time as indicated on the certificate of fitness as determined by the AHJ, but such period of time shall not exceed 3 years.

1.14.8 Applications for renewal of a certificate of fitness shall be filed in the same manner as an application for an original certificate.

1.14.9 Each individual or company holding a certificate of fitness shall notify the AHJ in writing of any address change within 10 days after such change.

1.14.10 A certificate of fitness shall be in the form of an identification card. The card shall contain the following information:

- (1) Purpose for which the certificate of fitness is issued
- (2) Date of expiration
- (3) Information necessary to easily identify the individual to whom the certificate of fitness is issued
- (4) Signature of the individual to whom the certificate of fitness is issued
- (5) Name and signature of the AHJ or a designated representative
- (6) Statement printed thereon in bold type the following:
THIS CERTIFICATE IS NOT AN ENDORSEMENT OF THIS INDIVIDUAL OR COMPANY BY THE AUTHORITY HAVING JURISDICTION.

1.14.11 Any individual or company to whom a certificate of fitness has been granted shall, upon request, produce and show proper identification and the certificate of fitness to anyone for whom that individual seeks to render services or to the AHJ.

1.14.12 Revocation or Suspension of Certificates of Fitness.

1.14.12.1 The AHJ shall be permitted to revoke or suspend a certificate of fitness issued if any violation of this *Code* is found upon inspection or where any false statements or misrepresentations are submitted in the application on which the approval was based.

1.14.12.2 Revocation or suspension shall be constituted when notification is served, posted, or mailed to the address of record for the certificate holder.

1.14.12.3 Failure on the part of an individual to give such notification of a change of address required by 1.14.9 shall constitute grounds for revocation of the certificate of fitness.

1.14.12.4 Revocations or suspensions of a certificate of fitness by the AHJ are appealable to the Board of Appeals as established in Section 1.11.

1.15 Plan Review.

1.15.1 Where required by the AHJ for new construction, modification, or rehabilitation, construction documents and shop drawings shall be submitted, reviewed, and approved prior to the start of such work as provided in Section 1.15.

1.15.2 The applicant shall be responsible to ensure that the following conditions are met:

- (1) The construction documents include all of the fire protection requirements.
- (2) The shop drawings are correct and in compliance with the applicable codes and standards.
- (3) The contractor maintains an approved set of construction documents on site.

1.15.3 It shall be the responsibility of the AHJ to promulgate rules that cover the following:

- (1) Criteria to meet the requirements of Section 1.15
- (2) Review of documents and construction documents within established time frames for the purpose of acceptance or providing reasons for nonacceptance

1.15.4 Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this *Code*.

1.15.5 When required by the AHJ, revised construction documents or shop drawings shall be prepared and submitted for review and approval to illustrate corrections or modifications necessitated by field conditions or other revisions to approved construction documents.

1.15.6* When required by the AHJ, plans and design documents shall be prepared by a registered design professional.

1.16 Technical Assistance.

1.16.1 The AHJ shall be permitted to require a review by an approved independent third party with expertise in the matter to be reviewed at the submitter's expense.

1.16.2 The independent reviewer shall provide an evaluation and recommend necessary changes of the proposed design, operation, process, or new technology to the AHJ.

1.16.3 The AHJ shall be authorized to require design submittals to bear the stamp of a registered design professional.

1.16.4 The AHJ shall make the final determination as to whether the provisions of this *Code* have been met.

1.17 Notice of Violations and Penalties.

1.17.1 Where Required. Whenever the AHJ determines violations of this *Code*, a written notice shall be issued to confirm such findings.

1.17.2 Serving Notice of Violation.

1.17.2.1 Any order or notice of violation issued pursuant to this *Code* shall be served upon the owner, operator, occupant, registered agent, or other person responsible for the condition or violation by one of the following means:

- (1) Personal service
- (2) Mail to last known address of the owner, operator, or registered agent

1.17.2.2 For unattended or abandoned locations, a copy of such order or notice of violation shall be posted on the premises in a conspicuous place at or near the entrance to such premises, and the order or notice shall be disseminated in accordance with one of the following:

- (1) Mailed to the last known address of the owner, occupant, or registered agent
- (2) Published in a newspaper of general circulation wherein the property in violation is located

1.17.2.3 Refusal of an owner, occupant, operator, or other person responsible for the violation to accept the violation notice shall not be cause to invalidate the violation or the notice of violation. When acceptance of a notice of violation is refused, valid notice shall have deemed to have been served under this section provided the methods of service in 1.17.2.1 or 1.17.2.2 have been followed.

1.17.3 Destruction or Removal of Notice. The mutilation, destruction, or removal of a posted order or violation notice without authorization by the AHJ shall be a separate violation of this *Code* and punishable by the penalties established by the AHJ.

1.17.4 Penalties.

1.17.4.1 Any person who fails to comply with the provisions of this *Code*, fails to carry out an order made pursuant to this *Code*, or violates any condition attached to a permit, approval, or certificate shall be subject to the penalties established by the AHJ.

1.17.4.2 Violations of the provisions of this *Code* shall be punishable by a fine or imprisonment as determined by a penalty schedule adopted by the AHJ or specified by state law/rules.

1.17.4.3 Where the AHJ has not adopted a separate penalty schedule, or if state laws or rules do not specify a penalty, violations of this *Code* shall be subject to a \$100.00 penalty per day for each violation.

1.17.4.4 Failure to comply with the time limits of an order or notice of violation issued by the AHJ shall result in each day that the violation continues being regarded as a separate offense and shall be subject to a separate penalty.

1.17.4.5 A separate notice of violation shall not be required to be served each day for a violation to be deemed a separate offense.

1.17.5 Abatement. Where a violation creates an imminent danger, the AHJ is authorized to abate such hazard in accordance with 1.7.16.

1.18* Fees. The AHJ shall be authorized to establish a schedule of fees.

Chapter 2 Referenced Publications

2.1 General. The documents referenced in this chapter or portions of such documents are referenced within this *Code* and shall be considered part of the requirements of this document.

- (1)* Documents referenced in this chapter or portion of such documents shall only be applicable to the extent called for within other chapters of this *Code*.
- (2) Where the requirements of a referenced code or standard differ from the requirements of this *Code*, the requirements of this *Code* shall govern.

2.1.1* Compliance with Subsequent Editions of the Referenced Publications. Compliance with subsequent editions of the referenced publications shall be considered evidence of compliance with the editions specified in this *Code*.

2.1.1.1* Compliance with subsequent editions of reference publications shall be achieved by complying with the entire subsequent edition of the referenced publication.

2.1.1.2* Compliance with individual specific sections contained in subsequent edition referenced publications, and not the entire reference publication, shall only be approved by the AHJ through technical documentation submitted in compliance with 1.4.1 or 1.4.2.

2.1.2* Referenced Publications Within Extracted Sections. A publication referenced within an extracted section shall be the edition referenced within the extract document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

- NFPA 2, *Hydrogen Technologies Code*, 2023 edition.
- NFPA 4, *Standard for Integrated Fire Protection and Life Safety System Testing*, 2024 edition.
- NFPA 10, *Standard for Portable Fire Extinguishers*, 2022 edition.
- NFPA 11, *Standard for Low-, Medium-, and High-Expansion Foam*, 2021 edition.
- NFPA 12, *Standard on Carbon Dioxide Extinguishing Systems*, 2022 edition.
- NFPA 12A, *Standard on Halon 1301 Fire Extinguishing Systems*, 2022 edition.
- NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2022 edition.
- NFPA 13D, *Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and Manufactured Homes*, 2022 edition.
- NFPA 13R, *Standard for the Installation of Sprinkler Systems in Low-Rise Residential Occupancies*, 2022 edition.
- NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*, 2024 edition.
- NFPA 15, *Standard for Water Spray Fixed Systems for Fire Protection*, 2022 edition.
- NFPA 17, *Standard for Dry Chemical Extinguishing Systems*, 2024 edition.
- NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*, 2022 edition.
- NFPA 22, *Standard for Water Tanks for Private Fire Protection*, 2023 edition.
- NFPA 24, *Standard for the Installation of Private Fire Service Mains and Their Appurtenances*, 2022 edition.
- NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2023 edition.

NFPA 30, *Flammable and Combustible Liquids Code*, 2024 edition.

NFPA 30A, *Code for Motor Fuel Dispensing Facilities and Repair Garages*, 2024 edition.

NFPA 30B, *Code for the Manufacture and Storage of Aerosol Products*, 2023 edition.

NFPA 31, *Standard for the Installation of Oil-Burning Equipment*, 2020 edition.

NFPA 32, *Standard for Drycleaning Facilities*, 2021 edition.

NFPA 33, *Standard for Spray Application Using Flammable or Combustible Materials*, 2021 edition.

NFPA 34, *Standard for Dipping, Coating, and Printing Processes Using Flammable or Combustible Liquids*, 2021 edition.

NFPA 35, *Standard for the Manufacture of Organic Coatings*, 2021 edition.

NFPA 36, *Standard for Solvent Extraction Plants*, 2021 edition.

NFPA 37, *Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines*, 2024 edition.

NFPA 40, *Standard for the Storage and Handling of Cellulose Nitrate Film*, 2022 edition.

NFPA 45, *Standard on Fire Protection for Laboratories Using Chemicals*, 2024 edition.

NFPA 51, *Standard for the Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting, and Allied Processes*, 2023 edition.

NFPA 51B, *Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*, 2024 edition.

NFPA 52, *Vehicular Natural Gas Fuel Systems Code*, 2023 edition.

NFPA 54, *National Fuel Gas Code*, 2024 edition.

NFPA 55, *Compressed Gases and Cryogenic Fluids Code*, 2023 edition.

NFPA 56, *Standard for Fire and Explosion Prevention During Cleaning and Purging of Flammable Gas Piping Systems*, 2023 edition.

NFPA 58, *Liquefied Petroleum Gas Code*, 2024 edition.

NFPA 59, *Utility LP-Gas Plant Code*, 2024 edition.

NFPA 59A, *Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG)*, 2023 edition.

NFPA 61, *Standard for the Prevention of Fires and Dust Explosions in Agricultural and Food Processing Facilities*, 2020 edition.

NFPA 68, *Standard on Explosion Protection by Deflagration Venting*, 2023 edition.

NFPA 69, *Standard on Explosion Prevention Systems*, 2019 edition.

NFPA 70®, *National Electrical Code®*, 2023 edition.

NFPA 72®, *National Fire Alarm and Signaling Code®*, 2022 edition.

NFPA 75, *Standard for the Fire Protection of Information Technology Equipment*, 2020 edition.

NFPA 76, *Standard for the Fire Protection of Telecommunications Facilities*, 2020 edition.

NFPA 80, *Standard for Fire Doors and Other Opening Protectives*, 2022 edition.

NFPA 82, *Standard on Incinerators and Waste and Linen Handling Systems and Equipment*, 2019 edition.

NFPA 85, *Boiler and Combustion Systems Hazards Code*, 2023 edition.

NFPA 86, *Standard for Ovens and Furnaces*, 2023 edition.

NFPA 88A, *Standard for Parking Structures*, 2023 edition.

NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*, 2024 edition.

NFPA 90B, *Standard for the Installation of Warm Air Heating and Air-Conditioning Systems*, 2024 edition.

NFPA 91, *Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Particulate Solids*, 2020 edition.

NFPA 92, *Standard for Smoke Control Systems*, 2021 edition.

NFPA 96, *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations*, 2024 edition.

NFPA 99, *Health Care Facilities Code*, 2024 edition.

NFPA 99B, *Standard for Hypobaric Facilities*, 2024 edition.

NFPA 101®, *Life Safety Code®*, 2024 edition.

NFPA 102, *Standard for Grandstands, Folding and Telescopic Seating, Tents, and Membrane Structures*, 2021 edition.

NFPA 105, *Standard for Smoke Door Assemblies and Other Opening Protectives*, 2022 edition.

NFPA 110, *Standard for Emergency and Standby Power Systems*, 2022 edition.

NFPA 111, *Standard on Stored Electrical Energy Emergency and Standby Power Systems*, 2022 edition.

NFPA 115, *Standard for Laser Fire Protection*, 2020 edition.

NFPA 120, *Standard for Fire Prevention and Control in Coal Mines*, 2023 edition.

NFPA 122, *Standard for Fire Prevention and Control in Metal/Nonmetal Mining and Metal Mineral Processing Facilities*, 2023 edition.

NFPA 130, *Standard for Fixed Guideway Transit and Passenger Rail Systems*, 2023 edition.

NFPA 140, *Standard on Motion Picture and Television Production Studio Soundstages, Approved Production Facilities, and Production Locations*, 2024 edition.

NFPA 150, *Fire and Life Safety in Animal Housing Facilities Code*, 2022 edition.

NFPA 160, *Standard for the Use of Flame Effects Before an Audience*, 2021 edition.

NFPA 170, *Standard for Fire Safety and Emergency Symbols*, 2021 edition.

NFPA 204, *Standard for Smoke and Heat Venting*, 2021 edition.

NFPA 211, *Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances*, 2024 edition.

NFPA 220, *Standard on Types of Building Construction*, 2024 edition.

NFPA 221, *Standard for High Challenge Fire Walls, Fire Walls, and Fire Barrier Walls*, 2024 edition.

NFPA 232, *Standard for the Protection of Records*, 2022 edition.

NFPA 241, *Standard for Safeguarding Construction, Alteration, and Demolition Operations*, 2022 edition.

NFPA 252, *Standard Methods of Fire Tests of Door Assemblies*, 2022 edition.

NFPA 253, *Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source*, 2023 edition.

NFPA 257, *Standard on Fire Test for Window and Glass Block Assemblies*, 2022 edition.

NFPA 259, *Standard Test Method for Potential Heat of Building Materials*, 2023 edition.

NFPA 260, *Standard Methods of Tests and Classification System for Cigarette Ignition Resistance of Components of Upholstered Furniture*, 2024 edition.

NFPA 261, *Standard Method of Test for Determining Resistance of Mock-Up Upholstered Furniture Material Assemblies to Ignition by Smoldering Cigarettes*, 2023 edition.

NFPA 265, *Standard Methods of Fire Tests for Evaluating Room Fire Growth Contribution of Textile or Expanded Vinyl Wall Coverings on Full Height Panels and Walls*, 2023 edition.

NFPA 286, *Standard Methods of Fire Tests for Evaluating Contribution of Wall and Ceiling Interior Finish to Room Fire Growth*, 2024 edition.

NFPA 288, *Standard Methods of Fire Tests of Horizontal Fire Door Assemblies Installed in Horizontal Fire Resistance-Rated Assemblies*, 2022 edition.

NFPA 289, *Standard Method of Fire Test for Individual Fuel Packages*, 2023 edition.

NFPA 301, *Code for Safety to Life from Fire on Merchant Vessels*, 2023 edition.

NFPA 302, *Fire Protection Standard for Pleasure and Commercial Motor Craft*, 2020 edition.

NFPA 303, *Fire Protection Standard for Marinas and Boatyards*, 2021 edition.

NFPA 307, *Standard for the Construction and Fire Protection of Marine Terminals, Piers, and Wharves*, 2021 edition.

NFPA 312, *Standard for Fire Protection of Vessels During Construction, Conversion, Repair, and Lay-Up*, 2021 edition.

NFPA 318, *Standard for the Protection of Semiconductor Fabrication Facilities*, 2022 edition.

NFPA 326, *Standard for the Safeguarding of Tanks and Containers for Entry, Cleaning, or Repair*, 2020 edition.

NFPA 385, *Standard for Tank Vehicles for Flammable and Combustible Liquids*, 2022 edition.

NFPA 400, *Hazardous Materials Code*, 2022 edition.

NFPA 407, *Standard for Aircraft Fuel Servicing*, 2022 edition.

NFPA 408, *Standard for Aircraft Hand Portable Fire Extinguishers*, 2022 edition.

NFPA 409, *Standard on Aircraft Hangars*, 2022 edition.

NFPA 410, *Standard on Aircraft Maintenance*, 2020 edition.

NFPA 415, *Standard on Airport Terminal Buildings, Fueling Ramp Drainage, and Loading Walkways*, 2022 edition.

NFPA 418, *Standard for Heliports*, 2021 edition.

NFPA 423, *Standard for Construction and Protection of Aircraft Engine Test Facilities*, 2022 edition.

NFPA 460, *Standard for Aircraft Rescue and Firefighting Services at Airports, Recurring Proficiency of Airport Fire Fighters, and Evaluating Aircraft Rescue and Firefighting Foam Equipment*, 2024 edition.

NFPA 484, *Standard for Combustible Metals*, 2022 edition.

NFPA 495, *Explosive Materials Code*, 2023 edition.

NFPA 498, *Standard for Safe Havens and Interchange Lots for Vehicles Transporting Explosives*, 2023 edition.

NFPA 501, *Standard on Manufactured Housing*, 2022 edition.

NFPA 501A, *Standard for Fire Safety Criteria for Manufactured Home Installations, Sites, and Communities*, 2021 edition.

NFPA 502, *Standard for Road Tunnels, Bridges, and Other Limited Access Highways*, 2023 edition.

NFPA 505, *Fire Safety Standard for Powered Industrial Trucks Including Type Designations, Areas of Use, Conversions, Maintenance, and Operations*, 2024 edition.

NFPA 601, *Standard for Security Services in Fire Loss Prevention*, 2020 edition.

NFPA 652, *Standard on the Fundamentals of Combustible Dust*, 2019 edition.

NFPA 654, *Standard for the Prevention of Fire and Dust Explosions from the Manufacturing, Processing, and Handling of Combustible Particulate Solids*, 2020 edition.

NFPA 655, *Standard for Prevention of Sulfur Fires and Explosions*, 2017 edition.

NFPA 664, *Standard for the Prevention of Fires and Explosions in Wood Processing and Woodworking Facilities*, 2020 edition.

NFPA 701, *Standard Methods of Fire Tests for Flame Propagation of Textiles and Films*, 2023 edition.

NFPA 703, *Standard for Fire-Retardant-Treated Wood and Fire-Retardant Coatings for Building Materials*, 2024 edition.

NFPA 704, *Standard System for the Identification of the Hazards of Materials for Emergency Response*, 2022 edition.

NFPA 731, *Standard for the Installation of Premises Security Systems*, 2023 edition.

NFPA 750, *Standard on Water Mist Fire Protection Systems*, 2019 edition.

NFPA 770, *Standard on Hybrid (Water and Inert Gas) Fire-Extinguishing Systems*, 2021 edition.

NFPA 780, *Standard for the Installation of Lightning Protection Systems*, 2023 edition.

NFPA 801, *Standard for Fire Protection for Facilities Handling Radioactive Materials*, 2020 edition.

NFPA 804, *Standard for Fire Protection for Advanced Light Water Reactor Electric Generating Plants*, 2020 edition.

NFPA 805, *Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants*, 2020 edition.

NFPA 820, *Standard for Fire Protection in Wastewater Treatment and Collection Facilities*, 2024 edition.

NFPA 855, *Standard for the Installation of Stationary Energy Storage Systems*, 2023 edition.

NFPA 909, *Code for the Protection of Cultural Resource Properties — Museums, Libraries, and Places of Worship*, 2021 edition.

NFPA 914, *Code for the Protection of Historic Structures*, 2023 edition.

NFPA 1030, *Standard for Professional Qualifications for Fire Prevention Program Positions*, 2024 edition.

NFPA 1122, *Code for Model Rocketry*, 2018 edition.

NFPA 1123, *Code for Fireworks Display*, 2022 edition.

NFPA 1124, *Code for the Manufacture, Transportation, and Storage of Fireworks and Pyrotechnic Articles*, 2022 edition.

NFPA 1125, *Code for the Manufacture of Model Rocket and High-Power Rocket Motors*, 2022 edition.

NFPA 1126, *Standard for the Use of Pyrotechnics Before a Proximate Audience*, 2021 edition.

NFPA 1127, *Code for High Power Rocketry*, 2018 edition.

NFPA 1140, *Standard for Wildland Fire Protection*, 2022 edition.

NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*, 2022 edition.

NFPA 1192, *Standard on Recreational Vehicles*, 2021 edition.

NFPA 1194, *Standard for Recreational Vehicle Parks and Campgrounds*, 2021 edition.

NFPA 1225, *Standard for Emergency Services Communications*, 2022 edition.

NFPA 1660, *Standard on Community Risk Assessment, Pre-Incident Planning, Mass Evacuation, Sheltering, and Re-entry Programs*, 2024 edition.

NFPA 1730, *Standard on Organization and Deployment of Fire Prevention Inspection and Code Enforcement, Plan Review, Investigation, and Public Education Operations*, 2019 edition.

NFPA 1900, *Standard for Aircraft Rescue and Firefighting Vehicles, Automotive Fire Apparatus, Wildland Fire Apparatus, and Automotive Ambulances*, 2024 edition.

NFPA 1910, *Standard for Marine Firefighting Vessels and the Inspection, Maintenance, Testing, Refurbishing, and Retirement of In-Service Emergency Vehicles*, 2024 edition.

NFPA 1963, *Standard for Fire Hose Connections*, 2019 edition.

NFPA 2001, *Standard on Clean Agent Fire Extinguishing Systems*, 2022 edition.

NFPA 2010, *Standard for Fixed Aerosol Fire Extinguishing Systems*, 2020 edition.

NFPA 2113, *Standard on Selection, Care, Use, and Maintenance of Flame-Resistant Garments for Protection of Industrial Personnel Against Short-Duration Thermal Exposures from Fire*, 2020 edition.

NFPA 5000®, *Building Construction and Safety Code*®, 2024 edition.

2.3 Other Publications.

2.3.1 ANSI Publications. American National Standards Institute, Inc., 25 West 43rd Street, 4th Floor, New York, NY 10036.

ANSI B11.19, *Performance Requirements for Risk Reduction Measures: Safeguarding and other Means of Reducing Risk*, 2019.

ANSI/BHMA A156.3, *Exit Devices*, 2020.

ANSI/AWWA G200, *Distribution Systems Operation and Management*, 2021.

2.3.2 APA Publications. 7910 Woodmont Avenue, Suite 1220, Bethesda, MD 20814.

APA 87-1, *Standard for the Construction and Approval for Transportation of Fireworks, Novelties, and Theatrical Pyrotechnics*, 2001.

▲ **2.3.3 API Publications.** American Petroleum Institute, 1220 L Street, NW, Washington, DC 20005-4070.

API-ASME *Code for Unfired Pressure Vessels for Petroleum Liquids and Gases*, Pre-July 1, 1961.

API Specification 12B, *Bolted Tanks for Storage of Production Liquids*, 15th edition, 2014.

API Specification 12D, *Field-welded Tanks for Storage of Production Liquids*, 12th edition, 2017.

API Specification 12F, *Shop-welded Tanks for Storage of Production Liquids*, 13th edition, 2019.

API 607, *Fire Test for Quarter-Turn Valves and Valves Equipped with Nonmetallic Seats*, 7th edition, 2016.

API 620, *Design and Construction of Large, Welded, Low-Pressure Storage Tanks*, 12th edition, Addendum 2 (2018), 2013.

API 650, *Welded Tanks for Oil Storage*, 12th edition, Addendum 3 (2018), 2013.

API 653, *Tank Inspection, Repair, Alteration, and Reconstruction*, 5th edition, Addendum 1 (2014), Addendum 2 (2018), Addendum 3 (2021), 2014.

2.3.4 ASCE Publications. American Society of Civil Engineers, 1801 Alexander Bell Drive, Reston, VA 20191-4400.

ASCE/SEI 7, *Minimum Design Loads and Associated Criteria for Buildings and Other Structures*, 2016.

2.3.5 ASHRAE Publications. ASHRAE, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305.

ANSI/ASHRAE 15, *Safety Standard for Refrigeration Systems*, 2019.

ANSI/ASHRAE 34, *Designation and Safety Classification of Refrigerants*, 2019.

▲ **2.3.6 ASME Publications.** American Society of Mechanical Engineers, Two Park Avenue, New York, NY 10016-5990.

ASME A13.1, *Scheme for the Identification of Piping Systems*, 2020.

ASME A17.1, *Safety Code for Elevators and Escalators*, 2019.

ASME A17.3, *Safety Code for Existing Elevators and Escalators*, 2020.

ANSI/ASME B31.1, *Power Piping*, 2020.

ANSI/ASME B31.3, *Process Piping*, 2020.

ANSI/ASME B31.4, *Pipeline Transportation Systems for Liquids and Slurries*, 2019.

ASME Boiler and Pressure Vessel Code, 2021.

ASME Boiler and Pressure Vessel Code, Section VIII, "Rules for the Construction of Unfired Pressure Vessels," 2021.

▲ **2.3.7 ASTM Publications.** ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM A395, *Standard Specification for Ferritic Ductile Iron Pressure-Retaining Castings for Use at Elevated Temperatures*, 1999, reapproved 2018.

ASTM D56, *Standard Test Method for Flash Point by Tag Closed Cup Tester*, 2021a.

ASTM D92, *Standard Test Method for Flash and Fire Points by Cleveland Open Cup Tester*, 2018.

ASTM D86, *Standard Test Method for Distillation of Petroleum Products at Atmospheric Pressure*, 2020b.

ASTM D93, *Standard Test Methods for Flash Point by Pensky-Martens Closed Cup Tester*, 2020.

ASTM D323, *Standard Method of Test for Vapor Pressure of Petroleum Products (Reid Method)*, 2020a.

ASTM D396, *Standard Specification for Fuel Oils*, 2021.

ASTM D635, *Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position*, 2018.

ASTM D1929, *Standard Test Method for Determining Ignition Temperature of Plastics*, 2020.

ASTM D2843, *Standard Test Method for Density of Smoke from the Burning or Decomposition of Plastics*, 2019.

ASTM D2859, *Standard Test Method for Ignition Characteristics of Finished Textile Floor Covering Materials*, 2016, reapproved 2021.

ASTM D2898, *Standard Practice for Accelerated Weathering of Fire-Retardant-Treated Wood for Fire Testing*, 2010, reapproved 2017.

ASTM D3278, *Standard Test Methods for Flash Point of Liquids by Small Scale Closed-Cup Apparatus*, 2021.

ASTM D3699, *Standard Specification for Kerosene*, 2019.

ASTM D3828, *Standard Test Methods for Flash Point by Small Scale Closed Cup Tester*, 2016a, reapproved 2021.

ASTM D5391, *Standard Test Method for Electrical Conductivity and Resistivity of a Flowing High Purity Water Sample*, 2014.

ASTM D5456, *Standard Specification for Evaluation of Structural Composite Lumber Products*, 2021e1.

ASTM D6448, *Standard Specification for Industrial Burner Fuels from Used Lubricating Oils*, 2016.

ASTM D6751, *Standard Specification for Biodiesel Fuel Blend Stock (B100) for Middle Distillate Fuel*, 2020a.

ASTM D6823, *Standard Specification for Commercial Burner Fuels with Used Lubricating Oils*, 2008, reapproved 2021.

ASTM D7666, *Standard Specification for Triglyceride Burner Fuel*, 2019.

ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials*, 2021a.

ASTM E108, *Standard Test Methods for Fire Tests of Roof Coverings*, 2020a.

ASTM E119, *Standard Test Methods for Fire Tests of Building Construction and Materials*, 2020.

ASTM E136, *Standard Test Method for Assessing Combustibility of Materials Using a Vertical Tube Furnace at 750 Degrees C*, 2019a.

ASTM E648, *Standard Test Method for Critical Radiant Flux of Floor-Covering Systems Using a Radiant Heat Energy Source*, 2019ae1.

ASTM E681, *Standard Test Method for Concentration Limits of Flammability of Chemicals (Vapors and Gases)*, 2009, reapproved 2015.

ASTM E814, *Standard Test Method for Fire Tests of Penetration Firestop Systems*, 2013a, reapproved 2017.

ASTM E1354, *Standard Test Method for Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter*, 2017.

ASTM E1537, *Standard Test Method for Fire Testing of Upholstered Furniture*, 2016.

ASTM E1590, *Standard Test Method for Fire Testing of Mattresses*, 2022.

ASTM E1591, *Standard Guide for Obtaining Data for Fire Growth Models*, 2020.

ASTM E1966, *Standard Test Method for Fire-Resistive Joint Systems*, 2015, reapproved 2019.

ASTM E2019, *Standard Test Method for Minimum Ignition Energy of a Dust Cloud in Air*, 2003, reapproved 2019.

ASTM E2174, *Standard Practice for On-Site Inspection of Installed Firestops*, 2020a.

ASTM E2307, *Standard Test Method for Determining Fire Resistance of Perimeter Fire Barriers Using Intermediate-Scale, Multi-story Test Apparatus*, 2020.

ASTM E2336, *Standard Test Methods for Fire Resistive Grease Duct Enclosure Systems*, 2020.

ASTM E2393, *Standard Practice for On-Site Inspection of Installed Fire Resistive Joint Systems and Perimeter Fire Barriers*, 2020a.

ASTM E2404, *Standard Practice for Specimen Preparation and Mounting of Textile, Paper or Polymeric (Including Vinyl) and Wood Wall or Ceiling Coverings, Facings and Veneers, to Assess Surface Burning Characteristics*, 2017.

ASTM E2573, *Standard Practice for Specimen Preparation and Mounting of Site-Fabricated Stretch Systems to Assess Surface Burning Characteristics*, 2019.

ASTM E2599, *Standard Practice for Specimen Preparation and Mounting of Reflective Insulation, Radiant Barrier and Vinyl Stretch Ceiling Materials for Building Applications to Assess Surface Burning Characteristics*, 2018.

ASTM E2652, *Standard Test Method for Assessing Combustibility of Materials Using a Tube Furnace with a Cone-Shaped Airflow Stabilizer, at 750 Degrees C*, 2018.

ASTM E2768, *Standard Test Method for Extended Duration Surface Burning Characteristics of Building Materials (30 min Tunnel Test)*, 2011, reapproved 2018.

ASTM E2965, *Standard Test for Determination of Low Levels of Heat Release Rate for Materials and Products Using an Oxygen Combustion Calorimeter*, 2017.

ASTM E3082, *Standard Test Methods for Determining the Effectiveness of Fire Retardant Treatments for Natural Christmas Trees*, 2020.

ASTM F852/F852M, *Standard for Portable Gasoline, Kerosene, and Diesel Containers for Consumer Use*, 2022.

ASTM F2200, *Standard Specification for Automated Vehicular Gate Construction*, 2020.

▲ **2.3.8 CGA Publications.** Compressed Gas Association, 14501 George Carter Way, Suite 103, Chantilly, VA 20151.

CGA C-7, *Guide to Classification and Labeling of Compressed Gases*, 2020.

ANSI/CGA G-13, *Storage and Handling of Silane and Silane Mixtures*, 2016.

CGA P-1, *Standard for Safe Handling of Compressed Gases in Containers*, 2022.

ANSI/CGA P-18, *Standard for Bulk Inert Gas Systems*, 2020.

CGA P-20, *Standard for the Classification of Toxic Gas Mixtures*, 2017.

CGA P-23, *Standard for Categorizing Gas Mixtures Containing Flammable and Nonflammable Components*, 2015.

CGA S-1.1, *Pressure Relief Device Standards — Part 1 — Cylinders for Compressed Gases*, 2022.

CGA S-1.2, *Pressure Relief Device Standards — Part 2 — Portable Containers for Compressed Gases*, 2019.

CGA S-1.3, *Pressure Relief Device Standards — Part 3 — Stationary Storage Containers for Compressed Gases*, 2020.

2.3.9 CTA Publications. Canadian Transportation Agency, Queen's Printer, Ottawa, Ontario, Canada. (Available from the Canadian Communications Group Publication Centre, Ordering Department, Ottawa, Canada K1A 0S9.)

Transportation of Dangerous Goods Regulations.

2.3.10 EI Publications. Energy Institute, 61 New Cavendish Street, London W1G 7AR, United Kingdom.

EI 1529, *Aviation Fueling Hose and Hose Assemblies*, 2014 (reaffirmed 2019).

▲ **2.3.11 FM Publications.** FM Approvals LLC, 1151 Boston-Providence Turnpike, P.O. Box 9102, Norwood, MA 02062.

ANSI/FM 4880, *American National Standard for Evaluating the Fire Performance of Insulated Building Panel Assemblies and Interior Finish Materials*, 2017.

FM 6051/6052, *Approval Standard for Safety Containers and Filling, Supply, and Disposal Containers — for Ignitable (Flammable) Liquids*, November 2017.

FM 6083, *Approval Standard for Plastic Plugs for Steel Drums*, October 2006.

FM 6921, *Approval Standard for Oily Containers for Combustible Waste*, 2004.

2.3.12 ICC Publications. International Code Council, 500 New Jersey Avenue, NW, 6th Floor, Washington, DC 20001-2070.

ICC A117.1, *Accessible and Usable Buildings and Facilities*, 2017.

2.3.13 IEC Publications. International Electrotechnical Commission, 3, rue de Varembé, P.O. Box 131, CH-1211 Geneva 20, Switzerland.

IEC 61340-4-4, *Electrostatics—Part 4-4: Standard Test Methods for Specific Applications — Electrostatic Classification of Flexible Intermediate Bulk Containers (FIBC)*, 2018.

▲ **2.3.14 IIAR Publications.** International Institute of Ammonia Refrigeration, 1001 N. Fairfax Street, Suite 503, Alexandria, VA 22314.

ANSI/IIAR 2, *Standard for Design of Safe Closed-Circuit Ammonia Refrigeration Systems*, 2021.

ANSI/IIAR 6, *Standard for the Inspection, Testing, and Maintenance of Closed-Circuit Ammonia Refrigeration Systems*, 2019.

ANSI/IIAR 7, *Standard for Developing Operating Procedures for Closed-Circuit Ammonia Mechanical Refrigeration Systems*, 2019.

ANSI/IIAR 8, *Standard for Decommissioning of Closed-Circuit Ammonia Mechanical Refrigeration Systems*, 2020.

2.3.15 ISO Publications. International Organization for Standardization, ISO Central Secretariat, BIBC II, Chemin de Blandonnet 8, CP 401, 1214 Vernier, Geneva, Switzerland.

ISO 10156, *Gas Cylinders — Gases and Gas Mixtures — Determination of Fire Potential and Oxidizing Ability for the Selection of Cylinder Valve Outlets*, 2017.

ISO 10298, *Gas Cylinders — Gases and Gas Mixtures — Determination of Toxicity for the Selection of Cylinder Valve Outlets*, amendment 1 (2021), 2018.

2.3.16 ITSDF Publications. Industrial Truck Standards Development Foundation, Suite 460, 1750 K Street NW, Washington, DC 20006.

ANSI/ITSDF B56.1, *Safety Standard for Low Lift and High Lift Trucks*, 2020.

2.3.17 NBBPVI Publications. National Board of Boiler and Pressure Vessel Inspectors, 1055 Crupper Avenue, Columbus, OH 43229.

NBBI NB23, *National Board Inspection Code*, 2021.

2.3.18 NRFC Publications. National Railroad Freight Committee, 222 South Riverside Plaza, Chicago, IL 60606-5945.

Uniform Freight Classification (UFC), 2005.

2.3.19 RVIA Publications. Recreation Vehicle Industry Association, 1896 Preston White Drive, P.O. Box 2999, Reston, VA 20195-0999.

RVIA/ANSI A119.5, *Park Model Recreational Vehicle Standard*, 2020.

2.3.20 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

UL 8, *Water Based Agent Fire Extinguishers*, 2016, revised 2020.

UL 9, *Fire Tests of Window Assemblies*, 2009, revised 2020.

UL 10B, *Fire Tests of Door Assemblies*, 2008, revised 2020.

UL 10C, *Positive Pressure Fire Tests of Door Assemblies*, 2016, revised 2021.

UL 25, *Meters for Flammable and Combustible Liquids and LP-Gas*, 2021.

UL 30, *Metal Safety Cans*, 1995, revised 2019.

UL 38, *Manual Signaling Boxes for Fire Alarm Systems*, 2008, revised 2018.

UL 58, *Steel Underground Tanks for Flammable and Combustible Liquids*, 2018.

UL 79, *Power-Operated Pumps for Petroleum Dispensing Products*, 2016, revised 2021.

UL 79A, *Power-Operated Pumps for Gasoline and Gasoline/Ethanol Blends with Nominal Ethanol Concentrations up to 85 Percent (E0–E85)*, 2015 (2016), revised 2020.

UL 80, *Steel Tanks for Oil Burner Fuels and Other Combustible Liquids*, 2007, revised 2019.

UL 87A, *Power-Operated Dispensing Devices for Gasoline and Gasoline/Ethanol Blends with Nominal Ethanol Concentrations up to 85 Percent (E0–E85)*, 2015, revised 2020.

UL 142, *Steel Aboveground Tanks for Flammable and Combustible Liquids*, 2019, revised 2021.

UL 142A, *Special Purpose Aboveground Tanks for Specific Flammable or Combustible Liquids*, 2018, revised 2021.

UL 147A, *Nonrefillable (Disposable) Type Fuel Gas Cylinder Assemblies*, 2018, revised 2019.

UL 147B, *Nonrefillable (Disposable) Type Metal Container Assemblies for Butane*, 2016, revised 2019.

UL 154, *Carbon Dioxide Fire Extinguishers*, 2005, revised 2021.

UL 162, *Foam Equipment and Liquid Concentrates*, 2018, revised 2022.

UL 197, *Commercial Electric Cooking Appliances*, 2010, revised 2020.

UL 263, *Fire Tests of Building Construction and Materials*, 2011, revised 2021.

UL 294, *Access Control System Units*, 2018.

UL 296A, *Waste Oil-Burning Air-Heating Appliances*, 2018.

UL 299, *Dry Chemical Fire Extinguishers*, 2012, revised 2021.

UL 300, *Fire Testing of Fire Extinguishing Systems for Protection of Commercial Cooking Equipment*, 2019.

UL 305, *Panic Hardware*, 2012, revised 2017.

UL 325, *Door, Drapery, Gate, Louver, and Window Operators and Systems*, 2017, revised 2020.

UL 330A, *Hose and Hose Assemblies for Use with Dispensing Devices Dispensing Gasoline and Gasoline/Ethanol Blends with Nominal Ethanol Concentrations up to 85 Percent (E0–E85)*, 2019, revised 2020.

UL 340, *Tests for Comparative Flammability of Liquids*, 2017.

UL 499, *Electric Heating Appliances*, 2014, revised 2021.

UL 555, *Fire Dampers*, 2006, revised 2020.

UL 555S, *Smoke Dampers*, 2014, revised 2020.

UL 567, *Emergency Breakaway Fittings, Swivel Connectors and Pipe Connection Fittings for Petroleum Products and LP-Gas*, 2021.

UL 567A, *Emergency Breakaway Fittings, Swivel Connectors and Pipe-Connection Fittings for Gasoline and Gasoline/Ethanol Blends with Nominal Ethanol Concentrations up to 85 Percent (E0–E85)*, 2015 revised 2019.

UL 626, *Water Fire Extinguishers*, 2005, revised 2021.

UL 647, *Unvented Kerosene-Fired Room Heaters and Portable Heaters*, 1993, revised 2010.

UL 710B, *Recirculating Systems*, 2011, revised 2021.

UL 711, *Rating and Fire Testing of Fire Extinguishers*, 2018.

UL 723, *Test for Surface Burning Characteristics of Building Materials*, 2018.

UL 790, *Test Methods for Fire Tests of Roof Coverings*, 2022.

UL 842, *Valves for Flammable Fluids*, 2007, 2022.

UL 842A, *Valves for Gasoline and Gasoline/Ethanol Blends with Nominal Ethanol Concentrations up to 85 Percent (E0–E85)*, 2015, revised 2019.

UL 900, *Air Filter Units*, 2015.

UL 913, *Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III Division 1, Hazardous (Classified) Locations*, 2013, revised 2019.

UL 924, *Emergency Lighting and Power Equipment*, 2016, revised 2020.

UL 962A, *Furniture Power Distribution Units*, 2018, revised 2021.

- UL 971, *Nonmetallic Underground Piping for Flammable Liquids*, 2021.
- UL 1026, *Household Electric Cooking and Food Serving Appliances*, 2021, revised 2021.
- UL 1037, *Antitheft Alarms and Devices*, 2016, revised 2017.
- UL 1040, *Fire Test of Insulated Wall Construction*, 1996, revised 2022.
- UL 1278, *Movable and Wall- or Ceiling-Hung Electric Room Heaters*, 2014, revised 2022.
- UL 1313, *Nonmetallic Safety Cans for Petroleum Products*, 2015.
- UL 1315, *Metal Waste Paper Containers*, 2017.
- UL 1316, *Fibre Reinforced Underground Storage Tanks for Flammable and Combustible Liquids*, 2018, revised 2019.
- UL 1363, *Relocatable Power Taps*, 2018.
- UL 1363A, *Outline of Investigation for Special Purpose Relocatable Power Taps*, 2010.
- UL 1369, *Above Ground Piping for Flammable and Combustible Liquids*, 2018, revised 2020.
- CAN/UL 1389, *Plant Oil Extraction Equipment for Installation and Use in Ordinary (Unclassified) Locations and Hazardous (Classified) Locations*, 2019, revised 2021.
- UL 1479, *Fire Tests of Penetration Firestops*, 2015, revised 2021.
- UL 1484, *Residential Gas Detectors*, 2016, revised 2022.
- UL 1564, *Industrial Battery Chargers*, 2015, revised 2020.
- UL 1573, *Stage and Studio Luminaires and Connector Strips*, 2003, revised 2019.
- UL 1640, *Portable Power-Distribution Equipment*, 2016, revised 2021.
- UL 1715, *Fire Test of Interior Finish Material*, 1997, revised 2022.
- UL 1803, *Factory Follow-up on Third Party Certified Portable Fire Extinguishers*, 2012, revised 2021.
- UL 1973, *Batteries for Use in Stationary and Motive Auxiliary Power Applications*, 2022.
- UL 1975, *Fire Tests for Foamed Plastics Used for Decorative Purposes*, 2006.
- UL 1994, *Luminous Egress Path Marking Systems*, 2015, revised 2020.
- UL 2011, *Outline of Investigation for Machinery*, 2019, revised 2021.
- UL 2034, *Single and Multiple Station Carbon Monoxide Alarms*, 2017, revised 2018.
- UL 2075, *Gas and Vapor Detectors and Sensors*, 2013, revised 2021.
- UL 2079, *Tests for Fire Resistance of Building Joint Systems*, 2015, revised 2020.
- UL 2080, *Fire Resistant Tanks for Flammable and Combustible Liquids*, 2000.
- UL 2085, *Protected Aboveground Tanks for Flammable and Combustible Liquids*, 1997, revised 2010.
- UL 2129, *Halocarbon Clean Agent Fire Extinguishers*, 2017, revised 2021.
- UL 2208, *Solvent Distillation Units*, 2010, revised 2020.
- UL 2245, *Below-Grade Vaults for Flammable Liquid Storage Tanks*, 2006.
- UL 2258, *Aboveground Nonmetallic Tanks for Fuel Oil and Other Combustible Liquids*, 2018, revised 2019.
- CAN/UL 2272, *Electrical Systems for Personal E-Mobility Devices*, 2016, revised 2019.
- UL 2358, *Outline of Investigation for Fire Tests of Pre-Lit Artificial Seasonal Use Trees and Other Seasonal Decorative Items*, 2013.
- UL 2368, *Fire Exposure Testing of Rigid Nonmetallic and Composite Nonmetallic Intermediate Bulk Containers for Flammable and Combustible Liquids*, 2012, revised 2018.
- UL 2524, *In-building 2-Way Emergency Radio Communication Enhancement Systems*, 2019.
- UL 2586, *Hose Nozzle Valves for Flammable and Combustible Liquids*, 2021.
- UL 2586A, *Hose Nozzle Valves for Gasoline and Gasoline/Ethanol Blends with Nominal Ethanol Concentrations up to 85 Percent (E0–E85)*, 2015, revised 2019.
- CAN/UL 2849, *Electrical Systems for eBikes*, 2020.
- UL 2930, *Outline of Investigation for Cord-and-Plug-Connected Health Care Facility Outlet Assemblies*, 2020.
- UL 3400, *Outline of Investigation for Additive Manufacturing Facility Safety Management*, 2017.
- UL 9540, *Energy Storage Systems and Equipment*, 2020, revised 2021.
- UL 60601-1, *Medical Electrical Equipment, Part 1: General Requirements for Safety*, 2003, revised 2006.
- UL 60950-1, *Information Technology Equipment — Safety — Part 1: General Requirements*, 2007, revised 2019.
- UL 62368-1, *Audio/Video, Information and Communication Technology Equipment — Part 1: Safety Requirements*, 2019, revised 2021.
- 2.3.21 ULC Publications.** ULC Standards, 171 Nepean Street, Suite 400, Ottawa, ON K2P 0B4, Canada.
- CAN/ULC 8800, *Horticultural Lighting Equipment and Systems*, 2019, revised 2022.
- CAN/ULC-S503, *Carbon-Dioxide Fire Extinguishers*, 2005.
- CAN/ULC-S504, *Dry Chemical Fire Extinguishers*, 2012, revised 2021.
- CAN/ULC-S507, *Water Fire Extinguishers*, 2005, revised 2021.
- CAN/ULC-S508, *Rating and Testing of Fire Extinguishers*, 2018.
- CAN/ULC-S512, *Halogenated Agent Hand and Wheeled Fire Extinguishers*, 2005.
- CAN/ULC-S554, *Water Based Agent Fire Extinguishers*, 2016.

CAN/ULC-S566, *Halocarbon Clean Agent Fire Extinguishers*, 2017, revised 2021.

2.3.22 UN Publications. United Nations Headquarters, New York, NY 10017.

Recommendations on the Transport of Dangerous Goods, 19th revised edition, 2015.

Manual of Tests and Criteria, Part II, 7th edition, 2019.

2.3.23 US Government Publications. US Government Publishing Office, 732 North Capitol Street, NW, Washington, DC 20401-0001.

FAA AC 150/5390-2C, *Heliport Design Advisory Circular*, April 24, 2012.

Interstate Commerce Commission (ICC), *Rules for Construction of Unfired Pressure Vessels*, US Department of Transportation, Washington, DC.

Resource Conservation and Recovery Act (RCRA), US Department of Transportation, Washington, DC, 1976.

Title 16, Code of Federal Regulations, Part 1500.41, "Method of Testing Primary Irritant Substances."

Title 16, Code of Federal Regulations, Part 1632, "Standard for the Flammability of Mattresses and Mattress Pads," (FF 4-72).

Title 21, Code of Federal Regulations, Part 210, "Processing, Packing, or Holding Drugs; General."

Title 21, Code of Federal Regulations, Part 211, "Current Good Manufacturing Practice for Finished Pharmaceuticals."

Title 27, Code of Federal Regulations, Part 555.

Title 29, Code of Federal Regulations, Part 1910.242(b), "Compressed Air Used for Cleaning."

Title 29, Code of Federal Regulations, Part 1910.1000, "Air Contaminants."

Title 29, Code of Federal Regulations, Part 1910.1200, "Hazard Communication."

Title 46, Code of Federal Regulations, Parts 30, 32, 35, and 39, "Shipping."

Title 49, Code of Federal Regulations, Parts 100 through 199.

Title 49, Code of Federal Regulations, Part 173, "Shippers — General Requirements for Shipments and Packages."

Title 49, Code of Federal Regulations, Part 173, Annex H, "Method of Testing for Sustained Combustibility."

Title 49, Code of Federal Regulations, Part 180.205, "General Requirements for Requalification of Specification Cylinders."

Title 49, Code of Federal Regulations, Part 571.108, "Lamps, Reflective Devices, and Associated Equipment."

2.3.24 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 10, *Standard for Portable Fire Extinguishers*, 2022 edition.
NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2022 edition.

NFPA 14, *Standard for the Installation of Standpipe and Hose Systems*, 2024 edition.

NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*, 2022 edition.

NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2023 edition.

NFPA 30, *Flammable and Combustible Liquids Code*, 2024 edition.

NFPA 30A, *Code for Motor Fuel Dispensing Facilities and Repair Garages*, 2024 edition.

NFPA 30B, *Code for the Manufacture and Storage of Aerosol Products*, 2023 edition.

NFPA 31, *Standard for the Installation of Oil-Burning Equipment*, 2020 edition.

NFPA 33, *Standard for Spray Application Using Flammable or Combustible Materials*, 2021 edition.

NFPA 34, *Standard for Dipping, Coating, and Printing Processes Using Flammable or Combustible Liquids*, 2021 edition.

NFPA 36, *Standard for Solvent Extraction Plants*, 2021 edition.

NFPA 45, *Standard on Fire Protection for Laboratories Using Chemicals*, 2024 edition.

NFPA 51B, *Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*, 2024 edition.

NFPA 52, *Vehicular Natural Gas Fuel Systems Code*, 2023 edition.

NFPA 55, *Compressed Gases and Cryogenic Fluids Code*, 2023 edition.

NFPA 58, *Liquefied Petroleum Gas Code*, 2024 edition.

NFPA 59A, *Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG)*, 2023 edition.

NFPA 61, *Standard for the Prevention of Fires and Dust Explosions in Agricultural and Food Processing Facilities*, 2020 edition.

NFPA 68, *Standard on Explosion Protection by Deflagration Venting*, 2023 edition.

NFPA 69, *Standard on Explosion Prevention Systems*, 2019 edition.

NFPA 70®, *National Electrical Code®*, 2023 edition.

NFPA 72®, *National Fire Alarm and Signaling Code®*, 2022 edition.

NFPA 80, *Standard for Fire Doors and Other Opening Protectives*, 2022 edition.

NFPA 88A, *Standard for Parking Structures*, 2023 edition.

NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*, 2024 edition.

NFPA 96, *Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations*, 2024 edition.

NFPA 101®, *Life Safety Code®*, 2024 edition.

NFPA 140, *Standard on Motion Picture and Television Production Studio Soundstages, Approved Production Facilities, and Production Locations*, 2024 edition.

NFPA 211, *Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances*, 2019 edition.

NFPA 303, *Fire Protection Standard for Marinas and Boatyards*, 2021 edition.

NFPA 307, *Standard for the Construction and Fire Protection of Marine Terminals, Piers, and Wharves*, 2021 edition.

NFPA 312, *Standard for Fire Protection of Vessels During Construction, Conversion, Repair, and Lay-Up*, 2021 edition.

NFPA 400, *Hazardous Materials Code*, 2022 edition.

NFPA 407, *Standard for Aircraft Fuel Servicing*, 2022 edition.

NFPA 415, *Standard on Airport Terminal Buildings, Fueling Ramp Drainage, and Loading Walkways*, 2022 edition.

NFPA 418, *Standard for Heliports*, 2021 edition.

NFPA 440, *Guide for Aircraft Rescue and Firefighting Operations and Airport/Community Emergency Planning*, 2024 edition.

NFPA 470, *Hazardous Materials/Weapons of Mass Destruction (WMD) Standard for Responders*, 2022 edition.

NFPA 652, *Standard on the Fundamentals of Combustible Dust*, 2019 edition.

NFPA 654, *Standard for the Prevention of Fire and Dust Explosions from the Manufacturing, Processing, and Handling of Combustible Particulate Solids*, 2020 edition.

NFPA 805, *Performance-Based Standard for Fire Protection for Light Water Reactor Electric Generating Plants*, 2020 edition.

NFPA 855, *Standard for the Installation of Stationary Energy Storage Systems*, 2023 edition.

NFPA 914, *Code for the Protection of Historic Structures*, 2023 edition.

NFPA 1030, *Standard for Professional Qualifications for Fire Prevention Program Positions*, 2024 edition.

NFPA 1124, *Code for the Manufacture, Transportation, and Storage of Fireworks and Pyrotechnic Articles*, 2022 edition.

NFPA 1140, *Standard for Wildland Fire Protection*, 2022 edition.

NFPA 1142, *Standard on Water Supplies for Suburban and Rural Fire Fighting*, 2022 edition.

NFPA 1730, *Standard on Organization and Deployment of Fire Prevention Inspection and Code Enforcement, Plan Review, Investigation, and Public Education Operations*, 2019 edition.

NFPA 5000®, *Building Construction and Safety Code*®, 2024 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this *Code*. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the AHJ.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3* Code. A standard that is an extensive compilation of provisions covering broad subject matter or that is suitable for adoption into law independently of other codes and standards.

3.2.4 Guide. A document that is advisory or informative in nature and that contains only nonmandatory provisions. A guide may contain mandatory statements such as when a guide can be used, but the document as a whole is not suitable for adoption into law.

3.2.5 Labeled. Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

3.2.6* Listed. Equipment, materials, or services included in a list published by an organization that is acceptable to the AHJ and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

3.2.7 Recommended Practice. A document that is similar in content and structure to a code or standard but that contains only nonmandatory provisions using the word “should” to indicate recommendations in the body of the text.

3.2.8 Shall. Indicates a mandatory requirement.

3.2.9 Should. Indicates a recommendation or that which is advised but not required.

3.2.10 Standard. An NFPA Standard, the main text of which contains only mandatory provisions using the word “shall” to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase “standards development process” or “standards development activities,” the term “standards” includes all NFPA Standards, including Codes, Standards, Recommended Practices, and Guides.

3.3 General Definitions.

3.3.1* Absolute Pressure. Pressure based on a zero reference point, the perfect vacuum. [55, 2023] (FCC-HAZ)

3.3.2 Access Box. An approved secure box, accessible by the AHJ's master key or control, containing entrance keys or other devices to gain access to a structure or area. (FCC-FUN)

3.3.3 Addition. An increase in the building area, aggregate floor area, building height, or number of stories of a structure. [5000, 2024] (FCC-FUN)

3.3.4 Additive Manufacturing. A process of joining materials to make objects from 3D model data, usually layer upon layer, sometimes referred to as 3D printing. (FCC-HAZ)

3.3.4.1 Industrial Additive Manufacturing. 3D printing operations that utilize combustible powders or metals, an inert gas supply, or a combustible dust collection system or that create a hazardous electrical classification area outside of the equipment. (FCC-HAZ)

3.3.4.2 Nonindustrial Additive Manufacturing. 3D printing operations that do not create a hazardous electrical classification area outside of the equipment and do not utilize an

inert gas supply or combustible dust collection system. (FCC-HAZ)

N 3.3.5* Aerosol Container. A metal can or plastic container, up to a maximum size of 1000 ml (33.8 fl oz), or a glass bottle, up to a maximum size of 118 ml (4 fl oz), that is designed and intended to dispense an aerosol. [30B, 2023] (FCC-HAZ)

3.3.6* Aerosol Products. A nonrefillable combination of an aerosol container, aerosol propellant, and aerosol valve, with or without a base product, that is dispensed through the aerosol valve. [30B, 2023] (FCC-HAZ)

N 3.3.7 Aerosol Propellant. A liquefied or compressed gas that is used in whole or in part, such as a cosolvent, to expel a liquid or any other material from the same self-pressurized container or from a compartmented container. [30B, 2023] (FCC-HAZ)

N 3.3.8* Aerosol Valve. A self-closing device attached to an aerosol container to allow dispensing of the contents of an aerosol product. [30B, 2023] (FCC-HAZ)

Δ 3.3.9 Airport (Aerodrome). An area on land or water that is used or intended to be used for the landing and takeoff of aircraft and includes buildings and facilities. [440, 2024] (FCC-OCF)

3.3.10 Airport Ramp. Any outdoor area, including aprons and hardstands, where aircraft can be positioned, stored, serviced, or maintained, irrespective of the nature of the surface of the area. [415, 2022] (FCC-OCF)

3.3.11* Aisle Width. The horizontal dimension between the face of the loads in racks under consideration. [13, 2022] (FCC-OCF)

3.3.12 Alarm. An indication of the existence of a condition that requires immediate response. [72, 2019] (FCC-OCF)

3.3.13 Alarm Signal. See 3.3.256.1.

3.3.14 Alcohol-Based Hand Rub. An alcohol-containing preparation designed for application to the hands for reducing the number of visible microorganisms on the hands and containing ethanol or isopropanol in an amount not exceeding 95 percent by volume. (FCC-HAZ)

3.3.15 Alleyway. An accessible clear space between storage piles or groups of piles suitable for housekeeping operations, visual inspection of piling areas, and initial fire-fighting operations. (FCC-OCF)

3.3.16 ANSI/ASME. The designation for American National Standards Institute publication sponsored and published by the American Society of Mechanical Engineers. (FCC-FUN)

3.3.17 Area.

3.3.17.1 Back Stock Area. The area of a mercantile occupancy that is physically separated from the sales area and not intended to be accessible to the public. [30B, 2023] (FCC-HAZ)

3.3.17.2 Control Area. A building or portion of a building or outdoor area within which hazardous materials are allowed to be stored, dispensed, used, or handled in quantities not exceeding the maximum allowable quantities (MAQ). [400, 2022] (FCC-HAZ)

3.3.17.3 Fire Area. An area of a building separated from the remainder of the building by construction having a fire

resistance of at least 1 hour and having all communicating openings properly protected by an assembly having a fire resistance rating of at least 1 hour. [30, 2024] (FCC-OCF)

3.3.17.4 Fire Flow Area. The floor area, in square feet, used to determine the required fire flow. (FCC-FUN)

3.3.17.5 Indoor Area. An area that is within a building or structure having overhead cover, other than a structure qualifying as “weather protection.” [55, 2023] (FCC-HAZ)

3.3.17.6 Organic Peroxide Storage Area. An area used for the storage of organic peroxide formulations. [400, 2022] (FCC-HAZ)

3.3.17.7 Outdoor Area. An area that is not an indoor area. [55, 2023] (FCC-HAZ)

3.3.17.8 Permissible Areas.

3.3.17.8.1 Designated Area. A specific location designed and approved for hot work operations that is maintained fire-safe, such as a maintenance shop or a detached outside location, that is of noncombustible or fire-resistive construction, essentially free of combustible and flammable contents, and suitably segregated from adjacent areas. [51B, 2024] (FCC-HAZ)

3.3.17.8.2 Permit-Required Area. Any location other than a designated area that is approved for hot work and is made fire-safe by removing or protecting combustibles from ignition sources. [51B, 2024] (FCC-HAZ)

3.3.17.9 Sales Display Area. The area of a mercantile occupancy that is open to the public for the purpose of viewing and purchasing goods, wares, and merchandise. Individuals are free to circulate among the items, which are typically displayed on shelves, on racks, or on the floor. [30B, 2023] (FCC-HAZ)

3.3.17.10 Smoking Area. A designated area where smoking is permitted within a premises in which smoking is otherwise generally prohibited. (FCC-OCF)

3.3.17.11* Spray Area. Any fully enclosed, partly enclosed, or unenclosed area in which flammable or combustible vapors, mists, residues, dusts, or deposits are present due to the operation of spray processes, including (1) any area in the direct path of a spray application process; (2) the interior of a spray booth, spray room, or limited finishing workstation, as herein defined; (3) the interior of any exhaust plenum, eliminator section, or scrubber section; (4) the interior of any exhaust duct or exhaust stack leading from a spray application process; (5) the interior of any air recirculation path up to and including recirculation particulate filters; (6) any solvent concentrator (pollution abatement) unit or solvent recovery (distillation) unit; and (7) the inside of a membrane enclosure. The following are not part of the spray area: (1) fresh air make-up units; (2) air supply ducts and air supply plenums; (3) recirculation air supply ducts downstream of recirculation particulate filters; and (4) exhaust ducts from solvent concentrator (pollution abatement) units. [33, 2021] (FCC-HAZ)

3.3.18 ASME. American Society of Mechanical Engineers. [58, 2024] (FCC-HAZ)

3.3.19 ASME Container (or Tank). See 3.3.73.1.

3.3.20 ASTM. American Society for Testing and Materials, now known as “ASTM International.” [55, 2023] (FCC-HAZ)

3.3.21 Automatic Emergency Shutoff Valve. A designated fail-safe automatic closing valve designed to shut off the flow of gases or liquids that is initiated by a control system where the control system is activated by either manual or automatic means. [55, 2023] (FCC-HAZ)

N 3.3.22 Automatic Sprinkler. A fire suppression or control device that operates automatically when its heat-activated element is heated to its thermal rating or above, allowing water to discharge over a specified area. [13, 2022] (FCC-OCF)

3.3.23* Baled Cotton. A natural seed fiber wrapped and secured in industry-accepted materials, usually consisting of burlap, woven polypropylene, or sheet polyethylene, and secured with steel, synthetic, or wire bands, or wire; also includes linters (lint removed from the cottonseed) and motes (residual materials from the ginning process). (FCC-HAZ)

3.3.23.1 Block. A basic yard storage unit for baled cotton comprising multiple-row storage with clear spaces on all sides. (FCC-HAZ)

3.3.23.2* Densely Packed Baled Cotton. Cotton, made into banded bales, with a packing density of at least 22 lb/ft³ (360 kg/m³), and dimensions complying with the following: a length of 55 in. (ca. 1400 mm ± 20 mm), a width of 21 in. (ca. 530 mm ± 20 mm), and a height of 27.6 in. to 35.4 in. (700 mm to 900 mm). (FCC-HAZ)

3.3.23.3 Fire-Packed Baled Cotton. A cotton bale within which a fire has been packed as a result of a process in which ginning is the most frequent cause. (FCC-HAZ)

3.3.23.4 Naked Cotton Bale. An unwrapped cotton bale secured with wire or steel straps. (FCC-HAZ)

3.3.24 Barrel. A unit of volume used in the petroleum industry that is equal to 42 gal (159 L). [30, 2024] (FCC-HAZ)

3.3.25 Basement. Any story of a building wholly or partly below grade plane that is not considered the first story above grade plane. (See also 3.3.289.1 in NFPA 5000®, First Story Above Grade Plane.) [5000, 2024] (FCC-FUN)

3.3.26 Battery System. A system that consists of these interconnected subsystems: (1) stationary storage batteries, (2) battery chargers, and (3) a collection of rectifiers, inverters, converters, and associated electrical equipment as required for a particular application. (FCC-HAZ)

3.3.27 Battery Types, Stationary.

3.3.27.1 Lithium-Ion Battery. A storage battery that consists of lithium ions imbedded in a carbon graphite or nickel metal-oxide substrate. The electrolyte is a carbonate mixture or a gelled polymer. The lithium ions are the charge carriers of the battery. (FCC-HAZ)

3.3.27.2 Lithium Metal Polymer Battery. A storage battery that is comprised of nonaqueous liquid or polymerized electrolytes, which provide ionic conductivity between lithiated positive active material electrically separated from metallic lithium or lithiated negative active material. (FCC-HAZ)

3.3.27.3 Nickel Cadmium (NiCad) Battery. An alkaline storage battery in which the positive active material is nickel

oxide, the negative contains the cadmium, and the electrolyte is potassium hydroxide. (FCC-HAZ)

3.3.27.4* Valve-Regulated (VRLA). A lead-acid battery consisting of sealed cells furnished with a valve that opens to vent the battery whenever the internal pressure of the battery exceeds the ambient pressure by a set amount. (FCC-HAZ)

3.3.28 Block. See 3.3.23.1.

3.3.29 Board of Appeals. A group of persons appointed by the governing body of the jurisdiction adopting this Code for the purpose of hearing and adjudicating differences of opinion between the AHJ and the citizenry in the interpretation, application, and enforcement of this Code. (FCC-FUN)

3.3.30* Boiling Point (BP). The temperature at which the vapor pressure of a liquid equals the surrounding atmospheric pressure. [30, 2024] (FCC-HAZ)

3.3.31* Boil-Over. An event in the burning of certain oils in an open-top tank when, after a long period of quiescent burning, there is a sudden increase in fire intensity associated with expulsion of burning oil from the tank. [30, 2024] (FCC-HAZ)

3.3.32* Building. Any structure used or intended for supporting or sheltering any use or occupancy. [101, 2024] (FCC-FUN)

3.3.32.1* Airport Terminal Building. A structure used primarily for air passenger enplaning or deplaning, including ticket sales, flight information, baggage handling, and other necessary functions in connection with air transport operations. This term includes any extensions and satellite buildings used for passenger handling or aircraft flight service functions. Aircraft loading walkways and “mobile lounges” are excluded. [415, 2022] (FCC-OCF)

3.3.32.2 Apartment Building. See 3.3.203.2.

3.3.32.3 Attached Building. A building having only one common wall with another building having other types of occupancies. (FCC-HAZ)

3.3.32.4 Bulk Merchandising Retail Building. See 3.3.203.4.

3.3.32.5* Existing Building. A building erected or officially authorized prior to the effective date of the adoption of this edition of the Code by the agency or jurisdiction. [101, 2024] (FCC-FUN)

3.3.32.6* High-Rise Building. A building where the floor of an occupiable story is greater than 75 ft (23 m) above the lowest level of fire department vehicle access. [5000, 2024] (FCC-FUN)

3.3.32.7* Important Building. A building that is considered not expendable in an exposure fire. [30, 2024] (FCC-HAZ)

3.3.32.8 Mini-Storage Building. See 3.3.203.31.1.

3.3.32.9 Satellite. A structure that can be adjacent to but separated from the airport terminal building, accessible above ground or through subway passages, and used to provide flight service operations, such as passenger check-in, waiting rooms, food service, enplaning or deplaning, etc. [415, 2022] (FCC-OCF)

3.3.32.10* Special Amusement Building. A building or portion thereof that is temporary, permanent, or mobile and contains a ride or device that conveys patrons where the

patrons can be contained or restrained, or provides a walkway along, around, or over a course in any direction as a form of amusement or entertainment, and arranged so that the egress path is not readily apparent due to visual or audio distractions, contains an intentionally confounded egress path, or is not readily available due to the mode of conveyance through the building or structure. [101, 2024] (FCC-OCP)

3.3.32.11 Storage Tank Building. A three-dimensional space that is enclosed by a roof and walls that cover more than one-half of the possible area of the sides of the space, is of sufficient size to allow entry by personnel, will likely limit the dissipation of heat or dispersion of vapors, and restricts access for fire fighting. [30, 2024] (FCC-HAZ)

3.3.33 Bulk Hydrogen Compressed Gas System. See 3.3.283.1.

3.3.34 Bulk Inert Gas System. See 3.3.283.2.

3.3.35 Bulk Liquefied Hydrogen Gas System. See 3.3.283.3.

3.3.36 Bulk Oxygen System. See 3.3.283.4.

3.3.37 Bulk Plant or Terminal. That portion of a property where liquids are received by tank vessel, pipelines, tank car, or tank vehicle and are stored or blended in bulk for the purpose of distributing such liquids by tank vessel, pipeline, tank car, tank vehicle, portable tank, or container. (FCC-HAZ)

3.3.38 Burn-It. A fire-fighting strategy that allows for the free burn of a tire fire. (FCC-OCP)

3.3.39 Bury-It. A fire-fighting strategy in which a tire pile is buried with soil, sand, gravel, cement dust, or other cover material. (FCC-OCP)

3.3.40 Cannabis Extraction Equipment. Equipment or appliances used for the extraction of botanical material, such as essential oils, from cannabis. (FCC-OCP)

3.3.41 Cannabis Extraction Facility. A building used for the solvent-based extraction process of cannabis. (FCC-OCP)

3.3.42 Carbon Dioxide Enrichment Process. A process where carbon dioxide gas is intentionally introduced into an indoor environment for the purpose of accelerating plant growth. (FCC-OCP)

3.3.43* Cathodic Protection. A technique to resist the corrosion of a metal surface by making the surface the cathode of an electrochemical cell. [55, 2023] (FCC-HAZ)

3.3.44 Cathodic Protection Tester. A person who demonstrates an understanding of the principles and measurements of all common types of cathodic protection systems applicable to metal piping and container systems and who has education and experience in soil resistivity, stray current, structure-to-soil potential, and component electrical isolation measurements of metal piping and container systems. [55, 2023] (FCC-HAZ)

3.3.45 Certificate of Fitness. A written document issued by the AHJ to any person for the purpose of granting permission to such person to conduct or engage in any operation or act for which certification is required. (FCC-FUN)

3.3.46 CFR. The Code of Federal Regulations of the United States Government. (FCC-FUN)

3.3.47 CGA. Compressed Gas Association. (FCC-FUN)

3.3.48 Chemical Fume Hood. A ventilated enclosure designed to contain and exhaust fumes, gases, vapors, mists, and particulate matter generated within the hood interior. [45, 2024] (FCC-OCP)

3.3.49 Chemical Name. The scientific designation of a chemical in accordance with the nomenclature system developed by the International Union of Pure and Applied Chemistry or the Chemical Abstracts Service rules of nomenclature, or a name that clearly identifies a chemical for the purpose of conducting an evaluation. (FCC-HAZ)

3.3.50 Chemical Plant. A large integrated plant or that portion of such a plant, other than a refinery or distillery, where liquids are produced by chemical reactions or used in chemical reactions. [30, 2024] (FCC-HAZ)

3.3.51* Chip. A wood chip of various species used in the manufacture of pulp. (FCC-OCP)

3.3.52* Cleaning Media. Materials used to clean piping systems. [55, 2023] (FCC-HAZ)

3.3.53 Cleanroom. A room in which the concentration of airborne particles is controlled to specified limits, including areas below the raised floor and above the ceiling grid if these areas are part of the air path and within the rated construction. [5000, 2024] (FCC-OCP)

3.3.54 Clear Space. An area free of combustible materials but that can contain noncombustible materials that cannot transmit an exposure fire. (FCC-OCP)

3.3.55 Closed System Use. See 3.3.298.1.

3.3.56 Closed-Top Diking. A dike with a cover intended to minimize the entrance of precipitation into the diked area. [30, 2024] (FCC-HAZ)

3.3.57 Code.

Δ **3.3.57.1 Building Code.** The building code enforced by the jurisdiction or agency enforcing this Code. [101, 2021] (FCC-FUN)

3.3.57.2 Electrical Code. The electrical code adopted by the jurisdiction. (FCC-FUN)

3.3.57.3 Mechanical Code. The mechanical or mechanical construction code adopted by the jurisdiction. [55, 2023] (FCC-HAZ)

3.3.57.4 Plumbing Code. The plumbing code adopted by the jurisdiction. (FCC-FUN)

3.3.58 Cold Deck. A single ranked pile of logs with individual logs of regular or irregular length usually 20 ft to 50 ft (6.1 m to 15.2 m) long, but greater than 8 ft (2.4 m) long. (FCC-OCP)

3.3.59 Column (Paper). A single vertical stack of rolls of paper. (FCC-OCP)

3.3.60 Combustible (Material). A material that, in the form in which it is used and under the conditions anticipated, will ignite and burn; a material that does not meet the definition of noncombustible or limited-combustible. [101, 2024] (FCC-FUN)

3.3.61* Combustible Dust. A finely divided combustible particulate solid that presents a flash fire hazard or explosion hazard when suspended in air or the process-specific oxidizing

medium over a range of concentrations. [652, 2019] (FCC-HAZ)

3.3.62* Combustible Fiber. Any material in a fibrous or shredded form that readily ignites when heat sources are present. (FCC-HAZ)

3.3.63 Combustible Liquid. See 3.3.180.1.

3.3.64 Combustible Particulate Solid. See 3.3.264.1.

3.3.65 Combustible Refuse. All combustible or loose rubbish, litter, or waste materials generated by an occupancy that are refused, rejected, or considered worthless and are disposed of by incineration on the premises where generated or periodically transported from the premises. (FCC-OCF)

3.3.66* Combustible Waste. Combustible or loose waste material that is generated by an establishment or process and, if salvageable, is retained for scrap or reprocessing on the premises where generated or transported to a plant for processing. (FCC-OCF)

3.3.67 Combustion. A chemical process of oxidation that occurs at a rate fast enough to produce heat and usually light in the form of either a glow or flame. (FCC-FUN)

3.3.68 Commodity. The combination of products, packing material, and container that determines commodity classification. [13, 2022] (FCC-OCF)

3.3.69* Common Path of Travel. The portion of exit access that must be traversed before two separate and distinct paths of travel to two exits are available. [101, 2024] (FCC-OCF)

3.3.70 Compartment.

3.3.70.1* Fire Compartment. A space within a building that is enclosed by fire barriers on all sides, including the top and bottom. [101, 2024] (FCC-OCF)

3.3.70.2* Smoke Compartment. A space within a building enclosed by smoke barriers on all sides, including the top and bottom. [101, 2024] (FCC-OCF)

3.3.71 Condition, Existing. See 3.3.109.

3.3.72 Construction Documents. Documents that consist of scaled design drawings and specifications for the purpose of construction of new facilities or modification to existing facilities. (See also 3.3.255, *Shop Drawings*.) (FCC-FUN)

3.3.73 Container. A vessel, including cylinders, tanks, portable tanks, and cargo tanks, used for transporting or storing materials. (FCC-HAZ)

3.3.73.1 ASME Container. A container constructed in accordance with the ASME Code. [58, 2024] (FCC-HAZ)

3.3.73.2 Compressed Gas Container. A pressure vessel designed to hold compressed gas at an absolute pressure greater than 1 atmosphere at 68°F (20°C) that includes cylinders, containers, and tanks. [55, 2023] (FCC-HAZ)

3.3.73.3* Container (Flammable or Combustible Liquid). A vessel of 119 gal (450 L) or less capacity used for transporting or storing liquids, excluding intermediate bulk containers. [30, 2024] (FCC-HAZ)

3.3.73.3.1 Closed Container. A container as herein defined, so sealed by means of a lid or other device that neither

liquid nor vapor will escape from it at ordinary temperatures. [30, 2024] (FCC-HAZ)

3.3.73.4 Cryogenic Fluids Container. A cryogenic vessel used for transportation, handling, or storage. (FCC-HAZ)

3.3.73.5 Intermediate Bulk Container. Any closed vessel having a liquid capacity not exceeding 3000 L (793 gal) and intended for storing and transporting liquids, as defined in Title 49, Code of Federal Regulations, Parts 100 through 199 or in Part 6 of the United Nations *Recommendations on the Transport of Dangerous Goods*. [30, 2024] (FCC-HAZ)

3.3.73.6 [LP-Gas] Container. Any vessel, including cylinders, tanks, portable tanks, and cargo tanks, used for the transporting or storing of LP-Gases. [58, 2024] (FCC-HAZ)

3.3.74 Control Area. See 3.3.17.2.

3.3.75* Conventional Pallet. A material-handling aid designed to support a unit load with openings to provide access for material-handling devices. (See Figure A.3.3.75.) [13, 2022] (FCC-OCF)

3.3.76 Cooking Fire. The noncommercial, residential burning of materials not exceeding 3 ft (0.9 m) in diameter and 2 ft (0.6 m) in height, other than rubbish in which the fuel burned is contained in an outdoor fireplace, a barbecue grill, or a barbecue pit for the purpose of preparing food. (FCC-FUN)

3.3.77 Cordwood. Logs 8 ft (2.4 m) or less in length customarily intended for pulpwood or fuel uses. (FCC-OCF)

3.3.78 Corrosive Material. See 3.3.189.3.

3.3.79 Crude Petroleum. Hydrocarbon mixtures that have a flash point below 150°F (65.6°C) and that have not been processed in a refinery. [30, 2024] (FCC-HAZ)

3.3.80 Cryogenic Fluid. A fluid with a boiling point lower than -130°F (-90°C) at an absolute pressure of 14.7 psi (101.3 kPa). [55, 2023] (FCC-HAZ)

3.3.80.1 Flammable Cryogenic Fluid. A cryogenic fluid that forms flammable mixtures in air when in its vapor state. [55, 2023] (FCC-HAZ)

3.3.80.2 Inert Cryogenic Fluid. A cryogenic fluid that vaporizes to produce an inert gas when in its vapor state. [55, 2023] (FCC-HAZ)

3.3.80.3 Oxidizing Cryogenic Fluid. An oxidizing gas in the cryogenic state. [55, 2023] (FCC-HAZ)

3.3.81* Cultural Resource Properties. Buildings, structures, or sites, or portions thereof, that are culturally significant, or that house culturally significant collections for museums, libraries, and places of worship. [914, 2023] (FCC-OCF)

3.3.82 Cylinder. A pressure vessel designed for absolute pressures higher than 40 psi (276 kPa) and having a circular cross-section. It does not include a portable tank, multiunit tank car tank, cargo tank, or tank car. [55, 2023] (FCC-HAZ)

3.3.83 Cylinder Containment Vessel. A gastight recovery vessel designed so that a leaking compressed gas container can be placed within its confines, thereby encapsulating the leaking container. [55, 2023] (FCC-HAZ)

3.3.84* Cylinder Pack. An arrangement of cylinders into a cluster where the cylinders are confined into a grouping or

arrangement with a strapping or frame system and connections are made to a common manifold. The frame system is allowed to be on skids or wheels to permit movement. [55, 2023] (FCC-HAZ)

Δ **3.3.85 Damage-Limiting Construction.** For the purposes of this *Code*, any set of construction elements, used individually or in combination, which will act to limit damage from an explosion, including open structures, pressure relieving construction, or pressure resistant construction. [30, 2024] (FCC-HAZ)

3.3.86* Deficiency. For the purposes of inspection, testing, and maintenance of water-based fire protection systems, a condition that will or has the potential to adversely impact the performance of a system or portion thereof but does not rise to the level of an impairment. [25, 2023] (FCC-OCP)

3.3.86.1 Critical Deficiency. A deficiency that, if not corrected, can have a material effect on the ability of the fire protection system or unit to function as intended in a fire event. [25, 2023] (FCC-OCP)

Δ **3.3.86.2 Noncritical Deficiency.** A deficiency that does not have a material effect on the ability of the fire protection system or unit to function in a fire event, but correction is needed to meet the requirements of this *Code* and NFPA 25 or for the proper inspection, testing, and maintenance of the system or unit. [25, 2023] (FCC-OCP)

3.3.87 Deflagration. Propagation of a combustion zone at a velocity that is less than the speed of sound in the unreacted medium. [68, 2023] (FCC-HAZ)

3.3.88 Delivered Audio Quality (DAQ). A measure of speech intelligibility over a transmission medium. (FCC-FUN)

3.3.89 Desolventizing. The act of removing a solvent from a material. (FCC-HAZ)

3.3.90 Detector. A device suitable for connection to a circuit that has a sensor that responds to a physical stimulus such as gas, heat or smoke. [72, 2019] (FCC-OCP)

3.3.90.1 Air Sampling-Type Detector. A detector that consists of a piping or tubing distribution network that runs from the detector to the area(s) to be protected. An aspiration fan in the detector housing draws air from the protected area back to the detector through air-sampling ports, piping, or tubing. At the detector, the air is analyzed for fire products. [72, 2019] (FCC-OCP)

3.3.90.2 Automatic Fire Detector. A device designed to detect the presence of a fire signature and to initiate action. For the purpose of this *Code*, automatic fire detectors are classified as follows: Automatic Fire Extinguishing or Suppression System Operation Detector, Fire-Gas Detector, Heat Detector, Other Fire Detectors, Radiant Energy-Sensing Fire Detector, and Smoke Detector. [72, 2019] (FCC-OCP)

3.3.90.3 Automatic Fire Extinguishing or Suppression System Operation Detector. A device that automatically detects the operation of a fire extinguishing or suppression system by means appropriate to the system employed. [72, 2019] (FCC-OCP)

3.3.90.4* Combination Detector. A device that either responds to more than one of the fire phenomena or employs more than one operating principle to sense one of these phenomena. Typical examples are a combination of a

heat detector with a smoke detector or a combination rate-of-rise and fixed-temperature heat detector. This device has listings for each sensing method employed. [72, 2019] (FCC-OCP)

3.3.90.5 Electrical Conductivity Heat Detector. A line-type or spot-type sensing element in which resistance varies as a function of temperature. [72, 2019] (FCC-OCP)

3.3.90.6 Fire-Gas Detector. A device that detects gases produced by a fire. [72, 2019] (FCC-OCP)

3.3.90.7* Fixed-Temperature Detector. A device that responds when its operating element becomes heated to a predetermined level. [72, 2019] (FCC-OCP)

3.3.90.8* Flame Detector. A radiant energy-sensing fire detector that detects the radiant energy emitted by a flame. (Refer to A.17.8.2 of NFPA 72.) [72, 2019] (FCC-OCP)

3.3.90.9 Gas Detector. A device that detects the presence of a specified gas concentration. Gas detectors can be either spot-type or line-type detectors. [72, 2019] (FCC-OCP)

3.3.90.10 Heat Detector. A fire detector that detects either abnormally high temperature or rate of temperature rise, or both. [72, 2019] (FCC-OCP)

3.3.90.11 Line-Type Detector. A device in which detection is continuous along a path. Typical examples are rate-of-rise pneumatic tubing detectors, projected beam smoke detectors, and heat-sensitive cable. [72, 2019] (FCC-OCP)

3.3.90.12* Multi-Criteria Detector. A device that contains multiple sensors that separately respond to physical stimulus such as heat, smoke, or fire gases, or employs more than one sensor to sense the same stimulus. This sensor is capable of generating only one alarm signal from the sensors employed in the design either independently or in combination. The sensor output signal is mathematically evaluated to determine when an alarm signal is warranted. The evaluation can be performed either at the detector or at the control unit. This detector has a single listing that establishes the primary function of the detector. [72, 2019] (FCC-OCP)

3.3.90.13* Multi-Sensor Detector. A device that contains multiple sensors that separately respond to physical stimulus such as heat, smoke, or fire gases, or employs more than one sensor to sense the same stimulus. A device capable of generating multiple alarm signals from any one of the sensors employed in the design, independently or in combination. The sensor output signals are mathematically evaluated to determine when an alarm signal is warranted. The evaluation can be performed either at the detector or at the control unit. This device has listings for each sensing method employed. [72, 2019] (FCC-OCP)

3.3.90.14 Other Fire Detectors. Devices that detect a phenomenon other than heat, smoke, flame, or gases produced by a fire. [72, 2019] (FCC-OCP)

3.3.90.15 Pneumatic Rate-of-Rise Tubing Heat Detector. A line-type detector comprising small-diameter tubing, usually copper, that is installed on the ceiling or high on the walls throughout the protected area. The tubing is terminated in a detector unit containing diaphragms and associated contacts set to actuate at a predetermined pressure. The

system is sealed except for calibrated vents that compensate for normal changes in temperature. [72, 2019] (FCC-OCP)

3.3.90.16 Projected Beam-Type Detector. A type of photoelectric light obscuration smoke detector wherein the beam spans the protected area. [72, 2019] (FCC-OCP)

3.3.90.17 Radiant Energy-Sensing Fire Detector. A device that detects radiant energy, such as ultraviolet, visible, or infrared, that is emitted as a product of combustion reaction and obeys the laws of optics. [72, 2019] (FCC-OCP)

3.3.90.18* Rate Compensation Detector. A device that responds when the temperature of the air surrounding the device reaches a predetermined level, regardless of the rate of temperature rise. [72, 2019] (FCC-OCP)

3.3.90.19* Rate-of-Rise Detector. A device that responds when the temperature rises at a rate exceeding a predetermined value. [72, 2019] (FCC-OCP)

3.3.90.20 Smoke Detector. A device that detects visible or invisible particles of combustion. [72, 2019] (FCC-OCP)

3.3.90.21 Spark/Ember Detector. A radiant energy-sensing fire detector that is designed to detect sparks or embers, or both. These devices are normally intended to operate in dark environments and in the infrared part of the spectrum. [72, 2019] (FCC-OCP)

3.3.90.22 Spot-Type Detector. A device in which the detecting element is concentrated at a particular location. Typical examples are bimetallic detectors, fusible alloy detectors, certain pneumatic rate-of-rise detectors, certain smoke detectors, and thermoelectric detectors. [72, 2019] (FCC-OCP)

3.3.91 Detonation. Propagation of a combustion zone at a velocity greater than the speed of sound in the unreacted medium. [68, 2023] (FCC-HAZ)

3.3.92 Dispensing. The pouring or transferring of a material from a container tank, or similar vessel whereby vapors, dusts, fumes, mists, or gases could be liberated to the atmosphere. [5000, 2024] (FCC-HAZ)

3.3.93 Distillery. A plant or that portion of a plant where liquids produced by fermentation are concentrated and where the concentrated products are also mixed, stored, or packaged. [30, 2024] (FCC-HAZ)

3.3.94 Distributor. A business engaged in the sale or resale, or both, of compressed gases or cryogenic fluids, or both. [55, 2023] (FCC-HAZ)

3.3.95 Donor Antenna. Antennas used with in-building emergency responder communications enhancement systems that provide the connection between the wide-area communications system of interest and the in-building system. (FCC-FUN)

3.3.96 Dormitory. See 3.3.203.9.

3.3.97 DOT. US Department of Transportation. (FCC-FUN)

3.3.98 Driveway. A clear space suitable for fire-fighting operations by motorized fire apparatus. (FCC-FUN)

3.3.99* Dwelling Unit. One or more rooms arranged for complete, independent housekeeping purposes, with space for eating, living, and sleeping; facilities for cooking; and provisions for sanitation. [5000, 2024] (FCC-OCP)

3.3.99.1 One- and Two-Family Dwelling Unit. See 3.3.203.25.1.

3.3.100 Emergency. A fire, explosion, or hazardous condition that poses an immediate threat to the safety of life or damage to property. (FCC-FUN)

3.3.101 Emergency Relief Vent. An opening, construction method, or device that will automatically relieve excessive internal pressure due to an exposure fire. [30, 2024] (FCC-HAZ)

3.3.102 Emergency Shutoff Valve. A designated valve designed to shut off the flow of gases or liquids. [55, 2023] (FCC-HAZ)

Δ **3.3.103* Energy Storage Systems (ESS).** One or more devices, assembled together, capable of storing energy to supply electrical energy at a future time. [855, 2023] (FCC-HAZ)

Δ **3.3.104 Ethylene Oxide Drum.** For the purposes of this Code, containers built to UN specification 1A1. [55, 2023] (FCC-HAZ)

3.3.105 Excess Flow Control. A fail-safe system or approved means designed to shut off flow due to a rupture in pressurized piping systems. [55, 2023] (FCC-HAZ)

3.3.106 Excess Flow Valve. A valve inserted into a compressed gas cylinder, portable tank, or stationary tank that is designed to positively shut off the flow of gas in the event that its predetermined flow is exceeded. (FCC-HAZ)

3.3.107* Exhausted Enclosure. An appliance or piece of equipment that consists of a top, a back, and two sides that provides a means of local exhaust for capturing gases, fumes, vapors, and mists. [55, 2023] (FCC-HAZ)

3.3.108* Existing. That which is already in existence on the date this edition of the Code goes into effect. [101, 2024] (FCC-FUN)

3.3.109 Existing Condition. Any situation, circumstance, or physical makeup of any structure, premise, or process that was ongoing or in effect prior to the adoption of this Code. (FCC-FUN)

3.3.110* Exit. That portion of a means of egress that is separated from all other spaces of the building or structure by construction, location, or equipment as required to provide a protected way of travel to the exit discharge. [101, 2024] (FCC-OCP)

3.3.110.1* Horizontal Exit. A way of passage from one building to an area of refuge in another building on approximately the same level, or a way of passage through or around a fire barrier to an area of refuge on approximately the same level in the same building that affords safety from fire and smoke originating from the area of incidence and areas communicating therewith. [101, 2024] (FCC-OCP)

3.3.111 Exit Access. That portion of a means of egress that leads to an exit. [101, 2024] (FCC-OCP)

3.3.112 Exit Discharge. That portion of a means of egress between the termination of an exit and a public way. [101, 2024] (FCC-OCP)

3.3.113 Explosion. The bursting or rupture of an enclosure or a container due to the development of internal pressure from a deflagration. [69, 2019] (FCC-HAZ)

3.3.114* Explosion Control. A means of either preventing an explosion through the use of explosion suppression, fuel reduction, or oxidant reduction systems or a means to prevent the structural collapse of a building in the event of an explosion through the use of deflagration venting, barricades, or related construction methods. [55, 2023] (FCC-HAZ)

3.3.115* Explosive Material. A chemical compound, mixture, or device, the primary or common purpose of which is to function by explosion. [5000, 2024] (FCC-HAZ)

3.3.116 Extraction Room (Cannabis). The room or space in which the solvent-based extraction process of cannabis occurs. (FCC-OCF)

3.3.117 Facility. As applied to access and water supply, a structure or use in a fixed location including exterior storage, use, and handling areas that relates to the occupancies and operations covered by this Code. (FCC-FUN)

3.3.117.1 Animal Housing Facility. Area of a building or structure, including interior and adjacent exterior spaces, where animals are fed, rested, worked, exercised, treated, exhibited, or used for production. (FCC-OCF)

3.3.117.2 Hazardous Material Storage Facility. See 3.3.157.

3.3.117.3 Limited Care Facility. See 3.3.203.16.

3.3.117.4 Motor Fuel Dispensing Facility. See 3.3.203.22.

3.3.117.4.1 Fleet Vehicle Motor Fuel Dispensing Facility. See 3.3.203.22.1.

3.3.117.4.2 Marine Motor Fuel Dispensing Facility. See 3.3.203.22.2.

3.3.117.4.3 Motor Fuel Dispensing Facility Located Inside a Building. See 3.3.203.22.3.

3.3.118 Fail-Safe. A design arrangement incorporating one or more features that automatically counteracts the effect of an anticipated source of failure or which includes a design arrangement that eliminates or mitigates a hazardous condition by compensating automatically for a failure or malfunction. (FCC-HAZ)

3.3.119* Festival Seating. A form of audience/spectator accommodation in which no seating, other than a floor or finished ground level, is provided for the audience/spectators gathered to observe a performance. [101, 2024] (FCC-OCF)

3.3.120 Fines (Wood). Small pieces or splinters of wood by-products that can pass through a 0.25 in. (6.4 mm) screen. (FCC-HAZ)

3.3.121 Finish.

3.3.121.1 Interior Ceiling Finish. The interior finish of ceilings. [101, 2024] (FCC-OCF)

3.3.121.2* Interior Finish. The exposed surfaces of walls, ceilings, and floors within buildings. [101, 2024] (FCC-OCF)

3.3.121.3* Interior Floor Finish. The interior finish of floors, ramps, stair treads and risers, and other walking surfaces. [101, 2024] (FCC-OCF)

3.3.121.4* Interior Wall Finish. The interior finish of columns, fixed or movable walls, and fixed or movable partitions. [101, 2024] (FCC-OCF)

3.3.122 Fires, Classification of.

3.3.122.1 Class A Fires. Class A fires are fires in ordinary combustible materials, such as wood, cloth, paper, rubber, and many plastics. [10, 2018] (FCC-OCF)

3.3.122.2 Class B Fires. Class B fires are fires in flammable liquids, combustible liquids, petroleum greases, tars, oils, oil-based paints, solvents, lacquers, alcohols, and flammable gases. [10, 2018] (FCC-OCF)

3.3.122.3 Class C Fires. Class C fires are fires that involve energized electrical equipment. [10, 2018] (FCC-OCF)

3.3.122.4 Class D Fires. Class D fires are fires in combustible metals, such as magnesium, titanium, zirconium, sodium, lithium, and potassium. [10, 2018] (FCC-OCF)

3.3.122.5 Class K Fires. Class K fires are fires in cooking appliances that involve combustible cooking media (vegetable or animal oils and fats). [10, 2018] (FCC-OCF)

3.3.123 Fire, Recreational. See 3.3.239.

3.3.124 Fire Alarm System. See 3.3.283.10.

3.3.125 Fire Apparatus Access Road. The road or other means developed to allow access and operational setup for fire-fighting and rescue apparatus. (FCC-FUN)

3.3.126 Fire Compartment. See 3.3.70.1.

3.3.127 Fire Door Assembly. Any combination of a fire door, a frame, hardware, and other accessories that together provide a specific degree of fire protection to the opening. [80, 2019] (FCC-OCF)

3.3.128 Fire Flow. The flow rate of a water supply, measured at 20 psi (137.9 kPa) residual pressure, that is available for fire fighting. (FCC-FUN)

3.3.129 Fire Hazard. Any situation, process, material, or condition that, on the basis of applicable data, can cause a fire or explosion or that can provide a ready fuel supply to augment the spread or intensity of a fire or explosion, all of which pose a threat to life or property. [914, 2019] (FCC-FUN)

Δ 3.3.130* Fire Hydrant. A valved connection on a water supply system having one or more outlets and that is used to supply hose and fire department pumpers with water. [1140, 2022] (FCC-FUN)

3.3.131* Fire Lane. A fire apparatus access road, which is marked with approved signs or other approved notices. (FCC-FUN)

3.3.132 Fire Monitoring. Provisions implemented to provide early warning of smoldering fire conditions in the hot work area following completion of the established fire watch time period. [51B, 2024] (FCC-HAZ)

3.3.133 Fire Point. The lowest temperature at which a liquid will ignite and achieve sustained burning when exposed to a test flame in accordance with ASTM D92, *Standard Test Method for Flash and Fire Points by Cleveland Open Cup Tester*. [30, 2024] (FCC-HAZ)

3.3.134 Fire Retardant. A liquid, solid, or gas that tends to inhibit combustion when applied on, mixed in, or combined with combustible materials. (FCC-OCF)

3.3.135 Fire Watch. The assignment of a person or persons to an area for the express purpose of notifying the fire department, the building occupants, or both of an emergency; preventing a fire from occurring; extinguishing small fires; protecting the public from fire and life safety dangers. (FCC-FUN)

3.3.136* Fireworks. Any composition or device for the purpose of producing a visible or an audible effect for entertainment purposes by combustion, deflagration, or detonation, that meets the definition of *Consumer Fireworks* or *Display Fireworks* as set forth in NFPA 1124. [1124, 2022] (FCC-HAZ)

3.3.136.1* Display Fireworks. Large fireworks devices that are explosive materials intended for use in fireworks displays and designed to produce visible or audible effects by combustion, deflagration, or detonation, as set forth in 27 CFR 555, 49 CFR 172, and APA 87-1, *Standard for the Construction and Approval for Transportation of Fireworks, Novelties, and Theatrical Pyrotechnics*. [1124, 2022] (FCC-HAZ)

3.3.137* Flame Spread. The propagation of flame over a surface. [101, 2024] (FCC-OCF)

3.3.138 Flame Spread Index. A comparative measure, expressed as a dimensionless number, derived from visual measurements of the spread of flame versus time for a material tested in accordance with ASTM E84, *Standard Test Method for Surface Burning Characteristics of Building Materials*, or UL 723, *Test for Surface Burning Characteristics of Burning Materials*. [101, 2024] (FCC-OCF)

3.3.139 Flammable Vapors. Flammable vapors are the concentration of flammable constituents in air that exceed 25 percent of their lower flammability limit (LFL). (FCC-HAZ)

3.3.140 Flash Point (FP). The minimum temperature of a liquid at which sufficient vapor is given off to form an ignitable mixture with the air, near the surface of the liquid or within the vessel used, as determined by the appropriate test procedure and apparatus specified in Section 4.4 of NFPA 30. [30, 2024] (FCC-HAZ)

3.3.141 Floor Area.

3.3.141.1* Gross Floor Area. The floor area within the inside perimeter of the outside walls, or the outside walls and fire walls of a building, or outside and/or inside walls that bound an occupancy or incidental use area with no deduction for hallways, stairs, closets, thickness of interior walls, columns, elevator and building services shafts, or other features, but excluding floor openings associated with atriums and communicating spaces. [5000, 2024] (FCC-OCF)

3.3.141.2 Net Floor Area. The floor area within the inside perimeter of the outside walls, or the outside walls and fire walls of a building, or outside and/or inside walls that bound an occupancy or incidental use area with deductions for hallways, stairs, closets, shafts, thickness of interior walls, columns, and other features. [5000, 2024] (FCC-OCF)

3.3.142 Forecasting. The ability to predict fire progression in a scrap tire storage location prior to the completion of the inventory fire break using heavy equipment. (FCC-OCF)

3.3.143* Fugitive Emissions. Releases of flammable vapor that continuously or intermittently occur from process equipment during normal operations. [30, 2024] (FCC-HAZ)

3.3.144 Gallon, US Standard. 1 US gal = 0.833 Imperial gal = 231 in.³ = 3.785 L. [58, 2024] (FCC-HAZ)

3.3.145 Garage. A building or portion of a building in which one or more self-propelled vehicles carrying volatile Class I liquid for fuel or power are kept for use, sale, storage, rental, repair, exhibition, or demonstrating purposes, and all that portion of a building that is on or below the floor or floors in which such vehicles are kept and that is not separated therefrom by suitable cutoffs. [5000, 2024] (FCC-OCF)

3.3.146 Gas.

3.3.146.1* Compressed Gas. A material, or mixture of materials, that (1) is a gas at 68°F (20°C) or less at an absolute pressure of 14.7 psi (101.3 kPa) and (2) has a boiling point of 68°F (20°C) or less at an absolute pressure of 14.7 psi (101.3 kPa) and that is liquefied, nonliquefied, or in solution, except those gases that have no other health or physical hazard properties are not considered to be compressed gases until the pressure in the packaging exceeds an absolute pressure of 40.6 psi (280 kPa) at 68°F (20°C). [55, 2023] (FCC-HAZ)

3.3.146.1.1 Compressed Gas Mixtures. A mixture of two or more compressed gases contained in a packaging, the hazard properties of which are represented by the properties of the mixture as a whole. (FCC-HAZ)

3.3.146.1.2 Compressed Gases in Solution. Nonliquefied gases that are dissolved in a solvent. (FCC-HAZ)

3.3.146.1.3 Liquefied Compressed Gases. Gases that are contained in a packaging under the charged pressure and are partially liquid at a temperature of 68°F (20°C). (FCC-HAZ)

3.3.146.1.4 Nonliquefied Compressed Gases. Gases, other than those in solution, that are contained in a packaging under the charged pressure and are entirely gaseous at a temperature of 68°F (20°C). (FCC-HAZ)

3.3.146.2 Corrosive Gas. A gas that causes visible destruction of or irreversible alterations in living tissue by chemical action at the site of contact. [55, 2023] (FCC-HAZ)

▲ **3.3.146.3* Flammable Gas.** A material that is a gas at 68°F (20°C) or less at an absolute pressure of 14.7 psi (101.3 kPa). [55, 2023] (FCC-HAZ)

3.3.146.4 Flammable Liquefied Gas. A liquefied compressed gas that, when under a charged pressure, is partially liquid at a temperature of 68°F (20°C) and is flammable. [55, 2023] (FCC-HAZ)

3.3.146.5 Highly Toxic Gas. A chemical that has a median lethal concentration (LC₅₀) in air of 200 ppm by volume or less of gas or vapor, or 2 mg/L or less of mist, fume, or dust, when administered by continuous inhalation for 1 hour (or less if death occurs within 1 hour) to albino rats weighing between 0.44 lb and 0.66 lb (200 g and 300 g) each. [55, 2023] (FCC-HAZ)

3.3.146.6* Inert Gas. A nonreactive, nonflammable, noncorrosive gas such as argon, helium, krypton, neon, nitrogen, and xenon. [55, 2023] (FCC-HAZ)

3.3.146.7 Liquefied Gas. A gas, other than in solution, that in a packaging under the charged pressure exists both as a

liquid and a gas at a temperature of 68°F (20°C). [30, 2024] (FCC-HAZ)

3.3.146.8 Liquefied Natural Gas (LNG). A fluid in the cryogenic liquid state that is composed predominantly of methane and that can contain minor quantities of ethane, propane, nitrogen, and other components normally found in natural gas. [59A, 2023] (FCC-HAZ)

3.3.146.9* Liquefied Petroleum Gas (LP-Gas). Any material having a vapor pressure not exceeding that allowed for commercial propane that is composed predominantly of the following hydrocarbons, either by themselves (except propylene) or as mixtures: propane, propylene, butane (normal butane or isobutane), and butylenes. [58, 2024] (FCC-HAZ)

3.3.146.10 Nonflammable Gas. A gas that does not meet the definition of a flammable gas. [55, 2023] (FCC-HAZ)

3.3.146.11* Other Gas. A gas that is not a corrosive gas, flammable gas, highly toxic gas, oxidizing gas, pyrophoric gas, toxic gas, or unstable reactive gas with a hazard rating of Class 2, Class 3, or Class 4 gas. [55, 2023] (FCC-HAZ)

3.3.146.12 Oxidizing Gas. A gas that can support and accelerate combustion of other materials more than air does. [55, 2023] (FCC-HAZ)

3.3.146.13 Pyrophoric Gas. A gas with an autoignition temperature in air at or below 130°F (54.4°C). [55, 2023] (FCC-HAZ)

3.3.146.14 Scavenged Gas. A residual process gas that is collected for treatment or release at a location remote from the site of use. (FCC-HAZ)

3.3.146.15 Simple Asphyxiant Gas. A gas that does not provide sufficient oxygen to support life and that has none of the other physical or health hazards. (FCC-HAZ)

3.3.146.16 Toxic Gas. A gas with a median lethal concentration (LC₅₀) in air of more than 200 ppm but not more than 2000 ppm by volume of gas or vapor, or more than 2 mg/L but not more than 20 mg/L of mist, fume, or dust, when administered by continuous inhalation for 1 hour (or less if death occurs within 1 hour) to albino rats weighing between 0.44 lb and 0.66 lb (200 g and 300 g) each. [55, 2023] (FCC-HAZ)

3.3.146.17* Unstable Reactive Gas. A gas that, in the pure state or as commercially produced, will vigorously polymerize, decompose, or condense; become self-reactive; or otherwise undergo a violent chemical change under conditions of shock, pressure, or temperature. [55, 2023] (FCC-HAZ)

3.3.147* Gas Cabinet. A fully enclosed, noncombustible enclosure used to provide an isolated environment for compressed gas cylinders in storage or use. [55, 2023] (FCC-HAZ)

3.3.148 Gas Manufacturer/Producer. A business that produces compressed gases or cryogenic fluids, or both, or fills portable or stationary gas cylinders, containers, or tanks. [55, 2023] (FCC-HAZ)

3.3.149 Gas Room. A separately ventilated, fully enclosed room in which only compressed gases, cryogenic fluids, associated equipment, and supplies are stored or used. [55, 2023] (FCC-HAZ)

3.3.150* Gaseous Hydrogen (GH₂) System. An assembly of equipment that consists of, but is not limited to, storage containers, pressure regulators, pressure relief devices, compressors, manifolds, and piping and that terminates at the source valve. [55, 2023] (FCC-HAZ)

3.3.151* Grade Plane. A reference plane upon which vertical measurements of a building are based representing the average of the finished ground level adjoining the building at all exterior walls. [5000, 2024] (FCC-OCF)

3.3.152 Ground Kettle. A container that could be mounted on wheels and is used for heating tar, asphalt, or similar substances. (FCC-OCF)

3.3.153 Handling. The deliberate movement of material by any means to a point of storage or use. (FCC-FUN)

3.3.154* Hazard of Contents.

3.3.154.1 High Hazard. High hazard contents shall include materials defined as hazardous materials in Chapter 3, whether stored, used, or handled. (See also 6.3.2.4.1.2 and 6.3.2.4.1.3 of NFPA 5000®.) [5000:6.3.2.4.1.1] [5000:6.3.2.4.1.2] (FCC-HAZ)

3.3.154.1.1 High Hazard Level 1 Contents. High hazard Level 1 contents shall include materials that present a detonation hazard including, but not limited to, the following: (1) Explosives; (2) Unclassified detonable organic peroxides; (3) Class 4 oxidizers; (4) Detonable pyrophoric materials; (5) Class 3 detonable and Class 4 unstable (reactive) materials. [5000:6.3.2.4.2, 6.3.2.4.1.3] (FCC-HAZ)

3.3.154.1.2 High Hazard Level 2 Contents. High hazard Level 2 contents shall include materials that present a deflagration hazard or a hazard from accelerated burning including, but not limited to, the following: (1) Class I, Class II, or Class III-A ignitable (flammable or combustible) liquids that are used or stored in normally open containers or systems, or in closed containers or systems at gauge pressures of more than 15 psi (103 kPa); (2) Combustible dusts stored, used, or generated in a manner creating a severe fire or explosion hazard; (3) Flammable gases and flammable cryogenic liquids; (4) Class I organic peroxides; (5) Class 3 solid or liquid oxidizers that are used or stored in normally open containers or systems, or in closed containers or systems at gauge pressures of more than 15 psi (103 kPa); (6) Nondetonable pyrophoric materials; (7) Class 3 nondetonable unstable (reactive) materials; (8) Class 3 water-reactive materials. [5000:6.3.2.4.3] (FCC-HAZ)

3.3.154.1.3 High Hazard Level 3 Contents. High hazard Level 3 contents shall include materials that readily support combustion or present a physical hazard including, but not limited to, the following: (1) Level 2 and Level 3 aerosols; (2) Class I, Class II, or Class III-A ignitable (flammable or combustible) liquids that are used or stored in normally closed containers or systems at gauge pressures of less than 15 psi (103 kPa); (3) Flammable solids, other than dusts classified as high hazard Level 2, stored, used, or generated in a manner creating a high fire hazard; (4) Class II and Class III organic peroxides; (5) Class 2 solid or liquid oxidizers; (6) Class 3 solid or liquid oxidizers that are used or stored in normally closed containers or systems at gauge pressures of less than 15 psi (103 kPa); (7) Oxidizing gases and oxidizing cryogenic liquids; (8) Class 2 unstable (reac-

tive) materials; (9) Class 2 water-reactive materials. [5000:6.3.2.4.4] (FCC-HAZ)

3.3.154.1.4 High Hazard Level 4 Contents. High hazard Level 4 contents shall include materials that are acute health hazards including, but not limited to, the following: (1) Corrosives; (2) Highly toxic materials; (3) Toxic materials. [5000:6.3.2.4.5] (FCC-HAZ)

3.3.154.1.5 High Hazard Level 5 Contents. High hazard Level 5 contents shall include hazardous production materials (HPM) used in the fabrication of semiconductors or semiconductor research and development. [5000:6.3.2.4.6] (FCC-HAZ)

3.3.154.2* Low Hazard Contents. Low hazard contents shall be classified as those of such low combustibility that no self-propagating fire therein can occur. [5000:6.3.2.2] (FCC-FUN)

3.3.154.3* Ordinary Hazard Contents. Ordinary hazard contents shall be classified as those that are likely to burn with moderate rapidity or to give off a considerable volume of smoke. [5000:6.3.2.3] (FCC-FUN)

3.3.155* Hazard Rating. The numerical rating of the health, flammability, self-reactivity, and other hazards of the material, including its reaction with water. [55, 2023] (FCC-HAZ)

3.3.156 Hazardous Material. See 3.3.189.4.

3.3.157 Hazardous Material Storage Facility. A building, a portion of a building, or exterior area used for the storage of hazardous materials in excess of exempt amounts. (FCC-HAZ)

3.3.158 Hazardous Materials Storage Locker. A movable prefabricated structure, manufactured primarily at a site other than the final location of the structure and transported completely assembled or in a ready-to-assemble package to the final location, and intended to meet local, state, and federal requirements for outside storage of hazardous materials. [30, 2024] (FCC-HAZ)

3.3.159* Hazardous Reaction or Hazardous Chemical Reaction. Reactions that result in dangers beyond the fire problems relating to flash point and boiling point of either the reactants or of the products. [30, 2024] (FCC-HAZ)

3.3.160 Heat Transfer Fluid (HTF). A liquid that is used as a medium to transfer heat energy from a heater or vaporizer to a remote heat consumer (e.g., injection molding machine, oven, or dryer, or jacketed chemical reactor). [30, 2024] (FCC-HAZ)

3.3.161* Heliport. An identifiable area located on land, on water, or on a structure, that also includes any existing buildings or facilities thereon, used or intended to be used for landing and takeoff of helicopters. [418, 2016] (FCC-OCP)

3.3.162 Hogged Material. Mill waste consisting mainly of hogged bark but possibly including a mixture of bark, chips, dust, or other by-products from trees; also includes material designated as hogged fuel. (FCC-OCP)

3.3.163 Home.

3.3.163.1 Day-Care Home. See 3.3.203.6.

3.3.163.2 Nursing Home. See 3.3.203.24.

3.3.164 Horizontal Exit. See 3.3.110.1.

3.3.165* Immediately Dangerous to Life and Health (IDLH). A concentration of airborne contaminants, normally expressed in parts per million (ppm) or milligrams per cubic meter, that represents the maximum level from which one could escape within 30 minutes without any escape-impairing symptoms or irreversible health effects. [55, 2023] (FCC-HAZ)

3.3.166* Imminent Danger. A condition, use, or practice in an occupancy or structure that poses a hazard that could reasonably be expected to cause death, serious physical harm, or serious property loss. (FCC-FUN)

N 3.3.167 Impairment. A condition where a fire protection system or unit or portion thereof is out of order, and the condition can result in the fire protection system or unit not functioning in a fire event. [25, 2020] (FCC-OCP)

3.3.168 In-Building Emergency Responder Communications Enhancement System. A combination of components, RF-emitting devices, antennas, cables, power supplies, control circuitry, and programming installed at a specific location to improve wireless communication at that location. (FCC-OCP)

Δ 3.3.169* Incident Commander (IC). The individual responsible for all incident activities, including the development of strategies and tactics and the ordering and the release of resources. [470, 2022] (FCC-FUN)

3.3.170 Incidental Liquid Use or Storage. Use or storage as a subordinate activity to that which establishes the occupancy or area classification. [30, 2024] (FCC-HAZ)

3.3.171 Indicating Valve. See 3.3.300.1.

3.3.172 Indoor Horticultural Grow Structure. An enclosed structure installed within buildings that creates a controlled environment for enhanced horticultural growing conditions using an artificial light source. (FCC-OCP)

N 3.3.173 Initiating Device. A system component that originates transmission of a signal indicating a change-of-state condition. [72, 2022] (FCC-OCP)

3.3.174 Initiating Device Circuit. A circuit to which automatic or manual initiating devices are connected where the signal received does not identify the individual device operated. [72, 2016] (FCC-OCP)

3.3.175 Inside Liquid Storage Area. See 3.3.17.6.

3.3.176* ISO Module. An assembly of tanks or tubular cylinders permanently mounted in a frame conforming to International Organization for Standardization (ISO) requirements. [55, 2023] (FCC-HAZ)

3.3.177 Jurisdiction. A governmental unit or political division or a subdivision. (FCC-FUN)

3.3.178 Limit.

3.3.178.1* Ceiling Limit. The maximum concentration of an airborne contaminant to which one can be exposed. [5000, 2024] (FCC-HAZ)

3.3.178.2* Permissible Exposure Limit (PEL). The maximum permitted 8-hour, time-weighted average concentration of an airborne contaminant. [55, 2023] (FCC-HAZ)

3.3.178.3* Short-Term Exposure Limit (STEL). The concentration to which it is believed that workers can be exposed continuously for a short period of time without suffering

from irritation, chronic or irreversible tissue damage, or narcosis of a degree sufficient to increase the likelihood of accidental injury, impairment of self-rescue, or the material reduction of work efficiency, without exceeding the daily permissible exposure limit (PEL). [55, 2023] (FCC-HAZ)

3.3.179 Limited-Combustible (Material). See 4.5.10. [5000, 2024]

3.3.180 Liquid. A material that has a melting point that is equal to or less than 68°F (20°C) at a boiling point that is greater than 68°F (20°C) and 14.7 psia (101.3 kPa). When not otherwise identified, the term *liquid* shall mean all ignitable (flammable and combustible) liquids. [5000, 2024] (FCC-HAZ)

3.3.180.1 Combustible Liquid. An ignitable liquid that is classified as a Class II or Class III liquid. (See 66.4.1.2 and 66.4.1.3.) [30, 2024] (FCC-HAZ)

3.3.180.2 Flammable Liquid. An ignitable liquid that is classified as a Class I liquid. (See 66.4.1.1.) [30, 2024] (FCC-HAZ)

3.3.180.3 Highly Volatile Liquid. A liquid with a boiling point of less than 68°F (20°C). (FCC-HAZ)

3.3.180.4* Ignitable Liquid. Any liquid or liquid mixture that has a measurable closed-cup flash point. [30, 2024] (FCC-HAZ)

3.3.180.5 Liquid Class. A uniform system of classifying ignitable liquids. (See 66.4 and Chapter 4 of NFPA 30.) (FCC-HAZ)

3.3.180.6 Stable Liquid. Any liquid not defined as unstable. [30, 2024] (FCC-HAZ)

3.3.181 Log. Felled tree from which all the branches have been removed. (FCC-OCP)

3.3.182 Loose House. A separate detached building in which unbaled combustible fibers are stored. (FCC-HAZ)

3.3.183 Lumber. Wood from felled trees having a section produced by lengthwise sawing or chipping of logs or other solid wood of large dimensions and possible crosscutting and/or further machining to obtain a certain size and includes boards, dimension lumber, timber, and similar wood products. (FCC-OCP)

3.3.184 Manual Emergency Shutoff Valve. A designated valve designed to shut off the flow of gases or liquids that is manually operated. [55, 2023] (FCC-HAZ)

3.3.185 Manual Fire Alarm Box. A manually operated device used to initiate a fire alarm signal. [72, 2016] (FCC-OCP)

3.3.186 Manual Pull Station. See 3.3.185, Manual Fire Alarm Box.

3.3.187 Marine Terminal. A facility comprised of one or more berths, piers, wharves, loading and unloading areas, warehouses, and storage yards and used for transfer of people and/or cargo between waterborne and land transportation modes. [307, 2021] (FCC-OCP)

3.3.188 Marine Vessel. A water craft or other artificial contrivance used as a means of transportation in or on the water. (FCC-OCP)

3.3.189 Material.

3.3.189.1 Combustible (Material). See 3.3.60.

3.3.189.2 Compatible Material. A material that, when in contact with an oxidizer, will not react with the oxidizer or promote or initiate its decomposition. (FCC-HAZ)

3.3.189.3* Corrosive Material. A chemical that causes visible destruction of, or irreversible alterations in, living tissue by chemical action at the site of contact. [400, 2022] (FCC-HAZ)

3.3.189.4* Hazardous Material. A chemical or substance that is classified as a physical hazard material or a health hazard material, whether the chemical or substance is in usable or waste condition. (See also 3.3.189.6, *Health Hazard Material*, and 3.3.189.12, *Physical Hazard Material*.) [400, 2022] (FCC-HAZ)

3.3.189.5 Hazardous Production Material (HPM). A solid, liquid, or gas associated with semiconductor manufacturing that has a degree-of-hazard rating of 3 or 4 in health, flammability, instability, or water reactivity in accordance with NFPA 704 and that is used directly in research, laboratory, or production processes that have as their end product materials that are not hazardous. [5000, 2024] (FCC-HAZ)

3.3.189.6 Health Hazard Material. A chemical or substance classified as a toxic, highly toxic, or corrosive material in accordance with definitions set forth in this Code. [400, 2022] (FCC-HAZ)

3.3.189.7* Highly Toxic Material. A material that produces a lethal dose or lethal concentration that falls within any of the following categories: (1) a chemical that has a median lethal dose (LD₅₀) of 50 mg/kg or less of body weight when administered orally to albino rats weighing between 200 g and 300 g each; (2) a chemical that has a median lethal dose (LD₅₀) of 200 mg/kg or less of body weight when administered by continuous contact for 24 hours, or less if death occurs within 24 hours, with the bare skin of albino rabbits weighing between 2 kg and 3 kg each or albino rats weighing 200 g to 300 g each; (3) a chemical that has a median lethal concentration (LC₅₀) in air of 200 parts per million by volume or less of gas or vapor, or 2 mg/L or less of mist, fume, or dust, when administered by continuous inhalation for 1 hour, or less if death occurs within 1 hour, to albino rats weighing between 200 g and 300 g each. [400, 2022] (FCC-HAZ)

3.3.189.8 Hogged Material. See 3.3.162.

3.3.189.9* Incompatible Material. Materials that, when in contact with each other, have the potential to react in a manner that generates heat, fumes, gases, or by-products that are hazardous to life or property. [400, 2022] (FCC-HAZ)

3.3.189.10 Limited-Combustible (Material). See 4.5.10. [5000, 2024]

3.3.189.11 Noncombustible Material. See 4.5.9. [5000, 2024]

3.3.189.12 Physical Hazard Material. A chemical or substance classified as an explosive, flammable cryogen, flammable gas, flammable solid, ignitable (flammable or combustible) liquid, organic peroxide, oxidizer, oxidizing cryogen, pyrophoric, unstable (reactive), or water-reactive material. [400, 2022] (FCC-HAZ)