

NFPA®

1150

**Standard on
Foam Chemicals for
Fires in Class A Fuels**

2017



IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that NFPA Standards may be amended from time to time through the issuance of Tentative Interim Amendments or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any Tentative Interim Amendment and any Errata then in effect.

In order to determine whether an NFPA Standard has been amended through the issuance of Tentative Interim Amendments or corrected by Errata, visit the “Codes & Standards” section on NFPA’s website. There, the document information pages located at the “List of NFPA Codes & Standards” provide up-to-date, document-specific information including any issued Tentative Interim Amendments and Errata.

To view the document information page for a specific Standard, go to <http://www.nfpa.org/docinfo> to choose from the list of NFPA Standards or use the search feature to select the NFPA Standard number (e.g., NFPA 101). The document information page includes postings of all existing Tentative Interim Amendments and Errata. It also includes the option to register for an “Alert” feature to receive an automatic email notification when new updates and other information are posted regarding the document.

ISBN: 978-145591596-5 (Print)
ISBN: 978-145591597-2 (PDF)

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

Copyright © 2016 National Fire Protection Association®. All Rights Reserved.

NFPA® 1150

Standard on

Foam Chemicals for Fires in Class A Fuels

2017 Edition

This edition of NFPA 1150, *Standard on Foam Chemicals for Fires in Class A Fuels*, was prepared by the Technical Committee on Water Additives for Fire Control and Vapor Mitigation. It was issued by the Standards Council on November 11, 2016, with an effective date of December 1, 2016, and supersedes all previous editions.

This edition of NFPA 1150 was approved as an American National Standard on December 1, 2016.

Origin and Development of NFPA 1150

The first edition of this document was issued in 1989 as NFPA 298, *Standard on Foam Chemicals for Wildland Fire Control*, in response to a perceived need for a performance standard dealing with the foam chemicals being used in controlling wildland fires. The 1994 edition was a complete revision to make the document consistent with the developing changes in Class A foam technology. The title was changed to *Standard on Fire Fighting Foam Chemicals for Class A Fuels in Rural, Suburban, and Vegetated Areas*.

In 1999, the document was again revised to reflect further advancements in technology and a greater number of Class A concentrates and delivery systems available for use. The document was renumbered as NFPA 1150, which put it within the numerical grouping of documents under the responsibility of the Technical Committee on Forest and Rural Fire Protection.

The 2004 edition was a complete revision to bring the document into conformance with the *Manual of Style for NFPA Technical Committee Documents*. The title was changed to *Standard on Foam Chemicals for Fires in Class A Fuels* to recognize that these chemicals are being used not only in rural and wildland areas but in structural fire fighting and urban areas as well. The test procedures for the chemicals as well as the lists of materials tested for compatibility with the chemicals were updated to ensure the product is consistent with the needs of fire suppression personnel who are using the chemicals to control, suppress, or prevent fires in Class A fuels.

In the 2010 edition, an entirely new section was added regarding exposure protection effectiveness of Class A foams and included a test methodology involving lateral ignition flame spread on substrate treated with foam solutions. That important information is useful for fire departments as well as manufacturers and producers of Class A foam products.

For the 2017 edition, a new section has been created within Chapter 5 to provide requirements for alternate viscosity test methods for situations in which the viscosity is too low to obtain meaningful results. Editorial changes include updating the standard to comply with the *Manual of Style for NFPA Technical Committee Documents*.

Technical Committee on Water Additives for Fire Control and Vapor Mitigation

Armand V. Brandao, *Chair*
FM Approvals, MA [I]

Michael T. Greiner, *Secretary*
Hazard Control Technologies, Inc., GA [M]

Tracy Browder, XCEL Energy, TX [U]
Rep. Edison Electric Institute

Brian R. Foster, AEGIS Insurance Services, Inc., NC [I]

Walter Groden, AIG Global Technical Office, NY [I]

Alison C. Gude, Tyco Fire Suppression & Building Products, WI [M]

Gerald J. Halpin III, CET Fire Pumps Manufacturing, Canada [M]
Rep. Fire Apparatus Manufacturers Association

Cecilia W. Johnson, USDA Forest Service, MT [RT]

Blake M. Shugarman, UL LLC, IL [RT]

Robert E. Tinsley, Jr., Pyrocool Technologies, Inc., VA [M]

Qingsheng Wang, Oklahoma State University, OK [SE]

Alternates

Robert M. Cordell, FM Approvals, MA [I]
(Alt. to Armand V. Brandao)

Michael P. Dupay, Fire Research Corporation, NY [M]
(Alt. to Gerald J. Halpin III)

Jerauld R. Kirkpatrick, UI LLC, IL [RT]
(Alt. to Blake M. Shugarman)

Anthony Natale, Consolidated Edison of New York, NY [U]
(Alt. to Tracy Browder)

Jacqueline Wilmot, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on the manufacture, testing, application, and use of water additives for the control and/or suppression of fire and flammable vapor mitigation including water additives used to prevent or reduce the spread of fire and the use of water additives in fixed, semi-fixed, mobile, and portable fire suppression systems.

Contents

Chapter 1 Administration	1150- 4	4.2 Foam Concentrate.	1150- 6
1.1 Scope.	1150- 4	4.3 Foam Solution.	1150- 8
1.2 Purpose.	1150- 4	4.4 Foam.	1150- 8
Chapter 2 Referenced Publications	1150- 4	4.5 Labeling and Documentation.	1150- 8
2.1 General.	1150- 4	Chapter 5 Test Methods	1150- 9
2.2 NFPA Publications.	1150- 4	5.1 General.	1150- 9
2.3 Other Publications.	1150- 4	5.2 Exposure Protection Effectiveness.	1150- 9
2.4 References for Extracts in Mandatory Sections.	1150- 5	5.3 Health, Safety, and Environmental Considerations.	1150- 10
Chapter 3 Definitions	1150- 5	5.4 Physical Properties.	1150- 11
3.1 General.	1150- 5	5.5 Corrosion and Materials Compatibility.	1150- 12
3.2 NFPA Official Definitions.	1150- 5	Annex A Explanatory Material	1150- 15
3.3 General Definitions.	1150- 5	Annex B Informational References	1150- 19
Chapter 4 Characteristics and Acceptance Requirements	1150- 6	Index	1150- 21
4.1 General.	1150- 6		

NFPA 1150

Standard on

Foam Chemicals for Fires in Class A Fuels

2017 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Standards." They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the "List of NFPA Codes & Standards" at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex B. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex B.

Chapter 1 Administration

1.1* Scope. This standard specifies requirements for Class A foam and the chemicals used to produce Class A foam that is used to control, suppress, or prevent fires in Class A fuels.

1.2* Purpose.

1.2.1 The purpose of this standard is to define the acceptance requirements and test methods for fire-fighting foam chemicals that are used to control, suppress, or prevent fires in Class A fuels.

1.2.2 Acceptance requirements shall not be deemed as establishing performance levels in actual fire-fighting situations.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. (Reserved)**2.3 Other Publications.**

2.3.1 ASTM Publications. ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM D92, *Standard Test Method for Flash and Fire Points by Cleveland Open Cup Tester*, 2012b.

ASTM D97, *Standard Test Method for Pour Point of Petroleum Products*, 2012.

ASTM D1331, *Standard Test Methods for Surface and Interfacial Tension of Solutions of Surface-Active Agents and Related Materials*, reinstated 2014.

ASTM D2196, *Standard Test Methods for Rheological Properties of Non-Newtonian Materials by Rotational Viscometer*, 2015.

ASTM D2281, *Standard Test Method for Evaluation of Wetting Agents by the Skein Test*, 2010.

ASTM D4976, *Standard Specification for Polyethylene Plastics Molding and Extrusion Materials*, 2012B.

ASTM E3, *Standard Practice for Preparation of Metallographic Specimens*, 2011.

ASTM E407, *Standard Practice of Microetching Metals and Alloys*, 2011 e1.

ASTM E729, *Standard Guide for Conducting Acute Toxicity Tests on Test Materials with Fishes, Macroinvertebrates, and Amphibians*, reapproved 2011.

ASTM E1321, *Standard Test Method for Determining Material Ignition and Flame Spread Properties*, 2013.

2.3.2 EPA Publications. Environmental Protection Agency, William Jefferson Clinton East Building, 1200 Pennsylvania Avenue, NW, Washington, DC 20460.

OPPTS 835.3110, *Ready Biodegradability*, Section M, CO₂ Evolution (Modified Sturm), Test, Fate, Transport and Transformation Test Guidelines, January 1998.

OPPTS 850.1075, *Fish Acute Toxicity Test, Freshwater and Marine*, Ecological Effects Test Guidelines, April 1996 (December 2002).

OPPTS 870.1100, *Acute Oral Toxicity*, Health Effects Test Guidelines, August 2002.

OPPTS 870.1200, *Acute Dermal Toxicity*, Health Effects Test Guidelines, June 1996.

OPPTS 870.2400, *Acute Eye Irritation*, Health Effects Test Guidelines, August 1998.

OPPTS 870.2500, *Acute Dermal Irritation*, Health Effects Test Guidelines, August 1998.

2.3.3 ISO Publications. International Organization for Standardization, ISO Central Secretariat, BIBC II, Chemin de Blandonnet 8, CP 401, 1214 Vernier, Geneva, Switzerland.

ISO 304, *Surface Active Agents — Determination of Surface Tension by Drawing Up Liquid Films*, 2nd edition, 1985.

ISO 17025, *General Requirements for the Competence of Testing and Calibration Laboratories*, 2005.

2.3.4 NACE Publications. NACE International, 15835 Park Ten Place, Houston, TX 77084-4906.

NACE TM0169 F0031 12A, *Standard Test Guide for Laboratory Immersion Corrosion Testing of Metals*, reaffirmed 2000.

2.3.5 OECD Publications. Organisation for Economic Co-operation and Development, 2, rue André-Pascal, 75775 Paris Cedex 16, France.

OECD Principles of Good Laboratory Practice, Annex 2, C(89)87(Final).

2.3.6 SAE Publications. SAE International, 400 Commonwealth Drive, Warrendale, PA 15096-0001.

SAE AMS-3208, *Chloroprene (CR) Rubber, Weather Resistant*, 45–55, revised 2007.

SAE AMS-C-9084, *Cloth, Glass, Finished for Resin Laminates*, 1999, reaffirmed 2013.

AMS-DTL-23053/5, *Insulation Sleeving, Electrical, Heat Shrinkable, Polyolefin, Flexible Crosslinked*, 2012.

AMS-S-8802C, *Sealing Compound, Temperature Resistant, Integral Fuel Tanks and Fuel Cell Cavities, High Adhesion*, 2011.

2.3.7 U.S. Government Publications. U.S. Government Publishing Office, 732 North Capitol Street, NW, Washington, DC 20401-0001.

Title 40, Code of Federal Regulations, Part 160, “Good Laboratory Practice Standards.”

Title 40, Code of Federal Regulations, Part 792, “Good Laboratory Practice Standards.”

Federal Test Standard No. 601, Methods 3021 and 3025 (April 12, 1985).

Wildland Fire Chemicals Standard Test Procedures, STP-2.2, Lateral Ignition and Flame Spread Test (LIFT), U.S.D.A. Forest Service, May 30, 2007.

2.3.8 U.S. Military Specifications. Standardization Documents Order Desk, Building 4D, 700 Robbins Ave., Philadelphia, PA 19111-5094. Also available at <http://stinet.dtic.mil/>.

MIL-A-A-55859A, *Tube, Nonmetallic, Polyvinyl Chloride (PVC), Flexible (General Use)*, October 31, 2002.

MIL-PRF-81733D, *Sealing and Coating Compound, Corrosion Inhibitive*, May 15, 1998.

2.3.9 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 472, *Standard for Competence of Responders to Hazardous Materials/Weapons of Mass Destruction Incidents*, 2013 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.2 Shall. Indicates a mandatory requirement.

3.2.3 Should. Indicates a recommendation or that which is advised but not required.

3.2.4 Standard. An NFPA Standard, the main text of which contains only mandatory provisions using the word “shall” to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase “standards development process” or “standards development activities,” the term “standards” includes all NFPA Standards, including Codes, Standards, Recommended Practices, and Guides.

3.3 General Definitions.

3.3.1 Artificial Sea Water. A solution that consists of 1.10 percent magnesium chloride hexahydrate, 0.16 percent calcium chloride dihydrate, 0.40 percent anhydrous sodium sulfate, 2.50 percent sodium chloride, and 95.84 percent deionized or distilled water.

3.3.2 Biodegradability. A measure of the decomposition of organic matter through the action of microorganisms.

3.3.3 Class A Foam. Foam for use on fires in Class A fuels.

3.3.4 Class A Fuel. Materials such as vegetation, wood, cloth, paper, rubber, and some plastics in which combustion can occur at or below the surface of the material.

3.3.5 Drain Time. The time that it takes for a specified percent (customarily 25 percent) of the total solution that is contained in the foam to revert to liquid and drain out of the bubble structure.

3.3.6 Expansion Ratio. The ratio of the volume of the foam in its aerated state to the original volume of the non-aerated foam solution.

3.3.7 Exposure Protection Effectiveness. The ability of a product to increase the time to ignition of a substrate subjected to a prescribed radiant heat source.

3.3.8 Fixed Tank. A tank that is internal to or attached directly to a helicopter.

3.3.9 Flash Point. The minimum temperature of a liquid at which it gives off vapor sufficient to form an ignitable mixture

with air near the surface of the liquid under specified environmental conditions.

3.3.10 Foam. An aggregation of bubbles lighter than water created by forcing or entraining air into a foam solution by means of suitably designed equipment or by cascading it through the air.

3.3.11 Foam Chemicals. A generic name for the liquid foam concentrate, foam solution, and foam in whatever form it is being used.

3.3.12* Foam Concentrate. The foaming agent as received from the supplier that, when mixed with water, becomes foam solution.

3.3.13 Foam Solution. A homogeneous mixture of foam concentrate and water in the mix ratio required to meet the needs of the user.

3.3.14 Intergranular Corrosion. A corrosive attack on metal at the grain boundary.

3.3.15* Laboratory Fresh Water. Deionized or distilled water to which calcium chloride has been added to provide a hardness measure of 120 to 140 ppm of calcium carbonate.

3.3.16 LC₅₀ (Lethal Concentration₅₀). The concentration of agent in water, usually expressed as milligrams of agent in a liter of solution, that results in the death of 50 percent of the aquatic test specimens within a specified time frame.

3.3.17 LD₅₀ (Lethal Dosage₅₀). The dosage of a chemical, usually expressed as milligrams of the chemical per kilogram of body weight of the test animal, at which 50 percent of the test animals die within a specified time frame.

3.3.18* Material Safety Data Sheet (MSDS). A form, provided by manufacturers and compounders (blenders) of chemicals, containing information about chemical composition, physical and chemical properties, health and safety hazards, emergency response, and waste disposal of the material. [472, 2013]

3.3.19 Miscibility. The ability of concentrate to mix with water under specified conditions without separation into phases.

3.3.20 Mix Ratio. The proportion of foam concentrate in the foam solution, expressed as a volume percentage.

3.3.21 Surface Tension. The elastic-like force at the surface of a liquid, which tends to minimize the surface area, causing drops to form.

3.3.22 Uniform Corrosion. Removal of metal by chemical means over the entire surface.

3.3.23 Viscosity. A measure of the resistance of a liquid to flow.

3.3.24 Wetting Ability. The ability of foam solution to penetrate and soak into a solid.

Chapter 4 Characteristics and Acceptance Requirements

4.1 General.

4.1.1* The characteristics, requirements, and handling of Class A foam concentrates, foam solutions, and foam shall be in accordance with this chapter.

4.1.2 A minimum of six 20 L or six 5 gal sealed containers of foam concentrate taken from a single production lot shall be used for the purpose of evaluating the foam concentrate properties and requirements of this standard.

4.1.2.1 The test product shall be identified by a unique product identifier, lot number, and production date.

4.1.2.2 Three of the containers shall be used for the stability test required in 4.2.2.1.

4.1.2.3 Three containers shall be used for evaluating the other properties and requirements of this standard.

4.2 Foam Concentrate.

4.2.1* Health, Safety, and Environmental Considerations.

4.2.1.1 Mammalian Toxicity. The foam concentrate shall not exceed the toxicity limits defined in Table 4.2.1.1 when tested in accordance with 5.3.1.

4.2.1.2 Aquatic Toxicity. The LC₅₀ of the foam concentrate shall be greater than 10 mg/L when tested in accordance with 5.3.2.

4.2.1.3 Biodegradability. The foam concentrate shall have a minimum of 60 percent biodegradation within 42 days when tested in accordance with 5.3.3.

Table 4.2.1.1 Toxicity Limits for Class A Foam Concentrates and Solutions

	Acute Oral Toxicity	Acute Dermal Toxicity	Primary Dermal Irritation	Primary Eye Irritation	
				Unwashed Eyes	Washed Eyes
Foam concentrate	LD ₅₀ > 500 mg/kg	LD ₅₀ > 2000 mg/kg	Primary irritation score: <5.0 If more irritating, recommend protective gear and safe handling procedures	Mildly irritating or less If more irritating, recommend protective gear and safe handling procedures	Mildly irritating or less If more irritating, recommend protective gear and safe handling procedures
Foam solution	LD ₅₀ > 5000 mg/kg	LD ₅₀ > 2000 mg/kg	Primary irritation score: <5.0	Mildly irritating or less	Mildly irritating or less