

NFPA®

306

Standard for the Control of Gas Hazards on Vessels

2019



IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A **Δ** before a section number indicates that words within that section were deleted and a **Δ** to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the **Δ** symbol. Where one or more sections were deleted, a **•** is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an **N**.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at www.nfpa.org/docinfo. Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.

REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that NFPA Standards may be amended from time to time through the issuance of a Tentative Interim Amendment (TIA) or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of Tentative Interim Amendments or corrected by Errata, go to www.nfpa.org/docinfo to choose from the list of NFPA Standards or use the search feature to select the NFPA Standard number (e.g., NFPA 13). The document information page provides up-to-date document-specific information as well as postings of all existing TIAs and Errata. It also includes the option to register for an “Alert” feature to receive an automatic email notification when new updates and other information are posted regarding the document.

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

Copyright © 2018 National Fire Protection Association®. All Rights Reserved.

NFPA® 306

Standard for the

Control of Gas Hazards on Vessels

2019 Edition

This edition of NFPA 306, *Standard for the Control of Gas Hazards on Vessels*, was prepared by the Technical Committee on Gas Hazards. It was issued by the Standards Council on May 4, 2018, with an effective date of May 24, 2018, and supersedes all previous editions.

This edition of NFPA 306 was approved as an American National Standard on May 24, 2018.

Origin and Development of NFPA 306

The original standard on this subject was developed by the NFPA Committee on Marine Fire Hazards in 1922 in cooperation with the NFPA Committee on Flammable Liquids. It was adopted by the Association and published as Appendix A of the “Regulations Governing Marine Fire Hazards.” Further editions with minor changes were published in 1923, 1926, and 1930. In 1947, a completely revised standard was prepared by a joint committee of the American Bureau of Shipping and the National Fire Protection Association. A revised edition was developed by the NFPA Sectional Committee on Gas Hazards, approved by the Committee on Marine Fire Protection, adopted in 1962, and amended in 1963, 1969, 1971, 1972, 1975, 1980, and 1984.

In 1988, a complete revision was prepared by the committee. It added a new safety designation, a safe condition for vessels in lay-up, and a section on military unique vessels. Chapters 2, 3, and 4 were restructured to present the sequence for obtaining a Marine Chemist Certificate.

The 1993 edition contained amendments to the 1988 edition.

The 1997 edition, which marked the 75th year for these requirements, incorporated a new standard safety designation that reflected a common approach to an industry practice. That new designation was also supported by other changes to the document, including expanded inspection of vessel piping systems.

The 2001 edition incorporated a revised standard safety designation, and several changes that reflect safe, commonly used industry practices. Several new definitions were also included. For the first time in this document, the well-established relationship between the Marine Chemist and the competent person [as defined by U.S. Department of Labor, Occupational Safety and Health Administration (OSHA) regulations], and the frequency of retesting confined spaces, was provided.

The 2003 edition was completed on an expedited schedule to further revise requirements in the standard that must complement those shipyard safety requirements defined by OSHA. The committee clarified the standard and the Marine Chemist’s role by further defining the atmospheric hazards associated with safe entry and hot work as the standard’s primary focus. The standard also clarified the intent for defining *permissible concentrations* by stating that the most conservative value for the various exposure limits should be used.

The 2009 edition included changes to several definitions within the standard. The term *vessel* was expanded to apply to special purpose floating structures such as offshore drilling, production, and/or storage vessels. Definitions for *contract employer*, *host employer*, and *multiemployer workplace* were added to the standard. The committee amended the definition of *adjacent spaces* to include areas affected by hot work and also clarified requirements for testing and inspecting spaces adjacent to hot work operations. The committee also made several revisions to the requirements for obtaining a Marine Chemist Certificate and maintaining the conditions on the Certificate.

For the 2014 edition, the Technical Committee on Gas Hazards reorganized the requirements to reflect the actual work process that is involved when a marine vessel goes from normal operating status to the point where a Marine Chemist’s Certificate is obtained and repair work can begin. Over

the years, Marine Chemists have become recognized experts in fire prevention during vessel repairs, which has led to repair contractors calling on them to provide services or consultation for areas and spaces on a vessel where the chemist is not necessarily required by either OSHA or U.S. Coast Guard regulations. Those consultations can include tests and inspections in accommodation areas, storage spaces, and auxiliary equipment rooms. New provisions were added that address this evolution of the NFPA Certificated Marine Chemist's role in ship repair. In addition, the Technical Committee established a maximum acceptable concentration of combustible or flammable gas of less than 10 percent of the lower explosive limit (LEL) in all spaces adjacent to hot work, and incorporated information from an OSHA compliance directive for cargo, passenger, and miscellaneous vessels explaining that a Marine Chemist's Certificate is necessary any time hot work is closer than 7.6 m (25 ft) to an adjacent tank that contains a liquid with a flashpoint at or below 65.6°C (150°F). The 2014 edition also provided new explanatory material in Annex A about how frequently a space must be checked by the shipyard's competent person after a certificate has been posted. This guidance stresses the importance of maintaining safe conditions within confined spaces and provides minimum reinspection and testing criteria to achieve this objective.

In the 2019 edition, the technical committee revised the scope and purpose of NFPA 306 to align more accurately with U.S. Coast Guard and OSHA regulations that affect waterfront facilities, shipyards, and facilities engaged in shipyard employment. Accordingly, a new definition for the term *waterfront facility* from U.S. Coast Guard regulation 33 CFR 6.01-4 was added to the standard. The hazards associated with hot work in, on, and adjacent to ammunition spaces are addressed with references provided for applicable publications issued by the U.S. Navy, Naval Sea Systems Command (NAVSEA). The committee clarified that the determination of conditions for the purpose of issuing a Marine Chemist's Certificate must exist at the time of the Marine Chemist's tests and inspection. The standard now mandates that if a space is designated "Inerted" it must also be designated "Not Safe for Workers." Depending on the scope of work, it must be designated "Safe for Hot Work" or "Safe for Limited Hot Work" as applicable. To emphasize that a change of the conditions that affect the safety of work authorized by a Marine Chemist's Certificate needs to be communicated to the Marine Chemist, the Marine Chemist's name and a contact number are now required to be noted on the Certificate. With the growth of marine vessels fueled by liquefied natural gas (LNG), Chapter 9 was revised to apply to both flammable cryogenic liquids that are carried as cargo and/or as fuel.

Technical Committee on Gas Hazards

James R. Thornton, *Chair*
Newport News Shipbuilding, VA [U]

Robert V. Albert, U.S. Department of the Navy, NH [E]
Rep. U.S. Department of the Navy

Leslie Blaize, Belay Incorporated, OR [SE]
Rep. Marine Chemist Association, Inc.

Thomas Cinko, Honeywell Analytics, MD [M]

Jason A. Fox, MSA, PA [M]
Rep. International Safety Equipment Association

Thomas T. Govey, Marathon Petroleum Logistics, KY [U]
Rep. American Petroleum Institute

Patrick O. Killeen, VT Marine, MS [U]
Rep. Shipbuilders Council of America

Sean Kline, Chamber of Shipping of America, DC [SE]

Joseph P. McElhinney, Jr., U.S. Department of Transportation, DC [SE]

Carolyn Oyster, U.S. Coast Guard Headquarters, DC [E]

Donald V. Raffo, General Dynamics, Electric Boat Corporation, CT [U]

Joseph A. Riva, American Bureau of Shipping, TX [E]

John W. Sansing, Kirby Inland Marine, LP, TX [U]
Rep. American Waterways Operators

Amy A. Wangdahl, U.S. Department of Labor, DC [E]

Alternates

John T. Bell, Marine Inspection Services Inc., TX [SE]
(Alt. to Leslie Blaize)

James P. Bruff, Atlantic Coast Marine Chemist, PA [SE]
(Voting alt.)

Joseph J. Cox, Chamber of Shipping of America, DC [SE]
(Alt. to Sean Kline)

James Fewell, Kirby Inland Marine, TX [U]
(Alt. to John W. Sansing)

Richard S. Kraus, API/Petroleum Safety Consultants, VA [M]
(Alt. to Thomas T. Govey)

John R. Ward, Jr., Huntington Ingalls Industries, VA [U]
(Alt. to James R. Thornton)

Lawrence Russell, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on the prevention of fire and explosion of flammable vapors in compartments or in spaces on board vessels and within shipyards and on the conditions that must exist in those compartments or spaces in order that workers can safely enter them and perform work.

Contents

Chapter 1 Administration	306– 5	5.7 Requirements for Use of a Designated Berthing Area for Cleaning, Gas Freeing, or Inerting.	306– 10
1.1 Scope.	306– 5	5.8 Vessel Fuel Oil Tanks.	306– 10
1.2 Purpose.	306– 5		
1.3 Emergency Exception.	306– 5	Chapter 6 Procedures for the Marine Chemist Prior to Issuance of a Certificate	306– 10
1.4 Governmental Regulations.	306– 5	6.1 Calibration and Function Verification.	306– 10
Chapter 2 Referenced Publications	306– 6	6.2 Determination of Conditions.	306– 10
2.1 General.	306– 6		
2.2 NFPA Publications.	306– 6	Chapter 7 Standard Safety Designations and Conditions Required	306– 11
2.3 Other Publications.	306– 6	7.1 General.	306– 11
2.4 References for Extracts in Mandatory Sections.	306– 6		
Chapter 3 Definitions	306– 6	Chapter 8 The Marine Chemist's Certificate	306– 12
3.1 General.	306– 6	8.1 Preparation of Certificates.	306– 12
3.2 NFPA Official Definitions.	306– 6	8.2 Issuance of Certificates.	306– 13
3.3 General Definitions.	306– 6	8.3 Responsibility for Obtaining the Marine Chemist's Certificate.	306– 13
Chapter 4 Vessels Required to Have Marine Chemist's Certificate	306– 7	8.4 Responsibility for Maintaining the Conditions. .	306– 13
4.1 Tank Vessels.	306– 7		
4.2 Vessels Other Than Tank Vessels.	306– 8	Chapter 9 Additional Requirements for Vessels Having Flammable Cryogenic Liquid Fuel or Cargo	306– 13
4.3 Military Unique Vessels (i.e., U.S. Navy, Coast Guard, Army).	306– 8	9.1 Scope.	306– 13
4.4 Vessels in Lay-Up.	306– 8	9.2 Definitions.	306– 13
4.5 Vessels Carrying Flammable Compressed Gas. ..	306– 8	9.3 Minimum Requirements.	306– 14
4.6 Obtaining the Marine Chemist's Certificate.	306– 8	9.4 Minimum Conditions.	306– 14
Chapter 5 Preparing Vessels by the Vessel Owner, Operator, or Repairer, for Issuance of a Marine Chemist's Certificate Involving Hot Work	306– 8	Annex A Explanatory Material	306– 14
5.1 Where a Safe Condition Is to Be Obtained Entirely by Cleaning.	306– 8	Annex B Examples of Safe Conditions	306– 17
5.2 Where a Safe Condition Is to Be Obtained by Both Cleaning and Inerting or Entirely by Inerting.	306– 9	Annex C Samples of Marine Chemist's Certificates	306– 18
5.3 Where a Safe Condition Is to Be Obtained by Cleaning Certain Compartments and by Securing the Other Compartments.	306– 9	Annex D Guidance to Vessel Owners and Operators When Hot Work and/or Enclosed/Confined Space Entry Is Conducted on a Vessel at Sea and a Marine Chemist Is Not Required	306– 21
5.4 Where a Safe Condition Is to Be Obtained by Cleaning Some Compartments, by Inerting Some Compartments, and by Securing Some Compartments.	306– 9	Annex E Limiting Oxidant Concentrations	306– 21
5.5 Cargo Heater Coils.	306– 10	Annex F Informational References	306– 26
5.6 Electric Welding Operations.	306– 10	Index	306– 27

NFPA 306

Standard for the

Control of Gas Hazards on Vessels

2019 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Standards.” They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the “List of NFPA Codes & Standards” at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex F. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex F.

Chapter 1 Administration

1.1 Scope.

1.1.1 This standard applies to vessels that carry or burn as fuel, flammable or combustible liquids, flammable compressed gases, flammable cryogenic liquids, chemicals in bulk, or other products capable of creating a hazardous condition.

Δ 1.1.2 This standard applies to vessels while in the United States, including its territories and possessions, both within and outside of yards for ship construction, ship alteration, ship repair, or shipbreaking.

1.1.3 This standard describes the conditions and procedures for determining such conditions required before a space can be entered or before work can be started, continued, or started and continued on any vessel under construction, alteration, or repair, or on any vessel awaiting shipbreaking.

1.1.4 This standard applies specifically to those spaces on vessels that are subject to concentrations of combustible, flammable, and toxic liquids, vapors, gases, and chemicals as herein described.

N 1.1.4.1 This standard is also applicable to those spaces on vessels that might not contain sufficient oxygen to permit safe entry.

1.1.4.2 When requested, the Marine Chemist shall apply this standard to other spaces to ensure and promote safe working conditions.

1.1.5 This standard applies to cold work, application or removal of protective coatings, and hot work involving riveting, welding, burning, or similar fire-producing and/or spark-producing operations.

1.1.6 This standard applies to land-side confined spaces, located within the boundaries of a waterfront facility, shipyard, or ship repair facility, and related shipyard employment — regardless of geographic location, whether stationary or mobile — including, but not limited to, the following:

- (1) Underground and aboveground storage tanks
- (2) Other hollow structures such as tank trucks, railroad tank cars, power plant fuel tanks, storage tanks, dip and laundry tanks, vaults, and tunnels
- (3) Other spaces that could contain dangerous atmospheres

1.1.7 This standard applies to Marine Chemists performing activities related to inspection and certification procedures described in this standard and consulting services connected therewith on board any vessel.

Δ 1.1.8* This standard does not apply to physical, biological, or radiological hazards of tanks and confined or enclosed spaces on a vessel, in vessel sections, or in the shipyard.

N 1.1.8.1 For the purposes of this standard, physical hazards do not include fire and explosion hazards.

1.2 Purpose. The purpose of this standard is to provide minimum requirements and conditions for use in determining that a space or area located within the boundaries of a waterfront facility, shipyard, or ship repair facility and related shipyard employment regardless, of geographic location, is safe for entry or work.

1.3* Emergency Exception. Nothing in this standard shall be construed as prohibiting the Marine Chemist from allowing the immediate drydocking or emergency repair of a vessel whose safety is imperiled or that presents the potential of a serious release, discharge, or disbursement into the environment of combustible, flammable, or toxic liquids, vapors, gases, or solid chemicals (the vessel is sinking or is seriously damaged), making it impracticable to clean and to gas free in advance. This emergency exception shall be subject to the approval of any authority having jurisdiction.

Δ 1.4* Governmental Regulations. Nothing in this standard shall be construed as superseding existing requirements of any governmental or local authority. Attention of owners, repairers, and Marine Chemists is directed to the rules and regulations for tank vessels in 46 CFR 35, “Operations,” and other rules and regulations for vessel inspection of the U.S. Coast Guard and the Occupational Safety and Health Administration standards (OSHA) of the U.S. Department of Labor in 29 CFR 1915, “Occupational Safety and Health Standards for Shipyard

Employment,” which prescribe an inspection prior to making repairs involving hot work and prior to entering spaces where oxygen deficiency can exist. Those standards provide, under the conditions stated therein, for inspection by a Marine Chemist certificated by the National Fire Protection Association or, alternatively, for inspection by certain other persons.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 312, *Standard for Fire Protection of Vessels During Construction, Conversion, Repair, and Lay-Up*, 2016 edition.

“Rules for the Certification and Recertification of Marine Chemists,” as amended 2014.

2.3 Other Publications.

Δ **2.3.1 U.S. Government Publications.** U.S. Government Publishing Office, 732 North Capitol Street, NW, Washington, DC 20401-0001.

Title 29, Code of Federal Regulations, Part 1915, “Occupational Safety and Health Standards for Shipyard Employment.”

Title 46, Code of Federal Regulations, Part 35, “Operations.”

2.3.2 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 55, *Compressed Gases and Cryogenic Fluids Code*, 2016 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.2 Shall. Indicates a mandatory requirement.

3.2.3 Standard. An NFPA Standard, the main text of which contains only mandatory provisions using the word “shall” to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational

note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase “standards development process” or “standards development activities,” the term “standards” includes all NFPA Standards, including Codes, Standards, Recommended Practices, and Guides.

3.3 General Definitions.

Δ **3.3.1* Adjacent Spaces.** Those spaces in all directions from subject space, including all points of contact, corners, diagonals, decks, tank tops, and bulkheads.

3.3.2 Barge. Any vessel not equipped with a means of self-propulsion.

3.3.3 Certificate. See 3.3.23, Marine Chemist's Certificate.

3.3.4 Chemical. Any compound, mixture, or solution in the form of a solid, liquid, or gas that might be hazardous by virtue of its properties other than or in addition to flammability or by virtue of the properties of compounds that might be evolved from hot work or cold work.

• **3.3.5 Coiled Vessels.** Tank vessels using a closed system or heating coils that use thermal oil as the heating medium.

Δ **3.3.6 Cold Work.** Any construction, alteration, repair, or ship-breaking that does not involve heat, fire, or spark-producing operations.

3.3.7* Combustible Liquid. Any liquid that has a closed-cup flash point at or above 37.8°C (100°F).

• **3.3.8* Combustible Material.** Material made of or surfaced with wood, compressed paper, plant fiber, plastic, or other material that will ignite and burn, whether flame-proofed or not, or whether plastered or unplastered.

3.3.9* Competent Person. A person who is designated in writing by their employer in accordance with 29 CFR 1915.7.

3.3.10 Contract Employer. An employer of welders, burners, grinders, painters, cleaners, or other workers who perform work under the direction of a host employer at a multi-employer worksite.

3.3.11 Cryogenic Liquid. A fluid with a boiling point lower than -90°C (-130°F) at an absolute pressure of 101.3 kPa (14.7 psi). [55, 2016]

Δ **3.3.12 Facility.** A shoreside location, such as a shipyard, cleaning plant, naval base, dock, or pier complex, that is under the ownership or control of the same party and has the same continuous shoreline under their ownership or operation.

3.3.13 Flammable Compressed Gas. Any flammable gas that has been compressed, liquefied, or compressed and liquefied for the purpose of transportation and has a Reid vapor pressure exceeding 2.76×10^5 Pa (40 psia).

Δ **3.3.14* Flammable Cryogenic Liquid Area.** That part of the vessel that contains the flammable cryogenic liquid containment system, pump room, and compressor room and that includes the deck areas over both the full beam and the length of the vessel located above the aforementioned.

3.3.15* Flammable Cryogenic Liquid Containment System.

The arrangement for containment of cargo or fuel including, where applicable, a primary and secondary barrier, associated insulation, and any intervening spaces and adjacent structures if necessary for the support of these elements.

3.3.16 Flammable Cryogenic Liquid Hold Space. The space enclosed by the vessel's structure in which a cargo containment system is situated.

3.3.17* Flammable Liquid. A liquid that has a closed-cup flash point that is below 37.8°C (100°F) and a maximum vapor pressure of 2068 mm Hg (40 psia) at 37.8°C (100°F).

3.3.18 Hollow Structures. A structure that is enclosed and not open to the atmosphere, including, but not limited to, the following: rudders, rudder stocks, skegs, castings, masts and booms, rails, lapped plates, and other hollow attachments on a vessel or in a shipyard that enclose a void space.

3.3.19 Host Employer. An employer who is in charge of coordinating work or who hires other employers to perform work at a multi-employer worksite.

3.3.20* Hot Work. Any activity involving any of the following: riveting, welding, burning, the use of powder-actuated tools or similar fire-producing operations; any operation that raises the temperature of the work piece equal to or greater than 204°C (400°F); or grinding, drilling, abrasive blasting, or similar operations in the presence of or against the accumulations of readily combustible materials or flammable or combustible liquids, gases, or vapors when the atmosphere exceeds 10 percent of the LEL.

3.3.21 Interbarrier Space. That space associated with a flammable cryogenic liquid tank between a primary and secondary barrier, whether or not completely or partially occupied by insulation or other material.

3.3.22* Marine Chemist. The holder of a valid Certificate issued by the National Fire Protection Association in accordance with the "Rules for the Certification and Recertification of Marine Chemists," establishing the person's qualifications to determine whether construction, alteration, repair, or shipbreaking of vessels can be undertaken with safety.

3.3.23 Marine Chemist's Certificate (Certificate). A document issued by a Marine Chemist, on a form authorized by the National Fire Protection Association, stating the conditions that the Marine Chemist found at the time of inspection. (See Annex C for an example.)

3.3.24 Multi-Employer Worksite. A workplace where there is a host employer and at least one contract employer.

3.3.25 Primary Barrier. The inner element of a flammable cryogenic liquid tank designed to contain the flammable cryogenic liquid when the containment system includes two boundaries.

3.3.26* Requester. A host employer or contract-employer noted at the top of the Marine Chemist's Certificate in the space, "Survey Requested by" The Requester is responsible for maintenance of safe conditions as noted on the Marine Chemist's Certificate.

3.3.27 Secondary Barrier. The liquid-resisting outer element of a flammable cryogenic liquid containment system designed to afford temporary containment of any envisaged leakage of

flammable cryogenic liquid through the primary barrier and to prevent the lowering of the temperature of the vessel's structure to an unsafe level.

3.3.28* Secured. Closed in a manner to prevent opening or operation.

3.3.29 Ship. Any vessel propelled by power or sail.

3.3.30 Shipbreaking. The breaking down of a vessel's structure for the purpose of scrapping the vessel.

3.3.31 Special Endorsement for Vessels Having Flammable Cryogenic Liquid Fuel or Cargo (FCL Endorsement). An endorsement to a Marine Chemist's Certificate in accordance with the *Rules for the Certification and Recertification of Marine Chemists*, establishing that the holder is qualified to determine whether construction, alteration, repair, or shipbreaking of vessels that carry flammable cryogenic liquid as cargo and/or use flammable cryogenic liquid as fuel can be undertaken with safety.

3.3.32 Tank Vessel. Any vessel especially constructed or converted to carry liquid bulk cargo in tanks.

3.3.33 Toxic. A property of any chemical that has the capacity to produce adverse health effects or injury to workers, which is dependent on concentration and route of entry.

3.3.34* Vessel. Every description of watercraft or other artificial contrivance used or capable of being used as a means of transportation on water, including special purpose floating structures not primarily designed for or used as a means of transportation on water.

3.3.35 Visual Inspection. The physical survey of the space or compartment and surroundings in order to identify potential atmospheric and fire hazards.

3.3.36 Waterfront Facility. All piers, wharves, docks, or similar structures to which vessels might be secured and all naval yards, stations, and installations, including ranges; areas of land, water, or land and water under and in immediate proximity to them; buildings on them or contiguous to them; and equipment and materials on or in them.

Chapter 4 Vessels Required to Have Marine Chemist's Certificate

4.1 Tank Vessels. Tank vessels shall be permitted to be repaired in accordance with the provisions of Chapter 5. A Certificate to this effect shall be required. Repairs or alterations involving hot work shall not be undertaken unless specifically authorized by the Certificate.

Exception No. 1: Tank vessels shall be permitted to enter a repair yard — while afloat or in dry dock — for examination, provided that all bulk cargo compartments and cofferdams are kept closed.

Exception No. 2: Tank vessels shall be permitted to enter a repair yard — while afloat or in dry dock — for scraping, washing down, and painting, provided that all bulk cargo compartments and cofferdams are kept closed.

Exception No. 3: Tank vessels shall be permitted to enter a repair yard — while afloat or in dry dock — for cold work to be performed outside of the vessel on the propeller, tailshaft, or rudder, or for hot work to be performed off the vessel, such as on the anchors or chains, provided that all bulk cargo compartments and cofferdams are kept closed.

Exception No. 4: Tank vessels shall be permitted to enter a repair yard — while afloat or in dry dock — for work within boiler and machinery spaces and other locations provided that, where hot work is to be undertaken, a Certificate shall be required. This Certificate shall set forth each specific location for which hot work is approved. All bulk cargo compartments, cofferdams, and other areas where the flammable content of the atmosphere is above 10 percent of the LEL shall be kept closed and secured. The securing of the compartments, cofferdams, and other areas shall be noted on the Certificate.

4.2 Vessels Other Than Tank Vessels.

N 4.2.1 On vessels that have carried flammable or combustible liquid in bulk as fuel or cargo, or that have carried cargoes that can produce hazardous atmospheres (including, but not limited to, those caused by decomposition or reaction with oxygen from the atmosphere), no repairs involving hot work shall be made in or on the external boundaries (shell, tank top, or deck) of cargo tanks, fuel tanks, oil pipelines, heating coils or hollow structures, and machinery spaces unless such compartments and pipelines, as deemed necessary by the Marine Chemist, have been inerted or cleaned to meet the appropriate designation requirements of 7.1.4, 7.1.6, or 7.1.8 and, for spaces that will be entered, the requirements of 7.1.1.

N 4.2.2 Repairs and alterations shall not be undertaken until a Certificate is obtained.

4.3 Military Unique Vessels (i.e., U.S. Navy, Coast Guard, Army).

4.3.1 Oilers and tank barges shall be treated as tank vessels in accordance with Section 4.1.

4.3.2* All ammunition shall be removed from the compartment where hot work is conducted or isolated from hot work.

N 4.3.2.1 Adjacent spaces containing ammunition shall be treated in accordance with the Marine Chemist's requirements.

N 4.3.2.2 Adjacent spaces containing flammable or combustible liquids shall be treated in accordance with the Marine Chemist's requirements and acknowledged on the Certificate.

4.3.3 Adjacent tanks used for radiation shielding on nuclear-powered vessels shall be treated in accordance with the Marine Chemist's requirements.

Δ 4.3.4 All tanks, confined spaces, and machinery spaces in which internal repairs or alterations are to be undertaken shall be cleaned to comply with the requirements of either 7.1.1 or 7.1.3.

N 4.3.4.1 For repair or alteration involving hot work, the spaces described in 4.3.4 shall meet the requirements of 7.1.4, 7.1.6, or 5.1.3, and adjacent compartments shall be cleaned to meet the requirements of 7.1.4, 7.1.6, or 5.1.3 or shall be permitted to be inerted to meet the requirements of 7.1.8.

N 4.3.4.2 Spaces that are adjacent to those described in 4.3.4 shall be permitted to be secured in accordance with the Marine Chemist's requirements and acknowledged on the Certificate.

Δ 4.3.5 All tanks, confined spaces, and machinery spaces in which external repairs or alterations are to be undertaken either shall be cleaned to comply with the requirements of 7.1.4 or 7.1.6 or shall be inerted to comply with the requirements of 7.1.8.

N 4.3.5.1 All adjacent compartments shall be cleaned to meet the requirements of 7.1.4, 7.1.6, or 5.1.3 or shall be permitted to be inerted to meet the requirements of 7.1.8.

N 4.3.5.2 The adjacent spaces described in 4.3.5.1 shall be permitted to be secured in accordance with the Marine Chemist's requirements and acknowledged on the Certificate.

4.3.6 All other types of military vessels shall be treated in accordance with Section 4.2.

Δ 4.4 Vessels in Lay-Up. A tank vessel in lay-up shall be treated in accordance with Section 4.1 and NFPA 312. No repairs or alterations involving hot work shall be made unless authorized by the Marine Chemist in accordance with the provisions of 7.1.10.

4.5 Vessels Carrying Flammable Compressed Gas. On any vessels that have carried flammable compressed gas in bulk, no repairs or alterations involving hot work shall be made unless the provisions of Section 4.1 have been complied with, provided individual pressure tanks (inerted in accordance with 7.1.9) are considered in a safe condition for such work not directly involving these tanks or their pipelines.

4.6 Obtaining the Marine Chemist's Certificate. It shall be the responsibility of the Certificate requester to retain the services of the Marine Chemist and to obtain copies of the Marine Chemist's Certificate in accordance with the provisions of Section 8.3.

Chapter 5 Preparing Vessels by the Vessel Owner, Operator, or Repairer, for Issuance of a Marine Chemist's Certificate Involving Hot Work

5.1* Where a Safe Condition Is to Be Obtained Entirely by Cleaning. [See Figure B.1, part (a).]

Δ 5.1.1 All cargo pumps, transfer pumps, associated transfer lines, inert gas lines, crude oil wash lines, piped cargo fire-extinguishing lines, vapor control and recovery lines, and vent lines to the spaces involved in the scope of work shall have been flushed with water or blown with steam or air.

5.1.2 Compartments concerned shall be cleaned so that the atmosphere in all cargo compartments and adjacent spaces, including those diagonally adjacent to the cargo compartments, is in accordance with 7.1.1, 7.1.4, or 7.1.6, or with both 7.1.1 and 7.1.6, or with both 7.1.1 and 7.1.4, as applicable.

5.1.3 Partial Cleaning for Limited Hot Work.

N 5.1.3.1 Tanks or compartments containing combustible residues or preservative coatings shall be permitted to be partially cleaned for limited hot work as described by 5.1.3.2, 5.1.3.3, and 5.1.3.4.

N 5.1.3.1.1 Areas to be cleaned shall be cleaned a sufficient distance from the hot work to prevent the spread of fire and shall be cleaned in such a manner as to prevent sparks or slag from the hot work operations from being thrown or dropped into combustible residues or preservative coatings.

N 5.1.3.1.2 A fire watch shall not be used in lieu of cleaning to establish a safe condition.

N 5.1.3.1.3 The specific location and type of hot work shall be listed on the Marine Chemist's Certificate.