

NFPA®

407

Standard for
Aircraft Fuel Servicing

2022



NFPA[®] 407

Standard for Aircraft Fuel Servicing

2022 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02269-9101
An International Codes and Standards Organization

Documents
Document Sharing Hub

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NFPA® codes, standards, recommended practices, and guides (“NFPA Standards”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A **Δ** before a section number indicates that words within that section were deleted and a **Δ** to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the **Δ** symbol. Where one or more sections were deleted, a **•** is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an **N**.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at www.nfpa.org/docinfo. Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.

REMINDER: UPDATING OF NFPA STANDARDS

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at www.nfpa.org.

ADDITIONAL IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Standards”) should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the “Codes & Standards” section at www.nfpa.org.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

Copyright © 2021 National Fire Protection Association®. All Rights Reserved.

NFPA® 407

Standard for

Aircraft Fuel Servicing

2022 Edition

This edition of NFPA 407, *Standard for Aircraft Fuel Servicing*, was prepared by the Technical Committee on Aircraft Fuel Servicing. It was issued by the Standards Council on June 18, 2021, with an effective date of July 8, 2021, and supersedes all previous editions.

This edition of NFPA 407 was approved as an American National Standard on July 8, 2021.

Origin and Development of NFPA 407

NFPA began active work on the development of this standard in 1951. Since then, the technical committee responsible for the document has made every effort to keep the text up-to-date, and subsequent editions were published almost every year from 1955 to 1975. The 21st edition was issued in 1980, and the technical committee completed a partial revision in 1984.

The 1990 edition was a complete rewrite that reorganized the design and operational requirements into separate chapters. The requirements for grounding were deleted and the requirements for bonding were clarified.

The 1996 edition was a partial revision. In addition, requirements for self-service fueling and rapid refueling of helicopters were added.

The 2001 edition included new requirements for non-driven hydrant carts. The 2007 edition was a partial revision. The 2012 edition added new requirements for vehicles with diesel particulate filters.

The 2017 edition was a complete reorganization of the material designed to make the document easier to use. The changes included the addition of a general chapter applying to all types of aircraft fueling facilities and four specific chapters applying to aviation fueling facilities, airport fueling vehicles, rooftop heliports, and self-service aircraft fueling. Each of those four chapters was split into a design section and an operation section, and consistent numbering was added to assist users in locating similar topics. The changes also incorporated many technical revisions to clarify existing requirements, address gaps, and update old or obsolete material. Requirements for rapid refueling of fixed-wing aircraft were also added.

The 2022 edition is a partial revision that includes new requirements regarding the scope of the standard, as well as fuel transfers, grounding straps, fire extinguishers, fueling cabinets, and tank vehicles. The requirements for aircraft fuel servicing vehicle loading and unloading racks have also been updated to include a compliance date. Finally, in addition to reference publication updates, a new Annex C was created to clarify changes to the design and construction requirements of retroactivity.

Technical Committee on Aircraft Fuel Servicing

Cary Skinner, *Chair*

Aviation Fire Safety Consultants Inc., IL [SE]

Richard M. Arvin, Annapolis Fire & Life Safety Engineering, MD [SE]

John H. Bagnall, Burns & McDonnell Engineering Company, MO [SE]

Thomas Boriak, Cla-Val, CA [M]

Brittany Brown, US Department of the Air Force, NM [E]

Peter E. Buffkin, Westmor Fluid Solutions, KS [M]

Fred A. Cnota, Swissport North America, IL [U]

Roy Creley, Lakes Region Environmental Inc., NH [M]

John J. Demyan, Lehigh-Northampton Airport Authority, PA [E]

Chris Dukes, Titan Aviation, United Arab Emirates [M]

Dan Frank, Argus Consulting, Inc., KS [SE]

Thomas D. Gambino, Prime Engineering, Inc., GA [SE]

James Gammon, Gammon Technical Products Inc., NJ [M]

Nathan R. Gerlich, EPIC Fuels, TX [M]

John Ingold, Beta Fueling Systems, NC [M]

Michael Kluttz, Robert and Company, GA [SE]

Jeremy Paul LaFlamme, Green Airport, RI [E]

John Leahey, Connecticut Airport Authority, CT [E]

Andrew Lipari, Kansas City Fire Department (KCMOFD), MO [E]

Michael Loveridge, Aircraft Service International Group, IL [U]

Philip Myers, PEMY Consulting LLC, CA [SE]

Michael Shawn Osborne, Metro Washington Airports Authority, VA [E]

Ronald F. Pattie, Skyfuel Aviation Services, LLC, FL [U]

Jeremy Souza, Code Red Consultants, LLC, MA [SE]

Mark W. Straub, Air BP, IL [U]

Rep. American Petroleum Institute

Paul E. Sundby, American Environmental Aviation, KS [M]

Steve Thickstun, Advanced Fuel Systems, OH [M]

Alternates

Larry Beasley, Robert and Company, GA [SE]
(Alt. to Michael Kluttz)

Kenneth M. Bilson, Burns & McDonnell Engineering Company, GA [SE]
(Alt. to John H. Bagnall)

Charles A. Davis, AECOM/URS Corporation, FL [SE]
(Voting Alt.)

Edward M. Hawthorne, DFW Dynamics, TX [U]
(Alt. to Mark W. Straub)

Stephen Gano, NFPA Staff Liaison

Jean-Luc Kassabian, Titan Aviation, France [M]
(Alt. to Chris Dukes)

Michael Motschman, Swissport Fueling Services, IL [U]
(Alt. to Fred A. Cnota)

Ian S. Thickstun, Advanced Fuel Systems, OH [M]
(Alt. to Steve Thickstun)

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on fire safe procedures, equipment, and installations for aircraft fuel servicing.

Contents

Chapter 1 Administration	407- 4	5.2 Operations.	407- 14
1.1 Scope.	407- 4	Chapter 6 Airport Fueling Vehicles	407- 14
1.2 Purpose.	407- 4	6.1 Design and Construction.	407- 14
1.3 Retroactivity.	407- 4	6.2 Operations.	407- 19
1.4 Equivalency.	407- 4	Chapter 7 Rooftop Heliports	407- 20
1.5 Units.	407- 4	7.1 Design and Construction.	407- 20
Chapter 2 Referenced Publications	407- 4	7.2 Operations.	407- 21
2.1 General.	407- 4	Chapter 8 Self-Service Aircraft Fueling	407- 21
2.2 NFPA Publications.	407- 4	8.1 Design and Construction.	407- 21
2.3 Other Publications.	407- 5	8.2 Operations.	407- 22
2.4 References for Extracts in Mandatory Sections.	407- 5	Annex A Explanatory Material	407- 22
Chapter 3 Definitions	407- 5	Annex B Aviation Fuel	407- 28
3.1 General.	407- 5	Annex C Clarification of Retroactivity	407- 29
3.2 NFPA Official Definitions.	407- 5	Annex D Informational References	407- 31
3.3 General Definitions.	407- 5	Index	407- 33
Chapter 4 General Requirements	407- 7		
4.1 Design and Construction.	407- 7		
4.2 Operations.	407- 8		
Chapter 5 Aviation Fueling Facilities	407- 12		
5.1 Design and Construction.	407- 12		

NFPA 407

Standard for

Aircraft Fuel Servicing

2022 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Standards." They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes® Subscription Service or the "List of NFPA Codes & Standards" at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced and extracted publications can be found in Chapter 2 and Annex D.

Chapter 1 Administration

1.1 Scope. This standard applies to the fuel servicing of all types of aircraft using liquid fuel.

1.1.1 This standard does not apply to any of the following:

- (1) In-flight fueling
- (2) Fuel servicing of flying boats or amphibious aircraft on water
- (3) Draining or filling of aircraft fuel tanks incidental to aircraft fuel system maintenance operations or manufacturing
- (4) Spacecraft

1.1.2* This document is not intended to be used as the sole standard for design, construction, operation, and maintenance of fuel storage and transfer facilities, as it does not address requirements for environmental protection, fuel quality, or other issues not directly related to fire safety.

1.2* Purpose.

1.2.1 The purpose of this standard is to establish reasonable minimum fire safety requirements for procedures, equipment, and installations for the protection of persons, aircraft, and other property during ground fuel servicing of aircraft using liquid petroleum fuels. These requirements are based upon sound engineering principles, test data, and field experience.

1.2.2 The fire hazard properties of aviation fuels vary; however, for the purpose of this standard, the same fire safety precautions are specified for all types.

1.3 Retroactivity. The provisions of this standard reflect a consensus of what is necessary to provide an acceptable degree of protection from the hazards addressed in this standard at the time the standard was issued.

1.3.1 Unless otherwise specified, the design and installation provisions of this standard shall not apply to facilities, equipment, structures, or installations that existed or were approved for construction or installation prior to the effective date of the standard.

1.3.2 Unless otherwise specified, operations and maintenance activities shall meet the current standard.

1.3.3 In those cases where the authority having jurisdiction determines that the existing situation presents an unacceptable degree of risk, the authority having jurisdiction shall be permitted to apply retroactively any portions of this standard deemed appropriate.

1.3.4 The retroactive requirements of this standard shall be permitted to be modified if their application clearly would be impractical in the judgment of the authority having jurisdiction, and only where it is clearly evident that a reasonable degree of safety is provided.

1.4 Equivalency. Nothing in this standard is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, rating, and safety over those prescribed by this standard.

1.4.1 Technical documentation shall be submitted to the authority having jurisdiction to demonstrate equivalency.

1.4.2 The system, method, or device shall be approved for the intended purpose by the authority having jurisdiction.

1.5 Units. Where the value for a measurement as specified in this standard is followed by an equivalent value in other units, the first value shall be regarded as the requirement. The equivalent value could be approximate.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 10, *Standard for Portable Fire Extinguishers*, 2022 edition.

NFPA 30, *Flammable and Combustible Liquids Code*, 2021 edition.

NFPA 70®, *National Electrical Code*®, 2020 edition.

NFPA 385, *Standard for Tank Vehicles for Flammable and Combustible Liquids*, 2022 edition.

NFPA 410, *Standard on Aircraft Maintenance*, 2020 edition.

NFPA 415, *Standard on Airport Terminal Buildings, Fueling Ramp Drainage, and Loading Walkways*, 2022 edition.

NFPA 418, *Standard for Heliports*, 2021 edition.

NFPA 704, *Standard System for the Identification of the Hazards of Materials for Emergency Response*, 2022 edition.

2.3 Other Publications.

2.3.1 ASME Publications. American Society of Mechanical Engineers, Two Park Avenue, New York, NY 10016-5990.

ASME B31.3, *Process Piping*, 2018.

2.3.2 ASTM Publications. ASTM International, 100 Barr Harbor Drive, P.O. Box C700, West Conshohocken, PA 19428-2959.

ASTM D380, *Standard Test Methods for Rubber Hose*, 1994, (2020).

2.3.3 AWS Publications. American Welding Society, 8669 NW 36 Street, # 130, Miami, FL 33166-6672.

AWS A5.10, *Welding Consumables — Wire Electrodes, Wires, and Rods for Welding of Aluminum and Aluminum Alloys — Classification*, 2017.

2.3.4 EI Publications. Energy Institute, 61 New Cavendish Street, London W1G 7AR, United Kingdom.

EI 1529, *Aviation Fuelling Hose and Hose Assemblies*, 7th edition, 2014.

EI 1540, *Design, Construction, Commissioning, Maintenance and Testing of Aviation Fuelling Facilities*, 5th Edition, 2014.

EI 1542, *Identification Markings for Dedicated Aviation Fuel Manufacturing and Distribution Facilities, Airport Storage, and Mobile Fuelling Equipment*, 9th Edition, 2012.

2.3.5 UL Publications. Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096.

UL 913, *Standard for Intrinsically Safe Apparatus and Associated Apparatus for Use in Class I, II, and III Division 1, Hazardous (Classified) Locations*, 8th edition, 2013, revised 2019.

2.3.6 US Government Publications. US Government Publishing Office, 732 North Capitol Street, NW, Washington, DC 20401-0001.

Title 49, Code of Federal Regulations, Part 172.504, “General Placarding Requirements.”

Title 49, Code of Federal Regulations, Part 178.345, “General Design and Construction Requirements Applicable to Specification DOT 406.”

2.3.7 Other Publications.

Merriam-Webster’s Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 30, *Flammable and Combustible Liquids Code*, 2021 edition.

NFPA 385, *Standard for Tank Vehicles for Flammable and Combustible Liquids*, 2022 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster’s Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3 Labeled. Equipment or materials to which has been attached a label, symbol, or other identifying mark of an organization that is acceptable to the authority having jurisdiction and concerned with product evaluation, that maintains periodic inspection of production of labeled equipment or materials, and by whose labeling the manufacturer indicates compliance with appropriate standards or performance in a specified manner.

3.2.4* Listed. Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

3.2.5 Shall. Indicates a mandatory requirement.

3.2.6 Should. Indicates a recommendation or that which is advised but not required.

3.2.7 Standard. An NFPA Standard, the main text of which contains only mandatory provisions using the word “shall” to indicate requirements and that is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions are not to be considered a part of the requirements of a standard and shall be located in an appendix, annex, footnote, informational note, or other means as permitted in the NFPA Manuals of Style. When used in a generic sense, such as in the phrase “standards development process” or “standards development activities,” the term “standards” includes all NFPA Standards, including Codes, Standards, Recommended Practices, and Guides.

3.3 General Definitions.

3.3.1 Aircraft. A vehicle designed for flight that is powered by liquid petroleum fuel.

3.3.2 Aircraft Fuel Servicing. See 3.3.29.1.

3.3.3 Aircraft Fuel Servicing Hydrant Vehicle (Hydrant Vehicle). See 3.3.37.1.

3.3.4 Aircraft Fuel Servicing Ramp or Apron. An area or position at an airport used for the fuel servicing of aircraft.

3.3.5 Aircraft Fuel Servicing Tank Vehicle (Fueller). See 3.3.37.2.

3.3.6 Aircraft Fueling Vehicle. See 3.3.37.3.

3.3.7 Airport Fueling System. An arrangement of aviation fuel storage tanks, pumps, piping, and associated equipment, such as filters, water separators, hydrants and station, or aircraft fuel servicing vehicles, installed at an airport and designed to service aircraft at fixed positions.

3.3.8* Aviation Fuel. Any petroleum fuel for use in aircraft engines.

3.3.9 Bulkhead. A liquidtight transverse closure between compartments of a cargo tank.

3.3.10 Burst Pressure. See 3.3.26.1.

3.3.11* Cargo Tank. A container used for carrying fuels and mounted permanently or otherwise secured on a tank vehicle.

3.3.12 Cathodic Protection. A method of controlling or impressing an electrical current to prevent corrosion of metal components of airport fueling systems that are in contact with the ground.

3.3.13 Deadman Control. A device that requires a positive continuing action of a person to allow the flow of fuel.

3.3.14 Electric Hand Lamp. A portable lamp other than a flashlight.

3.3.15 Emergency Fuel Shutoff. A function performed to stop the flow of fuel in an emergency.

3.3.16* Fuel Servicing Station. A unit that includes all necessary equipment to enable the transfer of fuel into or from an aircraft or fueller.

3.3.17 Fueller. See 3.3.37.2.

3.3.18 Fueling Point. The location on an aircraft where fuel enters the aircraft from an external source.

3.3.19 Head. A liquidtight transverse closure at the end of a cargo tank.

3.3.20 Hydrant Cart. A non-driven vehicle used to deliver fuel from a hydrant to an aircraft.

3.3.21 Hydrant Valve. An outlet of an airport fueling system that includes a deadman-controlled valve and adapter assembly to which a coupler on a hose or other flexible conduit on an aircraft fuel servicing vehicle can be connected.

3.3.22 Hydrant Vehicle. See 3.3.37.4.

N 3.3.23 Loading Rack. A fixed site utilized for filling or emptying aircraft fuel servicing tank vehicle cargo tanks, excluding aircraft fuel servicing.

3.3.24 Misfueling. The accidental fueling of an aircraft or refueling vehicle tank with an incorrect grade of product.

3.3.25 Overshoot. The fuel that passes through a valve after the deadman control is released or another flow control device is activated.

3.3.26 Pressure.

3.3.26.1 Burst Pressure. The pressure at which a component fails due to stresses induced as a result of the pressure.

3.3.26.2 Test Pressure. The pressure to which a system or a component of a system is subjected to verify the integrity of the system or component.

3.3.26.3 Working Pressure. The maximum allowable pressure, including momentary surge pressure, to which a system, hose, or other component can be safely subjected while in service.

3.3.27 Pressure Fuel Servicing. See 3.3.29.3.

3.3.28 Self-Service Fueling. The dispensing of aviation fuels into aircraft fuel tanks by persons other than the facility owner/operator.

3.3.29 Servicing.

3.3.29.1 Aircraft Fuel Servicing. The transfer of fuel into or from an aircraft.

3.3.29.2 Overwing Fuel Servicing. A system used to fuel an aircraft through an opening in the aircraft fuel tank using a hose with a hand-held nozzle.

3.3.29.3 Pressure Fuel Servicing. A system used to fuel an aircraft by closed coupled connection under pressure.

3.3.30 Tank Baffle. A nonliquidtight transverse partition in a cargo tank.

3.3.31 Tank Compartment. A liquidtight division in a cargo tank.

3.3.32 Tank Full Trailer. A vehicle that is not self-propelled and that has a cargo tank for the transportation of aviation fuel mounted thereon or built as an integral part thereof. It is so constructed that its weight and load rest on its own wheels.

3.3.33 Tank Semitrailer. A vehicle that is not self-propelled and that has a cargo tank for the transportation of aviation fuel mounted thereon or built as an integral part thereof. It is so constructed that when drawn by a tractor by means of a fifth wheel connection, some of its load and weight rests upon the towing vehicle.

3.3.34 Tank Truck. Any single self-propelled motor vehicle equipped with a cargo tank mounted thereon and used for the transportation of flammable and combustible liquids or asphalt. [385, 2022]

3.3.35 Tank Vehicle. See 3.3.37.5.

3.3.36 Test Pressure. See 3.3.26.2.

3.3.37 Vehicle.

3.3.37.1 Aircraft Fuel Servicing Hydrant Vehicle (Hydrant Vehicle). A vehicle equipped with facilities to transfer fuel between a fuel hydrant and an aircraft.

3.3.37.2 Aircraft Fuel Servicing Tank Vehicle (Fueller). A vehicle having a cargo tank (tank truck, tank full trailer, tank semitrailer) designed for or used in the transportation and transfer of fuel into or from an aircraft.

3.3.37.3 Aircraft Fueling Vehicle. A fuel servicing hydrant vehicle, hydrant cart, or an aircraft fuel servicing tank vehicle.

3.3.37.4 Hydrant Vehicle. See 3.3.37.1.

3.3.37.5 Tank Vehicle. Any tank truck, tank full trailer, or tractor and tank semitrailer combination.

3.3.38 Vent Point. The location on the exterior of an aircraft where fuel vapors are released from the aircraft's fuel system.

3.3.39 Working Pressure. See 3.3.26.3.

Chapter 4 General Requirements

4.1 Design and Construction.

4.1.1 General Requirements.

4.1.1.1 The requirements of Chapter 4 shall apply to all aviation fueling facilities, aircraft fueling vehicles, rooftop heliport fueling facilities, and self-service aviation fueling facilities.

4.1.1.2 Aviation fueling facilities shall also comply with the requirements of Chapter 5.

4.1.1.3 Aircraft fueling vehicles and carts shall also comply with the requirements of Chapter 6.

4.1.1.4 Rooftop heliport fueling facilities shall also comply with the requirements of Chapter 5 and Chapter 7.

4.1.1.5 Self-service aviation fueling facilities shall also comply with the requirements of Chapter 5 and Chapter 8.

4.1.2 Fuel Storage Tanks. (Reserved)

4.1.3 Fuel Dispensing Systems.

4.1.3.1 Any valve that controls the flow of fuel into or from an aircraft fuel servicing vehicle or cart, or into or from an aircraft shall have a deadman control(s).

4.1.3.2 The deadman flow control in the nozzle shall be permitted for overwing fueling.

4.1.3.3 Notches or latches in the handle of an overwing nozzle that could allow the valve to be locked open shall be prohibited.

4.1.3.4 Nozzles for pressure fuel servicing shall be designed to be attached securely to the aircraft adapter before the nozzle can be opened.

4.1.3.5 Disengaging the nozzle from the aircraft adapter shall not be possible until the nozzle is fully closed.

4.1.3.6 Fuel servicing pump mechanisms shall be designed and arranged so that failure or seizure does not cause rupture of the pump housing, of a tank, or of any component containing fuel.

4.1.3.7 Fuel pressure shall be controlled within the stress limits of the hose and plumbing by means of either an in-line pressure controller or, a system pressure relief valve, or other suitable means.

4.1.3.8 The working pressure of any system component shall equal or exceed any pressure to which it could be subjected.

4.1.4* Fueling Hose.

4.1.4.1 Performance Requirements. Hose and couplings shall comply with the requirements of EI 1529.

4.1.4.2 Fueling Hose Apparatus. Nozzle receptacles and hose storage shall be arranged to avoid kinks and maintain the hose bend radius within the requirements of EI 1529 and EI 1540.

4.1.4.3 Additional Requirements.

4.1.4.3.1 Each coupled length of hose shall be tested at the same minimum proof pressure rating for that grade of hose as defined in EI 1529.

4.1.4.3.2 A test certificate shall be provided for each coupled length of hose and shall state the following:

- (1) Manufacturer's name of hose
- (2) Manufacturer's name of couplings
- (3) Hose type
- (4) Hose grade
- (5) Size and length of hose
- (6) Serial number or reference number of hose
- (7) Quarter and year of manufacture of hose
- (8) Model number of couplings
- (9) Sizes of coupling ferrules
- (10) Hydrostatic test pressures
- (11) Coupled length serial number
- (12) Identification of individual responsible for coupling the hose
- (13) Name and address of company responsible for coupling the hose
- (14) Date of certification

4.1.4.3.3 The coupling tests as specified in EI 1529 shall be performed for each hose grade, type, and manufacturer.

4.1.4.3.4 Each coupling of a coupled length of hose shall be permanently marked with a serial number corresponding to its hydrostatic test certificate.

4.1.4.3.5 The hose at the end of each coupling ferrule shall be permanently marked prior to hydrostatic testing to serve as a reference to determine whether a coupling has slipped during testing or while in service.

4.1.4.3.6* Lengths of hose shall not be spliced together.

4.1.4.3.7 Hydrostatic Testing. Hydrostatic testing shall be in accordance with ASTM D380.

4.1.4.3.7.1 Following a hydrostatic test, all the water shall be drained and the hose shall be dried internally.

4.1.4.3.7.2 Following a hydrostatic test, the open ends of the hose, including the threads of the couplings, shall be suitably covered to protect the threads and to prevent contamination.

4.1.4.3.7.3 A hose that is recoupled for any reason shall be hydrostatically tested and recertified to the same criteria as a newly coupled hose.

4.1.4.3.8 Hose shall be connected to rigid piping or coupled to a hose reel in a manner that prevents kinks or undue bending action or mechanical stress on the hose or hose couplings.

4.1.5 Electrostatic Hazards and Bonding.

4.1.5.1 A provision for bonding shall be incorporated in the design of fuel servicing vehicles or carts and airport fueling systems to prevent differences in electrostatic potential.

4.1.5.2 The maximum resistance between the bonding cable clip and the fueling system framework shall not exceed 25 ohms.

4.1.5.3 Bonding cables shall be constructed of conductive, durable, and flexible material.

4.1.5.4 Bonding connections shall be electrically and mechanically firm.

4.1.5.5 Jacks, plugs, clamps, and connecting points shall be clean, unpainted metal to provide a positive electrical connection.

4.1.5.6 EI 1529 Type C hose (semiconductive) shall be used to prevent electrostatic discharges but shall not be used to accomplish required bonding.

4.1.5.7 EI 1529 Type A hose that does not have a semiconductive cover shall not be used.

4.1.5.8 EI 1529 Type F hose (hard wall) and EI 1529 Type CT hose (cold temperature) shall be permitted because they have semiconductive covers.

4.1.5.9* The design of airport fueling systems shall incorporate the provision of a 30-second relaxation period following the filter separator, monitors, or other filtration devices discharging into tanks.

4.1.5.9.1 The relaxation period required by 4.1.5.9 shall not apply to the actual refueling of an aircraft.

4.1.5.9.2 The relaxation period required by 4.1.5.9 shall not apply to fuels with static dissipater additives.

4.1.6 Electrical Systems. (Reserved)

4.1.7 Control of Fuel Flow. (Reserved)

4.1.8 Filters and Ancillary Equipment.

4.1.8.1 Filter vessels used in aviation fuel service shall have a functional automatic air vent (AAV) or automatic air eliminator (AAE).

4.1.8.2 The AAV or AAE shall discharge to a closed system.

4.1.9 Emergency Fuel Shutoff Systems. (Reserved)

4.1.10 Fire Extinguishers.

4.1.10.1* During fueling operations, fire extinguishers shall be available on aircraft servicing ramps or aprons, in accordance with NFPA 410.

4.1.10.2 All fire extinguishers shall conform to the requirements of NFPA 10.

4.1.10.3* ABC multipurpose dry chemical fire extinguishers (ammonium phosphate) shall not be placed on aircraft fueling vehicles, airport fuel servicing ramps or aprons, or at airport fuel facilities that are located within 150 m (500 ft) of aircraft operating areas.

4.1.11 Marking and Labeling.

4.1.11.1 Each emergency fuel shutoff station location shall be placarded EMERGENCY FUEL SHUTOFF in letters at least 50 mm (2 in.) high.

4.1.11.2 The method of operation shall be indicated by an arrow or by the word PUSH or PULL, as appropriate.

4.1.11.3 Any action necessary to gain access to the shutoff device (e.g., BREAK GLASS) shall be shown clearly.

4.1.11.4 Lettering shall be of a color contrasting sharply with the placard background for visibility.

4.1.11.5 Placards shall be weather resistant.

4.1.12 Aircraft Fueling Ramps.

4.1.12.1 Aircraft Radar Equipment.

4.1.12.1.1 Surveillance radar equipment in aircraft shall not be operated within 90 m (300 ft) of any fueling, servicing, or other operation in which flammable liquids, vapors, or mist could be present.

4.1.12.1.2 Weather-mapping radar equipment in aircraft shall not be operated while the aircraft in which it is mounted is undergoing fuel servicing.

4.1.12.2* Ground Radar Equipment.

4.1.12.2.1 Antennas of airport flight traffic surveillance radar equipment shall be located so that the beam will not be directed toward any fuel storage or loading racks within 90 m (300 ft).

4.1.12.2.2 Aircraft fuel servicing shall not be conducted within the 90 m (300 ft) distance established by 4.1.12.2.1.

4.1.12.2.3 Antennas of airport ground traffic surveillance radar equipment shall be located so that the beam will not be directed toward any fuel storage or loading racks within 30 m (100 ft).

4.1.12.2.4 Aircraft fuel servicing or any other operations involving flammable liquids or vapors shall not be conducted within 30 m (100 ft) of antennas of airport ground traffic surveillance radar equipment.

4.1.12.3 Emergency Fire Equipment Accessibility. Accessibility to aircraft by emergency fire equipment shall be considered in establishing aircraft fuel servicing positions.

4.1.12.4 Ramp and Apron Drainage. Aircraft servicing ramps or aprons shall be sloped and drained in accordance with NFPA 415.

4.1.12.4.1 The ramp or apron shall slope away from the rim or edge of fueling hydrants or fueling pits to prevent flooding.

4.1.12.4.2 Fueling hydrant boxes or fueling pits that are connected to a ramp drainage system shall be fitted with vapor-sealing traps.

4.2 Operations.

4.2.1 Security. (Reserved)

4.2.2 Training.

4.2.2.1* Only personnel trained in the safe operation of the equipment and the fuels they use, the operation of emergency controls, and the procedures to be followed in an emergency shall be permitted to handle fuel.

4.2.2.2* Fuel servicing personnel shall be trained in the use of the available fire-extinguishing equipment they could be expected to use.

4.2.3* Prevention and Control of Spills.

4.2.3.1 Following fueling of an aircraft or fuel servicing vehicle, all hoses shall be removed, including those from hydrant systems if applicable.

4.2.3.2 All hoses shall also be properly stowed.

4.2.3.3 Fuel nozzles shall not be dragged along the ground.