

NFPA® 557

Standard for Determination of Fire Loads for Use in Structural Fire Protection Design

2012 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02169-7471
An International Codes and Standards Organization



Become a
Member

Subscribe
to the



Register for
Seminars, Webinars,
and Online Courses



Documents

Document Sharing Hub

Visit the
NFPA Catalog

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® DOCUMENTS
NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA DOCUMENTS

NFPA® codes, standards, recommended practices, and guides (“NFPA Documents”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Documents.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Documents. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Documents available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Documents. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

ISBN: 978-145590300-9 (Print)
ISBN: 978-145590365-8 (PDF)

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA DOCUMENTS

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Documents

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Documents”) should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments. An official NFPA Document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Documents

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Document. The users of NFPA Documents bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Documents.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Document may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Documents should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Documents are copyrighted by the NFPA. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Documents for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Documents, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Documents and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02169-7471; email: stds_admin@nfpa.org

For more information about NFPA, visit the NFPA website at www.nfpa.org.

Copyright © 2012 National Fire Protection Association®. All Rights Reserved.

NFPA® 557

Standard for

**Determination of Fire Loads for Use in
Structural Fire Protection Design**

2012 Edition

This edition of NFPA 557, *Standard for Determination of Fire Loads for Use in Structural Fire Protection Design*, was prepared by the Technical Committee on Hazard and Risk of Contents and Furnishings. It was issued by the Standards Council on December 13, 2011, with an effective date of January 2, 2012.

This edition of NFPA 557 was approved as an American National Standard on January 2, 2012.

Origin and Development of NFPA 557

The 2012 edition marks the first edition of NFPA 557, *Standard for Determination of Fire Loads for Use in Structural Fire Protection Design*. This document dates back to 2003, when it was proposed that NFPA create a document to address the need for guidance and standardization in the area of structural fire engineering. The Technical Committee on Hazard and Risk of Contents and Furnishings was assigned the document and work began shortly thereafter.

NFPA 557 addresses the determination of the fire load and fire load density to be used as the basis for the evaluation and design of the structural fire performance of a building. The purpose of NFPA 557 is to provide standard methods and values for use in the determination of fire loads and fire load densities for design-basis fires. This is done using a risk framework. Two methodologies are detailed in the document: an occupancy-based density method and a survey-based method.



Technical Committee on Hazard and Risk of Contents and Furnishings

Marcelo M. Hirschler, *Chair*
GBH International, CA [SE]

Farid Alfawakhiri, American Iron and Steel Institute, IL [M]
Craig L. Beyler, Hughes Associates, Inc., MD [SE]
David A. Boverman, New South Wales Rural Fire Service, Australia [E]
Elizabeth C. Buc, Fire and Materials Research Laboratory, LLC, MI [RT]
David G. Bueche, Hoover Treated Wood Products, CO [M]
Cam Cope, Auto Fire and Safety Consultants, TX [SE]
Gordon H. Damant, Inter-City Testing & Consulting Corp. of California, CA [SE]
Bruce R. Ellingwood, Georgia Institute of Technology, GA [RT]
George V. Hadjisophocleous, Carleton University, Canada [RT]

John M. Hoffmann, Safety Engineering Laboratories, Inc., MI [RT]
Marc L. Janssens, Southwest Research Institute, TX [RT]
William E. Koffel, Koffel Associates, Inc., MD [SE]
Sergei Levchik, Israel Chemicals Ltd. (ICL-IP), NY [M]
Richard T. Long, Jr., Exponent, Inc., MD [M]
 Rep. Upholstered Furniture Action Council
Daniel J. O'Connor, Aon Fire Protection Engineering, IL [U]
 Rep. American Hotel & Lodging Association
Jeffrey Santrock, General Motors LLC, MI [M]
 Rep. Alliance of Automobile Manufacturers
Dwayne E. Sloan, Underwriters Laboratories Inc., NC [RT]
Jason Turpin, U.S. Department of the Air Force, OH [E]
Steven D. Wolin, Code Consultants, Inc., MO [SE]

Alternates

Erik H. Anderson, Koffel Associates, Inc., MD [SE]
 (Alt. to W. E. Koffel)
William Randall Edwards, Alliance of Automobile Manufacturers, MI [M]
 (Alt. to J. Santrock)
Donald J. Hoffmann, Safety Engineering Laboratories, Inc., MI [RT]
 (Alt. to J. M. Hoffmann)
Jason P. Huczek, Southwest Research Institute, TX [RT]
 (Alt. to M. L. Janssens)

Nestor R. Iwankiw, Hughes Associates, Inc., IL [SE]
 (Alt. to C. L. Beyler)
Randall K. Laymon, Underwriters Laboratories Inc., IL [RT]
 (Alt. to D. E. Sloan)
T. Hugh Talley, Hugh Talley Company, TN [M]
 (Alt. to R. T. Long, Jr.)

Kristin Collette, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on fire hazard calculation procedures for use by other Committees in writing provisions to control the fire hazards of contents and furnishings. This Committee shall also provide guidance and recommendations to Committees in assessing the fire hazard of contents and furnishings. It shall establish classification and rating systems, request the development and standardization of appropriate fire tests, and identify and encourage necessary research as it relates to the fire hazards of contents and furnishings. It shall act in a liaison capacity between NFPA and the committees of other organizations with respect to the hazard of contents and furnishings.



Contents

Chapter 1 Administration	557– 4	Chapter 6 Occupancy-Based Fire Load Density	557– 9
1.1 Scope	557– 4	6.1 Fire Load Density	557– 9
1.2 Purpose	557– 4	6.2 Design Fire Load Density	557– 9
1.3 Application	557– 4		
1.4 Equivalency	557– 4	Chapter 7 Survey Method-Based Fire Load	
1.5 Units and Formulas	557– 4	Density	557– 9
		7.1 Fire Load Density	557– 9
Chapter 2 Referenced Publications	557– 4	7.2 Fire Load	557– 9
2.1 General	557– 4	7.3 Heats of Combustion	557– 9
2.2 NFPA Publications	557– 4	7.4 Methodology and Limitations	557–10
2.3 Other Publications	557– 4		
2.4 References for Extracts in Mandatory		Chapter 8 Documentation, Inspection, and	
Sections	557– 4	Maintenance	557–10
		8.1 Documented Fire Load	557–10
Chapter 3 Definitions	557– 4	8.2 Prior to Occupancy Change	557–10
3.1 General	557– 4	8.3 Change in Occupancy	557–10
3.2 NFPA Official Definitions	557– 4	8.4 Repairs	557–10
3.3 General Definitions	557– 4	8.5 Formal Review	557–10
Chapter 4 Design Fundamentals	557– 5	Annex A Explanatory Material	557–10
4.1 Methodology	557– 5		
4.2 Fire Load	557– 5	Annex B Summary of Occupancy Based Fuel	
4.3 Statistical Distribution of Fire Load	557– 5	and Fire Load Survey Data	557–14
4.4 Frequency of Fire Initiations	557– 5		
4.5 Effectiveness of Fire Protection Features	557– 5	Annex C Guidance for Fuel or Fire Load	
		Surveys (Special Facility and	
Chapter 5 Development of Fire Loads	557– 5	Occupancy Based)	557–15
5.1 Types of Fire Loads	557– 5		
5.2 Defining the Compartment	557– 5	Annex D Analyses of Structurally Significant	
5.3 Distributed Fire Loads	557– 5	Fires in Buildings with Selected	
5.4 Localized Fire Loads	557– 5	Characteristics	557–16
5.5 Frequency of Structurally Significant			
Fires	557– 6	Annex E Informational References	557–21
5.6 Approvals and Limitations	557– 6		
5.7 Application of the Frequencies of		Index	557–22
Structurally Significant Fires to			
Occupancies	557– 6		

NFPA 557

Standard for

Determination of Fire Loads for Use in Structural Fire Protection Design

2012 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading “Important Notices and Disclaimers Concerning NFPA Documents.” They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex E. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex E

Chapter 1 Administration

1.1 Scope. The scope of this standard is the determination of the fire load and fire load density to be used as the basis for the evaluation and design of the structural fire performance of a building.

1.1.1 The determination of a design-basis fire is outside the scope of this standard.

1.1.2* This document is not intended to address facilities for storage of hazardous materials.

1.2 Purpose. The purpose of this standard is to provide standard methods and values for use in the determination of fire loads and fire load densities for design-basis fires, which is done using a risk framework.

1.3 Application. This standard applies to the determination of fire loads and fire load densities based on occupancy.

1.4 Equivalency. Nothing in this standard is intended to prevent the use of methods equivalent or superior in effectiveness and safety over those prescribed by this standard.

1.5 Units and Formulas.

1.5.1 The units of measure in this standard are presented in the International System (SI) of Units.

1.5.2 The values presented for measurements in this standard are expressed with a degree of precision appropriate for practical application and enforcement. It is not intended that

the application or enforcement of these values be more precise than the precision expressed.

1.5.3 Where extracted text contains values expressed in only one system of units, the values in the extracted text have been retained without conversion to preserve the values established by the responsible technical committee in the source document.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications.

NFPA 70®, *National Electrical Code*®, 2011 edition.

NFPA 90A, *Standard for the Installation of Air-Conditioning and Ventilating Systems*, 2012 edition.

NFPA 101®, *Life Safety Code*®, 2012 edition.

2.3 Other Publications.

Merriam-Webster's Collegiate Dictionary, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 101®, *Life Safety Code*®, 2012 edition.

NFPA 555, *Guide on Methods for Evaluating Potential for Room Flashover*, 2009 edition.

NFPA 5000®, *Building Construction and Safety Code*®, 2012 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3 Shall. Indicates a mandatory requirement.

3.2.4 Should. Indicates a recommendation or that which is advised but not required.

3.2.5 Standard. A document, the main text of which contains only mandatory provisions using the word “shall” to indicate requirements and which is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions shall be located in an appendix or annex, footnote, or fine-print note and are not to be considered a part of the requirements of a standard.

3.3 General Definitions

3.3.1 Alteration. See 3.3.10, Renovation.

3.3.2 Change of Use. A change in the purpose or level of activity within a structure that involves a change in the application of code requirements.



3.3.3 Contents and Furnishings. Any movable objects in a building that normally are secured or otherwise put in place for functional reasons, excluding (1) parts of the internal structure of the building and (2) any items meeting the definition of interior finish. [555, 2009]

3.3.4 Design-Basis Fire. The set of conditions that define the development of a fire and the spread of combustion products throughout a building or portions thereof.

3.3.5 Fire Load. The total energy content of combustible materials in a building, space, or area including furnishing and contents and combustible building elements expressed in MJ.

3.3.5.1* Contents Fire Load. The fire load of all movable or secured contents and furnishings and all occupant possessions within a compartment, including all the items that can be placed into a compartment or taken out of it without causing structural damage, expressed in MJ.

3.3.5.2 Distributed Fire Load. The overall fire load of the compartment, expressed in MJ.

3.3.5.3* Fixed Fire Load. The fire load of all combustible materials used as structural elements or as interior finish or trim (wall, ceiling, and floor) or installed concealed behind walls, floor, or ceiling, expressed in MJ.

3.3.5.4* Localized Fire Load. The fire load at a location within the compartment that is outside the scope of normal variations in the distributed fire load, expressed in MJ.

3.3.6* Fire Load Density. The heat energy, expressed in MJ/m², that could be released per unit floor area of a compartment by the combustion of the contents of the compartment and any combustible part(s) of the building itself.

3.3.7 Fuel Load. The total wood equivalent mass of combustible materials in a building, space, or area, including furnishings and contents and combustible building elements, expressed in kg.

3.3.8* Interior Finish. The exposed surfaces of walls, ceilings, and floors within buildings. [5000, 2012]

3.3.9 Occupancy. The purpose for which a building or other structure, or part thereof, is used or intended to be used. [5000, 2012]

3.3.10 Renovation. The replacement in kind or strengthening of load-bearing elements; or the refinishing, replacement, bracing, strengthening, or upgrading of existing materials, elements, equipment, or fixtures, without involving the reconfiguration of spaces. [101, 2012]

3.3.11 Repair. The patching, restoration, or painting of materials, elements, equipment, or fixtures for the purpose of maintaining such materials, elements, equipment, or fixtures in good or sound condition. [101, 2012]

3.3.12 Structurally Significant Fire. A fire that grows to a size that poses a threat to the structural elements.

Chapter 4 Design Fundamentals

4.1* Methodology. The methodology developed in this standard shall provide a risk-based design fire load and fire load densities for use in design and evaluation of structural fire performance.

4.2 Fire Load. The fire load for design-basis fires shall be determined by a combination of all of the following:

- (1) Statistical distribution of fire loads in buildings
- (2) Fire initiation frequency

- (3) Effectiveness and reliability of the fire protection features that contribute to fire control in the early stages of the fire

4.3 Statistical Distribution of Fire Load. The statistical distribution of the fire load of the building shall be determined by one of the following:

- (1) Statistical sampling and analysis of the subject or similar buildings, as provided in Chapter 7
- (2) Through the use of suitable occupancy-based means and standard deviation of the fire load distribution, as provided in Chapter 6

4.4 Frequency of Fire Initiations. The frequency of fire initiations in the building shall be determined from national statistical studies of fire incident data.

4.5 Effectiveness of Fire Protection Features.

4.5.1 The effectiveness of fire protection features in controlling fires before the fire becomes structurally significant shall be assessed by all of the following:

- (1) Functional analysis
- (2)*National statistical analysis for the country of the design site

4.5.2 Explanation of Statistics Used. If the statistics used for compliance with 4.5.1 are local or regional, an explanation shall be provided as to why these statistics are applicable for this analysis.

Chapter 5 Development of Fire Loads

5.1 Types of Fire Loads. Fire loads shall be calculated as both localized fire loads and distributed fire loads.

5.1.1 Prior to a change of use or occupancy, the building owner shall evaluate the fire load for the new use or occupancy.

5.1.2 If there is a change of use or occupancy, and the fire load in the new use or occupancy exceeds the fire load that was originally developed, then the fire resistance of the building shall be analyzed to evaluate if the existing passive fire protection meets the design objectives for the new use or occupancy.

5.2 Defining the Compartment.

5.2.1 The compartment shall be selected as either the entire building or that portion of the building that is bounded by exterior surfaces of the building and by fire-rated boundaries that are capable of containing a fire for the entire duration through burnout.

5.2.2 For areas where there are no fire-rated boundaries, the entire building shall be selected.

5.3 Distributed Fire Loads.

5.3.1 Distributed fire loads shall be determined to reflect the total fire load throughout a compartment.

5.3.2 Distributed fire loads shall be determined in accordance with Chapter 6 or Chapter 7.

5.4 Localized Fire Loads.

5.4.1 Localized fire loads shall be determined to reflect concentrations of combustible material that have the potential to pose a more severe thermal exposure than the thermal exposure that would result from the uniform fire load.

5.4.2* Combustible materials shall be considered concentrated whenever the mass per unit area of one or more items is a factor of 2.57 greater than the established distributed fire load.

5.4.3 Localized fire loads shall be determined based upon surveys as described in Chapter 7 or upon architectural design data.

5.4.4 The localized fire load determined in accordance with this section shall be subject to the approval of the authority having jurisdiction (AHJ).

5.4.5 Localized fire loads shall be reported by location in the building and shall include the expected value and a measure of the variability of the value (mean and standard deviation).

5.5 Frequency of Structurally Significant Fires.

5.5.1 Methodology.

5.5.1.1 The frequency of structurally significant fires shall be developed by estimating the rate of fires per year relative to the numbers of buildings and to the area of floor space, for buildings of similar occupancy to the building being designed.

5.5.1.2* The frequency of structurally significant fires shall be determined by multiplying the rate of reportable fires per year per floor area by the fraction of fires that are structurally significant in buildings with similar construction and fire protection systems as proposed for the building.

5.5.1.3 The frequency of structurally significant fires, f_{ss} , shall be calculated as the product of the fire frequency, f_f , and the floor area, A_f , as follows:

$$f_{ss} = f_f \times A_f$$

where:

f_{ss} = frequency of structurally significant fires
(fires/year)

f_f = fire frequency (fires/m² year)

A_f = floor area (m²)

5.6 Approvals and Limitations.

5.6.1* The limitations on the estimates of the frequency of structurally significant fires along with any limitations of the

applicability of the structurally significant fire frequency for a particular building shall be subject to the approval of the AHJ.

5.6.2 The limitations of the applicability on the estimate of the frequency of the structurally significant fire for each particular building or facility shall be addressed within a technical report and provided to the AHJ for review and approval.

5.6.3* The frequency of structurally significant fires shall be developed from national statistics per Section 5.7 and Annex D.

5.6.4 As an alternative to the procedures in Section 5.6, other published data shall be used subject to approval of the applicability of the data by the AHJ.

5.7* Application of the Frequencies of Structurally Significant Fires to Occupancies.

5.7.1* Office/Business Occupancies.

5.7.1.1* For office/business occupancies, the frequency of fires shall be taken as 6 fires per million square meters per year.

5.7.1.2* For office/business occupancies, the frequency of structurally significant fires shall be determined by multiplying the fire frequency in 5.7.1.1 by the value in Table 5.7.1.2 that corresponds to the construction type and fire protection systems specified for the building.

5.7.2* Religious Properties.

5.7.2.1* For religious properties, the frequency of fires shall be taken as 6 fires per million square meters per year.

5.7.2.2* For religious properties, the frequency of structurally significant fires shall be determined by multiplying the fire frequency in 5.7.2.1 by the value in Table 5.7.2.2 that corre-

Table 5.7.1.2 Fraction of Fires That Are Structurally Significant in Office/Business Occupancies

Type of Construction*	No Detection or No Alarm (No Sprinklers)	No Detection or No Alarm (Sprinklers Present)	Detection and Alarm Present (No Sprinklers)	Detection and Alarm Present (Sprinklers Present)
Fire resistive	0.13	0.04	0.07	0.03
Protected noncombustible	0.15	0.05	0.06	0.03
Unprotected noncombustible	0.19	0.07	0.10	0.05
Protected ordinary	0.21	0.03	0.10	0.04
Unprotected ordinary	0.30	0.11	0.17	0.07
Protected wood frame	0.30	0.13	0.18	0.08
Unprotected wood frame	0.37	0.12	0.20	0.07

*For more information on types of construction, see A.5.7.1.2.

Table 5.7.2.2 Fraction of Fires That Are Structurally Significant in Religious Properties

Type of Construction	No Detection or No Alarm (No Sprinklers)	Detection and Alarm Present (No Sprinklers)	No Detection or No Alarm (Sprinklers Present)	Detection and Alarm Present (Sprinklers Present)
Fire resistive	0.22	0.06	0	0
Protected noncombustible	0.16	0.07	0.07	0.03
Unprotected noncombustible	0.23	0.15	0	0.43
Protected ordinary	0.24	0.12	0.14	0
Unprotected ordinary	0.29	0.18	0.22	0.05
Protected wood frame	0.33	0.17	0.06	0.03
Unprotected wood frame	0.39	0.20	0.08	0.18

