

NFPA® 750

Standard on Water Mist Fire Protection Systems

2010 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02169-7471
An International Codes and Standards Organization

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® DOCUMENTS
NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA DOCUMENTS

NFPA® codes, standards, recommended practices, and guides (“NFPA Documents”), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Documents.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Documents. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Documents available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Documents. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

ISBN: 978-087765940-2 (Print)
ISBN: 978-087765988-4 (PDF)

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA DOCUMENTS

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Documents

Users of NFPA codes, standards, recommended practices, and guides (“NFPA Documents”) should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments. An official NFPA Document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Documents

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Document. The users of NFPA Documents bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Documents.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards (“the ANSI Patent Policy”), and hereby gives the following notice pursuant to that policy:

NOTICE: The user’s attention is called to the possibility that compliance with an NFPA Document may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Documents should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Documents are copyrighted by the NFPA. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Documents for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Documents, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Documents and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02169-7471; email: stds_admin@nfpa.org

For more information about NFPA, visit the NFPA website at www.nfpa.org.

Copyright © 2009 National Fire Protection Association®. All Rights Reserved.

NFPA® 750

Standard on

Water Mist Fire Protection Systems

2010 Edition

This edition of NFPA 750, *Standard on Water Mist Fire Protection Systems*, was prepared by the Technical Committee on Water Mist Fire Suppression Systems. It was issued by the Standards Council on October 27, 2009, with an effective date of December 5, 2009, and supersedes all previous editions.

This edition of NFPA 750 was approved as an American National Standard on December 5, 2009.

Origin and Development of NFPA 750

In 1993, representatives from the research and engineering communities, water mist system manufacturers, the insurance industry, enforcement authorities, and industrial users met and organized the NFPA Technical Committee on Water Mist Fire Suppression Systems. The committee started work on developing a new NFPA document that would begin to standardize water mist technology and provide for reliable design and installation of these systems.

Water mist systems were introduced in the 1940s and were utilized for specific applications such as on passenger ferries. The renewed interest in water mist systems is due partially to the phasing out of halon and their potential as a fire safety system for spaces where the amount of water that can be stored or that can be discharged is limited. In addition, their application and effectiveness for residential occupancies, flammable liquids storage facilities, and electrical equipment spaces continues to be investigated with encouraging results.

NFPA 750 contains elements that are similar to standards on other types of fire protection systems such as automatic sprinklers, fixed water spray, carbon dioxide, and halon. In many ways, water mist can be thought of as a hybrid of those systems. Overall, water mist systems utilize water as the extinguishing, suppression, or control medium but do so in a nontraditional manner. In developing this standard, the committee addressed system components and hardware, system types, installation requirements, design objectives, hazard classifications, calculations, water supplies, atomizing media, plans, documentation, acceptance criteria, and maintenance considerations.

The 2000 edition of NFPA 750 represented a significant advancement in water mist technology and the knowledge base associated with its application. That edition included a new definition of *water mist* and a complete rewrite and reorganization of what was Chapter 5, Design Objectives and Fire Test Protocols. Additionally, many new sections were added to address the design and safety considerations associated with positive displacement water mist pumps. New guidance was provided for the measurement of the water mist spray characteristics including drop distribution. Finally, two new appendixes were added to address many of the current and proposed fire test protocols and the reliability of water mist systems.

The 2003 edition incorporated revisions that updated the standard to comply with the *Manual of Style for NFPA Technical Committee Documents*. Style changes included a restructuring of the document, reworded exceptions as requirements, and transition to a metric-as-primary document. The 2003 edition contained updated requirements for additives, proportioning methods, supervision, calculation methods, and inspection and testing of water mist systems. New requirements were added that addressed protection of machinery spaces on towing vessels.

The 2006 edition updated requirements for hangers, supports, reserve water supplies, pump capacities, and appropriate test connections.

The 2010 edition includes new annex material providing guidance on obstruction to nozzle discharge and a number of editorial revisions.

Technical Committee on Water Mist Fire Suppression Systems

Larry W. Owen, *Chair*
Dooley Tackaberry, Inc., TX [IM]

John F. Devlin, Schirmer Engineering Corporation,
MD [I]
Randall Eberly, U.S. Coast Guard, DC [E]
Joshua M. Fleischer, AREVA Group, CA [U]
Rep. Edison Electric Institute
William A. Froh, U.S. Department of Energy, DC [U]
Raymond N. Hansen, U.S. Department of the Air Force,
FL [E]
Daniel J. Hubert, Janus Fire Systems, IN [IM]
Rep. Fire Suppression Systems Association
Mary P. Hunstad, U.S. Department of the Navy, DC [E]
William E. Janz, XL Global Asset Protection Services,
IL [I]
Robert Kasiski, FM Global, MA [I]
Andrew Kim, National Research Council of Canada,
Canada [RT]
Max Lakkonen, FOGTEC Fire Protection, Germany [M]
Rep. International Water Mist Association
George E. Laverick, Underwriters Laboratories Inc.,
IL [RT]

David J. LeBlanc, Tyco Fire Suppression & Building
Products, RI [M]
Kerry L. Madigan, Scandaliato Design Group, Inc.,
CO [IM]
Rep. American Fire Sprinkler Association
Jack R. Mawhinney, Hughes Associates, Inc., MD [SE]
Jason Pope, National Automatic Sprinkler Fitters LU 669,
MD [L]
Rep. United Association of Journeymen & Apprentices
of the Plumbing & Pipe Fitting Industry
Thomas Prymak, Rolf Jensen & Associates, Inc., TX [SE]
William J. Reilly, Victaulic Company of America, PA [M]
Michael B. Stevens, National Aeronautics & Space
Administration, FL [U]
Brad T. Stilwell, Fike Corporation, MO [M]
Thomas M. Suehr, Liberty Mutual Property, MA [I]
Rep. Property Casualty Insurers Association of America
Dennis W. Taylor, WorleyParsons, TX [SE]
Victoria B. Valentine, National Fire Sprinkler Association,
Inc., NY [M]
Thomas F. Ziegler, Verizon, NJ [U]

Alternates

Kerry M. Bell, Underwriters Laboratories Inc., IL [RT]
(Alt. to G. E. Laverick)
James G. Bisker, U.S. Department of Energy, DC [U]
(Alt. to W. A. Froh)
Bruce H. Clarke, XL Global Asset Protection, LLC,
NC [I]
(Alt. to W. E. Janz)
Robert L. Darwin, Hughes Associates, Inc., MD [SE]
(Alt. to J. R. Mawhinney)
Eric W. Haberichter, Kidde/Chemetron Fire Systems,
IL [IM]
(Alt. to D. J. Hubert)
Rick J. Jackson, Jackson Associates, Inc., MI [IM]
(Alt. to K. L. Madigan)

Michael Koczera, Liberty Mutual Property, MA [I]
(Alt. to T. M. Suehr)
Robert J. Libby, The RJA Group, Inc., MD [SE]
(Alt. to T. Prymak)
Earl D. Neargarth, Fike Corporation, MO [M]
(Alt. to B. T. Stilwell)
Erin A. M. Oneisom, U.S. Department of the Air Force,
AE [E]
(Alt. to R. N. Hansen)
Maarit Tuomisaari, Marioff Corporation Oy, Finland [M]
(Voting Alt. to Marioff Rep.)
Hong-Zeng Yu, FM Global, MA [I]
(Alt. to R. Kasiski)

Nonvoting

Lawrence A. McKenna, Jr., U.S. Department of
Homeland Security, MD [C]
Douglas J. Pickersgill, Fire and Safety Systems,
Australia [SE]

Woodrow W. Stratton, U.S. Department of Homeland
Security, MD [C]
Fernando Vigara, APICI, Spain [SE]

James D. Lake, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on the design, installation, and maintenance of systems which use a water mist for the control, suppression, or extinguishment of fire.



Contents

Chapter 1 Administration	750- 5	7.8 Valves and Pressure Gauges	750-19
1.1 Scope	750- 5	7.9 Electrical Systems	750-20
1.2 Purpose	750- 5	7.10 Test Connections	750-20
1.3 Application	750- 5	Chapter 8 Design Objectives and Fire Test	
1.4 Retroactivity	750- 5	Protocols	750-20
1.5 Equivalency	750- 5	8.1 General	750-20
1.6 Units	750- 5	8.2 Listing Evaluations	750-21
Chapter 2 Referenced Publications	750- 6	8.3 Performance Objectives	750-21
2.1 General	750- 6	8.4 Application Parameters	750-21
2.2 NFPA Publications	750- 6	8.5 Reliability	750-22
2.3 Other Publications	750- 6	Chapter 9 Calculations	750-22
2.4 References for Extracts in Mandatory		9.1 General	750-22
Sections	750- 7	9.2 Darcy-Weisbach Calculation Method	
Chapter 3 Definitions	750- 7	for Intermediate and High Pressure,	
3.1 General	750- 7	Single Fluid, Single Liquid Phase	
3.2 NFPA Official Definitions	750- 7	Systems	750-22
3.3 General Definitions	750- 7	9.3 Hazen-Williams Calculation Method	
Chapter 4 General	750- 8	(Low Pressure Systems)	750-22
4.1 General	750- 8	9.4 Calculation Procedures for Propellant	
4.2 Safety.	750- 8	Gas or Atomizing Media	750-25
Chapter 5 System Components and Hardware	750- 9	Chapter 10 Water Supplies and Atomizing	
5.1 General.	750- 9	Media	750-26
5.2 Gas and Water Containers	750- 9	10.1 General	750-26
5.3 Piping and Tube	750- 9	10.2 Quantity	750-26
5.4 Fittings	750-10	10.3 Duration	750-26
5.5 Hangers/Supports	750-11	10.4 Reserve Supplies	750-26
5.6 Nozzles	750-11	10.5 Water Supplies	750-26
5.7 Valves	750-12	10.6 Atomizing Media for Twin-Fluid	
5.8 Strainers and Filters	750-12	Systems	750-27
5.9 Pump Systems	750-13	10.7 Pressure Gauges	750-28
5.10 Detection, Actuation, Alarm, and		Chapter 11 Plans and Documentation	750-28
Control Systems	750-13	11.1 Working Plans	750-28
5.11 Compatibility	750-14	11.2 Hydraulic Calculation	
Chapter 6 System Requirements	750-14	Documentation	750-29
6.1 General	750-14	11.3 Pneumatic Calculation	
6.2 System Applications	750-14	Documentation	750-29
6.3 Nozzle Types	750-15	11.4 Detection, Actuation, and Control	
6.4 System Requirements.	750-15	Systems Documentation	750-29
6.5 Media System Types	750-15	Chapter 12 System Acceptance	750-30
6.6 Additive Systems	750-15	12.1 Approval of Water Mist Systems	750-30
Chapter 7 Installation Requirements	750-15	12.2 Acceptance Requirements	750-30
7.1 General.	750-15	Chapter 13 System Maintenance	750-32
7.2 Nozzles	750-15	13.1 Responsibility of the Owner or	
7.3 Pipe and Tubing	750-16	Occupant	750-32
7.4 Fittings	750-16	13.2 Inspection and Testing	750-33
7.5 Gas and Water Storage Containers	750-16	13.3 Maintenance	750-33
7.6 Pumps and Pump Controllers	750-18	13.4 Training	750-33
7.7 Strainers and Filters	750-18		

Chapter 14 Marine Systems	750-33	Annex B Research Summary	750-56
14.1 General	750-33	Annex C Examples of Fire Test Protocols	750-56
14.2 Sprinkler Equivalent Systems	750-35	Annex D Reliability	750-63
14.3 Flammable Liquids — Total Area Protection	750-36	Annex E Informational References	750-65
14.4 Human Factors	750-37	Index	750-66
14.5 Requirements for Water Mist Systems on Combatant Vessels	750-37		
Annex A Explanatory Material	750-37		



NFPA 750**Standard on****Water Mist Fire Protection Systems****2010 Edition**

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Documents." They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

Changes other than editorial are indicated by a vertical rule beside the paragraph, table, or figure in which the change occurred. These rules are included as an aid to the user in identifying changes from the previous edition. Where one or more complete paragraphs have been deleted, the deletion is indicated by a bullet (•) between the paragraphs that remain.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex E. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex E.

Chapter 1 Administration

1.1* Scope. This standard contains the minimum requirements for the design, installation, maintenance, and testing of water mist fire protection systems. This standard does not provide definitive fire performance criteria, nor does it offer specific guidance on how to design a system to control, suppress, or extinguish a fire. Reliance is placed on the procurement and installation of listed water mist equipment or systems that have demonstrated performance in fire tests as part of a listing process.

1.2* Purpose.

1.2.1 The purpose of this standard is to provide protection for life and property from fire through the standardization of design, installation, maintenance, and testing requirements for water-based fire suppression systems that use a specific spray (mist) that absorbs heat, displaces oxygen, or blocks radiant heat to control, suppress, or extinguish fires as required by the application.

1.2.2 The user of this standard shall recognize the complexity of water mist fire suppression systems. Therefore, the designer shall be cautioned that the standard is not a design handbook. The standard shall not do away with the need for the engineer or for competent engineering judgment. It is the intent that a designer capable of applying more complete and rigorous analysis to special or unusual problems shall have latitude in the development of such designs. In such cases, the designer shall be responsible for demonstrating the validity of the design approach.

1.3 Application. This standard shall apply to water mist fire protection systems and shall establish minimum requirements for water mist technology on the basis of sound engineering principles, test data, and field experience.

1.4 Retroactivity. The provisions of this standard reflect a consensus of what is necessary to provide an acceptable degree of protection from the hazards addressed in this standard at the time the standard was issued.

1.4.1 Unless otherwise specified, the provisions of this standard shall not apply to facilities, equipment, structures, or installations that existed or were approved for construction or installation prior to the effective date of the standard. Where specified, the provisions of this standard shall be retroactive.

1.4.2 In those cases where the authority having jurisdiction determines that the existing situation presents an unacceptable degree of risk, the authority having jurisdiction shall be permitted to apply retroactively any portions of this standard deemed appropriate.

1.4.3 The retroactive requirements of this standard shall be permitted to be modified if their application clearly would be impractical in the judgment of the authority having jurisdiction, and only where it is clearly evident that a reasonable degree of safety is provided.

1.5 Equivalency. Nothing in this standard is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety over those prescribed by this standard.

1.5.1 Technical documentation shall be submitted to the authority having jurisdiction to demonstrate equivalency.

1.5.2 The system, method, or device shall be approved for the intended purpose by the authority having jurisdiction.

1.6* Units.

1.6.1 Metric units of measurement in this standard are in accordance with the modernized metric system known as the International System of Units (SI).

1.6.2 Two units (liter and bar) outside of but recognized by SI are commonly used in international fire protection.

1.6.3 These units are listed in Table 1.6.3 with conversion factors.

1.6.4 If a value for measurement as given in this standard is followed by an equivalent value in other units, the first stated is to be regarded as the requirement.

Table 1.6.3 Metric Conversion Factors

Name of Unit	Unit Abbreviation or Symbol	Conversion Factor
Millimeter	mm	1 in. = 25.4 mm
Square meter	m ²	1 ft ² = 0.0929 m ²
Liter	L	1 gal = 3.785 L
Cubic decimeter	dm ³	1 gal = 3.785 dm ³
Cubic meter	m ³	1 ft ³ = 0.028317 m ³
Kilogram	kg	1 lb = 0.4536 kg
Kilograms per cubic meter	kg/m ³	1 lb/ft ³ = 16.0183 kg/m ³
Pascal	Pa	1 psi = 6895 Pa
Bar	bar	1 psi = 0.0689 bar; 1 bar = 10 ⁵ Pa
Liter per minute per square meter	L/min/m ²	1 gpm = 40.746 L/min/m ²
Micron	μ	1 mm = 1000 μ

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 13, *Standard for the Installation of Sprinkler Systems*, 2010 edition.

NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*, 2010 edition.

NFPA 22, *Standard for Water Tanks for Private Fire Protection*, 2008 edition.

NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2008 edition.

NFPA 70®, *National Electrical Code*®, 2008 edition.

NFPA 72®, *National Fire Alarm and Signaling Code*, 2010 edition.

NFPA 170, *Standard for Fire Safety and Emergency Symbols*, 2009 edition.

2.3 Other Publications.

2.3.1 ANSI Publications. American National Standards Institute, Inc., 25 West 43rd Street, 4th Floor, New York, NY 10036.

ANSI B1.20.1, *Pipe Threads, General Purpose (Inch)*, 1992.

ANSI B16.18, *Cast Copper Alloy Solder Joint Pressure Fittings*, 1994.

ANSI B16.22, *Wrought Copper and Copper Alloy Solder Joint Pressure Fittings*, 1995.

2.3.2 ASME Publications. American Society of Mechanical Engineers, Three Park Avenue, New York, NY 10016-5990.

ASME *Boiler and Pressure Vessel Code*, 2001.

ASME B31.1, *Power Piping Code*, 1998.

2.3.3 ASTM Publications. ASTM International, 100 Barr Harbor Drive, P. O. Box C700, West Conshohocken, PA 19428-2959.

ASTM A 269, *Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service*, 2000.

ASTM A 351/ASTM A 351M, *Standard Specification for Castings, Austenitic, Austenitic-Ferritic (Duplex) for Pressure-Containing Parts*, 2000.

ASTM A 403/ASTM A 403M, *Standard Specification for Wrought Austenitic Stainless Steel Piping Fittings*, 2000.

ASTM A 632, *Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing (Small-Diameter) for General Service*, 1990.

ASTM A 774/ASTM A 774M, *Standard Specification for As-Welded Wrought Austenitic Stainless Steel Fittings for General Corrosive Service at Low and Moderate Temperatures*, 2000.

ASTM A 778, *Standard Specification for Welded, Unannealed Austenitic Stainless Steel Tubular Products*, 2000.

ASTM A 789/ASTM A 789M, *Standard Specification for Seamless and Welded Ferritic/Austenitic Stainless Steel Tubing for General Service*, 1995.

ASTM A 815/ASTM A 815M, *Standard Specification for Wrought Ferritic, Ferritic/Austenitic, and Martensitic Stainless Steel Piping Fittings*, 1998.

ASTM B 32, *Standard Specification for Solder Metal*, 2000.

ASTM B 42, *Standard Specification for Seamless Copper Pipe, Standard Sizes*, 1998.

ASTM B 75, *Standard Specification for Seamless Copper Tube*, 1999.

ASTM B 88, *Standard Specification for Seamless Copper Water Tube*, 1999.

ASTM B 251, *Standard Specification for General Requirements for Wrought Seamless Copper and Copper-Alloy Tube*, 1997.

ASTM B 813, *Standard Specification for Liquid and Paste Fluxes for Soldering Applications of Copper and Copper-Alloy Tube*, 2000.

2.3.4 AWS Publications. American Welding Society, 550 N.W. LeJeune Road, Miami, FL 33126.

AWS A5.8, *Specification for Filler Metals for Brazing and Braze Welding*, 1992.

AWS D10.9, *Specification for Qualification of Welding Procedures and Welders for Piping and Tubing*, 1980.

2.3.5 IMO Publications. International Maritime Organization, 4 Albert Embankment, London, SE1 7SR, United Kingdom.

IMO Assembly Resolution A.800(19), *Revised Guidelines for Approval of Sprinkler Systems*.

IMO Code for Application of Fire Test Procedures, 1998.

IMO MSC/Circ. 668, *Alternative Arrangements for Halon Fire-Extinguishing Systems in Machinery Spaces and Pumprooms*.

IMO MSC/Circ. 728, *Revised Test Method for Equivalent Water-Based Fire-Extinguishing Systems for Machinery Spaces of Category A and Cargo Pump-Rooms Contained in MSC/Circ. 668*.

IMO MSC/Circ. 913, *Guidelines for the Approval of Fixed Water-Based Local Application Fire-Fighting Systems for Use in Category A Machinery Spaces*, 1999.

SOLAS Regulation 11-2/12.4.1, Consolidated Edition, 1992.

2.3.6 ISO Publications. International Organization for Standardization, 1 rue de Varembe, Case postale 56, CH-1211 Geneva 20, Switzerland.

ISO 1219-1, *Fluid power systems and components — Graphic symbols and circuit diagrams — Part 1: Graphic symbols*, 1991.

ISO 1219-2, *Fluid power systems and components — Graphic symbols and circuit diagrams — Part 2: Circuit diagrams*, 1995.



2.3.7 ULC Publications. Underwriters' Laboratories of Canada, 7 Underwriters Road, Toronto, Ontario M1R 3B4, Canada.

CAN/ULC S524-06, *Standard for the Installation of Fire Alarm Systems*, 2006.

CAN/ULC S529-02, *Standard for Smoke Detectors for Fire Alarm Systems*, 2002.

2.3.8 U.S. Coast Guard Publication. 2100 Second Street, S.W., Washington, DC 20593-0001.

NVIC 9-97, *Guide to Structural Fire Protection*, 1997.

2.3.9 U.S. Government Publication. U.S. Government Printing Office, Washington, DC 20402.

Title 46, Code of Federal Regulations, Parts 56.50 and 56.75, "Shipping."

Title 49, Code of Federal Regulations, "Transportation."

2.3.10 Other Publications. *Merriam-Webster's Collegiate Dictionary*, 11th edition, Merriam-Webster, Inc., Springfield, MA, 2003.

2.4 References for Extracts in Mandatory Sections.

NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2008 edition.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not defined in this chapter or within another chapter, they shall be defined using their ordinarily accepted meanings within the context in which they are used. *Merriam-Webster's Collegiate Dictionary*, 11th edition, shall be the source for the ordinarily accepted meaning.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.

3.2.2* Authority Having Jurisdiction (AHJ). An organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, an installation, or a procedure.

3.2.3* Listed. Equipment, materials, or services included in a list published by an organization that is acceptable to the authority having jurisdiction and concerned with evaluation of products or services, that maintains periodic inspection of production of listed equipment or materials or periodic evaluation of services, and whose listing states that either the equipment, material, or service meets appropriate designated standards or has been tested and found suitable for a specified purpose.

3.2.4 Shall. Indicates a mandatory requirement.

3.2.5 Should. Indicates a recommendation or that which is advised but not required.

3.2.6 Standard. A document, the main text of which contains only mandatory provisions using the word "shall" to indicate requirements and which is in a form generally suitable for mandatory reference by another standard or code or for adoption into law. Nonmandatory provisions shall be located in an

appendix or annex, footnote, or fine-print note and are not to be considered a part of the requirements of a standard.

3.3 General Definitions.

3.3.1* Additive. Any chemical or mixture of chemicals intentionally introduced into the system.

3.3.2* Additive Proportioning. Additive proportioning is the method (such as premix, metered, or balanced pressure) used for the introduction of an additive or additive mixture at the recommended percent ratio into the water system.

3.3.3 Deluge System. A water mist system using open nozzles attached to a piping system that is connected to a water supply through a valve that is opened by means of a detection system installed in the same area as the mist nozzles. When the valve opens, water flows into the piping system and discharges through all nozzles attached to the system.

3.3.4* D_v . A drop diameter such that the cumulative volume, from zero diameter to this respective diameter, is the fraction, f , of the corresponding sum of the total distribution.

3.3.5* Enclosure. A confined or partially confined volume.

3.3.6 Escutcheon. A protective or ornamental plate or flange.

3.3.7 Fire Control. Limiting the size of a fire by distribution of water so as to decrease the heat release rate and pre-wet adjacent combustibles, while controlling ceiling gas temperatures to avoid structural damage.

3.3.8 Fire Extinguishment. The complete suppression of a fire until there are no burning combustibles.

3.3.9 Fire Suppression. The sharp reduction of the rate of heat release of a fire and the prevention of regrowth.

3.3.10 High Pressure System. A water mist system where the distribution system piping is exposed to pressures of 34.5 bar (500 psi) or greater.

3.3.11 Intermediate Pressure System. A water mist system where the distribution system piping is exposed to pressures greater than 12.1 bar (175 psi) but less than 34.5 bar (500 psi).

3.3.12 Low Pressure System. A water mist system where the distribution piping is exposed to pressures of 12.1 bar (175 psi) or less.

3.3.13 Propellant. Compressed gas used as a prime mover to push water out of storage vessels, through pipe networks, or through distribution components.

3.3.14* Shall be Considered. Requires an objective assessment, the results and basis of which are documented, to determine to what extent the specific factor, criterion, guideline, standard, and so forth, is incorporated into or satisfied by the design.

3.3.15 Single-Fluid System. A water mist system utilizing a single piping system to supply each nozzle.

3.3.16 Supervision. In water-based fire protection systems, a means of monitoring system status and indicating abnormal conditions. [25, 2008]

3.3.17 Total Compartment Application System. A system designed to discharge water mist to protect all hazards in an enclosure.

3.3.18 Twin-Fluid System. A water mist system in which water and atomizing media are separately supplied to and mixed at the water mist nozzle.

3.3.19* Water Mist. A water spray for which the $Dv_{0.99}$, for the flow-weighted cumulative volumetric distribution of water droplets, is less than 1000 microns at the minimum design operating pressure of the water mist nozzle.

3.3.20 Water Mist, Atomizing Media. Compressed air or other gases that produce water mist by mechanical mixing with water.

3.3.21 Water Mist Nozzle. A special purpose device, containing one or more orifices, designed to produce and deliver a water spray meeting either the definition of *water mist* or meeting the specific requirements of an approved water mist fire test protocol. (See Annex C.)

3.3.21.1 Automatic Water Mist Nozzles. Nozzles that operate independently of other nozzles by means of a detection/activation device built into the nozzle.

3.3.21.2* Hybrid Water Mist Nozzles. Nozzles capable of operation using both automatic and nonautomatic means.

3.3.21.3 Nonautomatic Water Mist Nozzles (Open). Nozzles that operate as an entire system or grouping of nozzles, containing open orifices and activating the water flow to the nozzles by an independent detection system.

3.3.22 Water Mist System. A distribution system connected to a water supply or water and atomizing media supplies that is equipped with one or more nozzles capable of delivering water mist intended to control, suppress, or extinguish fires and that has been demonstrated to meet the performance requirements of its listing and this standard.

3.3.22.1 Dry Pipe Water Mist System. A water mist system using automatic nozzles attached to a piping system containing air, nitrogen, or inert gas under pressure, the release of which (as from an opening of an automatic nozzle) allows the water pressure to open a dry pipe valve. The water then flows into the piping system and out through any open nozzles.

3.3.22.2 Engineered Water Mist Systems. Those systems that need individual calculation and design to determine the flow rates, nozzle pressures, pipe size, area, or volume protected by each nozzle, discharge density of water mist, the number and types of nozzles, and the nozzle placement in a specific system.

3.3.22.3 Local-Application Water Mist System. A water mist system arranged to discharge directly on an object or hazard in an enclosed, unenclosed, or open outdoor condition.

3.3.22.4 Preaction Water Mist System. A water mist system using automatic nozzles attached to a piping system that contains air that might or might not be under pressure, with a supplemental detection system installed in the same areas as the mist nozzles. The actuation of the detection system opens a valve that allows water to flow into the piping system and discharges through all opened nozzles in the system.

3.3.22.5* Pre-engineered Water Mist Systems. Those systems having predetermined flow rates, nozzle pressures, and water quantities.

3.3.22.6 Wet Pipe Water Mist System. A water mist system using automatic nozzles attached to a piping system containing water and connected to a water supply so that water discharges immediately from nozzles operated by the heat from a fire.

3.3.23 Working Pressure. The maximum anticipated static (nonflowing) pressure applied to the system components exclusive of surge pressures.

3.3.24 Zoned Application System. A system designed to protect hazards in a predetermined portion of an enclosure.

Chapter 4 General

4.1* General.

4.1.1 Use and Limitations.

4.1.1.1 Water mist systems shall be permitted for use with a wide range of performance objectives, including the following:

- (1) Fire extinguishment
- (2) Fire suppression
- (3) Fire control
- (4) Temperature control
- (5) Exposure protection

4.1.1.2* Water mist systems shall not be used for direct application to materials that react with water to produce violent reactions or significant amounts of hazardous products. Such materials include the following:

- (1) Reactive metals, such as lithium, sodium, potassium, magnesium, titanium, zirconium, uranium, and plutonium
- (2) Metal alkoxides, such as sodium methoxide
- (3) Metal amides, such as sodium amide
- (4) Carbides, such as calcium carbide
- (5) Halides, such as benzoyl chloride and aluminum chloride
- (6) Hydrides, such as lithium aluminum hydride
- (7) Oxyhalides, such as phosphorus oxybromide
- (8) Silanes, such as trichloromethylsilane
- (9) Sulfides, such as phosphorus pentasulfide
- (10) Cyanates, such as methylisocyanate

4.1.1.3 Water mist systems shall not be used for direct application to liquefied gases at cryogenic temperatures (such as liquefied natural gas), which boil violently when heated by water.

4.2* Safety.

4.2.1* Electrical Clearances.

4.2.1.1* All system components shall be located to maintain minimum clearances from unenclosed and uninsulated energized electrical components in accordance with *NFPA 70, National Electrical Code*.

4.2.1.2 Where the design basic insulation level (BIL) is not known and where nominal voltage is used for the design criteria, the highest minimum clearance specified for this group shall be used.

4.2.1.3 The selected clearance to ground shall satisfy the greater of the switching surges or BIL duty, rather than being based on nominal voltage.

4.2.1.4 The clearance between uninsulated energized parts of the electrical system equipment and any portion of the water mist system shall not be less than the minimum clearance provided elsewhere for electrical system insulation on any individual component.

4.2.2 Environmental Factors.

4.2.2.1 When selecting water mist to protect a hazard area, the effects of water runoff on the environment shall be considered.



Chapter 5 System Components and Hardware

5.1 General. This chapter provides the requirements for water mist system components.

5.1.1 Component Listing.

5.1.1.1 Unless the requirements of 5.1.1.2 or 5.1.1.3 are met, all water mist system components shall be listed for their intended use.

5.1.1.2 The requirements of 5.1.1.1 shall not apply where approved components are specifically permitted to be substituted for listed components.

5.1.1.3 The requirements of 5.1.1.1 shall not apply to individual components where the components are part of a listed, pre-engineered system.

5.1.2 Working Pressure.

5.1.2.1 System components shall be rated for the maximum working pressure to which they are exposed but not less than 12.1 bar (175 psi).

5.1.2.2 Where components are part of a listed, pre-engineered system with a self-contained water supply, the pressure rating shall be in accordance with the listing requirements.

5.1.3 Corrosion Resistance.

5.1.3.1 Corrosive Atmospheres. Where components are subjected to severe corrosive atmospheres, corrosion protection such as special corrosion-resistive materials or coating shall be required.

5.1.3.2* Water Additives. All components in the water mist systems and the additive injection system shall be of corrosion-resistant material.

5.2 Gas and Water Containers.

5.2.1 Capacity. Gas and water containers, where provided, shall be sized to supply quantities of gas and water as required by Chapter 10.

5.2.2 Design.

5.2.2.1* Installation. Gas and water containers shall be designed for installation according to the manufacturer's installation manual, including provision for attachment of seismic restraint.

5.2.2.2* Specifications. Gas and water containers subject to pressurization shall be made, tested, approved, equipped, and marked in accordance with the current specifications of the ASME *Boiler and Pressure Vessel Code*, Section VIII, or the requirements of the U.S. Department of Transportation, 49 CFR 171-190, 178.36-178.37, or other approved international standards.

5.2.2.3 Shipping Containers. Containers used as shipping containers shall be designed to meet the requirements of the U.S. Department of Transportation or of Transport Canada or of other approved international standards.

5.2.2.4 Design Pressure. The design pressure shall be based on the maximum pressure developed by the water mist system at 54°C (130°F).

5.2.2.5 Excess Pressure. Each pressurized container shall be provided with a safety device to release excess pressure.

5.2.2.6 Water Container Nameplate.

5.2.2.6.1 Unless the requirements of 5.2.2.6.2 are met, each water container shall have a permanent nameplate or other permanent marking specifying the liquid held in the container (including additives) and the nominal water volume and pressurization level (where applicable) of the container.

5.2.2.6.2 The requirements of 5.2.2.6.1 shall not apply where the information required by 5.2.2.8.1 is provided on a nameplate or placard permanently installed on the system at a location convenient for servicing or content measuring.

5.2.2.7 Sight Glasses. External sight glasses on water containers shall be protected against mechanical damage.

5.2.2.8 Gas Container Nameplate.

5.2.2.8.1 Unless the requirements of 5.2.2.8.2 are met, each gas container shall have a permanent nameplate or other permanent marking specifying the type of gas, weight of gas, weight of container, nominal gas volume, and pressurization level of the container.

5.2.2.8.2 The requirements of 5.2.2.8.1 shall not apply where the information required by 5.2.2.8.1 is provided on a nameplate or placard permanently installed on the system at a location convenient for servicing or content measuring.

5.2.2.9 Pressure Indicator. A reliable means shall be provided to indicate the pressure in refillable, pressurized gas containers.

5.2.3 Multiple Container Systems. All containers supplying the same manifold outlet shall be interchangeable and of the same size and charge.

5.3 Piping and Tube.

5.3.1* General.

5.3.1.1 All piping, valves, and fittings, from the system strainer to the nozzle, shall have corrosion resistance at least equivalent to piping specified in Table 5.3.3.1.

5.3.1.2 Wherever the word *pipe* is used, it shall be understood also to mean *tube*.

5.3.2* Other Types of Pipe or Tube.

5.3.2.1 Other types of pipe or tube investigated for suitability in water mist system installations and listed for this service shall be permitted where installed in accordance with their listing limitations, including installation instructions.

5.3.2.2 Bending of the pipe shall be permitted as provided by the listing.

5.3.2.3 Pipe or tube shall not be listed for portions of an occupancy classification.

5.3.3 Low Pressure Systems.

5.3.3.1 Pipe or tube used in low pressure water mist systems shall meet or exceed one of the standards in Table 5.3.3.1 or shall be in accordance with 5.3.2.

5.3.3.2 The chemical properties, physical properties, and dimensions of the materials given in Table 5.3.3.1 shall conform at a minimum to the standards cited in the table.

5.3.3.3 Pipe and tube used in low pressure water mist systems shall be designed to withstand a working pressure of not less than 12.1 bar (175 psi).

Table 5.3.3.1 Pipe or Tube Standards

Materials and Dimensions and Standard Titles	Standard No.
Copper Tube (Drawn, Seamless)	
<i>Standard Specification for Solder Metal [95-5 (Tin-Antimony-Grade 95TA)]</i>	ASTM B 32
<i>Standard Specification for Seamless Copper Tube*</i>	ASTM B 75
<i>Standard Specification for Seamless Copper Water Tube*</i>	ASTM B 88
<i>Standard Specification for General Requirements for Wrought Seamless Copper and Copper-Alloy Tube</i>	ASTM B 251
<i>Standard Specification for Liquid and Paste Fluxes for Soldering Applications of Copper and Copper-Alloy Tube</i>	ASTM B 813
<i>Specification for Filler Metals for Brazing and Braze Welding (Classification BCuP-3 or BCuP-4)</i>	AWS A5.8
Stainless Steel	
<i>Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service</i>	ASTM A 269
<i>Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing (Small-Diameter) for General Service</i>	ASTM A 632
<i>Standard Specification for Welded, Unannealed Austenitic Stainless Steel Tubular Products</i>	ASTM A 778
<i>Standard Specification for Seamless and Welded Ferritic/Austenitic Stainless Steel Tubing for General Service</i>	ASTM A 789/ A 789M

*Denotes pipe or tube suitable for bending (see 5.3.6) according to ASTM standards.

5.3.3.4 Copper tube as specified in the standards referenced in Table 5.3.3.1 shall have a wall thickness of Type K, L, or M where used in water mist systems.

5.3.4 Intermediate and High Pressure Systems.

5.3.4.1* Pipe or tube shall be of noncombustible material having physical and chemical characteristics such that its deterioration under stress can be predicted with reliability.

5.3.4.2 The piping shall be in accordance with ASME B31.1, *Power Piping Code*.

5.3.4.3 Where using the equations provided in ASME B31.1 to calculate either the maximum working pressure (P_w) for a specific pipe or tube or the minimum wall thickness (t_m) of the pipe or tube for a specific operating pressure, a steel temperature of 54°C (130°F) or the expected ambient temperature to which the pipe or tube will be exposed shall be used, whichever is greater.

5.3.4.4* Flexible piping, tubing, or hoses (including connections) shall be listed for their intended use.

5.3.5 Pipe or Tube Identification.

5.3.5.1 All pipe or tube, including specially listed pipe or tube, shall be marked continuously along its length by the manufacturer in such a way as to identify the type of pipe or tube.

5.3.5.2 Pipe or tube identification shall include the manufacturer's name, model designation, or schedule.

5.3.5.3 Pipe or tube marking shall not be painted, concealed, or removed prior to approval by the authority having jurisdiction.

5.3.6* Pipe or Tube Bending.

5.3.6.1 Bending of Type K and Type L copper tube or stainless steel tube or pipe shall be permitted, provided that all bending details are in accordance with the tubing manufacturer's recommendations, the strength requirements of ASME B31.1, *Power Piping Code*, or the following, whichever is greatest:

- (1) For Type K or Type L copper tubing and stainless steel pipe, the minimum bending radius is six pipe or tube diameters.
- (2) For Type 304L or Type 316 stainless steel tube, the minimum bending radius is two diameters up to 38 mm (1½ in.) OD, and four diameters for 51 mm (2 in.) tubing.

5.3.6.2 Bending tools shall be used for all bending in accordance with the following:

- (1) Power bending tools with the correct radius dies shall be required for pipe and tube larger than 20 mm (¾ in.).
- (2) Hand or bench dies with the correct radius dies shall be permitted to be used to bend pipe or tubing 20 mm (¾ in.) and smaller.
- (3) Flattened bends where the larger diameter is greater than 1.08 times the least diameter shall not be permitted.

5.4 Fittings.

5.4.1* General.

5.4.1.1 Fittings. All fittings used on piping described in 5.3.1 shall have a corrosion resistance at least equivalent to wrought copper fittings conforming to ANSI B16.22, *Wrought Copper and Copper Alloy Solder Joint Pressure Fittings*.

5.4.1.2 Conversion Fittings.

5.4.1.2.1 Conversion fittings from metric to fractional units shall be identified by color or tagging for quick notification in the field.

5.4.1.2.2 A supply of spare adapters shall be maintained on the premises so that any adapters that have been damaged in any way can be promptly replaced.

5.4.1.2.3 Adapter information shall also be maintained on the drawings.

5.4.2 Low Pressure Systems.

5.4.2.1 Fittings used in water mist systems shall meet or exceed the standards in Table 5.4.2.1 or shall be in accordance with 5.4.2.2.

5.4.2.2* Other types of fittings investigated for suitability in water mist installations and listed for this service shall be permitted where installed in accordance with their listing limitations, including installation instructions.

5.4.2.3 Screwed unions shall not be used on pipe larger than 51 mm (2 in.).

5.4.2.4 Couplings and unions of other than the screwed type shall be listed for the intended use.

5.4.2.5 A one-piece reducing fitting shall be used wherever a change is made in the size of pipe.



Table 5.4.2.1 Fitting Standards

Materials and Dimensions and Standard Titles	Standard No.
Copper	
<i>Cast Copper Alloy Solder Joint Pressure Fittings</i>	ANSI B16.18
<i>Wrought Copper and Copper Alloy Solder Joint Pressure Fittings</i>	ANSI B16.22
Stainless Steel	
<i>Standard Specification for Castings, Austenitic, Austenitic-Ferritic (Duplex) for Pressure-Containing Parts</i>	ASTM A 351/A 351M
<i>Standard Specification for Wrought Austenitic Stainless Steel Piping Fittings</i>	ASTM A 403/A 403M
<i>Standard Specification for As-Welded Wrought Austenitic Stainless Steel Fittings for General Corrosive Service at Low and Moderate Temperatures</i>	ASTM A 774/A 774M
<i>Standard Specification for Wrought Ferritic, Ferritic/Austenitic, and Martensitic Stainless Steel Piping Fittings</i>	ASTM A 815/A 815M

5.4.2.6 Where standard fittings of the required size are not produced, hexagonal or face bushings shall be permitted in reducing the size of openings of fittings and shall meet the requirements of 5.4.2.5.

5.4.2.7 All threads used in joints and fittings shall conform to ANSI B1.20.1, *Pipe Threads, General Purpose (Inch)*. Joint compound, tape, or thread lubricant shall be applied only to the male threads of the joint.

5.4.2.8 Soldering fluxes shall be in accordance with Table 5.3.3.1.

5.4.2.9 Brazing fluxes, if used, shall not be of a highly corrosive type.

5.4.2.10 Welding shall be performed in accordance with AWS D10.9, *Specification for Qualification of Welding Procedures and Welders for Piping and Tubing*, Level AR-3.

5.4.3 Intermediate and High Pressure Systems.

5.4.3.1 Fittings shall have a minimum-rated working pressure equal to or greater than the maximum operating pressure of the water mist systems at 54°C (130°F).

5.4.3.2 For systems that employ the use of a pressure regulating device in the distribution piping, the fittings downstream of the device shall have a minimum-rated working pressure equal to or greater than the maximum anticipated pressure in the downstream piping.

5.4.3.3 All threads used in joints and fittings shall conform to ANSI B1.20.1, *Pipe Threads, General Purpose (Inch)*.

5.4.3.4 Joint compound, tape, or thread lubricant shall be applied only to the male threads of the joint.

5.4.3.5 Welding and brazing alloys shall have a melting point above 538°C (1000°F).

5.4.3.6 Welding and brazing shall be performed in accordance with Section IX of the ASME *Boiler and Pressure Vessel Code*.

5.4.3.7 Where acceptable tubing is joined with compression-type fittings, the manufacturer's pressure temperature ratings for the fitting shall not be exceeded.

5.5 Hangers/Supports.

5.5.1 Supports. All references to hangers shall include supports.

5.5.2 Listing. Unless the requirements of 5.5.3 are met, hangers shall be listed for use with the pipe or tube involved.

5.5.3 Special Designed Hangers.

5.5.3.1 The requirements of 5.5.2 shall not apply to hangers where the following conditions are met:

- (1) Documentation shall be submitted to show that the hangers and hanging method are recognized as good industry practice for the piping system.
- (2) Hangers shall be designed to support five times the weight of the pipe or tube when filled with gas or water, based on the system's use of the pipe or tube, plus 114 kg (250 lb) at each point of piping support.
- (3) The points of support shall be able to support the water mist system.
- (4) Hanger components shall be metal.
- (5) Plastic inserts shall be permitted in tube clamps to avoid dissimilar metal reactions or dampen vibrations.

5.5.3.2 Detailed calculations shall be submitted, where required by the authority having jurisdiction, showing the stresses developed in both the hangers and the piping and the safety factors provided.

5.5.4 Bending. Threaded portions of hangers shall not be bent.

5.5.5 Listed Inserts. The use of listed inserts set in concrete to support hangers shall be permitted.

5.5.6 Powder-Driven Fasteners.

5.5.6.1 Unless the requirements of 5.5.6.2 are met, powder-driven fasteners shall not be used to attach hangers to the building structure where systems are required to be protected against earthquakes.

5.5.6.2 The requirements of 5.5.6.1 shall not apply to powder-driven fasteners that are specifically listed for service in seismic areas.

5.6 Nozzles.

5.6.1* Listing. Nozzles shall be listed either individually or as a part of a pre-engineered system, and the listing information shall include the following:

- (1) Specific hazards and protection objectives
- (2) Volumetric flow rate characteristics of water discharge for each nozzle
- (3) Maximum height of protected space
- (4) Minimum distance between nozzle tip or diffuser, as applicable, and plane of protection
- (5) Maximum spacing between nozzles
- (6) Maximum coverage area per nozzle
- (7) Minimum spacing between nozzles
- (8) Maximum height between ceiling and nozzle diffuser or tip, as applicable
- (9) Nozzle obstruction spacing criteria
- (10) Maximum spacing of nozzles from walls
- (11) Minimum- and maximum-rated operating pressures of nozzles

- (12) Allowable range of nozzle orientation angle from vertically down
- (13) Classification of automatic nozzle thermal response characteristics as fast, special, or standard response
- (14) Maximum compartment volume, if applicable
- (15) Maximum time delay for water mist delivery to the most remote nozzle

5.6.2 New Nozzles. Only new nozzles shall be installed in water mist systems.

5.6.3 Marking. Nozzles shall be permanently marked to identify the manufacturer, type, and size of the orifice(s) or part number.

5.6.4 Corrosion Protection. Additional corrosion protection, such as special corrosion-resistant materials or coatings, shall be required in severely corrosive atmospheres.

5.6.5 Protective Coatings. Where protective coatings are used to meet the requirements of 5.1.3, the coatings shall be applied by the nozzle manufacturer, and the coated nozzle shall be listed.

5.6.6 Frangible Discs and Blowoff Caps.

5.6.6.1 Where clogging by external, foreign materials is possible, discharge nozzles shall be provided with frangible discs, blowoff caps, or other listed devices.

5.6.6.2 These devices shall provide an unobstructed opening upon system operation and shall be located so they cannot injure personnel.

5.6.7 Thermally Activated Nozzles.

5.6.7.1 The standard temperature ratings of individual, thermally activated nozzles shall be as shown in Table 5.6.7.1.

5.6.7.2 Individual, thermally activated nozzles shall be colored in accordance with the color code designated in Table 5.6.7.1.

5.6.7.3 The stock of spare, individual, thermally activated nozzles shall include all types and ratings installed and shall be as follows:

- (1) For systems having fewer than 50 nozzles, not fewer than 3 nozzles
- (2) For systems having 50 to 300 nozzles, not fewer than 6 nozzles
- (3) For systems having 301 to 1000 nozzles, not fewer than 12 nozzles
- (4) For systems having over 1000 nozzles, not fewer than 24 nozzles

5.7 Valves.

5.7.1 Valve Listing.

5.7.1.1 Unless the requirements of 5.7.1.2 are met, all valves shall be listed for their intended use.

5.7.1.2 The requirements of 5.7.1.1 shall not apply to valves used only for drains or test connections, which shall be permitted to be approved.

5.7.2 Compatibility. All gaskets, O-rings, sealants, and other valve components shall be constructed of materials that are compatible with the gas or water and any additives contained in the water.

5.7.3 Identification of Valves.

5.7.3.1 All control, drain, and test connection valves shall be provided with permanently marked, weatherproof, metal or rigid plastic identification signs.

5.7.3.2 The sign shall be secured with corrosion-resistant wire, chain, or other approved means.

5.8 Strainers and Filters.

5.8.1 Listing. A system strainer shall be provided downstream of each water supply system, water supply tank, pump, pipe section, fitting, valve, or other piping component having a wetted surface that does not have corrosion resistance equivalent to the materials given in Table 5.3.3.1 or Table 5.4.2.1.

5.8.2* Flow, Pressure, and Duration Sizing. The strainer or filter shall be sized for continuous operation at the required minimum flow and pressure, as verified by hydraulic calculations, for the minimum water supply duration.

5.8.3 Corrosion Resistance. Each system strainer shall have corrosion resistance equivalent to the materials given in Table 5.4.2.1.

5.8.4 Listing. Pipeline strainers and filters shall be listed for use in water supply connections.

5.8.5 Flush-Out Connection. Pipeline strainer and filter designs shall incorporate a flush-out connection.

5.8.6 Sizing. Pipeline strainers and filters shall be sized in accordance with 10.5.1.4, 10.5.1.5, and 10.5.1.6.

Table 5.6.7.1 Temperature Ratings, Classifications, and Color Coding of Individual, Thermally Activated Nozzles

Maximum Ambient Temperature		Nozzle Temperature Rating		Temperature Classification	Color Code	Glass Bulb Color
°C	°F	°C	°F			
38	100	57 to 77	135 to 170	Ordinary	Uncolored or black	Orange or red
66	150	79 to 107	175 to 225	Intermediate	White	Yellow or green
107	225	121 to 149	250 to 300	High	Blue	Blue
149	300	163 to 191	325 to 375	Extra high	Red	Purple
191	375	204 to 246	400 to 475	Very extra high	Green	Black
246	475	260 to 302	500 to 575	Ultra high	Orange	Black
329	625	343	650	Ultra high	Orange	Black

5.8.7 Nozzle Strainers and Filters. Individual strainers or filters for water mist nozzles, where required by the manufacturer, shall be listed as a part of a nozzle.

5.8.8 Spare Strainers and Filters.

5.8.8.1 Spare pipeline and individual nozzle strainers and filters for water mist nozzles, if replaceable, shall be provided and shall include all types and sizes installed.

5.8.8.2 Spare strainers and filters shall be provided to service the nozzles, if replaceable, for the largest single hazard or group of hazards to be protected simultaneously.

5.9 Pump Systems.

5.9.1 Pumps.

5.9.1.1 Installation Standard. Pumps for water mist systems shall be installed in accordance with NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*.

5.9.1.2 Capacity. Pumps shall be designed with capacities in accordance with 10.5.2.

5.9.1.3 Overpressure.

5.9.1.3.1 Pumps capable of overpressurizing the system shall be provided with an approved means of pressure relief to prevent an excessive increase in pressure and temperature.

5.9.1.3.2 Overpressure shall not exceed the working pressure of the piping system.

5.9.1.4 Automatic Start. Pumps shall start automatically upon system actuation.

5.9.1.5* Gauges. Where pump vibrations impact gauge performance, gauges shall be isolated to prevent damage.

5.9.1.6 Pump Information Plate. Pump installations shall have a metal plate that contains the following information:

- (1) Rated capacity and rated pressure of each pump
- (2) Capacity of pump assembly with all pumps operating
- (3) Capacity of individual unloader valve where there is one unloader valve per pump
- (4) Capacity of manifold unloader valve where there is one unloader for the entire pump assembly
- (5) Pressure setting for each individual unloader valve

5.9.1.7 Unloader Valves. Unloader valves shall be listed or approved as part of the pump assembly.

5.9.2 Power Supply.

5.9.2.1 Installation Standards. The power supply for pump drivers shall be installed in accordance with NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*; NFPA 70, *National Electrical Code*; and the manufacturer's listing.

5.9.2.2 Independent Service Feed. Power supplies for water mist system pumps shall not be required to be fed by an independent service feed to the building.

5.9.2.3 Arrangement. Power supplies for pumps shall be arranged so that if the power supply within the protected facility itself must be disconnected during a fire, the power supply to the pump feeder circuit will not be interrupted.

5.9.3 Controllers.

5.9.3.1 Listing. Controllers for pumps shall be listed fire pump controllers or listed limited-service controllers installed

in accordance with NFPA 20, *Standard for the Installation of Stationary Pumps for Fire Protection*.

5.9.3.2 Service-Disconnecting Means.

5.9.3.2.1 A service-disconnecting means in the feeder circuit to controllers shall be permitted where acceptable to the authority having jurisdiction, provided the disconnecting means is supervised in the proper position in accordance with 5.9.3.2.2.

5.9.3.2.2 Supervision for proper position shall be by one of the following methods:

- (1) Central station, proprietary, or remote station signaling service
- (2) Local electrical supervision through use of a signaling service that causes a supervisory signal at a constantly attended location
- (3) Locking of the disconnecting means in the proper position, with monthly recorded inspections

5.10 Detection, Actuation, Alarm, and Control Systems.

5.10.1 General.

5.10.1.1 Installation, Testing, and Maintenance Standards. Detection, actuation, alarm, and control systems shall be installed, tested, and maintained in accordance with the following protective signaling systems standards as applicable:

- (1) NFPA 70, *National Electrical Code*
- (2) NFPA 72, *National Fire Alarm and Signaling Code*
- (3) CAN/ULC S524-06, *Standard for the Installation of Fire Alarm Systems* (in Canada)
- (4) CAN/ULC S529-02, *Standard for Smoke Detectors for Fire Alarm Systems* (in Canada)

5.10.1.2 Automatic Systems. Unless the requirements of 5.10.1.3 are met, where a detection system is used to actuate the water mist system and additive system where used, detection and actuation shall be automatic.

5.10.1.3 Manual Systems. The requirements of 5.10.1.2 shall not apply to manual-only actuation systems where approved by the authority having jurisdiction.

5.10.2 Automatic Detection.

5.10.2.1* Listing. Automatic detection shall be by listed equipment installed in accordance with NFPA 72, *National Fire Alarm and Signaling Code*.

5.10.2.2 Primary and Standby Power. Adequate and reliable primary and 24-hour minimum standby sources of energy shall be used to provide for operation of the detection, signaling, control, and actuation requirements of the systems.

5.10.2.3 Existing Detection Systems. If an existing detection system is used in a new water mist system, the detection system shall comply with the requirements of this standard.

5.10.3 Operating Devices.

5.10.3.1 Devices. Operating devices shall include water mist releasing devices or valves, discharge controls, and shutdown equipment necessary for successful performance of the system.

5.10.3.2 Operating Methods. Operation shall be by listed mechanical, electrical, or pneumatic equipment. An adequate and reliable source of energy shall be used.

5.10.3.3 Service Conditions. Devices shall be designed for the service they are to encounter and shall not be rendered inoperative or susceptible to accidental operation.

5.10.3.4 Temperature Limitations. Devices shall be designed to function from -29°C to 54°C (-20°F to 130°F) or shall be marked to indicate temperature limitations.

5.10.3.5 Emergency Release Device.

5.10.3.5.1 An emergency release device for the system shall be provided.

5.10.3.5.2 The emergency release device shall be activated by a single manual operation.

5.10.3.5.3 This operation shall be accomplished by a mechanical manual release or by an electrical manual release when the control equipment that monitors the battery voltage level of the standby battery supply indicates a low battery signal.

5.10.3.5.4 The release shall cause simultaneous operation of automatically operated valves that control agent release and distribution.

5.10.3.5.5 Unless the requirements of 5.10.3.5.6 are met, the battery shall be sized to accomplish all functions.

5.10.3.5.6 The requirements of 5.10.3.5 shall not apply to dry and wet pipe systems utilizing individual, thermally activated nozzles.

5.10.3.6 Manual Release Device.

5.10.3.6.1 The manual release device(s) shall be located so as to be accessible at all times.

5.10.3.6.2 The manual release device(s) shall be of distinct appearance and clearly recognizable for the purpose intended.

5.10.3.6.3 Operation of any manual release device shall cause the system to operate in accordance with the design or listing.

5.10.3.6.4 The manual release device(s) shall not require a force of more than 178 N (40 lbf) nor a movement of more than 356 mm (14 in.) to cause activation.

5.10.3.6.5 At least one manual release device for activation shall be located not more than 1.2 m (4 ft) above the floor.

5.10.3.6.6 All devices for shutting down supplementary equipment shall be integral parts of the system and shall function with the system in operation.

5.10.3.6.7 All manual devices shall be identified as to the hazard they protect.

5.10.3.7* Supplementary Equipment and Interfaces. All devices for shutting down supplementary equipment or interface with other systems, necessary for effective operation of the water mist system, such as fuel shutoff and ventilation shutoff, shall be considered integral parts of the system and shall function with the system operation unless specifically permitted by the listing.

5.10.4 Control Equipment.

5.10.4.1 Electrical Control Equipment. Automatic control equipment shall be listed and installed in accordance with *NFPA 72, National Fire Alarm and Signaling Code*.

5.10.4.2 Listing. The control unit shall be listed for release device service.

5.10.4.3 Pneumatic Control Equipment.

5.10.4.3.1* Pneumatic control lines shall be protected against crimping and mechanical damage.

5.10.4.3.2 Unless the requirements of 5.10.4.3.3 or 5.10.4.3.4 are met, pneumatic control lines used to activate the system shall be supervised.

5.10.4.3.3 The requirements of 5.10.4.3.2 shall not apply to pneumatically operated control lines immediately adjacent to the pressurizing source.

5.10.4.3.4 The requirements of 5.10.4.3.2 shall not apply to pneumatic control lines from master to slave cylinders that are located in close proximity to one another.

5.10.4.3.5 The control equipment shall be specifically listed for the number and type of actuating devices utilized, and their compatibility shall have been listed.

5.11 Compatibility. All components of pneumatic, hydraulic, or electrical systems shall be compatible.

Chapter 6 System Requirements

6.1 General. Water mist systems shall be described by the following four parameters:

- (1) System application
- (2) Nozzle type
- (3) System operation method
- (4) System media type

6.2 System Applications. System applications shall consist of one of the following three categories:

- (1) Local-application systems
- (2) Total compartment application systems
- (3) Zoned application systems

6.2.1 Local-Application Systems. Local-application systems shall be designed and installed to provide complete distribution of mist on or around the hazard or object to be protected.

6.2.1.1 Local-application systems shall be designed to protect an object or a hazard in an enclosed, unenclosed, or open outdoor condition.

6.2.1.2 Local-application systems shall be actuated by automatic nozzles or by an independent detection system.

6.2.2 Total Compartment Application Systems.

6.2.2.1 Total compartment application systems are designed and installed to provide complete protection of an enclosure or space.

6.2.2.2* The complete protection of an enclosure or space shall be achieved by the simultaneous operation of all nozzles in the space by manual or automatic means.

6.2.3* Zoned Application Systems. Zoned application systems are a subset of the compartment system and are designed to protect a predetermined portion of the compartment by the activation of a selected group of nozzles.

6.2.3.1 Zoned application systems shall be designed and installed to provide complete mist distribution throughout a predetermined portion of an enclosure or space. This shall be achieved by simultaneous operation of a selected group of nozzles in a predetermined portion of the space by manual or automatic means.

6.2.3.2 Zoned application systems shall be actuated by automatic nozzles or by an independent detection system.



6.3 Nozzle Types. Water mist nozzles shall be classified as one of the following three types:

- (1) Automatic
- (2) Nonautomatic
- (3) Hybrid

6.4 System Requirements.

6.4.1 Deluge Systems.

6.4.1.1 Deluge systems shall employ nonautomatic nozzles (open) attached to a piping network connected to the fluid supply(ies) through a valve controlled by an independent detection system installed in the same area as the mist nozzles.

6.4.1.2 When the valve(s) is activated, the fluid shall flow into the piping network and discharge from all nozzles attached thereto.

6.4.2 Wet Pipe Systems. Wet pipe systems shall employ automatic nozzles attached to a piping network pressurized with water up to the nozzles.

6.4.3 Preaction Systems.

6.4.3.1 Preaction systems shall employ automatic nozzles attached to a piping network containing a pressurized gas with a supplemental, independent detection system installed in the same area as the nozzles.

6.4.3.2 Operation of the detection system shall actuate a tripping device that opens the valve, pressurizing the pipe network with water to the nozzles.

6.4.3.3 The pressurized piping in all preaction systems shall be supervised to ensure piping integrity.

6.4.4 Dry Pipe Systems.

6.4.4.1 Dry pipe systems shall employ automatic nozzles attached to a piping network containing a pressurized gas.

6.4.4.2 The loss of pressure in the piping network shall activate a control valve, which causes water to flow into the piping network and out through the activated nozzles.

6.5* Media System Types. Water mist systems shall be classified by two media system types:

- (1) Single fluid
- (2) Twin fluid

6.6 Additive Systems. The additive manufacturer or system provider shall be consulted and performance specifications shall be provided to ensure proper operation and reliability. Where additives are used to enhance fire performance, system proportioning accuracy shall comply with the appropriate standards.

7.1.4 Mechanical and Chemical Damage. System components shall be located, installed, or suitably protected so they are not subject to mechanical, chemical, or other damage that could render them inoperative.

7.1.5 Installation and Testing Procedures. Manufacturers shall provide installation and testing procedures to ensure that the system is installed and will operate as intended.

7.2 Nozzles.

7.2.1 General. Nozzles shall be installed in accordance with the manufacturer's listing.

7.2.2 Nozzle Height Limitations. The minimum and maximum heights shall be in accordance with the manufacturer's listing.

7.2.3 Nozzle Spacing Limitations. The minimum and maximum distances between nozzles shall be in accordance with the manufacturer's listing.

7.2.4 Distance from Walls. The minimum and maximum distance from nozzles to walls or partitions shall be in accordance with the manufacturer's listing.

7.2.5* Obstructions to Nozzle Discharge. The location of nozzles with respect to continuous or discontinuous obstructions shall be in accordance with the manufacturer's listing.

7.2.6 Distance Below Ceilings. The distance between the nozzle and the ceiling shall be in accordance with the range (minimum and maximum) identified in the manufacturer's listing.

7.2.7 Spacing Under Pitched or Curved Surfaces. The distance between nozzles in or under a pitched or curved surface shall be in accordance with the manufacturer's listing.

7.2.8 Nozzle Protection.

7.2.8.1 Nozzles subject to mechanical damage shall be protected with listed guards.

7.2.8.2 Guards shall not significantly reduce the effectiveness of the nozzle.

7.2.9 Escutcheons and Cover Plates.

7.2.9.1 Escutcheons used in a recessed or flush-type nozzle installation shall be a part of a listed nozzle assembly.

7.2.9.2 Nonmetallic escutcheons shall be listed.

7.2.9.3 Cover plates used with concealed nozzles shall be part of the listed assembly.

7.2.10 Thermally Activated Nozzle Temperature Ratings.

7.2.10.1 Temperature ratings shall be selected as follows:

- (1) Where the maximum ceiling temperature does not exceed 38°C (100°F), ordinary temperature nozzles shall be permitted to be used throughout.
- (2) Where maximum ceiling temperatures exceed 38°C (100°F), nozzles with temperature ratings in accordance with the maximum ambient temperatures of Table 5.6.7.1 shall be used.
- (3) High temperature nozzles shall be permitted to be used throughout.
- (4) Where high temperature nozzles are not utilized throughout, nozzles of intermediate and high temperature classifications shall be installed in specific locations as required by 7.2.10.2.

Chapter 7 Installation Requirements

7.1 General. This chapter provides requirements for the installation of water mist system components.

7.1.1 Listing. Listed materials and devices shall be installed in accordance with their listing.


7.1.2 System Design Manual. Materials and devices shall be installed in accordance with the system design manual.

7.1.3 Corrosive Environments. Systems installed in corrosive environments shall comply with 5.1.3.

7.2.10.2 The following practices shall be observed to provide nozzles of other than ordinary temperature classification unless other temperatures are determined or unless high temperature nozzles are used throughout. [See Figure 7.2.10.2, Table 7.2.10.2(a), and Table 7.2.10.2(b).]

- (1) Nozzles in the high temperature zone shall be of the high temperature classification, and nozzles in the intermediate temperature zone of the intermediate temperature classification.
- (2) Nozzles located within 305 mm (12 in.) to one side or 762 mm (30 in.) above an uncovered steam main, heating coil, or radiator shall be of the intermediate temperature classification.
- (3) Nozzles within 2.1 m (7 ft) of a low pressure blowoff valve that discharges free in a large room shall be of the high temperature classification.
- (4) Nozzles under glass or plastic skylights exposed to the direct rays of the sun shall be of the intermediate temperature classification.
- (5) Nozzles in an unventilated, concealed space, under an uninsulated roof, or in an unventilated attic shall be of the intermediate temperature classification.
- (6) Nozzles in unventilated show windows having high-powered electric lights near the ceiling shall be of the intermediate temperature classification.
- (7) Nozzles protecting commercial-type cooking equipment and ventilation systems shall be of the high or extra high temperature classification as determined by use of a temperature measuring device.

7.2.10.3 In case of occupancy change involving temperature change, the nozzles shall be changed accordingly.



For U.S. units: 1 m = 3.23 ft

FIGURE 7.2.10.2 High Temperature and Intermediate Temperature Zones at Unit Heaters.

7.3 Pipe and Tubing.

7.3.1 Installation Manual. Piping and tubing for water mist systems shall be installed in accordance with the manufacturer's installation manual.

7.3.2 Installation Standards. All water and atomizing media piping and tubing for water mist systems shall be installed in accordance with one of the following:

- (1) ASME B31.1, *Power Piping Code*
- (2) Water piping only, in low-pressure systems installed in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*
- (3) Piping installed in accordance with a water mist system listing where the listing provides installation criteria different from ASME B31.1, *Power Piping Code*

7.3.3 Pressure Rating. All system piping, tubing, and hose shall be rated for the maximum working pressure to which they are exposed.

7.3.4 Listing. Any flexible piping, tubing, hose, or combination thereof shall be constructed and installed in accordance with the manufacturer's listing.

7.3.5 Piping Support.

7.3.5.1 The system piping shall be supported by structural elements that are independent of the ceiling sheathing to prevent lateral and horizontal movement upon system actuation.

7.3.5.2 Tube hangers shall be spaced in accordance with Table 7.3.5.2.

7.3.6 System Drainage. All system piping and fittings shall be installed so that the entire system can be drained.

7.3.7 Location of Hangers and Supports.

7.3.7.1 Hangers and supports shall be located in accordance with the requirements contained within the system's design manual.

7.3.7.2 For low pressure and intermediate systems, steel pipe and copper tubing shall be supported in accordance with NFPA 13, *Standard for the Installation of Sprinkler Systems*.

7.3.7.3 The length of an unsupported arm over to a nozzle shall not exceed 0.6 m (2 ft) for steel pipe or 0.3 m (1 ft) for steel tubing.

7.3.8* Protection of System Components Against Damage Where Subject to Earthquakes. Where subject to earthquakes, water mist systems shall be protected to prevent pipe breakage in accordance with the seismic requirements of NFPA 13, *Standard for the Installation of Sprinkler Systems*.

7.4 Fittings.

7.4.1 Listing. All system fittings shall be installed in accordance with the manufacturer's listing.

7.4.2 Low Pressure Systems. In addition to the requirements of 7.4.1, all fittings installed in low pressure water mist systems shall conform to NFPA 13, *Standard for the Installation of Sprinkler Systems*.

7.4.3 Pressure Rating. All fittings shall be rated for the maximum working pressure to which they are exposed.

7.5 Gas and Water Storage Containers.

7.5.1 Listing. Storage containers shall be installed, mounted, and braced in accordance with the manufacturer's listing.



Table 7.2.10.2(a) Temperature Ratings of Nozzles Based on Distance from Heat Sources

Type of Heat Condition	Ordinary Degree Rating	Intermediate Degree Rating	High Degree Rating
1. Heating ducts			
(a) Above	More than 775 mm (2 ft 6 in.)	775 mm (2 ft 6 in.) or less	
(b) Side and below	More than 310 mm (1 ft 0 in.)	310 mm (1 ft 0 in.) or less	
(c) Diffuser	Any distance except as shown in Intermediate Degree Rating column	<i>Downward discharge:</i> Cylinder with 310 mm (1 ft 0 in.) radius from edge, extending 310 mm (1 ft 0 in.) below and 775 mm (2 ft 6 in.) above <i>Horizontal discharge:</i> Semi-cylinder with 775 mm (2 ft 6 in.) radius in direction of flow, extending 310 mm (1 ft 0 in.) below and 775 mm (2 ft 6 in.) above	
2. Unit heater			
(a) Horizontal discharge		<i>Discharge side:</i> 2.2 m to 6.2 m (7 ft 0 in. to 20 ft 0 in.) radius pie-shaped cylinder (<i>see Figure 7.2.10.2</i>) extending 2.2 m (7 ft 0 in.) above and 620 mm (2 ft 0 in.) below heater; also 2.2 m (7 ft 0 in.) radius cylinder more than 2.2 m (7 ft 0 in.) above unit heater	2.2 m (7 ft 0 in.) radius cylinder extending 2.2 m (7 ft 0 in.) above and 620 mm (2 ft 0 in.) below unit heater
(b) Vertical downward discharge		2.2 m (7 ft 0 in.) radius cylinder extending upward from an elevation 2.2 m (7 ft 0 in.) above unit heater	2.2 m (7 ft 0 in.) radius cylinder extending from the top of the unit heater to an elevation 2.2 m (7 ft 0 in.) above unit heater
3. Steam mains (uncovered)			
(a) Above	More than 775 mm (2 ft 6 in.)	775 mm (2 ft 6 in.) or less	
(b) Side and below	More than 310 mm (1 ft 0 in.)	310 mm (1 ft 0 in.) or less	
(c) Blowoff valve	More than 2.2 m (7 ft 0 in.)		2.2 m (7 ft 0 in.) or less

Table 7.2.10.2(b) Ratings of Nozzles in Specified Locations

Location	Ordinary Degree Rating	Intermediate Degree Rating	High Degree Rating
Skylights		Glass or plastic	
Attics	Ventilated	Unventilated	
Peaked roof: Metal or thin boards, concealed or not concealed, insulated or uninsulated	Ventilated	Unventilated	
Flat roof: Metal, concealed, insulated or uninsulated	Ventilated or unventilated	Note: For uninsulated roof, climate and occupancy could necessitate intermediate nozzles. Check on job.	
Flat roof: Metal, concealed, insulated or uninsulated	Ventilated		
Show windows	Ventilated		
		Unventilated	

Table 7.3.5.2 Tube Hanger Maximum Spacing

Tube O.D.		Maximum Distance Between Hangers	
mm	in.	m	ft
6-14	¼, ⅜, ½	1.21	4.0
15-22	¾-7/8	1.52	5.0
23-28	1	1.82	6.0
30-38	1¼-1½	2.12	7.0
40-49		2.42	8.0
50-59		3.00	10.0
60-70		3.33	11.0
71-89		3.64	12.0
90-108		3.94	13.0

7.5.2 Accessibility. Storage containers and accessories shall be installed so that inspection, testing, recharging, and other maintenance are facilitated and interruption to protection is held to a minimum.

7.5.3* Location. Storage containers shall be located as close as possible to the hazard or within the hazards they protect and shall not be exposed to fire or mechanical damage in a manner that affects performance.

7.5.4 Damage. Storage containers shall be protected from severe weather conditions and from mechanical, chemical, or other damage.

7.5.5 High Pressure Storage Containers.

7.5.5.1 Standards. High pressure containers or cylinders shall be constructed, tested, and marked in accordance with recognized international standards, such as the U.S. Department of Transportation, 49 CFR, 171-190, 178.36-178.37, specifications (in effect upon date of manufacture and test) for DOT-3A, 3AA-1800, or higher seamless steel cylinders.

7.5.5.2 Preshipping Testing. Charged cylinders shall be tested for tightness before shipment in accordance with an approved procedure.

7.5.5.3 Manifolded Cylinders.

7.5.5.3.1 Where manifolded, cylinders shall be mounted and supported in a rack provided for this purpose, including facilities for convenient, individual servicing or weighing of contents.

7.5.5.3.2 When any cylinder is removed for maintenance, automatic means shall be provided to prevent leakage from the manifold if the system is operated.

7.5.5.4 Storage Temperatures.

7.5.5.4.1 Storage temperatures shall be maintained within the range specified in the manufacturer's listing.

7.5.5.4.2 External heating or cooling shall be an approved method to keep the temperature of the storage container within desired ranges.

7.5.5.5 Container Securement. Containers shall be secured with manufacturer-listed supports to prevent container movement and possible physical damage.

7.5.6 Intermediate and Low Pressure Storage Cylinders.

7.5.6.1 Unless the requirements of 7.5.6.3 are met, the pressure container shall be made, tested, approved, equipped, and marked in accordance with the current specifications of the ASME *Boiler and Pressure Vessel Code*, Section VIII, or the requirements of U.S. Department of Transportation, 49 CFR, 171-190, 178.36-178.37, or other approved international standards.

7.5.6.2 The design working pressure shall be in accordance with the manufacturer's listing.

7.5.6.3 The requirements of 7.5.6.1 shall not apply to pressure containers for heated water mist systems, which shall be in accordance with the manufacturer's listing.

7.5.6.4 Each pressure container shall be equipped with a liquid level gauge, a pressure gauge, and a high/low pressure supervisory alarm set at the values identified in the manufacturer's listing.

7.5.6.5 Media storage containers that become pressurized only during system activation shall not require high/low pressure supervisory alarms.

7.5.6.6 Storage Temperature.

7.5.6.6.1 Storage temperatures shall be maintained within the range specified in the manufacturer's listing.

7.5.6.6.2 External heating or cooling shall be an approved method to keep the temperature of the storage container within desired ranges.

7.5.6.7 Securement. Containers shall be secured with manufacturer-listed supports to prevent container movement and possible physical damage.

7.6 Pumps and Pump Controllers.

7.6.1* Sizing. Pumps shall be sized to meet the required system water flow rate, at the minimum system pressure, as determined by hydraulic calculations.

7.6.2 Automatic Start. Pumps shall start automatically and shall supply water to the water mist system until manually shut off or automatically shut off in accordance with the manufacturer's listing.

7.6.3 Supervisory Service. Unless the requirements of 7.6.4 are met, pumps shall be provided with supervisory service from a listed central station, proprietary, or remote station system or equivalent.

7.6.4 Single Family Dwellings. The requirements of 7.6.3 shall not apply to pumps for single-family dwellings.

7.6.5 Test Fittings or Hose Outlets. Pumps shall be equipped with a test fitting or hose outlet on the discharge side of the pump to facilitate the annual full-flow pump test required in Table A.13.2.2.

7.7 Strainers and Filters.

7.7.1 Location. Strainers and filters shall be provided at all water supply connections in accordance with Chapter 10.

7.7.2 Installation. Filters and strainers shall be installed to minimize potential head loss due to accumulation of particulates.



7.8 Valves and Pressure Gauges.

7.8.1 General.

7.8.1.1 All valves shall be installed in accordance with the manufacturer's listing.

7.8.1.2 Valves having components that extend beyond the valve body shall be installed in a manner that does not interfere with the operation of any system components.

7.8.1.3 All valves shall be listed for their particular application and installation.

7.8.1.4 Valves forming part of a listed system shall not be required to be individually listed.

7.8.1.5 Valve Identification.

7.8.1.5.1 All control, drain, and test connection valves shall be provided with permanently marked, weatherproof, metal or rigid plastic identification signs.

7.8.1.5.2 The sign shall be secured by corrosion-resistant wire or chain or by other approved means.

7.8.1.6 Valve Accessibility. System valves and gauges shall be installed such that they are accessible for operation, inspection, and maintenance.

7.8.1.7 Indicating Valves.

7.8.1.7.1 Unless the requirements of 7.8.1.7.2 are met, at least one listed indicating valve shall be installed in each source of water supply.

7.8.1.7.2 The requirements of 7.8.1.7 shall not apply to systems with a single water supply source comprised of a self-contained system (cylinders, containers).

7.8.1.8 Valve Supervision.

7.8.1.8.1 Valves on connections to water supplies, sectional control and isolation valves, and other valves in supply pipes to nozzles and other fixed water-based fire suppression systems shall be supervised by one of the following methods:

- (1) Central station, proprietary, or remote station signaling service
- (2) Local signaling service that will cause the sounding of an audible signal at a constantly attended point
- (3) Valves locked in the correct position
- (4) Valves located within fenced enclosures under the control of the owner, sealed in the open position, and inspected weekly as part of an approved procedure

7.8.1.8.2 Valves controlling manual system activation shall not be locked and shall be supervised in accordance with 7.8.1.8.1(1), 7.8.1.8.1(2), or 7.8.1.8.1(3).

7.8.2 Control and Activation Valves.

7.8.2.1 Control and activation valves shall include any device or valve that automatically opens to supply water to the nozzles after the detection of a fire.

7.8.2.2 Control and activation valves shall operate by an approved mechanical, electrical, or pneumatic means.

7.8.2.3 Control and activation valves shall be installed such that they are not subject to mechanical, chemical, or other damage that would render them inoperative.

7.8.3 Pressure Regulating and Pressure Relief Valves.

7.8.3.1 Water Pressure Regulating Valves.

7.8.3.1.1 Pressure regulating valves shall be installed in any portion of the system where the potential exists for the system pressure to exceed the maximum-rated working pressure of the system or system components, or both.

7.8.3.1.2 These valves shall open when the system pressure reaches 95 percent of the system-rated pressure.

7.8.3.1.3 A relief valve of not less than 13 mm (½ in.) shall be provided on the discharge side of the pressure regulating valve that is set to operate at a pressure not exceeding the system-rated pressure.

7.8.3.1.4 Unless the requirements of 7.8.3.1.5 are met, a listed indicating valve shall be provided on the inlet side of each pressure reducing valve.

7.8.3.1.5 The requirements of 7.8.3.1.4 shall not apply where the pressure regulating valve meets the listing requirements for use as an indicating valve.

7.8.3.1.6 A waterflow test valve that is sized to produce the designed flow of the pressure reducing valve shall be installed on the downstream side of the pressure reducing valve.

7.8.3.1.7 A sign indicating the correct discharge pressure for static and residual pressures shall be attached to the pressure reducing valve.

7.8.3.2 Compressed Gas Pressure Regulating Valves (PRVs).

7.8.3.2.1 PRVs shall be installed in accordance with the manufacturer's listing.

7.8.3.2.2 PRVs shall be installed when the supply pressure is higher than the design operating pressure of the water mist system.

7.8.3.2.3 PRVs shall be capable of providing a stable regulating output at the rated flow capacity and design set point over the full range of input pressures that will be experienced over the course of the discharge period.

7.8.3.2.4 Downstream pressure drift under no-flow conditions shall not exceed the lesser of the downstream components' pressure rating or the pressure relief valve set point, if provided.

7.8.3.2.5 Pressure set, point-adjusting mechanisms on the PRVs shall be tamper resistant, and the adjustment shall be indicated by a permanent marking.

7.8.3.2.6 A means to indicate evidence of tampering shall be provided.

7.8.3.2.7 The PRVs' set point shall be set by the manufacturer.

7.8.3.2.8 Permanent markings shall indicate the inlet and outlet connections of the PRVs.

7.8.4 Check Valves and Backflow Preventers.

7.8.4.1 Check valves shall be installed in accordance with the manufacturer's listing.

7.8.4.2 A check valve shall be installed between the system and the point of permanent connection to a potable water supply.

7.8.4.3 Where additives are used in the water mist system, either by injection into flowing lines or by premixing into stored water sources, a backflow preventer shall be installed between the system control valve or stored water supply and a permanent connection to a potable water supply.

7.8.4.4 Check valves shall be installed in the main feed lines, near the control valves of both the water and pneumatic system piping of a twin-fluid system, to prevent the backflow of water or atomizing fluid into the companion piping.

7.8.4.4.1 Where the water and atomizing fluid are separated by an air gap, check valves shall be permitted to be omitted.

7.8.5 Pressure Gauges.

7.8.5.1 Pressure gauges shall be installed in the following locations:

- (1) On both sides of a pressure regulating valve
- (2) On the pressurized side of all supply connections
- (3) On the pressurized side of all system control valves
- (4) On all pressurized storage containers
- (5) On all air supplies for dry pipe and preaction systems
- (6) When multiple gas cylinders are employed with their individual cylinder valves sealed or supervised in the open position and connected to a pressurized manifold, a single pressure gauge on the pressurized section of the manifold shall be permitted for indicating the pressure in all the gas cylinders.

7.8.5.2 The required pressure gauges shall be compatible with their intended use and shall have an operating range not less than twice the working pressure of the system.

7.9 Electrical Systems.

7.9.1 Electrical Equipment.

7.9.1.1 Electrical equipment associated with water mist systems shall be installed in accordance with the requirements of *NFPA 70, National Electrical Code*.

7.9.1.2* All signaling system circuits and wiring shall be installed in accordance with *NFPA 72, National Fire Alarm and Signaling Code*.

7.9.1.3* All signaling line circuits and wiring shall be installed in accordance with *NFPA 72, National Fire Alarm and Signaling Code*, Style 6.

7.9.2 Control Equipment.

7.9.2.1 Installation Standards. Electrical fire detection and control equipment used to activate water mist systems shall be installed in accordance with the following:

- (1) *NFPA 70, National Electrical Code*
- (2) *NFPA 72, National Fire Alarm and Signaling Code*
- (3) Other approved, recognized standards and the manufacturer's recommendations

7.9.2.2 Supervision. All circuitry that is monitoring or controlling the water mist system shall be electrically supervised in accordance with *NFPA 72, National Fire Alarm and Signaling Code*.

7.9.2.3 Primary and Standby Power. Approved primary and 24-hour minimum standby sources of energy shall be used to provide for the operation of the detection, signaling, control, and actuation requirements of the system.

7.9.2.4 Alarms.

7.9.2.4.1 Alarms shall be provided to indicate system water-flow and system trouble.

7.9.2.4.2 Trouble and supervisory signals shall include power failure, operation (closing) of monitored valving, and electrical faults in the detection/activation of pump power control systems.

7.9.2.4.3 These alarms shall be both visible and audible inside the protected space, at the location of the primary system components (e.g., pumps, storage tanks), and in a continuously attended location.

7.9.2.4.4 The system activation alarm shall be distinctly different from the system trouble signal to prevent confusion.

7.9.3 Fire Detection.

7.9.3.1* Where electrically operated automatic fire detection systems are used, the installation shall be in accordance with *NFPA 72, National Fire Alarm and Signaling Code*.

7.9.3.2 Approved primary and 24-hour minimum standby sources of energy shall be used to provide for operation of the detection, signaling, control, and actuation requirements of the system.

7.9.3.3 Where a new water mist system is installed in a space that has an existing detection system, an analysis shall be made of the detection devices to ensure that the detection system meets the requirements of the water mist system listing and that the detection system is in operating condition.

7.9.4 Automatic and Manual Activation.

7.9.4.1 Unless the requirements of 7.9.4.2 are met, a means of automatic operation of the water mist system shall be provided.

7.9.4.1.1 Automatic operation shall be accomplished by means of automatic nozzles (independently thermally activated), automatic group control valves, or an independent automatic fire detection system, coupled with a listed system activation panel.

7.9.4.2 The requirements of 7.9.4.1 shall not apply to manual-only actuation systems where approved by the authority having jurisdiction.

7.9.4.3 A means of manual release of the system shall be installed and arranged in accordance with 5.10.3.

7.10 Test Connections.

7.10.1* A test connection shall be provided at the most hydraulically remote point on the water mist system.

7.10.2 The inside diameter shall not be less than the largest orifice diameter used in the water mist system.

7.10.3 Discharge from the test connection shall be piped to a safe discharge location.

7.10.4 Where occupancy conditions prohibit water from being discharged from the most hydraulically remote point, a test connection shall be provided immediately upstream of each hazard area protected.

Chapter 8 Design Objectives and Fire Test Protocols

8.1* General.

8.1.1 Listing. Water mist protection systems shall be designed and installed for the specific hazards and protection objectives specified in the listing.

