

NFPA 91

Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Noncombustible Particulate Solids

2004 Edition



NFPA, 1 Batterymarch Park, Quincy, MA 02169-7471
An International Codes and Standards Organization

IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA DOCUMENTS

NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA DOCUMENTS

NFPA codes, standards, recommended practices, and guides, of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in its codes and standards.

The NFPA disclaims liability for any personal injury, property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making this document available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the NFPA list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

ADDITIONAL NOTICES AND DISCLAIMERS

Updating of NFPA Documents

Users of NFPA codes, standards, recommended practices, and guides should be aware that these documents may be superseded at any time by the issuance of new editions or may be amended from time to time through the issuance of Tentative Interim Amendments. An official NFPA document at any point in time consists of the current edition of the document together with any Tentative Interim Amendments and any Errata then in effect. In order to determine whether a given document is the current edition and whether it has been amended through the issuance of Tentative Interim Amendments or corrected through the issuance of Errata, consult appropriate NFPA publications such as the National Fire Codes® Subscription Service, visit the NFPA website at www.nfpa.org, or contact the NFPA at the address listed below.

Interpretations of NFPA Documents

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing Committee Projects shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights asserted in connection with any items which are mentioned in or are the subject of NFPA codes, standards, recommended practices, and guides, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on these documents. Users of these documents are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

NFPA adheres to applicable policies of the American National Standards Institute with respect to patents. For further information contact the NFPA at the address listed below.

Law and Regulations

Users of these documents should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

This document is copyrighted by the NFPA. It is made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making this document available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to this document.

Use of NFPA documents for regulatory purposes should be accomplished through adoption by reference. The term “adoption by reference” means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA documents, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA codes, standards, recommended practices, and guides and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA documents during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

For more information about NFPA, visit the NFPA website at www.nfpa.org.

Copyright © 2004, National Fire Protection Association, All Rights Reserved

NFPA 91

Standard for

Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Noncombustible Particulate Solids

2004 Edition

This edition of NFPA 91, *Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Noncombustible Particulate Solids*, was prepared by the Technical Committee on Handling and Conveying of Dusts, Vapors, and Gases and acted on by NFPA at its May Association Technical Meeting held May 23–26, 2004, in Salt Lake City, UT. It was issued by the Standards Council on July 16, 2004, with an effective date of August 5, 2004, and supersedes all previous editions.

This edition of NFPA 91 was approved as an American National Standard on August 5, 2004.

Origin and Development of NFPA 91

The National Fire Protection Association as early as 1899 recognized the hazards of blower and exhaust systems. Since 1900, the NFPA Committee on Blower Systems has given continuing attention to the subject. Following World War II, revisions and additions to the standard were recommended by the NFPA Committee on Blower Systems to cover various new developments in the protection of dust collecting systems and stock and refuse conveying systems, and were adopted by the NFPA at its Annual Meetings in 1946, 1947, 1948, and 1949. Editorially revised editions were published in 1959 and 1961. In 1972, Section 200 (Chapter 2) was expanded, and a new Section 500 (Chapter 5), covering systems involving plastic materials, was added. In the 1973 edition, Section 400 (Chapter 4) was completely revised. The 1983 edition was completely updated to conform with the NFPA *Manual of Style* and incorporated minor revisions in each chapter.

The 1990 edition included minor revisions to Chapter 2 including a new Figure 2-8 and Table 2-8(b). Changes were made to recognize NFPA 45, *Standard on Fire Protection for Laboratories Using Chemicals*, and to remove conflicts with that standard. These changes included moving Section 5-2 and Figures 5-2 through 5-5 to Appendix A.

The Technical Committee on Blower Systems completely revised the standard for the 1992 edition, including a new title and new scope. The previous title was *Standard for the Installation of Blower and Exhaust Systems for Dust, Stock, and Vapor Removal or Conveying*. Chapters 3 and 4 from the 1990 edition were deleted with some requirements from those chapters included in the revised and reorganized Chapter 2 and new Chapters 5, 6, and 7.

Minor changes were made to all chapters in the 1995 edition. The Committee clarified their intent that ducts can be round, oval, or rectangular. A new figure was added to show access openings for different shapes of ducts, and a new table was added in the appendix to show duct velocities for types of materials conveyed.

The 1999 edition incorporated a new scope limiting the applicability of this document to noncombustible particulate solids. The Committee on Handling and Conveying of Dusts, Vapors, and Gases became responsible for NFPA 91 and made changes consistent with the committee's other documents, NFPA 650, *Standard for Pneumatic Conveying Systems for Handling Combustible Particulate Solids*, and NFPA 654, *Standard for the Prevention of Fire and Dust Explosions from the Manufacturing, Processing, and Handling of Combustible Particulate Solids*, that address combustible particulate solids.

In the 2004 revision, the Committee has completed changes according to the NFPA *Manual of Style*. The conditions under which flammable concentrations can exceed 25 percent of the lower flammable limit have been expanded to match provisions in other NFPA documents. The design requirements for duct hanging and bracing and fire protection requirements for ducting have also been updated.

Technical Committee on Handling and Conveying of Dusts, Vapors, and Gases

Walter L. Frank, Chair
ABS Consulting Group, DE [SE]

Joe R. Barton, Fountaintown, IN [U]
Paul A. Cera, Aon Risk Services, CT [I]
John M. Cholin, J. M. Cholin Consultants Inc., NJ [SE]
David G. Clark, E. I. du Pont de Nemours & Company, DE [U]
C. James Dahn, Safety Consulting Engineers, Inc., IL [SE]
Vahid Ebadat, Chilworth Technology Inc., NJ [SE]
Henry L. Febo, Jr., FM Global Research, MA [I]
Rep. FM Global/FM Research
Henry W. Garzia, Kidde-Fenwal, Inc., MA [M]
Joseph P. Gillis, Westboro, MA [SE]
Dan A. Guaricci, ATEX Explosion Protection L.P., FL [M]
Ray Hunter, Ray Hunter & Associates Inc., AL [M]
Rep. American Air Filter
Jerry J. Jennett, Georgia Gulf Sulfur Corporation, GA [M]
David C. Kirby, Baker Engineering & Risk Consultants, WV [SE]

James E. Maness, JEM Safety Consulting, MO [U]
Rep. Grain Elevator and Processing Society
Guillermo A. Navas, Sheet Metal and Air Conditioning Contractors' National Association, VA [M]
Rep. Sheet Metal and Air Conditioning Contractors' National Association
Robert W. Nelson, Pocasset, MA [I]
Rep. GE Global Asset Protection Services
James L. Roberts, Fluor Enterprises, Inc., SC [SE]
Richard F. Schwab, Honeywell, Inc., NJ [U]
Bill Stevenson, Cv Technology, Inc., FL [M]
Jeffrey J. Wanko, DSM Nutritional Products, Inc., NJ [U]
Harold H. Weber, Jr., The Sulphur Institute, DC [U]
(Vote Limited to NFPA 655)
W. H. White, White Consulting Services, OH [SE]
Rep. TC on Finishing Processes

Alternates

Ted Brown, International Sulphur, Inc., TX [M]
(Alt. to J. J. Jennett)
Paul F. Hart, GE Global Asset Protection Services, IL [I]
(Alt. to R. W. Nelson)
Gregory I. Hurst, National Starch & Chemical Company, IN [U]
(Alt. to J. R. Barton)

Bernadette N. Reyes, Safety Consulting Engineers, Inc., IL [SE]
(Alt. to C. J. Dahn)
Samuel A. Rodgers, Honeywell, Inc., VA [U]
(Alt. to R. F. Schwab)

Nonvoting

Harry Verakis, U.S. Department of Labor, WV

Guy R. Colonna, NFPA Staff Liaison

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on the prevention, control, and extinguishment of fires and explosions in the design, construction, installation, operation, and maintenance of facilities and systems processing or conveying flammable or combustible dusts, gases, vapors, and mists.

Contents

Chapter 1 Administration	91- 4	6.5 Maintenance and Inspection	91- 9
1.1 Scope	91- 4	6.6 Location	91- 9
1.2 Purpose	91- 4	6.7 Flexible Connections	91- 9
1.3 Retroactivity	91- 4		
1.4 Equivalency	91- 4	Chapter 7 Ignition Sources	91- 9
Chapter 2 Referenced Publications	91- 4	7.1 Electrical Equipment	91- 9
2.1 General	91- 4	7.2 Static Electricity	91- 9
2.2 NFPA Publications	91- 4	7.3 Manifolds	91- 9
2.3 Other Publications	91- 4	7.4 Open Flames and Sparks	91- 9
Chapter 3 Definitions	91- 4	7.5 Removal of Ferrous Materials	91- 9
3.1 General	91- 4	7.6 Belt Drives	91- 9
3.2 NFPA Official Definitions	91- 4	7.7 Bearings	91- 9
3.3 General Definitions	91- 5	7.8 Equipment	91- 9
Chapter 4 Design and Construction	91- 5	Chapter 8 Fire Protection	91- 9
4.1 General Requirements	91- 5	8.1 General	91- 9
4.2 Duct Material and Construction	91- 6	8.2 Drainage	91- 9
4.3 Access	91- 6	8.3 Testing and Inspection	91- 9
4.4 Design Requirements	91- 6	Chapter 9 Testing and Maintenance	91- 9
4.5 Hangers and Supports	91- 7	9.1 General	91- 9
4.6 Duct Installation	91- 7	9.2 System Test	91- 9
Chapter 5 Corrosive Materials	91- 8	9.3 System Inspection	91-10
5.1 General	91- 8	9.4 Cleanliness	91-10
Chapter 6 Air-Moving Devices	91- 8	9.5 Maintenance Program	91-10
6.1 General	91- 8	9.6 Maintenance Log	91-10
6.2 Flammable or Combustible Materials	91- 8	Annex A Explanatory Material	91-10
6.3 Clearance	91- 8	Annex B Informational References	91-13
6.4 Alignment	91- 9	Index	91-14

NFPA 91**Standard for****Exhaust Systems for Air Conveying
of Vapors, Gases, Mists,
and Noncombustible Particulate Solids****2004 Edition**

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Documents." They can also be obtained on request from NFPA or viewed at www.nfpa.org/disclaimers.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for mandatory extracts are given in Chapter 2 and those for nonmandatory extracts are given in Annex B. Editorial changes to extracted material consist of revising references to an appropriate division in this document or the inclusion of the document number with the division number when the reference is to the original document. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex B.

Chapter 1 Administration**1.1* Scope.**

1.1.1 This standard provides minimum requirements for the design, construction, installation, operation, testing, and maintenance of exhaust systems for air conveying of vapors, gases, mists, and noncombustible particulate solids except as modified or amplified by other applicable NFPA standards.

1.1.2 This standard does not cover exhaust systems for conveying combustible particulate solids that are covered in other NFPA standards (*see A.1.1*).

1.2 Purpose. The purpose of this standard is to provide technical requirements for exhaust systems that will achieve the following results:

- (1) Provide safety to life and property from fires and explosions
- (2) Minimize the damage in the event that such fires and explosions occur

1.3 Retroactivity. The provisions of this standard reflect a consensus of what is necessary to provide an acceptable degree of protection from the hazards addressed in this standard at the time the standard was issued.

1.3.1 Unless otherwise specified, the provisions of this standard shall not apply to facilities, equipment, structures, or installations that existed or were approved for construction or installation prior to the effective date of the standard. Where specified, the provisions of this standard shall be retroactive.

1.3.2 In those cases where the authority having jurisdiction determines that the existing situation presents an unacceptable degree of risk, the authority having jurisdiction shall be permitted to apply retroactively any portions of this standard deemed appropriate.

1.3.3 The retroactive requirements of this standard shall be permitted to be modified if their application clearly would be impractical in the judgment of the authority having jurisdiction, and only where it is clearly evident that a reasonable degree of safety is provided.

1.4 Equivalency. Nothing in this standard is intended to prevent the use of systems, methods, or devices of equivalent or superior quality, strength, fire resistance, effectiveness, durability, and safety over those prescribed by this standard.

1.4.1 Technical documentation shall be submitted to the authority having jurisdiction to demonstrate equivalency.

1.4.2 The system, method, or device shall be approved for the intended purpose by the authority having jurisdiction.

Chapter 2 Referenced Publications

2.1 General. The documents or portions thereof listed in this chapter are referenced within this standard and shall be considered part of the requirements of this document.

2.2 NFPA Publications. National Fire Protection Association, 1 Batterymarch Park, Quincy, MA 02169-7471.

NFPA 25, *Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems*, 2002 edition.

NFPA 51B, *Standard for Fire Prevention During Welding, Cutting, and Other Hot Work*, 2003 edition.

NFPA 69, *Standard on Explosion Prevention Systems*, 2002 edition.

NFPA 70, *National Electrical Code*®, 2005 edition.

NFPA 86, *Standard for Ovens and Furnaces*, 2003 edition.

NFPA 221, *Standard for Fire Walls and Fire Barrier Walls*, 2000 edition.

2.3 Other Publications.

2.3.1 SMACNA Publications. Sheet Metal and Air Conditioning Contractors' National Association, 4201 Lafayette Center Drive, Chantilly, VA 20151-1209.

Accepted Industry Practice for Industrial Duct Construction, 1975.

Rectangular Industrial Duct Construction Standard, 1980.

Round Industrial Duct Construction Standard, 1977.

Thermoplastic Duct (PVC) Construction Manual, 2nd edition, 1995.

Thermoset FRP Duct Construction Manual, 1997.

Chapter 3 Definitions

3.1 General. The definitions contained in this chapter shall apply to the terms used in this standard. Where terms are not included, common usage of the terms shall apply.

3.2 NFPA Official Definitions.

3.2.1* Approved. Acceptable to the authority having jurisdiction.