

*This document is for internal and contract specific use only.*

**Disclaimer**

*NGG and NGET or their agents, servants or contractors do not accept any liability for any losses arising under or in connection with this information. This limit on liability applies to all and any claims in contract, tort (including negligence), misrepresentation (excluding fraudulent misrepresentation), breach of statutory duty or otherwise. This limit on liability does not exclude or restrict liability where prohibited by the law nor does it supersede the express terms of any related agreements."*

**Copyright © National Grid plc 2011, all rights reserved**

*All copyright and other intellectual property rights arising in any information contained within this document are, unless otherwise stated, owned by National Grid plc or other companies in the National Grid group of companies. No part of this publication may be reproduced in any material form (including photocopying and restoring in any medium or electronic means and whether or not transiently or incidentally) without the written permission of National Grid plc*

*This information should not be forwarded to third parties.*

## WOUND VOLTAGE TRANSFORMERS

### TABLE OF CONTENTS

|                                                         |          |
|---------------------------------------------------------|----------|
| PURPOSE AND SCOPE .....                                 | 1        |
| <b>PART 1 – PROCEDURAL .....</b>                        | <b>1</b> |
| 1 GENERAL DATA .....                                    | 1        |
| 2 GENERAL CHECKS .....                                  | 2        |
| 3 CALIBRATED TEST EQUIPMENT .....                       | 2        |
| 4 TESTS AT THE VT .....                                 | 2        |
| 5 VT SECONDARY OUTPUT TESTS .....                       | 3        |
| 6 VT PHASING TESTS .....                                | 3        |
| 7 FORMS AND RECORDS .....                               | 3        |
| <b>PART 2 - DEFINITIONS AND DOCUMENT HISTORY .....</b>  | <b>4</b> |
| 8 DEFINITIONS .....                                     | 4        |
| 9 AMENDMENTS RECORD .....                               | 4        |
| <b>PART 3 - GUIDANCE NOTES AND APPENDICES .....</b>     | <b>5</b> |
| APPENDIX A – SCHEDULE OF SITE COMMISSIONING TESTS ..... | 5        |

### **PURPOSE AND SCOPE**

This document details commissioning tests for Wound Voltage Transformers (WVTs).

With the exception of sections 5 and 6, all tests and records are for Stage 1 Commissioning (tests carried out with the WVT isolated from the National Grid system).

Sections 5 and 6 deal with Stage 2 Commissioning (tests carried out with the WVT connected to National Grid system).

This document is not intended for the commissioning of transformers provided for Settlement Metering, these requirements are given in SCTs 16.3 and 16.4.

### **PART 1 – PROCEDURAL**

#### **1 GENERAL DATA**

Phase

Manufacturer's Serial No

Manufacturer's Type Reference

VT Ratio

VT Rating in VA

| R | Y | B |
|---|---|---|
|   |   |   |
|   |   |   |
|   |   |   |
|   |   |   |